


FINAL

LIGHTING STUDY
EEAP PROGRAM
FOR
LETTERKENNY
ARMY DEPOT



U.S. ARMY ENGINEER DISTRICT, NORFOLK
CORPS OF ENGINEERS
NORFOLK, VIRGINIA

PERFORMED BY

DISTRIBUTION STATEMENT A

Approved for public release;
Distribution Unlimited



ENTECH ENGINEERING, INC.
READING, PENNSYLVANIA

VOLUME 2 OF 3

SEPT
~~JUNE~~ 1995




DEPARTMENT OF THE ARMY
CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS
P.O. BOX 9005
CHAMPAIGN, ILLINOIS 61826-9005

REPLY TO
ATTENTION OF: TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited.
Distribution A. Approved for public release.


Marie Wakefield,
Librarian Engineering

19971017 202

DTIC QUALITY INSPECTED 2

SECTION 9.0 ATTACHMENTS

9.1 A/E Contract

9.2 Meeting Minutes and Monthly Reports

9.3 Electric Bills and Rate Schedule

9.4 Lighting Models

9.5 Energy Conservation Opportunities

ATTACHMENT 9.1

A/E Contract

TSM		ORDER FOR SUPPLIES OR SERVICES (Contractor must submit four copies of invoice)		Form Approved OMB No. 3704-0187 Expires Aug 31, 1992		PAGE 1 OF 1	
<small>Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (3704-0187), Washington, DC 20503. Please DO NOT RETURN your form to either of these addresses. Send</small>							
1. CONTRACT / PURCH ORDER NO DACA01-94-D-0037		2. DELIVERY ORDER NO 0004		3. DATE OF ORDER 27 Sep 94		4. REQUISITION / PURCH REQUEST NO.	
6. ISSUED BY US ARMY ENGINEER DISTRICT, MOBILE PO BOX 2288 MOBILE, AL 36628-0001		7. ADMINISTERED BY (if other than 6) US ARMY ENGINEER DISTRICT, NORFOLK 803 FRONT STREET NORFOLK, VA 23510-1096		5. CERTIFIED FOR NATIONAL DEFENSE UNDER DMS REG 1 DO		8. DELIVERY FOB <input type="checkbox"/> DEST <input type="checkbox"/> OTHER (See Schedule Form 1)	
9. CONTRACTOR ENTECH ENGINEERING, INC. 500 PENN STREET, PO BOX 32 READING, PA 19803		FACILITY CODE		10. DELIVER TO FOB POINT BY (Date) SEE APP A FOR SCH		11. MARK IF <input checked="" type="checkbox"/> BUS. DESER <input type="checkbox"/> SMALL BUS. ADVANTAGED <input type="checkbox"/> WOMEN-OWNED	
NAME AND ADDRESS				12. DISCOUNT TERMS MA		13. MAIL INVOICES TO SEE BLOCK 14	
14. SHIP TO US ARMY ENGINEER DISTRICT, NORFOLK ATTN: CENAO-EN-MP (MLECIK) 803 FRONT STREET NORFOLK, VA 23510-1096		15. PAYMENT WILL BE MADE BY FINANCE & ACCOUNTING OFFICE US ARMY ENGINEER DISTRICT, NORFOLK 803 FRONT STREET NORFOLK, VA 23510-1096		CODE		MARK ALL PACKAGES AND PAPERS WITH CONTRACT OR ORDER NUMBER	
16. TYPE OF ORDER <input checked="" type="checkbox"/> DELIVERY <input type="checkbox"/> PURCHASE		This delivery order is issued on another Government agency or in accordance with and subject to terms and conditions of above numbered contract. Reference your _____ furnish the following on terms specified _____ ACCEPTANCE. THE CONTRACTOR HEREBY ACCEPTS THE OFFER REPRESENTED BY THE NUMBERED PURCHASE ORDER AS IT MAY PREVIOUSLY HAVE BEEN OR IS NOW MODIFIED, SUBJECT TO ALL OF THE TERMS AND CONDITIONS SET FORTH, AND AGREES TO PERFORM THE SAME.					
NAME OF CONTRACTOR		SIGNATURE		TYPED NAME AND TITLE		DATE SIGNED	
<input type="checkbox"/> If this box is marked, supplier must sign Acceptance and return the following number of copies:							
17. ACCOUNTING AND APPROPRIATION DATA / LOCAL USE 2142050 408-8013 P70000000 S44110 RA4A834D04 DIRECT CITE TOTAL \$126,484.00							
18. ITEM NO.	19. SCHEDULE OF SUPPLIES / SERVICE	20. QUANTITY ORDERED / ACCEPTED*	21. UNIT	22. UNIT PRICE	23. AMOUNT		
	DELIVERY ORDER FOR LIGHTING STUDY, EEAP PROGRAM, LETTERKENNY ARMY DEPOT, PA				\$126,484.00		
* If quantity accepted by the Government is same as quantity ordered, indicate by X. If different, enter actual quantity accepted below quantity ordered and indicate.		24. UNITED STATES OF AMERICA <i>Edward M. Slana</i> BY EDWARD M. SLANA		25. TOTAL \$126,484.00		26. DIFFERENCE	
26. QUANTITY IN COLUMN 20 HAS BEEN <input type="checkbox"/> INSPECTED <input type="checkbox"/> RECEIVED <input type="checkbox"/> ACCEPTED AND CONFORMS TO THE CONTRACT EXCEPT AS NOTED		27. SHIP NO.		28. DD FORM NO.		29. INITIALS	
DATE _____ SIGNATURE OF AUTHORIZED GOVERNMENT REPRESENTATIVE _____		<input type="checkbox"/> PARTIAL <input type="checkbox"/> FINAL		30. PAGE NO.		31. AMOUNT VERIFIED CORRECT FOR	
32. I certify this account is correct and proper for payment		33. PAYMENT <input type="checkbox"/> COMPLETE <input type="checkbox"/> PARTIAL <input type="checkbox"/> FINAL		34. CHECK NUMBER		35. BILL OF LADING NO	
DATE _____ SIGNATURE AND TITLE OF CERTIFYING OFFICER _____		36. RECEIVED AT		37. RECEIVED BY		38. DATE RECEIVED	
39. TOTAL CONTAINERS		40. SHIPMENT NUMBER		41. VOUCHER NUMBER		42. VOUCHER NUMBER	

SCOPE OF WORK
LIGHTING STUDY
FOR
LETTERKENNY ARMY DEPOT

TABLE OF CONTENTS

1. BRIEF DESCRIPTION OF WORK
2. GENERAL
3. PROJECT MANAGEMENT
4. SERVICES AND MATERIALS
5. PROJECT DOCUMENTATION
 - 5.1 ECIP Projects
 - 5.2 Non-ECIP Projects
 - 5.3 Non-feasible ECOs
6. DETAILED SCOPE OF WORK
7. WORK TO BE ACCOMPLISHED
 - 7.1 Perform a Limited Site Survey
 - 7.2 Evaluate Selected ECOs
 - 7.3 Combine ECOs into Recommended Projects
 - 7.4 Submittals, Presentations and Reviews

APPENDIXES

- A. DETAILED SCOPE OF WORK
- B. EXECUTIVE SUMMARY GUIDELINE
- C. REQUIRED DD FORM 1391 DATA
- D. LIGHTING ENERGY CONSERVATION OPPORTUNITIES
- E. LIST OF AREAS/FACILITIES TO BE SURVEYED

1. BRIEF DESCRIPTION OF WORK: The Architect Engineer (AE) shall:

1.1 Perform a limited site survey of specific buildings or areas to collect all data required to evaluate the specific ECOs included in this study.

1.2 Evaluate specific ECOs to determine their energy savings potential and economic feasibility.

1.3 Provide project documentation for recommended ECOs as detailed herein.

1.4 Prepare a comprehensive report to document all work performed, the results and all recommendations.

2. GENERAL

2.1 This Study is limited to the evaluation of the specific buildings, systems, or ECOs listed in APPENDIX A, DETAILED SCOPE OF WORK.

2.2 The information and analysis outlined herein are considered to be minimum requirements for adequate performance of this Study.

2.3 For the buildings, systems or ECOs listed in APPENDIX A, DETAILED SCOPE OF WORK, all methods of energy conservation as relates to LIGHTING, as well as it's effects on HVAC systems, and which are reasonable and practical shall be considered, including improvements of operational methods and procedures as well as the physical facilities. All energy conservation opportunities which produce energy or dollar savings shall be documented in this report. Any energy conservation opportunity considered unfeasible shall also be documented in the report with reasons for elimination.

2.4 The study shall consider the use of all lighting sources applicable to each building, system, or ECO, including all effects lighting system changes may have on HVAC systems.

2.5 The "Energy Conservation Investment Program (ECIP) Guidance", described in letter from DAIM-FDF-U, dated 10 Jan 1994 establishes criteria for ECIP projects and shall be used for performing the economic analyses of all ECOs and projects. The Program Life Cycle Cost In Design (LCCID), has been developed for performing life cycle cost calculations in accordance with ECIP guidelines and is referenced in the ECIP Guidance. If any program other than LCCID is proposed for life cycle cost analysis, it must use the mode of calculation specified in the ECIP Guidance. The output must be in the format of the ECIP LCCA summary sheet, and it must be submitted for approval to the Contracting Officer.

2.6 Energy conservation opportunities determined to be technically and economically feasible shall be developed into projects acceptable to installation personnel. This may involve combining similar ECOs into larger packages which will qualify for ECIP, or O&M funding, and determining in coordination with

installation personnel the appropriate packaging and implementation approach for all feasible ECOs.

2.6.1 Projects which qualify for ECIP funding shall be identified, separately listed, and prioritized by the Savings to Investment Ratio (SIR).

2.6.2 All feasible Non-ECIP projects shall be ranked in order of highest to lowest SIR.

2.6.3 At some installations Energy Conservation and Management (ECAM) funding will be used instead of ECIP funding. The criteria for each program is the same. The Director of Public Works will indicate which program is used at this installation. This Scope of Work mentions only ECIP, however, ECAM is also meant.

3. PROJECT MANAGEMENT

3.1 Project Managers. The AE shall designate a project manager to serve as a point of contact and liaison for work required under this contract. Upon award of this contract, the individual shall immediately be designated in writing. The AE's designated project manager shall be approved by the Contracting Officer prior to commencement of work. This designated individual shall be responsible for coordination of work required under this contract. The Contracting Officer will designate a project manager to serve as the Government's point of contact and liaison for all work required under this contract. This individual will be the Government's representative.

3.2 Installation Assistance. The Commanding Officer or authorized representative at the installation will designate an individual to assist the AE in obtaining information and establishing contacts necessary to accomplish the work required under this contract. This individual will be the installation representative.

3.3 Public Disclosures. The AE shall make no public announcements or disclosures relative to information contained or developed in this contract, except as authorized by the Contracting Officer.

3.4 Meetings. Meetings will be scheduled whenever requested by the AE or the Contracting Officer for the resolution of questions or problems encountered in the performance of the work. The AE's project manager and the Government's representative shall be required to attend and participate in all meetings pertinent to the work required under this contract as directed by the Contracting Officer. These meetings, if necessary, are in addition to the presentation and review conferences.

3.5 Site Visits, Inspections, and Investigations. The AE shall visit and inspect/investigate the site of the project as necessary and required during the preparation and accomplishment of the work.

3.6 Records.

3.6.1 The AE shall provide a record of all significant conferences, meetings, discussions, verbal directions, telephone conversations, etc., with Government representative(s) relative to this contract in which the AE and/or designated representative(s) thereof participated. These records shall be dated and shall identify the contract number, and modification number if applicable, participating personnel, subject discussed and conclusions reached. The AE shall forward to the Contracting Officer within ten calendar days, a reproducible copy of the records.

3.6.2 The AE shall provide a record of requests for and/or receipt of Government furnished material, data, documents, information, etc., which if not furnished in a timely manner, would significantly impair the normal progression of the work under this contract. The records shall be dated and shall identify the contract number and modification number, if applicable. The AE shall forward to the Contracting Officer within ten calendar days, a reproducible copy of the record of request or receipt of material.

3.7 Interviews. The AE and the Government's representative shall conduct entry and exit interviews with the Director of Public Works before starting work at the installation and after completion of the field work. The Government's representative shall schedule the interviews at least one week in advance.

3.7.1 Entry. The entry interview shall describe the intended procedures for the survey and shall be conducted prior to commencing work at the facility. As a minimum, the interview shall cover the following points:

- ♦ Schedules.
- ♦ Names of energy analysts who will be conducting the site survey.
- ♦ Proposed working hours.
- ♦ Support requirements from the Director of Public Works.

3.7.2 Exit. The exit interview shall briefly describe the items surveyed and probable areas of energy conservation. The interview shall also solicit input and advice from the Director of Public Works.

4. SERVICES AND MATERIALS. All services, materials (except those specifically enumerated to be furnished by the Government), labor, supervision and travel necessary to perform the work and render the data required under this contract are included in the lump sum price of the contract.

5. PROJECT DOCUMENTATION. All energy conservation opportunities which the AE has considered shall be included in one of the following categories and presented in the report as such.

5.1 ECIP Projects. To qualify as an ECIP project, an ECO, or several ECOs which have been combined, must have a construction cost estimate greater than \$300,000, a Savings to Investment Ratio greater than 1.25 and a simple playback period of less than ten years. For ECAM projects, the \$300,000 limitation may not

apply in such cases, the AE shall check with the installation for guidance. The overall project and each discrete part of the project shall have an SIR greater than 1.25. All projects meeting the above criteria shall be arranged as specified in paragraph 2.6.1 and shall be provided with programming documentation. Programming documentation shall consist of a DD Form 1391, life cycle cost analysis (LCCA) summary sheet(s) (with necessary backup data to verify the numbers presented), and a Project Development Brochure(PDB). A life cycle cost analysis summary sheet shall be developed for each ECO and for the overall project when more than one ECO are combined. The energy savings for projects consisting of multiple ECOs must take into account the synergistic effects of the individual ECOs.

5.2 Non-ECIP Projects. Projects which do not meet ECIP criteria with regard to cost estimate or play back period, but which have a SIR greater than 1.25 shall be documented. Projects or ECOs in this category shall be arranged as specified in paragraph 2.6.2 and shall be provided with the following documentation: the life cycle cost analysis (LCCA) summary sheet completely filled out, a description of the work to be accomplished, backup data for the LCCA, i.e., energy savings calculations and cost estimate(s), and the simple play back period. The energy savings for projects consisting of multiple ECOs must take into account the synergistic effects of the individual ECOs. In addition these projects shall have the necessary documentation prepared, as required by the Government's representative, for one of the following categories:

5.2.1. O & M Energy Projects: An O&M Energy project is one that results in needed maintenance or repair to an existing facility, or replaces a failed or failing existing facility, and also results in energy savings. The criteria are similar to the criteria for ECIP projects, i.e., \$300,000 construction cost, SIR \geq 1.25, and simple play back period of less than ten years. In addition, if the project would replace a system or equipment that is considered failed or failing' due solely to obsolete technology or inefficiency, the equipment to be replaced must have been in use for at least three years; and the simple play back period must be three years or less.

5.2.2. Low Cost/No Cost Projects. These are projects which the Director of Public Works (DPW) can perform using his resources. Documentation shall be as required by the DPW.

5.3 Non-feasible ECOs. All ECOs which the AE has considered but which are not feasible, shall be documented in the report with reasons and justifications showing why they were rejected.

6. DETAILED SCOPE OF WORK. The Detailed Scope of Work is contained in APPENDIX A, DETAILED SCOPE OF WORK,.

7. WORK TO BE ACCOMPLISHED.

7.1 Perform A Limited site survey. The AE shall obtain all necessary data to evaluate the ECOs or projects by conducting a site survey. The AE shall document

his site survey on forms developed for the survey, or standard forms, and submit these completed forms as part of the report. Light levels shall be measured under typical operating conditions for all areas or spaces being evaluated. All test and/or measurement equipment shall be properly calibrated prior to its use. The requirements for color rendition and current maintenance and revamping practices shall be noted for consideration in the evaluations.

7.2 Evaluate Selected ECOs. The AE shall analyze the ECOs listed in APPENDIX A, DETAILED SCOPE OF WORK. These ECOs shall be analyzed in detail to determine their feasibility. Savings to Investment Ratios (SIRS) shall be determined using current ECIP guidance. The AE shall provide all data and calculations needed to support the recommended ECO. All assumptions and engineering equations shall be clearly stated. Calculations shall be prepared showing how all numbers in the CEO were figured. Calculations shall be an orderly step by step progression from the first assumption to the final number. Descriptions of the products, manufacturers catalog cuts, pertinent drawings and sketches shall also be included. Construction cost estimates shall be provided and shall break out the costs associated with rehab work (architectural, electrical, mechanical) where applicable. Existing and proposed light levels shall be compared with levels recommended by the Illumination Engineering Society (IES) or the Corps of Engineers Architectural and Engineering Instructions (AEI) for the applicable space and activity. A life cycle cost analysis summary sheet shall be prepared for each ECO and included as part of the supporting data

7.3 Combine ECOs Into Recommended Projects. During the Interim Review Conference, as outlined in paragraph 7.4.1, the AE will be advised of the DPW's preferred packaging of recommended ECOs into projects for implementation. Some projects may be a combination of several ECOs, and others may contain only one. These projects will be evaluated and arranged as outlined in paragraphs 5.1, 5.2, and 5.3. Energy savings calculations shall take into account the synergistic effects of multiple ECOs within a project and the effects of one project upon another. The results of this effort will be reported in the Final Submittal per par 7.4.2.

7.4 Submittals, Presentations and Reviews. The work accomplished shall be fully documented by a comprehensive report. The report shall have a table of contents and shall be indexed. Tabs and dividers shall clearly and distinctly divide sections, subsections, and appendices. All pages shall be numbered. Names of the person primarily responsible for the project shall be included. The AE shall give a formal presentation of the interim submittal to installation command, and other Government personnel. Slides or view graphs showing the results of the study to date shall be used during the presentation. During the presentation, the personnel in attendance shall be given ample opportunity to ask questions and discuss any changes deemed necessary to the study. A review conference will be conducted the same day, following the presentation. Each comment presented at the review conference will be discussed and resolved or action items assigned. It is anticipated that the presentation and review conference will require approximately one working day. The presentation and review conference will be at the installation on the date agreeable to the Director of Public Works, the AE and the Government's

representative. The Contracting Officer may require a re-submittal of any document(s), if such document(s) are not approved because they are determined by the Contracting Officer to be inadequate for the intended purpose.

7.4.1 Interim Submittal. An interim report shall be submitted for review after the field survey has been completed and an analysis has been performed on all of the ECOs. The report shall indicate the work which has been accomplished to date, illustrate the methods and justifications of the approaches taken and contain a plan of the work remaining to complete the study. Calculations showing energy and dollar savings, SIR, and simple pay back period of all the ECOs shall be included. The results of the ECO analyses shall be summarized by lists as follows:

7.4.1.a. All ECOs eliminated from consideration shall be grouped into one listing with reasons for their elimination as discussed in par 5.3.

7.4.1.b. All ECOs which were analyzed shall be grouped into two listings, recommended and non-recommended, each arranged in order of descending SIR. These lists may be subdivided by building or areas appropriate for the study. The AE shall submit the Scope of Work and any modifications to the Scope of Work as an appendix to the report. A narrative summary describing the work and results to date shall be a part of this submittal. At the Interim Submittal and Review Conference, the Government's and AE's representatives shall coordinate with the Director of Public Works to provide the AE with direction for packaging or combining ECOs for programming purposes and also indicate the fiscal year for which the programming or implementation documentation shall be prepared. The survey forms completed during this Study shall be submitted with this report. The survey forms only may be submitted in final form with this submittal. They should be clearly marked at the time of submission that they are to be retained. They shall be bound in a standard three ring binder which will allow repeated disassembly and re-assembly of the material contained within.

7.4.2 Final Submittal. The AE shall prepare and submit the final report when all sections of the report are 100% complete and all comments from the interim submittal have been resolved. The AE shall submit the Scope of Work for the study and any modifications to the Scope of Work as an appendix to the submittal. The report shall contain a narrative summary of conclusions and recommendations, together with all raw and supporting data, methods used, and sources of information. The report shall integrate all aspects of the study. The recommended projects, as determined in accordance with paragraph 5, shall be presented in order of priority by SIR. The lists of ECOs specified in paragraph 7.4.1 shall be included for continuity. The final report and all appendices shall be bound in standard three ring binders which will allow repeated disassembly and re-assembly. The final report shall be arranged to include:

7.4.2.a. An Executive Summary to give a brief overview of what was accomplished and the results of this study using graphs, tables and charts as much as possible (See APPENDIX B, EXECUTIVE SUMMARY GUIDELINE, for minimum requirements).

7.4.2.b. The narrative report describing the problem to be studied, the approach to be used, and the results of this study.

7.4.2.c. Documentation for the recommended projects.

1) Backup information as specified in par 5.1.

7.4.2.d. Appendices to include as a minimum:

1) Energy cost development and backup data.

2) Detailed calculations.

3) Cost estimates.

4) Computer printouts (where applicable).

5) Scope of Work.

APPENDIX A

DETAILED SCOPE OF WORK.

FY 94 LIGHTING STUDY

LETTERKENNY ARMY DEPOT, PENNSYLVANIA

1. All facilities to be investigated in this Study are located at LETTERKENNY ARMY DEPOT, PENNSYLVANIA.
2. The General Scope of Work outlines requirements for the Study and the report; and the detailed scope of work lists the specific areas to be Studied. If any conflicts arise between the General and the Detailed scopes of work, the Detailed Scope of Work shall govern.
3. The work consists of identifying and evaluating energy conservation opportunities (ECOs) for LIGHTINGs in specific areas or facilities. A list of suggested ECOs is provided in APPENDIX D, LIGHTING ECOs. The ECOs in APPENDIX D, are to be evaluated as applicable for the area or facilities listed in APPENDIX E, LIST OF AREAS/FACILITIES TO BE STUDIED.
4. Completion and Payment Schedule: The following schedule shall be used as a guide in approving payments on this contract. The Contracting Officer's representative is Mr. Bryant Wilkins of the Norfolk District, COE.

Interim Submittal	120 Calendar Days after Notice to Proceed
Pre-Final Submittal	200 Calendar Days after Notice to Proceed
Final Submittal	240 Calendar Days after Notice to Proceed

MILESTONE

PERCENT OF CONTRACT AMOUNT
AUTHORIZED FOR PAYMENT

Entry Interview	10
Completion of Field Work	25
Receipt of Interim Submittal	75
Completion of Interim Presentation & Review	85
Receipt of Final Submittal	100

5. The installation representative for this contract will be Mr. Jeffrey Hager, Energy Program Coordinator, Directorate of Public Works, LETTERKENNY ARMY DEPOT. (717) 267-8005, FAX (717) 267-9713.
6. Government Furnished Information: The following documents are available for the use of the AE.
 - ♦ As built drawings (as available) of buildings/systems
 - ♦ Energy Conservation Investment Program (ECIP) Guidance, dated 10 Jan 1994
 - ♦ ETL 11103282, Energy Conservation

- ♦ TM 58002, Cost Estimates, Military Construction
- ♦ AR 41515, 1-Jan 84, Military Construction, Army (MCA) Program Development
- ♦ Architectural and Engineering Instructions, Design Criteria; Chapter 12, Electrical Criteria, 9 December 1991
- ♦ The latest MCP Index

7. Direct Distribution of Submittals: The AE shall make direct distribution of correspondence, minutes, report submittals, and responses to comments as indicated by the following schedule:

AGENCY	CORRESPONDENCE			
	EXECUTIVE SUMMARIES			
	REPORTS			
	FIELD NOTES			
Commander LETTERKENNY ARMY DEPOT ATTN: SDSLE-EP (Mr. Hagar) DPW/Energy Engineer Chambersburg, PA 17201-4150	1	3	3	1*
Commander Army Material Command ATTN: AMCEN-A(Ms Linda Custer) 5001 Eisenhower Ave. Alexandria, VA 22333-0001	-	1	1	-
Commander U. S. Army Engineer District, Norfolk ATTN: CENAO-EN-MP (Mr Mlecik) 803 Front Street Norfolk, VA 23510	1	3	3	1*
Commander USAED, North Atlantic ATTN: CENAD-EN-MM (Mr Wong) 90 Church Street New York, NY 10007	-	1	1	-

Commander
USAED, Mobile
ATTN: CESAM-EN-DM (Battaglia)
PO Box 2288; Mobile, AL 36628-0001

1 1 1 -

Commander
US Army Corps of Engineers
ATTN: CEMP-ET (Mr Gentil)
20 Massachusetts Avenue NW
Washington, DC, 20314 1000

1
(Final Only)

Commander
US Army Logistics Evaluation Agency
ATTN: LOEA-PL (Mr Keath)
New Cumberland Army Depot
New Cumberland, PA, 17070 5007

1
(Final Only)

* Field Notes submitted in final form at interim submittal.

Progress reports will be prepared on a monthly basis to highlight the significant events of the prior month. This is especially true of actions completed, problems discovered, schedule changes and ECO developments. The progress reports will accompany monthly billings and will form the basis for progress meetings.

8. A computer program titled Life Cycle Costing in Design (LCCID) is available from the BLAST Support Office in Urbana, Illinois for a nominal fee. This computer program can be used for performing the economic calculations for ECIP and non-ECIP ECOs. The AE is encouraged to obtain and use this computer program. The BLAST Support Office can be contacted at 144 Mechanical Engineering Building, 1206 West Green Street, Urbana, Illinois 61801. The telephone number is (217) 3338977 or (800) 8425278.

9. METHOD

9.1 INVESTIGATION OF EXISTING CONDITIONS

The Contractor will collect information on the existing lighting systems and operations so as to have a reasonable understanding of operations, costs, energy use, problems, limitations, future needs, etc. This will be accomplished in the following steps.

Data Gathering. The Contractor will collect available data that will assist in energy use evaluations and recommendations. A partial list of data that will be sought are:

- Energy bills and summaries
- Prior studies and energy reports (if any)
- Schedules

LK

- Floor plans or building data
- Site plans
- Maintenance records
- Copies of other pertinent drawings
- Proposals from vendors or contractors
- Electrical demand profiles
- Energy management system profile
- Others

Site Visits, Inspections. An The Contractor design/study team (normally two or three people) will visit the facility. Site inspection will be done of areas covered in the study. Operators may be briefly interviewed on the basic function and normal time of use of individual areas and systems.

The team will observe the arrangement, physical condition and effectiveness of the lighting systems. Data collected generally will include the following information.

- Lighting levels
- Fixture and ceiling heights
- Electrical details including voltage, instantaneous amperage, kVA, and P.F.
- Lighting characteristics
- Lighting panel schedules (where possible)
- Room or area dimensions

Photographs will be taken of key areas for later reference.

ANALYSIS OF SYSTEMS

The Contractor will utilize standard methods of engineering calculations to understand current energy consumption in such detail as to permit identification of further improvement options.

Utility Rate Analysis. A calculation will be performed for determining electrical costs associated with lighting use. The incremental cost of electricity will be used for all energy savings options including demand and usage.

The current rate structure that applies to electrical use will be checked. Using a computerized program developed by The Contractor, all bills for the past two years will be checked for accuracy. This program will also determine the incremental cost of each kW of demand and kWh of usage for calculations of Energy Conservation Opportunities (ECOs) and other reports. A copy of the applicable analysis, together with sample bills and published tariffs will be included in the report.

Check Regulatory Requirements. Where applicable, a check of all regulatory bodies affecting lighting will be made. Any recommendations that are subsequently made, must be made in compliance with such requirements including the Illuminating Engineering Society (IES).

Lighting Lists. Data obtained during the walk-through inspection is tabulated into a comprehensive lighting list for the facilities covered by the scope. Using another The Contractor computer program, the information provided contains the following:

- Location - floor, room area in SF, etc.
- Luminaries - number, type, height
- Lamps - number, type, wattage
- Ballasts
- Light levels in foot-candles
- Watts/SF
- Hours of operation and kWhs
- Contribution to demand
- Monthly cost of operation

Copies of these calculations with recommendations noted in the margin are provided with the reports.

Electrical Models. A computerized list will show how each building's lighting load in the building contributes to energy use and cost. This list or model of actual use shows the contribution of all lighting summaries to demand in KW, usage in KWH, and cost per year in dollars. The arrangement of the model evaluates each major season (winter, summer, and intermediate months) as well as yearly totals.

A copy of the electrical model is included for the facility report. Note also that this model is used to determine the level of savings (electrical) that can be obtained from lighting Energy Conservation Opportunity improvements.

ENERGY CONSERVATION OPPORTUNITY INVESTIGATIONS

The Contractor will investigate all reasonable options of saving energy and energy-related costs in the operation of the lighting systems. The approach used to identify each option is briefly described below.

Existing Conditions. This section describes the nature of the existing operating system, its energy use, costs, advantages and disadvantages. Data is usually transferred to this section from the calculations.

Energy Conservation Opportunities. This section describes improvement ideas that are different from the existing conditions. They may describe a capital projects, modifications, or O&M procedures. The resulting improvements are described, energy costs, quantities and arrangements are briefly noted. Sufficient conceptual studies will be executed to determine feasibility, generate anticipated operational data and estimating values.

Construction Cost Estimate. A feasibility cost estimate in the format prescribed will be performed. The estimate breakdown will be included in the report showing known quantities and costs. Allowances for indirect costs and contingencies are included.

Annual Savings. The report will show the annual savings in energy, quantities, demand, costs, and BTU's. As the report is written, these savings are merely the difference between existing and proposed.

Discussion. This section of the report describes a number of relevant factors including payback period, impact on labor or non-energy costs, O&M concerns, appearances, comfort, life extension, etc. The intent of this section is to address normal impacts or uncertainties of various improvement ideas.

REPORT PREPARATION PHASE

The Contractor will prepare an Energy Analysis report which will fully document the steps previously described. The report will be prepared as follows.

Executive Summary - Section 1. The outline of the executive section is shown on Appendix B.

Methodology - Section 2. This part of the report describes the approach, sequence, assumptions, calculations methods, computer programs, sample outputs, etc. that were used for the study.

Facility Description - Section 3. The report will briefly discuss the buildings and systems covered by the study. It will show floor plans, layout flow diagrams, facility age and condition, major equipment characteristics by system, hours of operation, and concerns expressed by occupants and managers.

Energy Use and Costs - Section 4. The report will describe individual and combined energy consumption for the past two years. The report will describe rate structures, incremental cost calculations, trends, and analysis of use by source. This section critically establishes baseline use of energy for later improvement possibilities.

ECOs Recommended - Section 5. This section describes in detail each of the Energy Conservation Opportunities (ECOs) that are recommended for adoption and funding. The approach to each ECO write-up is described in Section 5, Project Documentation.

ECOs Not Recommended - Section 6. The report will also show ECOs that were investigated but not recommended for adoption due to economics, conflicts, with other ECOs or concerns of operations.

Discussion - Section 7. This part of the report will cover interesting findings of the study not related to other sections of the report. It may include

recommendations for non-energy problems, further studies, O&M procedures, training, etc.

Attachments. As part of the report, there will be enclosures for photos, backup calculations, referenced materials such as rate tariffs, codes, etc.

Applications and Funding Requests. As part of this study, applications for project funding will be made in accordance with Section 5, Project Documentation and directions from local authorized persons. The exact level of funding and funding program (expected to be ECIP), will be at the direction of the facility manager.

Suggested Implementation Schedules. The report will also contain a suggested timetable for implementing various projects or programs. This recommendation will be made in consultation with various facility managers.

Operation and Maintenance Instructions. Where appropriate, the study will recommend the formation of procedures or changes to processes that relate to improved energy usage and costs through Operation and Maintenance.

APPENDIX B
EXECUTIVE SUMMARY GUIDELINE.

1. Introduction.
2. Building Data (types, number of similar buildings, sizes etc.)
3. Present Energy Consumption of Buildings or Systems Studied.
 - ♦ Total Annual Energy Used.
 - ♦ Source Energy Consumption.
 - Electricity KWH, Dollars, BTU
 - Fuel Oil GALS, Dollars, BTU
 - Natural Gas THERMS, Dollars, BTU
 - Propane GALS, Dollars, BTU
 - Other QTY, Dollars, BTU
4. Reevaluated Projects Results.
5. Energy Conservation Analysis.
 - ♦ ECOs Investigated.
 - ♦ ECOs Recommended.
 - ♦ ECOs Rejected. (Provide economics or reasons)
 - ♦ ECIP Projects Developed. (Provide list)*
 - ♦ Non-ECIP Projects Developed. (Provide list)*
 - ♦ Operational or Policy Change Recommendations.
 - ♦

* Include the following data from the life cycle cost analysis summary sheet; the cost (construction plus SIOH), the annual energy savings (type and amount), the annual dollar savings, the SIR, the simple pay back period and the analysis date.
6. Energy and Cost Savings.
 - ♦ Total Potential Energy and Cost Savings.
 - ♦ Percentage of Energy Conserved.
 - ♦ Energy Use and Cost Before and After the Energy Conservation opportunities are Implemented.

APPENDIX C,
REQUIRED FORM DD1391 DATA.

To facilitate ECIP project approval, the following supplemental data shall be provided:

1. In title block clearly identify projects as "ECIP."
2. Complete description of each item of work to be accomplished including quantity, square footage, etc.
3. A comprehensive list of buildings, zones, or areas including building numbers, square foot floor area, designated temporary or permanent, and usage (administration, patient treatment, etc.).
4. List references, and assumptions, and provide calculations to support dollar and energy savings, and indicate any added costs.
 - 4.1. If a specific building, zone, or area is used for sample calculations, identify building, zone or area, category, orientation, square footage, floor area, window and wall area for each exposure.
 - 4.2. Identify weather data source.
 - 4.3. Identify infiltration assumptions before and after improvements
 - 4.4. Include source of expertise and demonstrate savings claimed. Identify any special or critical environmental conditions such as pressure relationships, exhaust or outside air quantities, temperatures, humidity, etc.
5. Lighting retrofit projects must identify number and type of fixtures, and wattage of each fixture being deleted and installed. New lighting shall be only of the level to meet current criteria. Lamp changes in existing fixtures is not considered an ECIP type project.
6. An ECIP life cycle cost analysis summary sheet as shown in the ECIP Guidance shall be provided for the complete project and for each discrete part included in the project. The SIR is applicable to all segments of the project. Supporting documentation consisting of basic engineering and economic calculations showing how savings were determined shall be included.
7. The DD Form 1391 face sheet shall include, for the complete project, the annual dollar and MBTU savings, SIR, simple amortization period and a statement attesting that all buildings and retrofit actions will be in active use throughout the amortization period.

APPENDIX C,
REQUIRED FORM DD1391 DATA.

To facilitate ECIP project approval, the following supplemental data shall be provided:

1. In title block clearly identify projects as "ECIP."
2. Complete description of each item of work to be accomplished including quantity, square footage, etc.
3. A comprehensive list of buildings, zones, or areas including building numbers, square foot floor area, designated temporary or permanent, and usage (administration, patient treatment, etc.).
4. List references, and assumptions, and provide calculations to support dollar and energy savings, and indicate any added costs.
 - 4.1. If a specific building, zone, or area is used for sample calculations, identify building, zone or area, category, orientation, square footage, floor area, window and wall area for each exposure.
 - 4.2. Identify weather data source.
 - 4.3. Identify infiltration assumptions before and after improvements
 - 4.4. Include source of expertise and demonstrate savings claimed. Identify any special or critical environmental conditions such as pressure relationships, exhaust or outside air quantities, temperatures, humidity, etc.
5. Lighting retrofit projects must identify number and type of fixtures, and wattage of each fixture being deleted and installed. New lighting shall be only of the level to meet current criteria. Lamp changes in existing fixtures is not considered an ECIP type project.
6. An ECIP life cycle cost analysis summary sheet as shown in the ECIP Guidance shall be provided for the complete project and for each discrete part included in the project. The SIR is applicable to all segments of the project. Supporting documentation consisting of basic engineering and economic calculations showing how savings were determined shall be included.
7. The DD Form 1391 face sheet shall include, for the complete project, the annual dollar and MBTU savings, SIR, simple amortization period and a statement attesting that all buildings and retrofit actions will be in active use throughout the amortization period.

8. The calendar year in which the cost was calculated shall be clearly shown on the DD Form 1391.
9. For each temporary building included in a project, separate documentation is required showing (1) a minimum 10 year continuing need, based on the installation's annual real property utilization survey, for active building retention after retrofit, (2) the specific retrofit action applicable and (3) an economic analysis supporting the specific retrofit.
10. Non-appropriated funded facilities will not be included in an ECIP project without an accompanying statement certifying that utility costs are not reimbursable.
11. Any requirements required by ECIP guidance dated 10 Jan 1994 and any revisions thereto. Note that non-escalated costs and savings are to be used in the economic analyses.
12. The five digit category number for all ECIP projects except for Family Housing is 80000. The category code number for Family Housing projects is 71100.

APPENDIX D LIGHTING ECOs

Energy Savings Opportunities include but are not necessarily limited to:

Daylighting/photo controls

Reflectors

Delamping

Change exit signs to LEDs or compact fluorescents

Motion sensors

Fluorescents to HID luminaires

Replacement of Lamps

Incandescents to fluorescents

Standard fluorescent lamps to compact fluorescent

Mercury vapor lamps to metal halide

Mercury vapor lamps to high pressure sodium

Mercury vapor lamps to low pressure sodium

Replace existing fluorescent fixtures with new fixtures having efficient reflectors, electronic ballasts and energy conserving lamps

Task lighting

Magnetic to electronic ballasts

Reductions where illumination exceeds recommended levels.

Installation of additional switches to control lighting arrangements

APPENDIX E LIST OF AREAS/FACILITIES TO BE STUDIED.

This study will include, but is not necessarily limited to, a thorough understanding of recommended improvements to the following:

This study will include a thorough review of existing lighting systems and suggest recommended improvements to the system of the facilities indicated on the attached list. The study will review and confirm the area in square feet, lighting levels, and the number of fixtures for each facility on the list.

The study will also include an analysis of existing street lighting at various locations throughout the Depot. It is estimated that approximately 1,000 existing mercury vapor street lights will be included in the street lighting study.

Building Location	Square Feet	# of Lighting Fixtures
1-S	51,177	771
RR	270	
Audio Visual	588	
2-S	17,434	251
RR	1,157	8
3	75,258	857
ADP RMS	16,296	345
RR	1,736	
4-S	6,743	139
RR	400	
5-N	11,481	162
ADP RMS	2,350	49
10	39,796	1,157
ADP RMS	7,901	120
RR	1,316	
20-1		2
198	960	9
199		8
200	1,063	9
211	856	11
529	2,583	37
KITCHEN	1,246	14
SECOND FLOOR	4,595	31
530		16
536		18
581	9,702	128
616	280	2
618	5,167	75
619	3,171	50

Building Location	Square Feet	# of Lighting Fixtures
629		13
637	1,400	42
639		15
639		3
640	1,256	12
645	1,920	28
646	2,778	42
412		44
412		26
416	3,106	32
417		25
418		25
421	14,350	164
REMOTE	500	12
428	1,520	21
500	28,774	343
HLTH CLINIC	4,526	47
NEW CLINIC	1,252	22
521	1,955	64
522	9,663	179
523	5,964	86
524	1,305	19
663-S	12,139	229
664	4,074	94
SECOND FLOOR OFC		
OFFICE		
2260	4,000	72
3311	6,499	151
3315		14
1N	30,120	129
4N		8
5S		
6	40,560	466
14	9,260	224
14	400	
19		5
37	549	42
42-S		9
42-S		9
47	783	4
47		
57	2,173	120
SHOP	53,425	589
102	1,750	28

Building Location	Square Feet	# of Lighting Fixtures
247		16
320		101
350	4.117	78
BREAK		28
HYD/TEST	3.400	16
370	5.752	1.169
COMPUTER RM		14
424	6.630	203
431	10.710	119
	2.160	
438		22
441	13.601	44
628	5.278	48
663-N		44
2268		12
2329		8
2755		23
3321		13
5425		9
31	90.180	152
32	90.180	137
33-N	45.000	75
	90.180	300
	90.180	175
42-S	50.927	210
43	90.527	256
44	90.180	169
47-S	90.860	152
51	85.559	366
52	90.180	93
53	90.180	90
54	90.180	
55	90.180	108
57	53.425	589
441	13.601	44
349	17.887	122
TOTAL	1.820.881	12.731

ATTACHMENT 9.2

Meeting Minutes and Monthly Reports

MEETING MINUTES NO. 1

Project: Letterkenny Lighting Study
Project No. 4130.01

Contract No.: DACA01-94-D-0037

Meeting Date: October 18, 1994

Minutes Issue Date:

Attendees:

Distribution:

Discussions generally followed proposed agenda which was distributed at the start of the conference and is attached hereto as an exhibit. This report will organize and document the proceedings pursuant to the agenda.

Items Discussed:

- 1.1 Introductions were made and individuals roles were discussed.
- 1.2 Contractual schedule obligations were noted. Army Material Command may ask for projects at any time of the year. Letterkenny will most likely be asked to submit for project funding in January. These projects will wait until January of 1996 for submission.
- 1.3 Project Scope was reviewed without contest.

Entech will collect data on all interior lights (except emergency)
Entech will consider all lamps operational and insert a factor for repairs in progress.

Entech will not review codes with respect to the operation of the lighting system.

Entech will present the IES lighting standards in a comparison to the actual lighting levels for Letterkenny to determine if reductions are feasible.

Entech will make assumptions of the type of lamps, ballasts, and other characteristics of the luminaries based on information collected on-site.

Actual model numbers and similar data will not be collected.

- 1.4 The Depot's standard working hours are 07:30-16:15, with buildings generally open between 06:00-17:00.
- 1.5 Access for Entech's field people will be assisted by badges. Keys will not be distributed to Entech. Escorts, where required, will be furnished by Jeff Hager.
- 1.6 Documentation required from DPW was discussed and the following was given to Entech:

A disc of the Depot's layout in AUTOCAD 12 format.

Prints of the Depot's building layout

Copy of the recent energy study performed by RS&H. (to be returned after review)

Summary of overall Energy usage for the Depot last year.

Copy of the utility companies rate schedule.

Name and phone number of the utility company representative for Letterkenny.

- 1.7 Other documentation needs were reviewed, Mr Hager will begin collection, and Mr. Haldeman will formally request. Copies of government documents will be requested through the Contracting Officer's Representative.
- 1.8 A copy of the distribution of documents matrix was distributed but not discussed.
- 1.9 Billing and change procedures were not discussed.
- 1.10 The use of the IES lighting standards is acceptable. No decision as to what type of funding will be requested.
- 1.11 Entech will contact Mr. Battaglia to determine if access to the ADDS/DIES energy reporting system is appropriate for Entech.
- 1.12 Entech will formally request data from the Depot.
- 1.13 Letterkenny will continue to assemble the data requested at the meeting.
- 1.14 Next meeting will be held on -----, -----, 1994 at ----- a.m. in Building

The above minutes reflect the writer's interpretation of the meeting events and discussions. Should there be any corrections which are deemed to be required to these minutes, please send a copy of your suggested corrections to the undersigned within 5 days of receipt. Receiving no corrections, these minutes shall stand as the meeting record.

Respectfully submitted,

Dwight Haldeman
Project Manager

cc:

EEAP MONTHLY REPORT

November 9, 1994

PROJECT: **LETTERKENNY LIGHTING STUDY**
CONTRACT: **DACA01-94-D-0037---DO-0004**
CONTRACTOR: **ENTECH ENGINEERING INC.,READING, PA.**

SUMMARY OF PROGRESS:

Last month Entech executed DD1155 and returned same. We petitioned for Project Manager approval as required and received an oral acceptance of the candidates. An Entry Interview was held and documentation prepared. Information was requested of the Government and much of the data was furnished. Plans to begin site work were developed.

FORECAST OF EFFORTS:

Planned for the month of November is the field collection of building data for inclusion in the study. The data will be collected and transferred into our computer models for analysis. With the amount of site investigation and its performance around the Christmas season, the date of the interim report may slip. We intend to begin work immediately and attempt to complete prior to the holiday. Should adjustments be in the best interests of the project, we will advise.

COMMERCIAL STATUS:

Invoice format and the proposed monthly schedule was submitted, reviewed, and approved. Invoice number one was submitted.

CORP ACTION ITEMS:

The Depot's Energy Coordinator has assembled and transmitted considerable data for the report. We still need a definition of the areas of the building to be included in the study when the area of the study does not include the entire building as well as some minor items needed to complete other transmissions. We expect Mr. Hager to deliver this information presently as he has in the recent past. We have requested and await certain government documents that may influence the study. Mr. Mlecik has promised these documents. Finally, payment on the aforementioned invoice is outstanding.

END OF MONTHLY REPORT

EEAP MONTHLY REPORT

December 9, 1994

PROJECT: **LETTERKENNY LIGHTING STUDY**
CONTRACT: **DACA01-94-D-0037---DO-0004**
CONTRACTOR: **ENTECH ENGINEERING INC.,READING, PA.**

SUMMARY OF PROGRESS:

Last month Entech received additional information from the Government. We also began our field investigation of the subject buildings. To date over one and one half million square feet has been reviewed on this project. This represents the majority of the total area and also over one half of the buildings. Plans to complete the site work are in place provided we receive timely instructions. The data that has been collected is being imputed into our computer models.

FORECAST OF EFFORTS:

Planned for the month of December is completion of the field collection of building data for inclusion in the study. We expect the outstanding data to be collected and transferred into our computer models for analysis. We would like to propose a progress meeting following the Christmas season, for the purpose of discussing our findings and how we expect to use the information in the interim report.

COMMERCIAL STATUS:

Invoice number two was submitted. Invoice number one remains unpaid.

CORP ACTION ITEMS:

We need a definition of the areas of the building to be included in the study when the area of the study does not include the entire building. This discussion is on-going with Mr.Hager.

We have requested and still await certain government documents that may influence the study. Mr. Mlecik has promised these documents.

Payment on invoices 1 & 2 is outstanding. Invoice number 1 is overdue and should be accruing interest.

END OF MONTHLY REPORT

EEAP MONTHLY REPORT

January 12, 1995

PROJECT: **LETTERKENNY LIGHTING STUDY**
CONTRACT: **DACA01-94-D-0037---DO-0004**
CONTRACTOR: **ENTECH ENGINEERING INC.,READING, PA.**

SUMMARY OF PROGRESS:

Last month Entech received additional information from the Government. We completed our field investigation of the subject buildings and inserted the data into our lighting models. We have also completed the incremental cost analysis based upon certain assumptions regarding the demand load. The energy use and its associated cost has been performed on a preliminary basis using the incremental cost data. An ECO list has been generated along with a matrix of the anticipated investigation of opportunities. Finally, a sample ECO analysis was performed to illustrate the intended format. All of the above was presented to the Government on 1-11-95. The Government will preform a review of the data Entech presented and confirm the prevailing post-meeting opinion that this effort will satisfy project requirements.

FORECAST OF EFFORTS:

Planned for the month of January is a short pause to allow Governmental review, followed by finalization of the lighting, cost and energy models. We expect this accomplishment to position us to perform the ECO analyses in February.

COMMERCIAL STATUS:

Invoice number three was submitted. Invoice number one has been paid. Invoice number two remains unpaid.

CORP ACTION ITEMS:

Entech needs to identify the assumptions used in the models for government review and comment.

Letterkenny is to furnish historical demand data for clarification of consumption patterns. We have requested and still await certain government documents that may influence the study. Mr. Mlecik has promised these documents.

Payment on invoices 2 & 3 is outstanding. Invoice number 2 is overdue and should be accruing interest. Invoice 1 was paid without the accrued interest.

END OF MONTHLY REPORT

EEAP LIGHTING STUDY

LETTERKENNY, PA

RESPONSE TO COMMENTS

Mobile District - Neiden

1. This EEAP Study reviews conceptual opportunities to save electric energy by considering revisions to the lighting system. The report does not pretend to offer a comprehensive design evaluation of lighting and, in fact, has highlighted many of the same concerns expressed in the review. Generally, the agreed upon methodology for this report analyses power consumption on a lumin per lumin basis using standard output values for the luminaires. This method sets forth a well founded *apple to apple* relationship for energy savings. It may not, as suggested by Mr. Neiden, present the full impact of the proposed project, equally however, such an effort is well beyond the scope of our contracted services.

The requested ECO - Retrofitting Existing Luminaires With New T-8 Lamps and Electronic Ballasts was not considered due to the anticipated life of the existing fixture. To review this decision, in light of Mobile District's comment, we ran a partial analysis (attached) of this potential ECO and found a thirteen year payback. This payback does not consider maintenance costs which (because of the age of the fixtures) would extend the payback. Given these findings, we did not adjust the report.

2. Lighting fixtures have been matched against US Army Corp of Engineers' Standard 40-06-04, February 1991. The two references cited by Mr. Neiden are a 230V (which is a type 230 fixture with a vapor proof enclosure) and n/a (which are miscellaneous fixtures that are not cataloged in the standard). This clarification has been added to the report.

ECO-17
Letterkenny Army Depot
Efficient Industrial Fluorescent Lighting Retrofit

Existing										Proposed				Implementation							
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw-hr Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$
Building 1																					
Chrome Plate Area (CP)	178	2	40	16,376	50	95.0%	15.6	3,554	\$1,438.61	\$1,057.55	\$2,496.15	2 - F32T8 & 1 - 2L Electronic Ballast	60	10.1	2,318	\$1,627.93	\$6,230	\$6,230	\$1,078	\$13,538	\$868.23
Paper Storage Area																					
Building 4																					
Warehouse	858	2	40	78,936	50	95.0%	75.0	17,129	\$6,934.40	\$5,097.62	\$12,032.03	2 - F32T8 & 1 - 2L Electronic Ballast	60	48.9	11,171	\$7,846.97	\$30,030	\$30,030	\$5,195	\$65,255	\$4,185.05
Warehouse Storage	820	2	40	75,440	50	95.0%	71.7	16,370	\$6,627.28	\$4,871.85	\$11,499.14	2 - F32T8 & 1 - 2L Electronic Ballast	60	46.7	10,676	\$7,499.44	\$28,700	\$28,700	\$4,965	\$62,365	\$3,999.70
Warehouse Packaging	10	2	40	920	50	95.0%	0.9	200	\$80.82	\$59.41	\$140.23	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.6	130	\$91.46	\$350	\$350	\$61	\$761	\$48.78
Building 14																					
Warehouse	4	4	40	736	50	95.0%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Initium Installation Room #2	4	3	40	552	50	95.0%	0.5	120	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49
Initium Room	4	4	40	736	50	95.0%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Initium Installation Room #1	4	4	40	736	10	0.0%	0.0	32	\$0.00	\$9.51	\$9.51	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.0	19	\$5.79	\$180	\$160	\$29	\$369	\$33.72
Initium Storage Room	4	4	40	736	10	0.0%	0.0	32	\$0.00	\$9.51	\$9.51	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.0	19	\$5.79	\$180	\$160	\$29	\$369	\$33.72
Initium Final Area	15	4	40	2,760	50	95.0%	2.6	599	\$242.46	\$178.24	\$420.70	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.6	365	\$256.08	\$675	\$600	\$110	\$1,385	\$164.63
Machine Shop Area	37	3	40	5,106	50	95.0%	4.9	1,108	\$448.55	\$329.74	\$778.30	3 - F32T8 & 1 - 3L Electronic Ballast	88	3.1	707	\$496.30	\$1,480	\$1,480	\$256	\$3,216	\$281.99
Second Floor																					
Small Parts Work Area	47	3	40	6,486	50	95.0%	6.2	1,407	\$569.78	\$418.86	\$888.65	3 - F32T8 & 1 - 3L Electronic Ballast	88	3.9	898	\$630.44	\$1,880	\$1,880	\$325	\$4,085	\$358.20
Building 33N																					
Warehouse	77	2	40	7,084	50	95.0%	6.7	1,537	\$622.32	\$457.48	\$1,079.80	2 - F32T8 & 1 - 2L Electronic Ballast	60	4.4	1,003	\$704.22	\$2,695	\$2,695	\$466	\$5,856	\$375.58
Warehouse																					
Building 34																					
Warehouse - Parts Storage Racks	12	2	40	1,104	50	95.0%	1.0	240	\$96.98	\$71.30	\$168.28	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.7	156	\$109.75	\$420	\$420	\$73	\$913	\$58.53
Building 42S																					
Warehouse	17	2	40	1,564	50	95.0%	1.5	339	\$137.39	\$101.00	\$238.40	2 - F32T8 & 1 - 2L Electronic Ballast	60	1.0	221	\$155.48	\$595	\$595	\$103	\$1,293	\$82.92
Warehouse South	124	4	40	2,816	50	95.0%	21.7	4,951	\$2,004.35	\$1,473.44	\$3,477.79	4 - F32T8 & 1 - 4L Electronic Ballast	112	13.2	3,014	\$2,116.91	\$5,580	\$4,960	\$912	\$11,452	\$1,360.87
Warehouse South	11	3	40	1,518	50	95.0%	1.4	329	\$133.35	\$98.03	\$231.39	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.9	210	\$147.55	\$440	\$440	\$76	\$956	\$83.84
Building 43																					
Warehouse	258	2	40	2,376	50	95.0%	22.5	5,151	\$2,085.17	\$1,532.85	\$3,618.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	14.7	3,359	\$2,359.58	\$9,030	\$9,030	\$1,562	\$19,622	\$1,258.44
Warehouse																					
Building 44																					
Warehouse	9	3	40	1,242	50	95.0%	1.2	270	\$109.11	\$80.21	\$189.32	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.8	172	\$120.72	\$360	\$360	\$62	\$782	\$68.59
Receiving Area																					
Building 47																					
Warehouse	20	2	40	1,840	90	95.0%	1.7	719	\$161.64	\$213.89	\$375.53	2 - F32T8 & 1 - 2L Electronic Ballast	60	1.1	469	\$244.91	\$700	\$700	\$121	\$1,521	\$130.62
Warehouse - North																					
Building 51																					
Warehouse	96	3	40	13,248	50	95.0%	12.6	2,875	\$1,163.82	\$855.55	\$2,019.36	3 - F32T8 & 1 - 3L Electronic Ballast	88	8.0	1,833	\$1,267.71	\$3,840	\$3,840	\$664	\$8,344	\$731.65
Warehouse Processing	15	4	40	2,760	50	95.0%	2.6	599	\$242.46	\$178.24	\$420.70	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.6	365	\$256.08	\$675	\$600	\$110	\$1,385	\$164.62
Warehouse Processing	51	3	40	7,038	50	95.0%	6.7	1,527	\$618.28	\$454.51	\$1,072.79	3 - F32T8 & 1 - 3L Electronic Ballast	88	4.3	974	\$684.10	\$2,040	\$2,040	\$353	\$4,433	\$388.69
Warehouse Milvan Processing																					
Building 57S																					
Warehouse	309	3	40	42,642	90	95.0%	40.5	16,656	\$3,746.03	\$4,956.82	\$8,702.85	3 - F32T8 & 1 - 3L Electronic Ballast	88	25.8	10,621	\$5,549.64	\$12,360	\$12,360	\$2,138	\$26,858	\$3,153.21
Warehouse Area																					
Building 424																					
Cable and Harness	72	3	40	9,936	90	95.0%	9.4	3,881	\$872.86	\$1,154.99	\$2,027.85	3 - F32T8 & 1 - 3L Electronic Ballast	88	6.0	2,475	\$1,293.12	\$2,880	\$2,880	\$498	\$6,258	\$734.73
Upholstery Work Shop	32	3	40	4,416	90	95.0%	4.2	1,725	\$387.94	\$513.33	\$901.27	3 - F32T8 & 1 - 3L Electronic Ballast	88	2.7	1,100	\$574.72	\$1,280	\$1,280	\$221	\$2,781	\$266.55
Upholstery Work Shop	12	3	40	1,656	90	95.0%	1.6	647	\$145.48	\$192.50	\$337.97	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.0	412	\$215.52	\$480	\$480	\$83	\$1,043	\$122.45
Rubber Mat Storage Room	12	3	40	1,656	90	95.0%	1.6	647	\$145.48	\$192.50	\$337.97	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.0	412	\$215.52	\$480	\$480	\$83	\$1,043	\$122.45
Work Area	12	3	40	1,656	90	95.0%	1.6	647	\$145.48	\$192.50	\$337.97	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.0	412	\$215.52	\$480	\$480	\$83	\$1,043	\$122.45
Work Area	12	3	40	1,656	90	95.0%	1.6	647	\$145.48	\$192.50	\$337.97	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.0	412	\$215.52	\$480	\$480	\$83	\$1,043	\$122.45
TOTALS	3120			334696			317.3	83577	\$29,000	\$25,000	\$54,000			204.3	53763	\$35,000	\$114,000	\$114,000	\$20,000	\$248,000	\$19,000

G:\PROJECTS\1501\SSUE\ECO_17.WK4

09-Aug-95

MOBILE DIST. OFFICE PROJECT REVIEW COMMENTS			DATE: 5 JUL 95	PAGE 1 of 1
TO: EN-DM Battaglia		FROM: (SECTION): Electrical (CESAM-EN-DE) (REVIEWER): Warren E. Neiden, Jr., PE (334) 694-4031		
PROJECT: KEAP Lighting Study LOCATION: Letterkenny AD,			Year: FY-	Line Item No.
Type of Action: Preliminary			ELECTRICAL REVIEW	
Item No.	Drawing No. or Par. No.	COMMENTS	Review Action	
1.	ECO-11	<p>This ECO proposes to replace Existing Industrial Fluorescent Fixtures with New HPS Fixtures. The ramifications of any proposal should be analyzed as well as indicate in this study so that the Letterkenny personnel can make wise decisions based on the facts.</p> <p>The following information should be included before any decision on this ECO is made:</p> <ol style="list-style-type: none"> Provide lighting calculations for proposed lighting system so as to indicate that the lighting levels are the same. Address the uniformity of the proposed lighting as compared with the existing lighting system. Address the Color Rendering impact to go to this proposed lighting system. Compare the operation of the proposed lighting system with the existing...warm-up time on start-up, as well as the restrict time on power outages, etc. Does the existing lighting system incorporate "battery-backup ballast" for emergency or egress lighting requirements? If so address how the proposed lighting system will incorporate requirement and include the cost in your analysis as well. Provide fixture information with the Coefficient of Utilization values indicated to substantiate the reduction in fixtures required in this proposal. <p>All of this information is just as necessary in making the right decision as the bottom line cost. Also the savings may be unfounded if these items are not addressed.</p> <p>I saw no ECO that considered just replacing these existing lamps and ballast with the more efficient T8 lamps and electronic ballast similar to that proposed in ECO-6.</p>		
2.	Section 9.4	Provide fixture details to correspond with Fixture Type "230V", and "n/a" that are indicated in these tables.		

3348902424

11-10-95

ATTACHMENT 9.3

Electric Bills and Rate Schedule

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

9 08/16/93 1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112001

TELEPHONE: (412) 626-5280

MAIL TO: JUL 012 SUB

--
41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 078814122000112001 14095863 9 13921840 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 07/15	401	07/16/93
		PREVIOUS 06/15		

METER	A	B
CURRENT READING	1331	1345
PREVIOUS READING	1173	1185
DIFFERENCE	158	160
MULTIPLIER	9600	9600
TOTAL KWH	1516800	1536000
KWH ADJUSTMENT	23942	
BILL USAGE	1540742	1536000
KW DEMAND	8341.0	
KW ADJUSTMENT	63.0	

TOTAL BILLED KW	8404.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 7.5370	15,074.00	
	6,404.0 @ 7.4390	47,639.36	62,713.36
TOTAL BILLED KWH	3,076,742		
KWH ENERGY CHARGES	FOR 30 DAYS		
	3,076,742 @ .02314	71,195.81	71,195.81
SURCHARGE	-.2100 %		281.21-
ENERGY COST RATE @	.0018170		3,590.44
CURRENT NET BILL			139,218.40

AMOUNT DUE

139,218.40

ESTIMATED PA STATE TAXES OF 10,232.55 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1,740.23
PAY AFTER 08/16/93 140,958.63

"75 Years At Your Service"

 West Penn Power Company
Part of the Allegheny Power System

Denny

West Penn Power Company
SOUTH 7TH STREET
CONNELLVILLE, PA 15425

PAYMENT DUE DATE	PAGE NO
09/16/93	1

TELEPHONE: (412) 626-5280

USE WHEN REFERRING TO BILL
ACCOUNT NO.
41/22/000/112001

MAIL TO: AUG 04 303

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

WEST PENN POWER COMPANY
PO BOX 640575
PITTSBURGH PA 15264-0575

14095863 9 873614122000112001 28671687 9 28319864 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 08/16 PREVIOUS 07/15	401	08/17/93
METER	A	B		
CURRENT READING	1498	1515		
PREVIOUS READING	1331	1345		
DIFFERENCE	167	170		
MULTIPLIER	9600	9600		
TOTAL KWH	1603200	1632000		
KWH ADJUSTMENT	25436			
BILL USAGE	1628636	1632000		
KW DEMAND	8133.0			
KW ADJUSTMENT	61.0			
TOTAL BILLED KW	8194.0			
KW DEMAND CHARGES	FOR 30 DAYS			
	2,000.0 @ 7.5370	15,074.00		
	6,194.0 @ 7.4390	46,077.17		
			61,151.17	
TOTAL BILLED KWH	3,260,636			
KWH ENERGY CHARGES	FOR 30 DAYS			
	3,260,636 @ .02314	75,451.12	75,451.12	
SURCHARGE	-.2100 %		286.86-	
ENERGY COST RATE @	.0018170		5,924.58	
CURRENT NET BILL				142,240.01
PREVIOUS BALANCE				140,958.63
AMOUNT DUE				283,198.64

ESTIMATED PA STATE TAXES OF 10,454.64 INCLUDED IN THIS BILLING.
LATE PAYMENT CHARGE 3,518.23
PAY AFTER 09/16/93 286,716.87
PREVIOUS BALANCE OF 140,958.63 IS PAST DUE. IF PAYMENT HAS NOT BEEN MADE, YOUR ELECTRIC SERVICE MAY BE SUBJECT TO TERMINATION.

West Penn Power Company

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

TELEPHONE: (412) 626-5280

PAYMENT DUE DATE	PAGE NO.
10/18/93	1

USE WHEN REFERRING TO BILL
ACCOUNT NO.
41/22/000/112001

MAIL TO: SEP

WEST PENN POWER COMPANY

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD.
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 079614122000112001 13770812 9 13600802 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 09/15 PREVIOUS 08/16	401	09/16/93

METER	A	B
CURRENT READING	1654	1673
PREVIOUS READING	1498	1515
DIFFERENCE	156	158
MULTIPLIER	9600	9600
TOTAL KWH	1497600	1516800
KWH ADJUSTMENT	23757	
BILL USAGE	1521357	1516800
KW DEMAND	8041.0	
KW ADJUSTMENT	60.0	

TOTAL BILLED KW	8101.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 7.5370	15,074.00	
	6,101.0 @ 7.4390	45,385.34	60,459.34
TOTAL BILLED KWH	3,038,157		
KWH ENERGY CHARGES	FOR 30 DAYS		
	3,038,157 @ .02314	70,302.95	70,302.95
SURCHARGE	-.2100 %		274.60-
ENERGY COST RATE @	.0018170		5,520.33
CURRENT NET BILL			136,008.02

AMOUNT DUE 136,008.02

ESTIMATED PA STATE TAXES OF 9,996.59 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1,700.10
PAY AFTER 10/18/93 137,708.12

REFER INQUIRIES TO:
West Penn Power Company

SOUTH 7TH STREET
 CONNELLSVILLE, PA 15425

TELEPHONE: (412) 626-5280

PAYMENT DUE DATE	PAGE NO.
11/22/93	1
USE WHEN REFERRING TO BILL ACCOUNT NO.	
41/22/000/112001	

MAIL TO: *oct*

WEST PENN POWER COMPANY

PO BOX 640575
 PITTSBURGH PA 15264-0575

--
 41 22 000 112001
 LETTERKENNY ARMY DEPOT
 SDSLE ERW
 * LETTERKENNY RD
 -- CHAMBERSBURG PA
 17201

00000000 9 076514122000112001 12237785 9 12086701 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL
 WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 10/15 PREVIOUS 09/15	401	10/21/93

METER	A	B
CURRENT READING	1789	1808
PREVIOUS READING	1654	1673
DIFFERENCE	135	135
MULTIPLIER	9600	9600
TOTAL KWH	1296000	1296000
KWH ADJUSTMENT	21874	
BILL USAGE	1317874	1296000
KW DEMAND	7430.0	
KW ADJUSTMENT	55.0	

TOTAL BILLED KW	7485.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 7.5370	15,074.00	
	5,485.0 @ 7.4390	40,802.92	55,876.92
TOTAL BILLED KWH	2,613,874		
KWH ENERGY CHARGES	FOR 30 DAYS		
	2,613,874 @ .02316	60,485.04	60,485.04
SURCHARGE	-.2100 %		244.36-
ENERGY COST RATE @	.0018170		4,749.41
CURRENT NET BILL			120,867.01

AMOUNT DUE 120,867.01

ESTIMATED PA STATE TAXES OF 8,883.73 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1,510.84
 PAY AFTER 11/22/93 122,377.85

REFER INQUIRIES TO:
West Penn Power Company
SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

TELEPHONE: (412) 626-5280

PAYMENT DUE DATE PAGE N

12/16/93

1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112001

MAIL TO: NOV

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

00000000 9 071414122000112001 11609369 9 11466043 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 11/15	401	11/16/93
		PREVIOUS 10/15		

Existing Sub.
METER A B
CURRENT READING 1920 1943
PREVIOUS READING 1789 1808
DIFFERENCE 131 135
MULTIPLIER 9600 9600
TOTAL KWH 1257600 1296000
KWH ADJUSTMENT 22101
BILL USAGE 1279701 1296000
KW DEMAND 6728.0
KW ADJUSTMENT 49.0

TOTAL BILLED KW 6777.0
KW DEMAND CHARGES FOR 30 DAYS
2,000.0 @ 7.5370 15,074.00
4,777.0 @ 7.4390 35,536.10

15,074.00
35,536.10 50,610.10

TOTAL BILLED KWH 2,575,701
KWH ENERGY CHARGES FOR 30 DAYS
2,575,701 @ .02314 59,601.72

59,601.72 59,601.72
231.46
4,680.05 114,660.43

SURCHARGE .2100 %
ENERGY COST RATE .0018170
CURRENT NET BILL

AMOUNT DUE

114,660.43

ESTIMATED PA STATE TAXES OF 8,427.54 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1,433.26
PAY AFTER 12/16/93 116,093.69

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

Allegany

9 01/18/94 1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112001

TELEPHONE: (412) 626-5280

MAIL TO: DEC

WEST PENN POWER COMPANY

-- 41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

11609369 9 173314122000112001 23778783 9 23486987 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 12/15	401	12/16/93
<i>Electric</i>		PREVIOUS 11/15		

METER	A	B
CURRENT READING	2055	2079
PREVIOUS READING	1920	1943
DIFFERENCE	135	136
MULTIPLIER	9600	9600
TOTAL KWH	1296000	1305600
KWH ADJUSTMENT	21914	
BILL USAGE	1317914	1305600
KW DEMAND	7119.0	
KW ADJUSTMENT	52.0	

TOTAL BILLED KW	7171.0			
KW DEMAND CHARGES	FOR 30 DAYS			
	2,000.0 @ 7.5370	15,074.00		
	5,171.0 @ 7.4390	38,467.07	53,541.07	
TOTAL BILLED KWH	2,623,514			
KWH ENERGY CHARGES	FOR 30 DAYS			
	2,623,514 @ .02314	60,708.11	60,708.11	
SURCHARGE	-.2100 %		239.92-	
ENERGY COST RATE @	.0018170		4,766.92	
CURRENT NET BILL				118,776.18
PREVIOUS BALANCE			116,093.69	
AMOUNT DUE				234,869.87

ESTIMATED PA STATE TAXES OF 8,730.05 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 2,917.96
PAY AFTER 01/18/94 237,787.83

"75 Years At Your Service"

 West Penn Power Company
Part of the Allegheny Power System

REFER INQUIRIES TO:

West Penn Power Company

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

TELEPHONE: (412) 626-5280

PAYMENT DUE DATE	PAGE NO.
02/16/94	1
USE WHEN REFERRING TO BILL ACCOUNT NO.	
41/22/000/112001	

MAIL TO:

JAN

WEST PENN POWER COMPANY

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00143326 9 771914122000112001 12646361 9 12490233 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 01/14	401	01/17/94
		PREVIOUS 12/15		

METER	A	B
CURRENT READING	2196	2221
PREVIOUS READING	2055	2179
DIFFERENCE	141	142
MULTIPLIER	9600	9600
TOTAL KWH	1353600	1363200
KWH ADJUSTMENT	22401	
BILL USAGE	1376001	1363200
KW DEMAND	7361.0	
KW ADJUSTMENT	54.0	

TOTAL BILLED KW	7415.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 7.5370	15,074.00	
	5,415.0 @ 7.4390	40,282.19	55,356.19
TOTAL BILLED KWH	2,739,201		
KWH ENERGY CHARGES	FOR 30 DAYS		
	2,739,201 @ .02314	63,385.11	63,385.11
SURCHARGE	-.2100 %		249.36-
ENERGY COST RATE @	.0018170		4,977.13
CURRENT NET BILL			123,469.07
PREVIOUS BALANCE		1,433.26	
AMOUNT DUE			124,902.33

ESTIMATED PA STATE TAXES OF 9,074.98 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1.561.28

PAY AFTER 02/16/94 126,463.61

West Penn Power Company

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

TELEPHONE: (412) 626-5280

PAYMENT DUE DATE	PAGE NO.
03/18/94	1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

1/41/22/000/112001

MAIL TO:

FEB

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

1/41/22/000/112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
LETTERKENNY RD
-- CHAMBERSBURG PA
17201

12646361 9 173114122000112001 26037882 9 25718354 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	RATE	BILLING DATE
1/41/22/000/11200/1	DAAG 34-70-C-0016	401	02/16/94
ACCOUNT BALANCE	01/17/94	124,902.33	
LATE PAYMENT CHARGE		1,561.28	
ACCOUNT BALANCE BROUGHT FORWARD		126,463.61	
CURRENT BILLING FOR 032 DAYS USE 01/14/94 TO 02/15/94			
METER	A	B	
CURRENT READING	2351	2377	
PREVIOUS READING	2196	2221	
DIFFERENCE	155	156	
MULTIPLIER	9600	9600	
KWH	1488000	1497600	
KWH ADJUSTMENT	24279		
KW DEMAND	7430.0		
DEMAND ADJUSTMENT	55.0		
TOTAL KWH	3009879		
TOTAL KW DEMAND	7485.0		
BILLING DEMAND CHARGE FOR	7,485.0 KW		
2,000.0 @	7.5370	15,074.00	
5,485.0 @	7.4390	40,802.92	
ENERGY CHARGE FOR	3,009,879 KWH		
2,994,000 @	.02314	69,281.16	
15,879 @	.02245	356.48	
BILLED CHARGES ON RATE 401		125,514.56	
PA TAX SURCHARGE @	.2100000%	263.58	
ENERGY COST RATE @	.0018170 /KWH	5,468.95	
CHARGE FOR CURRENT BILL PERIOD		130,719.93	
AMOUNT DUE		257,183.54	
LATE PAYMENT CHARGE		3,195.28	
TOTAL AMOUNT DUE AFTER	03/18/94	260,378.82	
ESTIMATED PA STATE TAXES OF	9,607.91 INCLUDED IN THIS BILLING		

"75 Years At Your Service"

 West Penn Power Company
Part of the Allegheny Power System

West Penn Power Company

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

TELEPHONE: (412) 626-5280

6

PAYMENT DUE DATE
04/15/94

PAGE NO
1

USE WHEN REFERRING TO BILL

ACCOUNT NO.

1/41/22/000/112001

MAIL TO:

mar

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

1/41/22/000/112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
LETTERKENNY RD
-- CHAMBERSBURG PA
17201

00145117 9 879814122000112001 12186195 9 12035748 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	RATE	BILLING DATE
1/41/22/000/112001/1 DAAG 34-70-C-0016		401	03/16/94
Accounting			
ACCOUNT BALANCE	02/16/94	257,183.54	
PAYMENT RECEIVED		254,189.00-	
ACCOUNT BALANCE BROUGHT FORWARD			1,451.17

CURRENT BILLING FOR 028 DAYS USE 02/15/94 TO 03/15/94			
METER	A	B	
CURRENT READING	2484	2512	
PREVIOUS READING	2351	2377	
DIFFERENCE	133	135	
MULTIPLIER	9600	9600	
	1276800	1296000	
ADJUSTMENT	21069		
KW DEMAND	7235.0		
DEMAND ADJUSTMENT	53.0		
TOTAL KWH	2593869		
TOTAL KW DEMAND	7288.0		
BILLING DEMAND CHARGE FOR 7,288.0 KW			
2,000.0 @ 7.5370		13,074.00	
5,288.0 @ 7.4390		39,337.43	
ENERGY CHARGE FOR 2,593,869 KWH			
2,593,869 @ .02314		60,022.13	
BILLED CHARGES ON RATE 401			114,433.56
PA TAX SURCHARGE @ .2100000%			240.31-
ENERGY COST RATE @ .0013170 /KWH			4,713.06
CHARGE FOR CURRENT BILL PERIOD			118,906.31
AMOUNT DUE			120,357.48
LATE PAYMENT CHARGE		1,504.47	
TOTAL AMOUNT DUE AFTER	04/15/94	121,861.95	
ESTIMATED PA STATE TAXES OF 8,739.61 INCLUDED IN THIS BILLING			



West Penn Power Company
Part of the Allegheny Power System

REFER INQUIRIES TO:
West Penn Power Company
SOUTH 7TH STREET
CONNELLSSVILLE, PA 15425

PAYMENT DUE DATE	PAGE NO
6 05/18/94	1

USE WHEN REFERRING TO BILL
ACCOUNT NO.
1/41/22/000/112001

TELEPHONE: (412) 626-5280

MAIL TO: *ARR*

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

1/41/22/000/112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
LETTERKENNY RD
CHAMBERSBURG PA
17201

00146931 9 174214122000112001 12771004 9 12613360 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	RATE	BILLING DATE
1/41/22/000/112001/1	DAAG 34-70-C-0016	401	04/18/94
<i>Existing</i>			
ACCOUNT BALANCE	03/16/94	120,357.48	
LATE PAYMENT CHARGE		18.14	
PAYMENT RECEIVED		118,906.31	
ACCOUNT BALANCE BROUGHT FORWARD			1,469.31
CURRENT BILLING FOR 031 DAYS USE 03/15/94 TO 04/15/94			
METER	A	B	
CURRENT READING	2630	2659	
PREVIOUS READING	2484	2512	
DIFFERENCE	146	147	
MULTIPLIER	9600	9600	
KWH	1401600	1411200	
KWH ADJUSTMENT	23171		
KW DEMAND	7131.0		
DEMAND ADJUSTMENT	52.0		
TOTAL KWH	2835971		
TOTAL KW DEMAND	7183.0		
BILLING DEMAND CHARGE FOR		7,183.0 KW	
2,000.0 @	7.5370		15,074.00
5,183.0 @	7.4390		38,556.34
ENERGY CHARGE FOR	2,835,971 KWH		
2,835,971 @	.02314		65,624.37
BILLED CHARGES ON RATE 401			119,254.71
PA TAX SURCHARGE			201.96-
ENERGY COST RATE @ .0019787 /KWH			5,611.54
CHARGE FOR CURRENT BILL PERIOD			124,664.29
AMOUNT DUE			126,133.60
LATE PAYMENT CHARGE			1,576.44
TOTAL AMOUNT DUE AFTER 05/18/94			127,710.04

ESTIMATED PA STATE TAXES OF 9,025.69 INCLUDED IN THIS BILLING

PREVIOUS BALANCE OF 1,469.31 IS PAST DUE. IF PAYMENT HAS NOT BEEN MADE, YOUR ELECTRIC SERVICE MAY BE SUBJECT TO TERMINATION.

West Penn Power Company

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

TELEPHONE: (412) 626-5280

PAYMENT DUE DATE	PAGE NO.
06/16/94	1
USE WHEN REFERRING TO BILL	
ACCOUNT NO.	
1/41/22/000/112001	

MAIL TO: MAY

WEST PENN POWER COMPANY

1/41/22/000/112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
LETTERKENNY RD
CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00146931 9 177214122000112001 11728251 9 11581666 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	RATE	BILLING DATE
1/41/22/000/112001/1	DAAG 34-70-C-0016	401	05/17/94
Existing			
ACCOUNT BALANCE	04/18/94	126,133.60	
PAYMENT RECEIVED		124,664.29	
ACCOUNT BALANCE BROUGHT FORWARD			1,469.31
CURRENT BILLING FOR 031 DAYS USE 04/15/94 TO 05/16/94			
METER	A	B	
CURRENT READING	2761	2793	
PREVIOUS READING	2630	2659	
DIFFERENCE	131	134	
MULTIPLIER	9600	9600	
KWH	1257600	1286400	
KWH ADJUSTMENT	22063		
KW DEMAND	6497.0		
DEMAND ADJUSTMENT	47.0		
TOTAL KWH	2566063		
TOTAL KW DEMAND	6544.0		
BILLING DEMAND CHARGE FOR 6,544.0 KW			
2,000.0 @ 7.5370		15,074.00	
4,544.0 @ 7.4390		33,802.82	
ENERGY CHARGE FOR 2,566,063 KWH			
2,566,063 @ .02314		59,378.70	
BILLED CHARGES ON RATE 401			
ENERGY COST RATE @ .0023740 /KWH		108,255.52	
		6,091.83	
CHARGE FOR CURRENT BILL PERIOD			
		114,347.35	
AMOUNT DUE			
		115,816.66	

LATE PAYMENT CHARGE 1,465.85
TOTAL AMOUNT DUE AFTER 06/16/94 117,282.51

TOTAL AMOUNT AFTER DUE DATE INCLUDES CURRENT LATE PAYMENT CHARGE OF
1,447.71 PLUS OUTSTANDING LATE PAYMENT CHARGES FROM PREVIOUS BILLS.

ESTIMATED PA STATE TAXES OF 8,278.75 INCLUDED IN THIS BILLING

West Penn Power Company

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

PAYMENT DUE DATE PAGE NO.

6

07/18/94

1

USE WHEN REFERRING TO BILL

ACCOUNT NO.

1/41/22/000/112001

TELEPHONE: (412) 626-5280

MAIL TO:

JUN

WEST PENN POWER COMPANY

1/41/22/000/112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
LETTERKENNY RD
CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00150582 9 579114122000112001 12715398 9 12558463 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	RATE	BILLING DATE
1/41/22/000/11200/1	DAAG 34-70-C-0016	401	06/16/94
ACCOUNT BALANCE	05/17/94	115,816.66	
LATE PAYMENT CHARGE		36.51	
PAYMENT RECEIVED		114,347.35-	
ACCOUNT BALANCE BROUGHT FORWARD			1,505.82

CURRENT BILLING FOR 030 DAYS USE 05/16/94 TO 06/15/94

METER	A	B
CURRENT READING	2897	2930
PREVIOUS READING	2761	2793
DIFFERENCE	136	137
LIPLIER	9600	9600
KWH	1305600	1315200
KWH ADJUSTMENT	21994	
KW DEMAND	7534.0	
DEMAND ADJUSTMENT	55.0	
TOTAL KWH	2642794	
TOTAL KW DEMAND	7589.0	

BILLING DEMAND CHARGE FOR 7589.0 KW

2,000.0 @ 7.5370	15,074.00
5,589.0 @ 7.4390	41,576.57
ENERGY CHARGE FOR 2,642,794 @ .02314 KWH	61,154.25

BILLED CHARGES ON RATE 401
ENERGY COST RATE @ .0023740 /KWH

CHARGE FOR CURRENT BILL PERIOD

AMOUNT DUE

LATE PAYMENT CHARGE 1,569.35
TOTAL AMOUNT DUE AFTER 07/18/94 127,153.98

ESTIMATED PA STATE TAXES OF 8,983.31 INCLUDED IN THIS BILLING



West Penn Power Company
Part of the Allegheny Power System

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

McNary

9 11/19/92 1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112001

TELEPHONE: (412) 626-5280

MAIL TO: OCT

WEST PENN POWER COMPANY

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 078014122000112001 16576553 9 16371904 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-79-C-0016	CURRENT 10/13	401	10/20/92
		PREVIOUS 09/13		

METER	A	B	C
CURRENT READING	0	4289	4450
PREVIOUS READING	0	4096	4255
DIFFERENCE	0	193	195
MULTIPLIER	1	9600	9600
TOTAL KWH	0	1852800	1872000
KWH ADJUSTMENT		27564	
BILL USAGE		1880364	
KW DEMAND	10817.0		
KW ADJUSTMENT	90.0		

TOTAL BILLED KW	10907.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 6.6650	13,330.00	
	8,907.0 @ 6.5670	58,492.27	71,822.27
TOTAL BILLED KWH	3,752,364		
KWH ENERGY CHARGES	FOR 30 DAYS		
	3,752,364 @ .02256	84,653.33	84,653.33
SURCHARGE	1.0800 %		1,689.94
ENERGY COST RATE @	.0014800		5,553.50
CURRENT NET BILL			163,719.04

AMOUNT DUE 163,719.04

ESTIMATED PA STATE TAXES OF 12,033.35 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 2,046.49
PAY AFTER 11/19/92 165,765.53

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

Agency B

9 12/21/92 11

USE WHEN REFERRING TO BILL
ACCOUNT NO.

TELEPHONE: (412) 626-5280

MAIL TO: NOV

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 073014122000112001 17786779 9 17567189 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 11/16	401	11/19/92
		PREVIOUS 10/15		

METER	A	B	C
CURRENT READING	0	4519	4683
PREVIOUS READING	0	4289	4450
DIFFERENCE	0	230	233
MULTIPLIER	1	9600	9600
TOTAL KWH	0	2208000	2236800
KWH ADJUSTMENT		32361	
BILL USAGE		2240361	
KW DEMAND	10022.0		
KW ADJUSTMENT	80.0		

TOTAL BILLED KW	10102.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 6.6650	13,330.00	
	8,102.0 @ 6.5670	53,205.83	66,535.83

TOTAL BILLED KWH	4,477,161		
KWH ENERGY CHARGES	FOR 30 DAYS		
	4,040,800 @ .02256	91,160.45	
	436,361 @ .02187	9,543.22	100,703.67
SURCHARGE	1.0800 %		1,806.19
ENERGY COST RATE @	.0014800		6,626.20
CURRENT NET BILL			175,671.89

AMOUNT DUE 175,671.89

ESTIMATED PA STATE TAXES OF 12,911.88 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 2,195.90
PAY AFTER 12/21/92 177,867.79

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

Henry B

9 01/20/93 1

USE WHEN REFERRING TO BILL

ACCOUNT NO.

41/22/000/112001

TELEPHONE: (412) 626-5280

MAIL TO:

DAB

WEST PENN POWER COMPANY

-- 41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 073214122000112001 17322826 9 17108964 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 12/16	401	12/21/92
		PREVIOUS 11/16		

METER	A	B	C
CURRENT READING	0	4737	4904
PREVIOUS READING	0	4519	4683
DIFFERENCE	0	218	221
MULTIPLIER	1	9600	9600
TOTAL KWH	0	2092800	2121600
KWH ADJUSTMENT		30654	
BILL USAGE		2123454	
KW DEMAND	10149.0		
KW ADJUSTMENT	82.0		

TOTAL BILLED KW	10231.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 6.6650	13,330.00	
	8,231.0 @ 6.5670	54,052.98	67,382.98

TOTAL BILLED KWH	4,245,054		
KWH ENERGY CHARGES	FOR 30 DAYS		
	4,092,400 @ .02256	92,324.54	
	152,654 @ .02187	3,338.54	95,663.08
SURCHARGE	1.0800 %		1,760.90
ENERGY COST RATE @	.0014800		6,282.68
CURRENT NET BILL			171,089.64

AMOUNT DUE

171,089.64

ESTIMATED PA STATE TAXES OF 12,575.09 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 2,138.62
PAY AFTER 01/20/93 173,228.26

REFER INQUIRIES TO:

West Penn Power Company

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

TELEPHONE: (412) 626-5280

PAYMENT DUE DATE PAGE NO.

03/22/93

1

USE WHEN REFERRING TO BILL

ACCOUNT NO.

41/22/000/112001

MAIL TO: JAN

WEST PENN POWER COMPANY

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
CHAMBERSBURG, PA 17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 072214122000112001 00000000 9 00000000 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER
41/22/000/11200/1

SERVICE LOCATION
DAAG 34-70-C-0016

READING DATES
CURRENT 01/15
PREVIOUS 12/16

RATE
402

DATE
02/19/93

METER	A	B
CURRENT READING	214	216
PREVIOUS READING	0	0
DIFFERENCE	214	216
MULTIPLIER	9600	9600
TOTAL KWH	2054400	2073600
KWH ADJUSTMENT	30081	
BILL USAGE	2084481	2073600
KW DEMAND	10333.0	
KW ADJUSTMENT	84.0	

TOTAL BILLED KW 10417.0
KW DEMAND CHARGES FOR 30 DAYS
2,000.0 @ 6.6650
8,417.0 @ 6.5670

13,330.00
55,274.44 68,604.44

TOTAL BILLED KWH 4,158,081
KWH ENERGY CHARGES FOR 30 DAYS
4,158,081 @ .02256

93,806.31 93,806.31
1,754.04
6,153.96

SURCHARGE 1.0800%
ENERGY COST RATE @ .0014800
CURRENT NET BILL

170,318.75

LESS CREDIT MEMO

170,318.75-

AMOUNT DUE

0.00

ESTIMATED PA STATE TAXES OF 12,518.43 INCLUDED IN THIS BILLING.

CORRECTED INVOICE

West Penn Power Company

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

TELEPHONE: (412) 626-5280

PAYMENT DUE DATE PAGE NO

03/22/93 1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112001

MAIL TO: JAN

WEST PENN POWER COMPANY

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 079514122000112001 18558491 9 18329374 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 02/16	401	02/19/93
		PREVIOUS 01/15		

METER	A	B
CURRENT READING	456	463
PREVIOUS READING	214	216
DIFFERENCE	242	247
MULTIPLIER	9600	9600
TOTAL KWH	2323200	2371200
KWH ADJUSTMENT	34061	
BILL USAGE	2357261	2371200
KW DEMAND	10264.0	
KW ADJUSTMENT	83.0	

TOTAL BILLED KW	10347.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 6.6650	13,330.00	
	8,347.0 @ 6.5670	54,814.75	68,144.75
TOTAL BILLED KWH	4,728,461		
KWH ENERGY CHARGES	FOR 30 DAYS		
	4,138,800 @ .02256	93,371.33	
	589,661 @ .02187	12,895.89	106,267.22
SURCHARGE	1.0800 %		1,883.65
ENERGY COST RATE @	.0014800		6,998.12
CURRENT NET BILL			183,293.74

AMOUNT DUE 183,293.74

ESTIMATED PA STATE TAXES OF 13,472.09 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 2,291.17
PAY AFTER 03/22/93 185,584.91

REFER INQUIRY TO:
West Penn Power Company

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

TELEPHONE: (412) 626-5280

CREDIT MEMORANDUM
FORM 11-105 REV 1

▼ USE WHEN REFERRING TO BILL

ACCOUNT NO.

41/22/000/112001

JAN

MAIL TO:

West Penn Power Company

PO BOX 640575
PITTSBURGH PA 15264-0575

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
CHAMBERSBURG, PA 17201

		DATE	RATE SCHEDULE
		02/19/93	401
ACCOUNT NO.	SERVICE LOCATION	\$	\$
41/22/000/11200/1	DAAG 34-70-C-0016		
TO CANCEL YOUR ELECTRIC SERVICE BILL DATED JANUARY 18, 1993 IN THE AMOUNT OF		\$170,318.75	\$170,318.75
TOTAL			
DUE TO A CLERICAL ERROR, THE KILOWATTHOUR READINGS WERE TRANPOSED FOR JANUARY 15, 1993			
SEE CORRECTED INVOICE			



West Penn Power Company
Part of the Allegheny Power System

West Penn Power Company

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

TELEPHONE: (412) 626-5280

9

03/22/93

USE WHEN REFERRING TO BILL

ACCOUNT NO.

41/22/000/112001

MAIL TO:

FEB

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

00000000 9 079514122000112001 18558491 9 18329374 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 02/16	401	02/19/93
		PREVIOUS 01/15		

METER	A	B
CURRENT READING	456	463
PREVIOUS READING	214	216
DIFFERENCE	242	247
MULTIPLIER	9600	9600
TOTAL KWH	2323200	2371200
KWH ADJUSTMENT	34061	
BILL USAGE	2357261	2371200
KW DEMAND	10264.0	
KW ADJUSTMENT	83.0	

TOTAL BILLED KW	10347.0
KW DEMAND CHARGES	FOR 30 DAYS
	2,000.0 @ 6.6650
	8,347.0 @ 6.5670

13,330.00
54,814.75
68,144.75

TOTAL BILLED KWH	4,728,461
KWH ENERGY CHARGES	FOR 30 DAYS
	4,138,800 @ .02256
	589,661 @ .02187
SURCHARGE	1.0800 %
ENERGY COST RATE @	.0014800
CURRENT NET BILL	

93,371.33
12,895.89
106,267.22
1,883.65
6,998.12

183,293.74

AMOUNT DUE

183,293.74

ESTIMATED PA STATE TAXES OF 13,472.09 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 2,291.17
PAY AFTER 03/22/93 185,584.91

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

04/16/93 1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112001

TELEPHONE: (412) 626-5280

MAIL TO: MAR

WEST PENN POWER COMPANY

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

18329374 9 575614122000112001 35462685 9 35024874 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 03/15	401	03/17/93
		PREVIOUS 02/16		

METER	A	B
CURRENT READING	664	671
PREVIOUS READING	456	463
DIFFERENCE	208	208
MULTIPLIER	9600	9600
TOTAL KWH	1996800	1996800
KWH ADJUSTMENT	28969	
BILL USAGE	2025769	1996800
KW DEMAND	10322.0	
KW ADJUSTMENT	84.0	

TOTAL BILLED KW	10406.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 6.6650	13,330.00	
	8,406.0 @ 6.5670	55,202.20	68,532.20

TOTAL BILLED KWH	4,022,569		
KWH ENERGY CHARGES	FOR 30 DAYS		
	4,022,569 @ .02256	90,749.16	90,749.16
SURCHARGE	1.0800 %		1,720.24
ENERGY COST RATE @	.0014800		5,953.40
CURRENT NET BILL			166,955.00

PREVIOUS BALANCE		183,293.74
------------------	--	------------

AMOUNT DUE	350,248.74
------------	------------

ESTIMATED PA STATE TAXES OF 12,271.19 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 4,378.11
PAY AFTER 04/16/93 354,626.85

West Penn Power Company
SOUTH 7TH STREET
CONNELLVILLE, PA 15425

05/17/93	1
USE WHEN REFERRING TO BILL ACCOUNT NO.	
41/22/000/112001	

TELEPHONE: (412) 626-5280

MAIL TO:

APR

--
41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
-- * LETTERKENNY RD
-- CHAMBERSBURG PA
17201

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 077114122000112001 17039360 9 16828998 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 04/15	401	04/16/93
		PREVIOUS 03/15		

METER	A	B
CURRENT READING	875	884
PREVIOUS READING	664	671
DIFFERENCE	211	213
MULTIPLIER	9600	9600
TOTAL KWH	2025600	2044800
KWH ADJUSTMENT	29832	
BILL USAGE	2055432	2044800
KW DEMAND	10149.0	
KW ADJUSTMENT	82.0	

EXISTING SUBSTATION

TOTAL BILLED KW	10231.0		
KW DEMAND CHARGES	FOR 31 DAYS		
	2,000.0 @ 6.6650	13,330.00	
	8,231.0 @ 6.5670	54,052.98	67,382.98
TOTAL BILLED KWH	4,100,232		
KWH ENERGY CHARGES	FOR 31 DAYS		
	4,092,400 @ .02256	92,324.54	
	7,832 @ .02187	171.29	92,495.83
SURCHARGE			1,674.08
ENERGY COST RATE @ .0016431			6,737.09
CURRENT NET BILL			168,289.98

AMOUNT DUE

168,289.98

ESTIMATED PA STATE TAXES OF 12,369.31 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 2,103.62
PAY AFTER 05/17/93 170,393.60

"75 Years At Your Service"

 West Penn Power Company
Part of the Allegheny Power System

West Penn Power Company

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

Henry B

PAYMENT DUE DATE

PAGE NO.

9

06/16/93

1

USE WHEN REFERRING TO BILL

ACCOUNT NO.

41/22/000/112001

TELEPHONE: (412) 626-5280

MAIL TO:

MAY

--

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 079714122000112001 12656940 9 12500681 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 05/14	401	05/17/93
		PREVIOUS 04/15		

METER	A	B
CURRENT READING	1024	1035
PREVIOUS READING	875	884
DIFFERENCE	149	151
MULTIPLIER	9600	9600
TOTAL KWH	1430400	1449600
KWH ADJUSTMENT	22804	
BILL USAGE	1453204	1449600
KW DEMAND	8006.0	
KW ADJUSTMENT	60.0	

TOTAL BILLED KW	8066.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 6.6650	13,330.00	
	6,066.0 @ 6.5670	39,835.42	53,165.42

TOTAL BILLED KWH	2,902,804		
KWH ENERGY CHARGES	FOR 30 DAYS		
	2,902,804 @ .02256	65,487.26	65,487.26
SURCHARGE	.9100 %		1,079.74
ENERGY COST RATE @	.0018170		5,274.39

CURRENT NET BILL 125,006.81

AMOUNT DUE 125,006.81

ESTIMATED PA STATE TAXES OF 9,188.00 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1,562.59
PAY AFTER 06/16/93 126,569.40

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

9 07/16/93 1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112001

TELEPHONE: (412) 626-5280

MAIL TO: *AM*

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

41 22 000 112001
LETTERKENNY ARMY DEPOT
SDSLE ERW
* LETTERKENNY RD
-- CHAMBERSBURG PA
17201

00000000 9 070614122000112001 13155951 9 12993532 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11200/1	DAAG 34-70-C-0016	CURRENT 06/15	401	06/16/93
		PREVIOUS 05/14		

METER	A	B
CURRENT READING	1173	1185
PREVIOUS READING	1024	1035
DIFFERENCE	149	150
MULTIPLIER	9600	9600
TOTAL KWH	1430400	1440000
KWH ADJUSTMENT	23776	
BILL USAGE	1454176	1440000
KW DEMAND	7799.0	
KW ADJUSTMENT	58.0	

TOTAL BILLED KW	7857.0		
KW DEMAND CHARGES	FOR 29 DAYS		
	2,000.0 @ 7.5370	13,660.81	
	5,857.0 @ 7.4390	39,485.51	53,146.32

TOTAL BILLED KWH	2,894,176		
KWH ENERGY CHARGES	FOR 29 DAYS		
	2,894,176 @ .02314	60,692.68	60,692.68
KW ADJUSTMENT	58.0		

TOTAL BILLED KW	7857.0		
KW DEMAND CHARGES	FOR 3 DAYS		
	2,000.0 @ 6.6650	1,249.69	
	5,857.0 @ 6.5670	3,605.90	4,855.59

TOTAL BILLED KWH	2,894,176		
KWH ENERGY CHARGES	FOR 3 DAYS		
	2,894,176 @ .02256	6,121.18	6,121.18
SURCHARGE			139.17-
ENERGY COST RATE @	.0018170		5,258.72
CURRENT NET BILL			129,935.32

AMOUNT DUE 129,935.32

ESTIMATED PA STATE TAXES OF 9,550.25 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1,624.19
PAY AFTER 07/16/93 131,559.51

"75 Years At Your Service"

 West Penn Power Company
Part of the Allegheny Power System

West Penn Power Company
SOUTH 7TH STREET
CONNELLVILLE, PA 15425

PAYMENT DUE DATE PAGE NO.

0

05/24/93

1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

TELEPHONE: (412) 626-5280

41/22/000/112051
DAAG5470C00167MODP000

MAIL TO:

APR

41 22 000 112051
LETTERKENNY ARMY DEPOT

WEST PENN POWER COMPANY

-- SDSLE-ERW
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 024314122000112051 01998235 9 01973565 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11205/1 3		CURRENT 04/15	302	04/23/93
		PREVIOUS 04/04		

METER A
CURRENT READING 44
PREVIOUS READING 0
DIFFERENCE 44
MULTIPLIER 9600
TOTAL KWH 422400
KW DEMAND 1884.0

NEW SUBSTATION

TOTAL BILLED KW	1884.0		
KW DEMAND CHARGES	FOR 11 DAYS		
	100.0 @ 4.6800	171.60	
	1,784.0 @ 3.8100	2,492.25	2,663.85

TOTAL BILLED KWH	422,400		
KWH ENERGY CHARGES	FOR 11 DAYS		
	14,667 @ .03662	537.11	
	407,733 @ .03226	13,153.47	13,690.58

RKVA DEMAND CHARGE	418.0 @ .350		53.64
VOLTAGE DISCOUNT			110.53-
SURCHARGE			160.89
ENERGY COST RATE @ .0032010			1,352.10
FACILITIES CHARGE		1,906.30	
SURCHARGE		18.82	1,925.12
CURRENT NET BILL			19,735.65

AMOUNT DUE 19,735.65

ESTIMATED PA STATE TAXES OF 1,450.57 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 246.70
PAY AFTER 05/24/93 19,982.35

REFER INQUIRIES TO:
West Penn Power Company
SOUTH 7TH STREET
CONNELLVILLE, PA 15425

Alimony

PAYMENT DUE DATE	PAGE NO.
06/16/93	1

TELEPHONE: (412) 626-5280

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112051
DAAG3470C00167MODP001

MAIL TO: may

41 22 000 112051
LETTERKENNY ARMY DEPOT

WEST PENN POWER COMPANY

SDSLE-ERW
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

01973565 9 329414122000112051 08490053 9 08385238 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11205/1 3		CURRENT 05/14 PREVIOUS 04/15	302	05/17/93

METER	A
CURRENT READING	189
PREVIOUS READING	44
DIFFERENCE	145
MULTIPLIER	9600
TOTAL KWH	1392000
KW DEMAND	2333.0

TOTAL BILLED KW	2333.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	100.0 @ 4.6800	468.00	
	2,233.0 @ 3.8100	8,507.73	8,975.73

TOTAL BILLED KWH	1,392,000		
KWH ENERGY CHARGES	FOR 30 DAYS		
	40,000 @ .03662	1,464.80	
	1,352,000 @ .03226	43,615.52	45,080.32

RKVA DEMAND CHARGE	689.0 @ .350		
VOLTAGE DISCOUNT			241.15
SURCHARGE	.9100 %		373.28-
ENERGY COST RATE @	.0032010		490.71
FACILITIES CHARGE			4,455.79
SURCHARGE		5,199.00	
CURRENT NET BILL		47.31	5,246.31
			64,116.73
PREVIOUS BALANCE			19,735.65

AMOUNT DUE			83,852.38
------------	--	--	-----------

ESTIMATED PA STATE TAXES OF 4,712.58 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1,048.15
PAY AFTER 06/16/93 84,900.53

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

9 07/16/93 1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

TELEPHONE: (412) 626-5280

41/22/000/112051
DAAG3470C0016/MODP000

MAIL TO: JUN

41 22 000 112051
LETTERKENNY ARMY DEPOT

WEST PENN POWER COMPANY

SDSLE-ERW
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 024914122000112051 08556188 9 08450556 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11205/1 3		CURRENT 06/15	302	06/16/93
		PREVIOUS 05/14		

METER A
CURRENT READING 373
PREVIOUS READING 189
DIFFERENCE 184
MULTIPLIER 9600
TOTAL KWH 1766400
KW DEMAND 3142.0

TOTAL BILLED KW	3142.0		
KW DEMAND CHARGES	FOR 29 DAYS		
	100.0 @ 5.2700	477.59	
	3,042.0 @ 4.4000	12,129.98	12,607.57

TOTAL BILLED KWH	1,766,400		
KWH ENERGY CHARGES	FOR 29 DAYS		
	40,000 @ .03859	1,398.89	
	1,726,400 @ .03423	53,554.54	54,953.43

RKVA DEMAND CHARGE	776.0 @ .400		281.30
--------------------	--------------	--	--------

TOTAL BILLED KW	3142.0		
KW DEMAND CHARGES	FOR 3 DAYS		
	100.0 @ 4.6800	43.88	
	3,042.0 @ 3.8100	1,086.56	1,130.44

TOTAL BILLED KWH	1,766,400		
KWH ENERGY CHARGES	FOR 3 DAYS		
	40,000 @ .03662	137.33	
	1,726,400 @ .03226	5,221.28	5,358.61

RKVA DEMAND CHARGE	776.0 @ .350		25.46
--------------------	--------------	--	-------

VOLTAGE DISCOUNT			616.62-
SURCHARGE			82.42-
ENERGY COST RATE @ .0032010			5,654.25
FACILITIES CHARGE		5,199.00	
SURCHARGE		5.46-	5,193.54
CURRENT NET BILL			84,505.56

AMOUNT DUE

84,505.56

ESTIMATED PA STATE TAXES OF 6,211.16 INCLUDED IN THIS BILLING.
(CONTINUED ON NEXT PAGE)

"75 Years At Your Service"

 West Penn Power Company
Part of the Allegheny Power System

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

0 08/16/93

1

USE WHEN REFERRING TO B:
ACCOUNT NO.

TELEPHONE: (412) 626-5280

41/22/000/112051
DAAG3470C0016/MODP00

MAIL TO: JUL NEW SUB

41 22 000 112051
LETTERKENNY ARMY DEPOT

WEST PENN POWER COMPANY

-- SDSLE-ERW
CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 025314122000112051 08957128 9 08846546 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/112051	3	CURRENT 07/15	302	07/16/93
		PREVIOUS 06/15		

METER	A
CURRENT READING	564
PREVIOUS READING	373
DIFFERENCE	191
MULTIPLIER	9600
TOTAL KWH	1833600
KW DEMAND	3391.0

TOTAL BILLED KW	3391.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	100.0 @ 5.2700	527.00	
	3,291.0 @ 4.4000	14,480.40	15,007.40

TOTAL BILLED KWH	1,833,600		
KWH ENERGY CHARGES	FOR 30 DAYS		
	40,000 @ .03859	1,543.60	
	1,793,600 @ .03423	61,394.93	62,938.53

RKVA DEMAND CHARGE	758.0 @ .400		
VOLTAGE DISCOUNT			303.20
SURCHARGE	-.2100 %		678.20-
ENERGY COST RATE @	.0032010		162.90-
FACILITIES CHARGE			5,869.35
SURCHARGE		5,199.00	
CURRENT NET BILL		10.92-	5,188.08
			88,465.46

AMOUNT DUE

88,465.46

ESTIMATED PA STATE TAXES OF 6,502.21 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1,105.82
PAY AFTER 08/16/93 89,571.28

"75 Years At Your Service"

 West Penn Power Company
Part of the Allegheny Power System

West Penn Power Company
SOUTH 7TH STREET
CONNELLVILLE, PA 15425

Henry

PAYMENT DUE DATE PAGE NO

0

09/16/93

1

▼ USE WHEN REFERRING TO BILL

ACCOUNT NO.

41/22/000/112051

DAAG3478C0016/M00P00018

MAIL TO:

406 NEW SUB

TELEPHONE: (412) 626-5280

41 22 000 112051
LETTERKENNY ARMY DEPOT

WEST PENN POWER COMPANY

SDSLE-ERW
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

08957128 9 523314122000112051 18230067 9 18006370 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/112051/1 3		CURRENT 08/16	302	08/17/93
		PREVIOUS 07/15		

METER	A
CURRENT READING	761
PREVIOUS READING	564
DIFFERENCE	197
MULTIPLIER	9600
TOTAL KWH	1891200
KW DEMAND	3363.0

TOTAL BILLED KW	3363.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	100.0 @ 5.2700	527.00	
	3,263.0 @ 4.4000	14,357.20	14,884.20

TOTAL BILLED KWH	1,891,200		
KWH ENERGY CHARGES	FOR 30 DAYS		
	40,000 @ .03859	1,543.60	
	1,851,200 @ .03423	63,366.58	64,910.18

RKVA DEMAND CHARGE	739.0 @ .400	295.60	
VOLTAGE DISCOUNT		672.60-	
SURCHARGE	-.2100 %	166.77-	
ENERGY COST RATE @	.0032010	6,053.73	
FACILITIES CHARGE		5,199.00	
SURCHARGE	10.92-	5,188.08	
CURRENT NET BILL			90,492.42
PREVIOUS BALANCE		89,571.28	

AMOUNT DUE 180,063.70

ESTIMATED PA STATE TAXES OF 6,651.19 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 2,236.97
PAY AFTER 09/16/93 182,300.67

PREVIOUS BALANCE OF 89,571.28 IS PAST DUE. IF PAYMENT HAS NOT BEEN MADE, YOUR ELECTRIC SERVICE MAY BE SUBJECT TO TERMINATION.

"75 Years At Your Service"

 West Penn Power Company
Part of the Allegheny Power System

West Penn Power Company

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

TELEPHONE: (412) 626-5280

41 22 000 112051
LETTERKENNY ARMY DEPOT

-- SDSLE-ERW
-- CHAMBERSBURG PA
17201

PAYMENT DUE DATE	PAGE NO
10/18/93	1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112051

DAAG3470C0016/MODP000

MAIL TO: SEP

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 020614122000112051 08771118 9 08662833 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11205/1 3		CURRENT 09/15	302	09/16/93
		PREVIOUS 08/16		

METER A
CURRENT READING 947
PREVIOUS READING 761
DIFFERENCE 186
MULTIPLIER 9600
TOTAL KWH 1785600
KW DEMAND 3383.0

TOTAL BILLED KW	3383.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	100.0 @ 5.2700	527.00	
	3,283.0 @ 4.4000	14,445.20	14,972.20

TOTAL BILLED KWH	1,785,600		
KWH ENERGY CHARGES	FOR 30 DAYS		
	40,000 @ .03859	1,543.60	
	1,745,600 @ .03423	59,751.89	61,295.49

RKVA DEMAND CHARGE	732.0 @ .400	292.80	
VOLTAGE DISCOUNT		676.60-	
SURCHARGE	-.2100 %	159.35-	
ENERGY COST RATE @	.0032010	5,715.71	
FACILITIES CHARGE		5,199.00	
SURCHARGE		10.92-	5,188.08
CURRENT NET BILL			86,628.33

AMOUNT DUE 86,628.33

ESTIMATED PA STATE TAXES OF 6,367.18 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1,082.85
PAY AFTER 10/18/93 87,711.18

REFER INQUIRIES TO:
West Penn Power Company
SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

PAYMENT DUE DATE PAGE 1

11/17/93

1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112051

DAAG3470C0016/MODP00

MAIL TO: OCT

TELEPHONE: (412) 626-5280

41 22 000 112051
LETTERKENNY ARMY DEPOT

WEST PENN POWER COMPANY

SDSLE-ERW
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-057

00000000 9 025114122000112051 08221996 9 08120490 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11205/1 3		CURRENT 10/15	302	10/18/93
		PREVIOUS 09/15		

METER A
CURRENT READING 1120
PREVIOUS READING 947
DIFFERENCE 173
MULTIPLIER 9600
TOTAL KWH 1660800
KW DEMAND 3210.0

TOTAL BILLED KW	3210.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	100.0 @ 5.2700	527.00	
	3,110.0 @ 4.4000	13,684.00	14,211.00

TOTAL BILLED KWH	1,660,800		
KWH ENERGY CHARGES	FOR 30 DAYS		
	40,000 @ .03859	1,543.60	
	1,620,800 @ .03423	55,479.98	57,023.58

RKVA DEMAND CHARGE	642.0 @ .400	256.80	
--------------------	--------------	--------	--

VOLTAGE DISCOUNT		642.00-	
SURCHARGE	-.2100 %	148.78-	
ENERGY COST RATE @	.0032010	5,316.22	
FACILITIES CHARGE		5,199.00	
SURCHARGE		10.92-	5,188.08
CURRENT NET BILL			81,204.90

AMOUNT DUE	81,204.90
------------	-----------

ESTIMATED PA STATE TAXES OF 5,968.56 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1,015.06
PAY AFTER 11/17/93 82,219.96

West Penn Power Company

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

PAYMENT DUE DATE PAGE NO

12/22/93

1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112051

DAAGS470C00167MODP001

MAIL TO: NeV

TELEPHONE: (412) 626-5280

41 22 000 112051
LETTERKENNY ARMY DEPOT

WEST PENN POWER COMPANY

-- SDSLE-ERW
-- CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 024114122000112051 07168085 9 07079590 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/112051/1 3 New Sub.		CURRENT 11/15 PREVIOUS 10/15	401	11/22/93

METER A
CURRENT READING 1295
PREVIOUS READING 1120
DIFFERENCE 175
MULTIPLIER 9600
TOTAL KWH 1680000
KW DEMAND 3180.0

TOTAL BILLED KW	3180.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 7.5370	15,074.00	
	1,180.0 @ 7.4390	8,778.02	23,852.02

TOTAL BILLED KWH	1,680,000		
KWH ENERGY CHARGES	FOR 30 DAYS		
	1,272,000 @ .02314	29,434.08	
	408,000 @ .02245	9,159.60	38,593.68

RKVA DEMAND CHARGE	603.0 @ .400	241.20	
SURCHARGE	-.2100 %	131.64	
ENERGY COST RATE @	.0018170	3,052.56	
FACILITIES CHARGE		5,199.00	
SURCHARGE		10.92	5,188.08
CURRENT NET BILL			70,795.90

AMOUNT DUE 70,795.90

ESTIMATED PA STATE TAXES OF 5,203.50 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 884.95
PAY AFTER 12/22/93 71,680.85

West Penn Power Company
SOUTH 7TH STREET
CONNELLVILLE, PA 15425

TELEPHONE: (412) 626-5280

41 22 000 112051
LETTERKENNY ARMY DEPOT

-- SDSLE-ERW
-- CHAMBERSBURG PA
17201

PAYMENT DUE DATE 12/16/93 PAGE 1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

41/22/000/112051
DAAG3470C0016/MDP00

MAIL TO: NOV

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-057

00000000 9 023914122000112051 08238870 9 08137156 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11205/1 3		CURRENT 11/15 PREVIOUS 10/15	302	11/16/93

METER	A
CURRENT READING	1295
PREVIOUS READING	1120
DIFFERENCE	175
MULTIPLIER	9600
TOTAL KWH	1680000
KW DEMAND	3079.0

TOTAL BILLED KW	3079.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	100.0 @ 5.2700	527.00	
	2,979.0 @ 4.4000	13,107.60	13,634.60

TOTAL BILLED KWH	1,680,000		
KWH ENERGY CHARGES	FOR 30 DAYS		
	40,000 @ .03859	1,543.60	
	1,640,000 @ .03423	56,137.20	57,680.80

RKVA DEMAND CHARGE	638.0 @ .400		
VOLTAGE DISCOUNT			255.20
SURCHARGE	-.2100 %		615.80-
ENERGY COST RATE @	.0032010		149.00-
FACILITIES CHARGE			5,377.68
SURCHARGE		5,199.00	
CURRENT NET BILL		10.92-	5,188.08
			31,371.56

AMOUNT DUE

81,371.56

ESTIMATED PA STATE TAXES OF 5,980.81 INC

LATE PAYMENT CHARGE 1,017.14
PAY AFTER 12/16/93 82,388.70

This invoice was calculated @ rate 302. The new invoice (corrected) was calculated @ rate 401.

DAB 13 Jan 94
This is the first invoice that the new substation is on rate 401!

"75 Years At Your Service"

West Penn Power Company

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

TELEPHONE: (412) 626-5280

41 22 000 112051
LETTERKENNY ARMY DEPOT

SDSLE-ERW
-- CHAMBERSBURG PA
17201

PAYMENT DUE DATE
01/18/94

USE WHEN REFERRING TO E
ACCOUNT NO.

41/22/000/11205
DAAG3470C0016/MDPO

MAIL TO: DEC

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

07079590 9 125414122000112051 14055670 9 13882143 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/11205/1 3		CURRENT 12/15	401	12/16/93
		PREVIOUS 11/15		

METER	A
CURRENT READING	1461
PREVIOUS READING	1295
DIFFERENCE	166
MULTIPLIER	9600
TOTAL KWH	1593600
KW DEMAND	3093.0

TOTAL BILLED KW	3093.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 7.5370	15,074.00	
	1,093.0 @ 7.4390	8,130.83	23,204.83

TOTAL BILLED KWH	1,593,600		
KWH ENERGY CHARGES	FOR 30 DAYS		
	1,237,200 @ .02314	28,628.81	
	356,400 @ .02245	8,001.18	36,629.99

RKVA DEMAND CHARGE	583.0 @ .400	233.20	
SURCHARGE	-.2100 X	126.14-	
ENERGY COST RATE @	.0018170	2,895.57	
FACILITIES CHARGE		5,199.00	
SURCHARGE		10.92-	5,188.08
CURRENT NET BILL			68,025.53

PREVIOUS BALANCE		70,795.90	
------------------	--	-----------	--

AMOUNT DUE			138,821.43
------------	--	--	------------

ESTIMATED PA STATE TAXES OF 4,999.88 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 1,735.27
PAY AFTER 01/18/94 140,556.70

REFER INQUIRIES TO:

West Penn Power Company

SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

TELEPHONE: (412) 626-5280

PAYMENT DUE DATE	PAGE NO
02/17/94	1
USE WHEN REFERRING TO BILL ACCOUNT NO.	
41/22/000/112051	

DAAG3470C0016/MODP0001

MAIL TO:

JAJ

WEST PENN POWER COMPANY

41 22 000 112051
LETTERKENNY ARMY DEPOT

-- SDSLE-ERW
CHAMBERSBURG PA
17201

PO BOX 640575
PITTSBURGH PA 15264-0575

13970638 9 620814122000112051 20782483 9 20527002 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.
WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	READING DATES	RATE	DATE
41/22/000/112051/3		CURRENT 01/14	401	01/18/94
		PREVIOUS 12/15		

METER A
CURRENT READING 1621
PREVIOUS READING 1461
DIFFERENCE 160
MULTIPLIER 9600
TOTAL KWH 1536000
KW DEMAND 2955.0

TOTAL BILLED KW	2955.0		
KW DEMAND CHARGES	FOR 30 DAYS		
	2,000.0 @ 7.5370	15,074.00	
	955.0 @ 7.4390	7,104.25	22,178.25

TOTAL BILLED KWH	1,536,000		
KWH ENERGY CHARGES	FOR 30 DAYS		
	1,182,000 @ .02314	27,351.48	
	354,000 @ .02245	7,947.30	35,298.78

RKVA DEMAND CHARGE	572.0 @ .400	228.80	
SURCHARGE	-.2100 %	121.18-	
ENERGY COST RATE @	.0018170	2,790.91	
FACILITIES CHARGE		5,199.00	
SURCHARGE		10.92-	5,188.08
CURRENT NET BILL			65,563.64

PREVIOUS BALANCE	139,706.38
------------------	------------

AMOUNT DUE	205,270.02
------------	------------

ESTIMATED PA STATE TAXES OF 4,818.93 INCLUDED IN THIS BILLING.

LATE PAYMENT CHARGE 2,554.81
PAY AFTER 02/17/94 207,824.83

"75 Years At Your Service"

 West Penn Power Company
Part of the Allegheny Power System

REFER INQUIRIES TO:

West Penn Power Company
SOUTH 7TH STREET
CONNELLSVILLE, PA 15425

TELEPHONE: (412) 626-5280

CREDIT MEMORANDUM
FORM 11-105 REV

▼ USE WHEN REFERRING TO BILL

ACCOUNT NO

41/22/000/112051

MAIL TO:

41 22 000 112051
LETTERKENNY ARMY DEPOT
SDSLE-ERW
CHAMBERSBURG PA
17201

West Penn Power Company

PO BOX 640575
PITTSBURGH PA 15264-0575

		DATE	RATE SCHEDULE
		01/18/94	302
ACCOUNT NO.	SERVICE LOCATION	\$	\$
41/22/000/11205/1	3		
TO CANCEL SIX OF YOUR ELECTRIC SERVICE BILLS DATED AND IN THE FOLLOWING AMOUNTS			
	MAY 17, 1993	\$64,116.73	
	TOTAL		\$ 64,116.73
	JUNE 16, 1993	84,505.56	
	TOTAL		84,505.56
	JULY 16, 1993	88,465.46	
	TOTAL		88,465.46
	AUGUST 17, 1993	90,492.42	
	TOTAL		90,492.42
	SEPTEMBER 16, 1993	86,628.33	
	TOTAL		86,628.33
	OCTOBER 18, 1993	81,204.90	
	TOTAL		81,204.90
	GRAND TOTAL		\$495,413.40

DUE TO RATE SCHEDULE STUDY. RATE 401 WILL BE EFFECTIVE
APRIL 15, 1993.

SEE CORRECTED INVOICES



West Penn Power Company
Part of the Allegheny Power System

West Penn Power CompanySOUTH 7TH STREET
CONNELLSVILLE, PA 15425

TELEPHONE: (412) 626-5280

0

03/18/94

1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

1/41/22/000/112051

DAAG3470C0016/MDP00018

MAIL TO:

FEB

WEST PENN POWER COMPANY

1/41/22/000/112051
LETTERKENNY ARMY DEPOT-- SDSLE-ERW
-- CHAMBERSBURG PA
17201PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 020014122000112051 00000000 9 00000000 00


WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	RATE	BILLING DATE
1/41/22/000/112051/3		401	02/16/94
NEW			
ACCOUNT BALANCE	01/17/94	205,270.02	
PAYMENT RECEIVED		80,000.00-	
OTHER ADJUSTMENTS		198,740.37-	
ACCOUNT BALANCE BROUGHT FORWARD			73,470.35-

CURRENT BILLING FOR 032 DAYS USE 01/14/94 TO 02/15/94			
METER	A		
CURRENT READING	1785		
PREVIOUS READING	1621		
DIFFERENCE	164		
TIPLIER	9600		
	1574400		
KW DEMAND	2886.0		
BILLING DEMAND CHARGE FOR 2,886.0 KW			
2,000.0 @ 7.5370		15,074.00	
886.0 @ 7.4390		6,590.95	
ENERGY CHARGE FOR 1,574,400 KWH			
1,154,400 @ .02314		26,712.82	
420,000 @ .02245		9,429.00	
RKVA DEMAND CHARGE			
516.0 @ 0.400		206.40	
BILLED CHARGES ON RATE 401			58,013.17
FACILITY CHARGE			5,199.00
PA TAX SURCHARGE @ .2100000%			132.75
ENERGY COST RATE @ .0018170 /KWH			2,860.68
CHARGE FOR CURRENT BILL PERIOD			65,940.10
CREDIT BALANCE - NO PAYMENT DUE			7,530.25-
ESTIMATED PA STATE TAXES OF 4,846.60 INCLUDED IN THIS BILLING			

"75 Years At Your Service"

 West Penn Power Company
Part of the Allegheny Power System

West Penn Power CompanySOUTH 7TH STREET
CONNELLSVILLE, PA 15425

0

04/15/94

1

▼ USE WHEN REFERRING TO BILL
ACCOUNT NO.

1/41/22/000/112051

DAAG5470C0016/MODP00018

MAIL TO:

MRA

TELEPHONE: (412) 626-5280

1/41/22/000/112051
LETTERKENNY ARMY DEPOT

WEST PENN POWER COMPANY

-- SDSLE-ERW
CHAMBERSBURG PA
17201PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 020014122000112051 00000000 9 00000000 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	RATE	BILLING DATE
1/41/22/000/112051 3 NEW		401	03/16/94
ACCOUNT BALANCE	02/16/94	7,530.25-	
PAYMENT RECEIVED		65,563.64-	
ACCOUNT BALANCE BROUGHT FORWARD			73,093.89-
CURRENT BILLING FOR 028 DAYS USE 02/15/94 TO 03/15/94			
METER	A		
CURRENT READING	1937		
PREVIOUS READING	1785		
DIFFERENCE	152		
MULTIPLIER	9600		
DEMAND	1459200		
	3007.0		
BILLING DEMAND CHARGE FOR		3,007.0 KW	
2,000.0 @	7.5370		15,074.00
1,007.0 @	7.4390		7,491.07
ENERGY CHARGE FOR		1,459,200 KWH	
1,202,800 @	.02314		27,832.79
256,400 @	.02245		5,756.18
RKVA DEMAND CHARGE			
524.0 @	0.400		209.60
BILLED CHARGES ON RATE 401			56,363.64
FACILITY CHARGE			5,199.00
PA TAX SURCHARGE @ -.2100000%			129.28-
ENERGY COST RATE @ .0018170 /KWH			2,651.37
CHARGE FOR CURRENT BILL PERIOD			64,084.73
CREDIT BALANCE - NO PAYMENT DUE			9,009.16-

ESTIMATED PA STATE TAXES OF 4,710.23 INCLUDED IN THIS BILLING

West Penn Power Company

SOUTH 7TH STREET
CONNELLVILLE, PA 15425

TELEPHONE: (412) 626-5280

PAYMENT DUE DATE PAGE

0 05/18/94 1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

1/41/22/000/11205

DAAG3470C00167MODP000

MAIL TO:

APR

1/41/22/000/112051
LETTERKENNY ARMY DEPOT

SDSLE-ERW
CHAMBERSBURG PA
17201

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 024514122000112051 06588916 9 06507571 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	RATE	BILLING DATE
1/41/22/000/11205/1 3		401	04/18/94
ACCOUNT BALANCE	03/16/94		9,009.16-
ACCOUNT BALANCE BROUGHT FORWARD			9,009.16-
CURRENT BILLING FOR 031 DAYS USE 03/15/94 TO 04/15/94			
METER	A		
CURRENT READING	2121		
PREVIOUS READING	1937		
DIFFERENCE	184		
MULTIPLIER	9600		
KWH	1766400		
KW DEMAND	3283.0		
BILLING DEMAND CHARGE FOR 3,283.0 KW			
2,000.0 @	7.5370		15,074.00
1,283.0 @	7.4390		9,544.24
ENERGY CHARGE FOR 1,766,400 KWH			
1,313,200 @	.02314		30,387.45
453,200 @	.02245		10,174.34
RKVA DEMAND CHARGE			
826.0 @	0.400		330.40
BILLED CHARGES ON RATE 401			
FACILITY CHARGE			65,510.43
PA TAX SURCHARGE			5,199.00
ENERGY COST RATE @	.0019787 /KWH		119.74-
3,495.18			
CHARGE FOR CURRENT BILL PERIOD			
74,084.87			
AMOUNT DUE			
65,075.71			
LATE PAYMENT CHARGE			
813.45			
TOTAL AMOUNT DUE AFTER			
05/18/94 65,889.16			
ESTIMATED PA STATE TAXES OF 5,363.74 INCLUDED IN THIS BILLING			

West Penn Power CompanySOUTH 7TH STREET
CONNELLVILLE, PA 15425

0 06/16/94 1

▼ USE WHEN REFERRING TO BILL

ACCOUNT NO.

1/41/22/000/112051

DAAG3470C0016/MODP00018

MAIL TO:

MAY

TELEPHONE: (412) 626-5280

WEST PENN POWER COMPANY

1/41/22/000/112051
LETTERKENNY ARMY DEPOTSDSLE-ERW
CHAMBERSBURG PA
17201PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 024514122000112051 08575484 9 08469614 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	RATE	BILLING DATE
1/41/22/000/112051 3 NELO		401	05/17/94
ACCOUNT BALANCE	04/18/94	65,075.71	
PAYMENT RECEIVED		65,075.71-	
ACCOUNT BALANCE BROUGHT FORWARD			.00
CURRENT BILLING FOR 031 DAYS USE 04/15/94 TO 05/16/94			
METER	A		
CURRENT READING	2321		
PREVIOUS READING	2121		
DIFFERENCE	200		
MULTIPLIER	9600		
DEMAND	1920000		
DEMAND	4044.0		
BILLING DEMAND CHARGE FOR 4,044.0 KW			
2,000.0 @	7.5370	15,074.00	
2,044.0 @	7.4390	15,205.32	
ENERGY CHARGE FOR 1,920,000 KWH			
1,617,600 @	.02314	37,431.26	
302,400 @	.02245	6,788.88	
RKVA DEMAND CHARGE			
1,099.0 @	0.400	439.60	
			74,939.06
BILLED CHARGES ON RATE 401			5,199.00
FACILITY CHARGE			4,558.08
ENERGY COST RATE @ .0023740 /KWH			
CHARGE FOR CURRENT BILL PERIOD			84,696.14
AMOUNT DUE			84,696.14
LATE PAYMENT CHARGE			1,058.70
TOTAL AMOUNT DUE AFTER 06/16/94			85,754.84
ESTIMATED PA STATE TAXES OF 6,132.00 INCLUDED IN THIS BILLING			

"75 Years At Your Service"

West Penn Power Company
Part of the Allegheny Power System

West Penn Power CompanySOUTH 7TH STREET
CONNELLVILLE, PA 15425

07/18/94

1

USE WHEN REFERRING TO BILL
ACCOUNT NO.

1/41/22/000/112051

DAAG3470C0016/MDP00018

MAIL TO:

JUN

TELEPHONE: (412) 626-5280

1/41/22/000/112051
LETTERKENNY ARMY DEPOTSDSLE-ERW
CHAMBERSBURG PA
17201

WEST PENN POWER COMPANY

PO BOX 640575
PITTSBURGH PA 15264-0575

00000000 9 028014122000112051 08876098 9 08766517 00

WHEN PAYING AT OFFICE OR AGENCY, PLEASE BRING ENTIRE BILL.

WHEN PAYING BY MAIL, PLEASE RETURN THIS PORTION OF BILL WITH PAYMENT IN ENCLOSED ENVELOPE.

ACCOUNT NUMBER	SERVICE LOCATION	RATE	BILLING DATE
1/41/22/000/112051 3		401	06/16/94

ACCOUNT BALANCE	05/17/94	84,696.14
PAYMENT RECEIVED		84,696.14-

ACCOUNT BALANCE BROUGHT FORWARD .00

CURRENT BILLING FOR 030 DAYS USE 05/16/94 TO 06/15/94

METER	A
CURRENT READING	2530
PREVIOUS READING	2321
DIFFERENCE	209
MULTIPLIER	9600
	2006400
EMAND	4147.0

BILLING DEMAND CHARGE FOR 4,147.00 KW

2,000.0	@	7.5370	15,074.00
2,147.0	@	7.4390	15,971.53

ENERGY CHARGE FOR	27006.400 KWH	
1,658,800	@	.02314
347,600	@	.02245

WKVA DEMAND CHARGE		
1,173.0	@	0.400
		469.20

BILLED CHARGES ON RATE 401	77,702.98
FACILITY CHARGE	5,199.00
ENERGY COST RATE @ .0023740 /KWH	4,763.19

CHARGE FOR CURRENT BILL PERIOD 87,665.17

AMOUNT DUE 87,665.17

LATE PAYMENT CHARGE	1,095.81
TOTAL AMOUNT DUE AFTER	07/18/94 88,760.98

ESTIMATED PA STATE TAXES OF 6,346.96 INCLUDED IN THIS BILLING

West Penn Power Company
Part of the Allegheny Power System

PRIMARY POWER SERVICE
SCHEDULE 40

AVAILABILITY

Available for service at 25,000 volts or higher for loads of 2,000 kilowatts or greater, supplied at a single point of delivery. Also available at 12,470 volts where Company elects, at its sole option, to supply service direct from an adjacent 138,000 volt transmission line by a single transformation. An Electric Service Agreement shall be executed.

Riders Available - Opportunity Power and Curtailable Service Riders are available under this schedule.

MONTHLY RATE

Demand Charge

First 2,000 kilowatts of Customer's Demand..... \$7.537 net per kilowatt
Additional kilowatts of Customer's Demand..... \$7.439 net per kilowatt

Voltage Discount

For loads of 10,000 kilowatts or greater, the Company will furnish service at voltages above 100,000 volts if such service is provided at a single delivery point from the Company's transmission system and in the sole judgment of the Company the necessary capacity is available. When such service is supplied and the Customer owns and maintains all required facilities, the following discounts will be allowed, but in no case will the amount of the minimum bill be hereby reduced.

First 10,000 kilowatts of Customer's Demand.....70 cents net per kilowatt
Additional kilowatt of Customer's Demand.....22 cents net per kilowatt

To qualify for this transmission voltage service, the Customer must be billed for at least 10,000 kilowatts at least once in every 12-month period.

Transformer Charge

When Customer desires to take service under this Schedule at a voltage between 1,000 and 15,000 volts, Company shall provide one transformation at a charge of 40 cents net per kilowatt for the first 2,000 kilowatts and 20 cents net per kilowatt for additional kilowatts of the highest on-peak or off-peak demand for the month, but not less than any such demand previously established during the Term of the Electric Service Agreement nor less than the capacity specified therein. This transformer charge does not apply for those connections supplied at 12,470 volts by a single transformation from an adjacent 138,000 volt line.

Reactive Kilovolt-Ampere Charge

40 cents net per reactive kilovolt-ampere of Customer's Reactive Kilovolt-Ampere Demand in excess of 35% of Customer's Kilowatt Demand.

Energy Charge

First 400 kilowatt-hours per kilowatt
of Customer's Demand..... 2.314 cents net per kilowatt-hour
Additional kilowatt-hours..... 2.245 cents net per kilowatt-hour

Minimum Charge

Rate Schedule Billing.

Tax Adjustment Surcharge

The Tax Adjustment Surcharge included in this Tariff applies to charges under this Schedule except for charges made under the Energy Cost Rate.

Energy Cost Rate

The Energy Cost Rate applies to all kilowatt-hours supplied under this Schedule.

Continued on Page No. 47

PRIMARY POWER SERVICE
SCHEDULE 40

AVAILABILITY

Available for service at 25,000 volts or higher for loads of 2,000 kilowatts or greater, supplied at a single point of delivery. Also available at 12,470 volts where Company elects, at its sole option, to supply service direct from an adjacent 138,000 volt transmission line by a single transformation. An Electric Service Agreement shall be executed.

MONTHLY RATE

Demand Charge

First 2,000 kilowatts of Customer's Demand.....\$6.355 net per kilowatt
Additional kilowatts of Customer's Demand.....\$6.251 net per kilowatt

Energy Charge

First 400 kilowatt-hours per kilowatt
of Customer's Demand.....2.219 cents net per kilowatt-hour
Additional kilowatt-hours.....2.167 cents net per kilowatt-hour

Reactive Kilovolt-Ampere Charge

27 cents net per reactive kilovolt-ampere of Customer's Reactive Kilovolt-Ampere Demand in excess of 35% of Customer's Kilowatt Demand.

Transformer Charge

When Customer desires to take service under this Schedule at a voltage between 1,000 and 15,000 volts, Company shall provide one transformation at a charge of 33 cents net per kilowatt for the first 2,000 kilowatts and 17 cents net per kilowatt for additional kilowatts of the highest on-peak or off-peak demand for the month, but not less than any such demand previously established during the Term of the Electric Service Agreement nor less than the capacity specified therein. This transformer charge does not apply for those connections supplied at 12,470 volts by a single transformation from an adjacent 138,000 volt line.

Minimum Charge

Rate Schedule Billing.

Tax Adjustment Surcharge

The Tax Adjustment Surcharge included in this Tariff applies to charges under this Schedule except for charges made under the Energy Cost Rate.

Energy Cost Rate

The Energy Cost Rate applies to all kilowatt-hours supplied under this Schedule.

Continued on Page No. 47

ATTACHMENT 9.4

Lighting Models

Lighting Model
Letterkenny Army Depot
Building 1
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Armv #	Luminaire Factor 1	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Office Area																
Office	9'10"	206	1.15	40	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Chief Requisition Office	9'10"	206	1.15	25	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Production Planning Conf. Rm.	9'10"	206	1.15	35	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Chief Production Office	9'10"	206	1.15	45	5	4	40	F	920	50	95.0%	0.9	200	\$6.74	\$4.95	\$11.69
Chief Maintenance Office	9'10"	206	1.15	35	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Manager Analysis Office	9'10"	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Logistics Office	9'10"	206	1.15	25	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Director of Maint. (Locked)																
Deputy Director Maint. Office	9'10"	206	1.15	35	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Director Maintenance Office	9'10"	206	1.15	30	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Corridor A	10'	218	1.15	10	16	1	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Corridor A (Entrance Lobby)	10'	230	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Corridor A (Exit Sign)		604	1		1	1	20	I	20	168	95.0%	0.0	15	\$0.15	\$0.36	\$0.51
Corridor B	10'	218	1.15		10	1	40	F	460	50	95.0%	0.4	100	\$3.37	\$2.48	\$5.84
DPME Work Area	9'10"	206	1.15	40	18	3	40	F	2,484	50	95.0%	2.4	539	\$18.18	\$13.37	\$31.55
DPME Copy Room	9'10"	206	1.15		1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
DPME Section Office	9'10"	206	1.15	45	8	4	40	F	1,472	50	95.0%	1.4	319	\$10.78	\$7.92	\$18.70
DPME File Room		230	1.15		1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
DPME Mens Room		206	1.15		2	4	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61
DPME Mens Room		206	1.15		2	3	40	F	138	30	50.0%	0.1	18	\$0.53	\$0.45	\$0.98
DPME Womens Room		206	1.15		2	4	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61
DPME Womens Room		206	1.15		1	3	40	F	138	30	50.0%	0.1	18	\$0.53	\$0.45	\$0.98
Engineering Work Area	9'10"	206	1.15	40	113	3	40	F	15,594	50	95.0%	14.8	3,384	\$114.16	\$83.92	\$198.08
Chief Engineering Support Office	9'10"	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Production Engineering Office	9'10"	206	1.15	40	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Chief Production Eng. Office	9'10"	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Conference Room Corridor	9'1"	206	1.15	50	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Conference Room A	9'1"	206	1.15	65	4	4	40	F	736	35	75.0%	0.6	112	\$4.25	\$2.77	\$7.03
Conference Room B	9'1"	206	1.15	65	4	4	40	F	736	35	75.0%	0.6	112	\$4.25	\$2.77	\$7.03
Chrome Plate Area (CP)																
CP-Office	8'	206	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
CP-Exit Lobby		230	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
CP-Shop Area A	10'10"	231	1.15	35	63	2	75	F	10,868	50	95.0%	10.3	2,358	\$79.56	\$58.48	\$138.04
CP-Shop Area A		230	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
CP-Shop Area A		230V	1.15		12	2	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
CP-Shop Area B	10'10"	231	1.15		28	2	75	F	4,830	50	95.0%	4.6	1,048	\$35.36	\$25.99	\$61.35
CP-Shop Area B		230	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
CP-Shop Area B		230V	1.15		4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
CP-Mechanical Room #2	10'5"	103	1		4	1	100	I	400	15	0.0%	0.0	26	\$0.00	\$0.65	\$0.65
CP-Room #3 Storage		230V	1.15		7	2	40	F	644	10	0.0%	0.0	28	\$0.00	\$0.69	\$0.69
CP-Room #4 Storage		107	1		4	1	100	I	400	10	0.0%	0.0	17	\$0.00	\$0.43	\$0.43
CP-Room #5 Storage		107	1		4	1	100	I	400	10	0.0%	0.0	17	\$0.00	\$0.43	\$0.43
CP-Room #6 Storage	10'5"	230V	1.15	40	3	2	40	F	276	10	0.0%	0.0	12	\$0.00	\$0.30	\$0.30
CP-Room #7 Storage		230V	1.15		1	4	40	F	184	10	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
CP-Room #7 Storage		112	1		6	1	100	I	600	10	0.0%	0.0	26	\$0.00	\$0.65	\$0.65
Corridor to Rooms #2-#6	10'5"	230	1.15	20	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Paper Storage Area	16'1"	228	1.15	30	178	2	40	F	16,376	50	95.0%	15.6	3,554	\$119.88	\$88.13	\$208.01
Mail Room (locked)																
Print Room	10'10"	228	1.15		13	4	40	F	2,392	50	95.0%	2.3	519	\$17.51	\$12.87	\$30.38

**Lighting Model
Letterkenny Army Depot
Building 1
Table Designation**

	Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Interior	Jeditions Office	10'10"	228	1.15		8	4	40	F	1,472	50	95.0%	1.4	319	\$10.78	\$7.92	\$18.70
	JMA Support Office	10'10"	206	1.15	30	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
	Record Managers Office	10'10"	206	1.15		4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
	Print Area (Abandon)																
	Cafe Area		206	1.15		3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
	Receiving Bay		230	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
	Corridor to Cafe		240	1.15		6	4	20	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Exterior																	
	Exterior		502	1.15		4	1	150	HPS	690	80	0.0%	0.0	240	\$0.00	\$5.94	\$5.94
	Exterior		123	1		8	1	100	I	800	80	0.0%	0.0	278	\$0.00	\$6.89	\$6.89
	Exterior		103	1		5	1	100	I	500	80	0.0%	0.0	174	\$0.00	\$4.31	\$4.31
	Exterior		103	1		1	1	200	I	200	80	0.0%	0.0	69	\$0.00	\$1.72	\$1.72
	Exterior		107	1		2	1	100	I	200	80	0.0%	0.0	69	\$0.00	\$1.72	\$1.72
	Exterior		110	1		1	1	100	I	100	80	0.0%	0.0	35	\$0.00	\$0.86	\$1.72

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KW =	\$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG1.WK4

**Lighting Model
Letterkenny Army Depot
Building 2-S
Table Designation**

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KW = \$0.0248

NOTE #2: I AMP TYPE: F - FLUORESCENT

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991

G:\PROJECTS\4130.01\SS\DATA\BLDG2-s.wk4

Lighting Model
Letterkenny Army Depot
Building 3
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (F.C.)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Computer Area																
Library	10'	206	1.15	30	25	3	40	F	3,450	126	95.0%	3.3	1,887	\$25.26	\$46.79	\$72.04
Raised Floor Computer Rm. #5	9'	206	1.15	85	64	4	40	F	11,776	126	95.0%	11.2	6,440	\$86.21	\$159.70	\$245.91
Raised Floor Computer Rm. #1	9'	206	1.15	50	54	4	40	F	9,936	126	95.0%	9.4	5,433	\$72.74	\$134.75	\$207.49
Raised Floor Computer Rm. #2	9'	206	1.15	50	76	4	40	F	13,984	126	95.0%	13.3	7,647	\$102.37	\$189.65	\$292.02
Raised Floor Computer Rm. #3	8'	206	1.15	70	65	4	40	F	11,960	126	95.0%	11.4	6,540	\$87.56	\$162.20	\$249.75
Raised Flr. Co. Rm. #3 (Exit Sign)		604	1		3	2	15	I	90	168	95.0%	0.1	66	\$0.66	\$1.63	\$2.29
Raised Floor Computer Center	9'	206	1.15	50	34	4	40	F	6,256	126	95.0%	5.9	3,421	\$45.80	\$84.84	\$130.64
Raised Floor Comp. Ctr. Office	9'	206	1.15	50	9	4	40	F	1,656	126	95.0%	1.6	906	\$12.12	\$22.46	\$34.58
Raised Floor Computer Rm. #6	9	206	1.15	50	76	4	40	F	13,984	126	95.0%	13.3	7,647	\$102.37	\$189.65	\$292.02
Raised Floor Computer Rm. #7	8.5'	206	1.15	45	55	4	40	F	10,120	126	95.0%	9.6	5,534	\$74.09	\$137.24	\$211.33
Raised Flr. Co. Rm. #7 (Exit Sign)		604	1		3	2	15	I	90	168	95.0%	0.1	66	\$0.66	\$1.63	\$2.29
Raised Floor Computer Rm. #6A	94"	206	1.15	40	6	4	40	F	1,104	126	95.0%	1.0	604	\$8.08	\$14.97	\$23.05
Computer Office 132A	10'	206	1.15	45	24	4	40	F	4,416	126	95.0%	4.2	2,415	\$32.33	\$59.89	\$92.22
Computer Office 132	10'	206	1.15	30	4	3	40	F	552	126	95.0%	0.5	302	\$4.04	\$7.49	\$11.53
Raised Fl. Tape Storage Rm. #8	8'	206	1.15	45	6	4	40	F	1,104	126	95.0%	1.0	604	\$8.08	\$14.97	\$23.05
Vault	87"	228	1.15	60	8	4	40	F	1,472	84	95.0%	1.4	537	\$10.78	\$13.31	\$24.08
EOC Open Office Area (Vacant)	99"	206	1.15	60	23	2	40	F	2,116	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Conference Room (Vacant)	99"	206	1.15	45	12	2	40	F	1,104	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Conference Rm. (Vacant)		110	1		6	1	75	I	450	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Conference Rm. (Exit) (Vacant)		602	1		1	2	7	I	14	168	95.0%	0.0	10	\$0.10	\$0.25	\$0.36
EOC Open Office Area Exit (V)		602	1		1	2	7	I	14	168	95.0%	0.0	10	\$0.10	\$0.25	\$0.36
Audio Visual Room (Vacant)	99"	206	1.15	35	2	2	40	F	184	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Electrical Room (Vacant)	99"	206	1.15	35	2	2	40	F	184	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Office (Vacant)	99"	206	1.15	40	2	2	40	F	184	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Mens Room (Vacant)	99"	n/a	1		1	2	75	I	150	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Womens Room (Vacant)	99"	n/a	1		1	3	75	I	225	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Kitchen (Vacant)	99"	206	1.15		1	2	40	F	92	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Vault Office (Vacant)		214	1.15	50	7	2	40	F	644	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
South East Area																
Office 1-K	10'	206	1.15	50	6	3	40	F	828	50	95.0%	0.8	180	\$6.06	\$4.46	\$10.52
Office 1-J	10'	206	1.15		2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Office 2-K	10'	206	1.15	30	6	3	40	F	828	50	95.0%	0.8	180	\$6.06	\$4.46	\$10.52
Office 3-K	10'	206	1.15	30	7	3	40	F	966	50	95.0%	0.9	210	\$7.07	\$5.20	\$12.27
Storage Area 5-K	10'	206	1.15	50	12	3	40	F	1,656	10	0.0%	0.0	72	\$0.00	\$1.78	\$1.78
Supply Room 5-K	10'	230	1.15		24	3	40	F	3,312	10	0.0%	0.0	144	\$0.00	\$3.56	\$3.56
Snack Bar 9-K	10'	228	1.15	40	12	4	40	F	2,208	50	95.0%	2.1	479	\$16.16	\$11.88	\$28.05
Snack Bar 9-K	10'	230	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Snokers Lounge 10-K	10'	230	1.15	30	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Stairwell Lobby 11-K		230	1.15		2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Stairwell Lobby Exit Sign		602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Storage Room 12-K	10'	206	1.15	30	5	3	40	F	690	10	0.0%	0.0	30	\$0.00	\$0.74	\$0.74
Storage Room 12-K	10'	220	1.15		1	2	40	F	92	10	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
Open Office 14-K	10'	206	1.15		14	2	40	F	1,288	50	95.0%	1.2	279	\$9.43	\$6.93	\$16.36
Corridor 14-1-J		206	1.15		24	3	40	F	3,312	50	95.0%	3.1	719	\$24.25	\$17.82	\$42.07
Room #8 12-J	10'	206	1.15		6	3	40	F	828	50	95.0%	0.8	180	\$6.06	\$4.46	\$10.52
Mens Room 12-J		206	1.15		5	2	40	F	460	30	50.0%	0.2	60	\$1.77	\$1.49	\$3.26
Womens Room		206	1.15		6	2	40	F	552	30	50.0%	0.3	72	\$2.13	\$1.78	\$3.91
Office 2-J	10'	206	1.15	45	5	3	40	F	690	50	95.0%	0.7	150	\$5.05	\$3.71	\$8.76
DMC Open Area 4-F	10'	206	1.15	35	70	3	40	F	9,660	50	95.0%	9.2	2,096	\$70.72	\$51.99	\$122.70

Lighting Model
Letterkenny Army Depot
Building 3
Table Designation

Room Area or Description	Ceiling Height Ft.	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Office 6-J	10'	206	1.15	45	39	3	40	F	5,382	50	95.0%	5.1	1,168	\$39.40	\$28.96	\$5.26
Open Office Area 7-G	10'	206	1.15	45	39	3	40	F	5,382	50	95.0%	5.1	1,168	\$39.40	\$28.96	\$5.26
Room #120 4-F	10'	206	1.15	45	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Office 5-F	10'	206	1.15	45	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 6-F	10'	206	1.15	45	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Office 7-F	10'	206	1.15	45	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Automation Open Area 10-H	10'	206	1.15	20	25	3	40	F	3,450	50	95.0%	3.3	749	\$25.26	\$18.57	\$43.82
DMC Office 8-J	10'	206	1.15	20	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Room #130 10-1	10'	206	1.15	35	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Open Office Area 13-G	10'	206	1.15	35	24	3	40	F	3,312	50	95.0%	3.1	719	\$24.25	\$17.82	\$42.07
Office 1-H	10'	206	1.15	30	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Office 1-G	10'	206	1.15	20	1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
Office 1-F	10'	206	1.15	20	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
South West Area																
Office 2-E	10'	206	1.15	15	1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
Office A 2-D	10'	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Office B 2-D	10'	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Office 2-C	10'	206	1.15	50	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Corridor 4-1-C	10'	206	1.15	40	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Office 4-B	10'	206	1.15	40	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Room #117 Front 2-B	10'	206	1.15	30	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Room #117 Rear 2-B	10'	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Office Front 3-B	10'	206	1.15	40	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Office Rear 3-B	10'	206	1.15	40	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Office Front 4-B	10'	206	1.15	40	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Office Rear 4-B	10'	206	1.15	40	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 5-B	10'	206	1.15	35	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 5-A	10'	206	1.15	35	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Room #111 6-A	10'	206	1.15	30	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Room #109 6-A	10'	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Room #107 7-A	10'	206	1.15	35	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Room #105 8-A	10'	206	1.15	60	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Corridor 5-10-B	10'	206	1.15	920	10	2	40	F	920	50	95.0%	0.9	200	\$6.74	\$4.95	\$11.69
Corridor 5-10-B	10'	206	1.15	552	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Corridor 5-10-B (Exit Sign)	10'	602	1	60	2	2	15	I	60	168	95.0%	0.1	44	\$0.44	\$1.08	\$1.52
North West Area																
Office 19-E	10'	206	1.15	50	5	3	40	F	690	50	95.0%	0.7	150	\$5.05	\$3.71	\$8.76
Office 19-A	10'	206	1.15	30	7	3	40	F	966	50	95.0%	0.9	210	\$7.07	\$5.20	\$12.27
Office 21-D	10'	206	1.15	40	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Fan Room 21-C		230	1.15		4	2	40	F	368	5	0.0%	0.0	8	\$0.00	\$0.20	\$0.15
Fan Room 21-C		230	1.15		3	3	40	F	276	5	0.0%	0.0	6	\$0.00	\$0.15	\$0.15
Closet 22-A		206	1.15		1	2	40	F	92	10	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
Office 23-A	10'	206	1.15	45	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 24-A	10'	206	1.15	40	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Lobby 25-A	10'	206	1.15	100	7	4	40	F	1,288	50	95.0%	1.2	279	\$9.43	\$6.93	\$16.36
Lobby Closet 25-A		206	1.15		1	2	40	F	92	10	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
Office 26-A	104"	206	1.15	60	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Office 26-B	104"	206	1.15	35	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 26-C	104"	206	1.15	40	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Office 26-D	104"	206	1.15	40	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02

Lighting Model
Letterkenny Army Depot
Building 3
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Office 26-E	10'4"	206	1.15	45	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Open Office Area 25-19-A	10'	206	1.15		111	3	40	F	15,318	50	95.0%	14.6	3,324	\$112.14	\$82.44	\$194.57
North East Area																
Office 16-K	9'	206	1.15	40	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 17-K	9'	206	1.15	45	6	3	40	F	828	50	95.0%	0.8	180	\$6.06	\$4.46	\$10.52
Womens Room 15-J		206	1.15		7	2	40	F	644	30	50.0%	0.3	84	\$2.48	\$2.08	\$4.56
Mens Room 16-J		206	1.15		5	2	40	F	460	30	50.0%	0.2	60	\$1.77	\$1.49	\$3.26
Office 16-J	10'	206	1.15	45	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Office 17-J	10'	206	1.15	40	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Corridor 22-14-J	10'	206	1.15		12	3	40	F	1,656	50	95.0%	1.6	359	\$12.12	\$8.91	\$21.04
Corridor 22-14-J Exit Sign		602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Conference Room 20-J	10'	206	1.15		16	4	40	F	2,944	35	75.0%	2.2	447	\$17.01	\$11.09	\$28.11
Office 21-J	10'	206	1.15	30	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office A 22-J	10'	206	1.15	20	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Office B 22-J	10'	206	1.15	30	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Open Office Area 26-18-K	9'	206	1.15	40	40	3	40	F	5,520	50	95.0%	5.2	1,198	\$40.41	\$29.71	\$70.12
Open Office Area (Exit Sign)		602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Open Office Area 25-J	10'	206	1.15	30	14	3	40	F	1,932	50	95.0%	1.8	419	\$14.14	\$10.40	\$24.54
Office 26-J	10'	206	1.15	40	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Corridor 23-J	10'	206	1.15		2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Open Office Area 20-F	10'	206	1.15		40	3	40	F	5,520	50	95.0%	5.2	1,198	\$40.41	\$29.71	\$70.12
Office 21-H	10'	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Office 22-H	10'	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Fan Room 21-H		230	1.15		5	2	40	F	460	5	0.0%	0.0	10	\$0.00	\$0.25	\$0.25
Fan Room 21-H		230	1.15		1	3	40	F	138	5	0.0%	0.0	3	\$0.00	\$0.07	\$0.07
Fan Room 21-H		220	1.15		1	1	40	F	46	5	0.0%	0.0	1	\$0.00	\$0.02	\$0.02
Office 21-G	10'	206	1.15	50	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Office A 21-F	10'	206	1.15	40	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office B 21-F	10'	206	1.15	40	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 26-H	10'	206	1.15	40	8	3	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Office 26-G	10'	206	1.15	15	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Conference 26-F	10'	206	1.15	55	6	3	40	F	828	35	75.0%	0.6	126	\$4.79	\$3.12	\$7.90
Conference 26-F	10'	116	1		14	1	90	I	1,260	35	75.0%	0.9	191	\$7.28	\$4.75	\$12.03
Conference 26-F (Exit Sign)		602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Open Office Area 25-F	10'	206	1.15		57	3	40	F	7,866	50	95.0%	7.5	1,707	\$57.58	\$42.33	\$99.92
Exterior																
Exterior		502	1.15		26	1	150	HPS	4,485	80	0.0%	0.0	1,557	\$0.00	\$38.62	\$38.62
Exterior		106	1		4	1	100	I	400	80	0.0%	0.0	139	\$0.00	\$3.44	\$3.44
												187	74,890	\$1,443	\$1,857	\$3,300
												TOTALS				
INCREMENTAL DEMAND COST \$/KW =												7.706				
INCREMENTAL USAGE COST \$/KW =												0.0248				

NOTE #1: LUMINAIRE TYPE ARMY #:
NOTE #2: LAMP TYPE:
NOTE #3: LUMINAIRE TYPE ARMY #:

FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

07-Apr-95

U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991

G:\PROJECTS\4130.01\SS\DATA\BLDG3.WK4

Lighting Model	Letterkenny Army Depot	Building 4	Table Designation
1	2	3	4

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248
NOTE #1: LUMINAIRE FACTOR:	FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.
NOTE #2: LAMP TYPE:	F = FLUORESCENT HPS = HIGH PRESSURE SODIUM I = INCANDESCENT MV = MERCURY VAPOR
NOTE #3: LUMINAIRE TYPE/ARMY #:	U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

**Lighting Model
Letterkenny Army Depot
Building 5N
Table Designation**

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SS\DATA\BLDG5N.WK4

Lighting Model
Watterkenny Army Depot
Building 6N
Table Designation

[illegible]

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR: FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG6N.WK4

Lighting Model
Letterkenny Army Depot
Building 10
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Computer Area																
Computer Room	9'7"	228	1.15	70	146	3	40	F	20,148	126	95.0%	19.1	11,018	\$147.50	\$273.24	\$420.74
Type Library	11'	206	1.15	40	8	4	40	F	1,472	84	95.0%	1.4	537	\$10.78	\$13.31	\$24.08
Classified Tape Library	10'9"	215	1.15	10	215	2	40	F	736	84	95.0%	0.7	268	\$5.39	\$6.65	\$12.04
Page Printing Room	11'	228	1.15	70	22	3	40	F	3,036	126	95.0%	2.9	1,660	\$22.23	\$41.17	\$63.40
South East Area																
Entrance Lobby		206	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Office 14-A	9'11"	206	1.15	30	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Conference Room 12-A	9'11"	206	1.15	30	18	2	40	F	1,656	35	75.0%	1.2	252	\$9.57	\$6.24	\$15.81
Office 11-A	9'11"	206	1.15	30	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Office A 10-A	9'11"	206	1.15	40	8	2	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Office B 10-A	9'11"	206	1.15	40	3	2	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Office A 9-A	9'11"	206	1.15	40	6	2	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office B 9-A	9'11"	206	1.15	40	6	2	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 11-B	11'	206	1.15	40	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Office 10-B	11'	206	1.15	35	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Office 9-B	11'	206	1.15	45	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Open Office Area 9-14-E	10'7"	228	1.15	50	188	2	40	F	17,296	50	95.0%	16.4	3,753	\$126.62	\$93.08	\$219.70
Fan Room 12-E		103	1		2	1	300	I	600	5	0.0%	0.0	13	\$0.00	\$0.32	\$0.32
South West Area																
Open Office Area 9-16-J	10'7"	228	1.15	50	214	2	40	F	19,688	50	95.0%	18.7	4,272	\$144.13	\$105.95	\$250.08
Office 9-K	11'	206	1.15	30	3	2	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Office 9-K		206	1.15		1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
Office 9-K Closet		206	1.15		3	2	40	F	276	10	0.0%	0.0	12	\$0.00	\$0.30	\$0.30
Office 10-K		206	1.15		4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Office 11-K	8'	206	1.15	25	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Office 12-K	8'	206	1.15	45	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Office 13-K	11'	228	1.15	25	6	2	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Fan Room 12-F		103	1		2	1	300	I	600	5	0.0%	0.0	13	\$0.00	\$0.32	\$0.32
North East Area																
Office 8-A	8'	206	1.15		6	2	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Smokers Room 6-A	8'	206	1.15		16	2	40	F	1,472	50	95.0%	1.4	319	\$10.78	\$7.92	\$18.70
Auditorium 6-B		228	1.15	45	12	3	40	F	1,656	35	75.0%	1.2	252	\$9.57	\$6.24	\$15.81
Auditorium 6-B		228	1.15		8	2	40	F	736	35	75.0%	0.6	112	\$4.25	\$2.77	\$7.03
Vending Area 5-B		228	1.15		4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Exit Lobby 5-A		101	1		1	1	100	I	100	50	95.0%	0.1	22	\$0.73	\$0.54	\$1.27
Cafe 5-B		228	1.15	40	8	3	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Computer Room 1-A	10'6"	228	1.15		20	2	40	F	1,840	50	95.0%	1.7	399	\$13.47	\$9.90	\$23.37
Women's Room 3-B		228	1.15		12	2	40	F	1,104	30	50.0%	0.6	144	\$4.25	\$3.56	\$7.82
Mens Room 3-A		228	1.15		8	2	40	F	736	30	50.0%	0.4	96	\$2.84	\$2.38	\$5.21
Janitors Closet		228	1.15		3	2	40	F	276	5	0.0%	0.0	6	\$0.00	\$0.15	\$0.15
Office 1-C	8'	206	1.15	45	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 1-D	8'	206	1.15	50	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 1-E	8'	206	1.15	70	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 1-E		206	1.15		2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Open Office Area 2-8-E	10'7"	228	1.15	50	247	2	40	F	22,724	50	95.0%	21.6	4,931	\$166.36	\$122.29	\$288.65
Fan Room 4-E		103	1		2	1	300	I	600	5	0.0%	0.0	13	\$0.00	\$0.32	\$0.32

Lighting Model
Letterkenny Army Depot
Building 10
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
North West Area																
Office 1-F	8'	206	1.15	35	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 1-G	8'	206	1.15		4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 1-H	8'	206	1.15	50	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Fan Room 4-F		103	1		2	1	300	I	600	5	0.0%	0.0	13	\$0.00	\$0.32	\$0.32
Conference Room 1-K	9'	206	1.15	50	6	3	40	F	828	35	75.0%	0.6	126	\$4.79	\$3.12	\$7.90
Conference Room 1-K		116	1		2	1	75	I	150	35	75.0%	0.1	23	\$0.87	\$0.57	\$1.43
Office 2-K	11'	206	1.15	40	6	3	40	F	828	50	95.0%	0.8	180	\$6.06	\$4.46	\$10.52
Office 3-K	11'	206	1.15	60	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Office 4-K	11'	206	1.15	50	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Office 5-K	11'	206	1.15	30	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Office A 6-K	11'	206	1.15	40	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Office B 6-K	11'	206	1.15	35	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 7-K	11'	206	1.15	35	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office 8-K	11'	206	1.15	50	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Main Entrance Lobby	15'	116	1		19	1	75	I	1,425	50	95.0%	1.4	309	\$10.43	\$7.67	\$18.10
Exterior																
Exterior		116	1		8	1	75	I	600	80	0.0%	0.0	208	\$0.00	\$5.17	\$5.17
Exterior		103	1		1	1	75	I	75	80	0.0%	0.0	26	\$0.00	\$0.65	\$0.65
Exterior		502	1.15		1	1	150	HPS	173	80	0.0%	0.0	60	\$0.00	\$1.49	\$1.49
Exterior		506	1.15		3	1	150	HPS	518	80	0.0%	0.0	180	\$0.00	\$4.46	\$4.46
Exterior		112	1		1	1	175	I	175	80	0.0%	0.0	61	\$0.00	\$1.51	\$1.51
Exterior		n/a	1		8	1	75	I	600	80	0.0%	0.0	208	\$0.00	\$5.17	\$5.17
TOTALS																
									120,341			108	33,308	\$830	\$826	\$1,706

INCREMENTAL DEMAND COST \$/KW = \$7.706
 INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
 FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
 AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
 F = FLUORESCENT
 HPS = HIGH PRESSURE SODIUM
 I = INCANDESCENT
 MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #:
 U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
 STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.0\ISSDATA\BLDG10.WK4

Lighting Model
Letterkenny Army depot
Building 14
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
First Floor																
Entrance Lobby		103	1	1	1	1	100	I	100	50	95.0%	0.1	22	\$0.73	\$0.54	\$1.27
Optical Shop	12'10"	230	1.15	90	36	3	40	F	4,968	50	95.0%	4.7	1,078	\$36.37	\$26.74	\$63.11
Optical Shop		230	1.15		14	4	40	F	2,576	50	95.0%	2.4	559	\$18.86	\$13.86	\$32.72
Corridor to Ladies Room		103	1	1	1	1	100	I	100	50	95.0%	0.1	22	\$0.73	\$0.54	\$1.27
Corridor to Mens Room		103	1	1	1	1	100	I	100	50	95.0%	0.1	22	\$0.73	\$0.54	\$1.27
Mens Room		103	1	1	1	1	100	I	100	30	50.0%	0.1	13	\$0.39	\$0.32	\$0.71
Ladies Room		103	1	1	1	1	100	I	100	30	50.0%	0.1	13	\$0.39	\$0.32	\$0.71
Machine Shop Area	11'9"	228	1.15	60	37	3	40	F	5,106	50	95.0%	4.9	1,108	\$37.38	\$27.48	\$64.86
Quality Control/Shop Area	11'9"	230	1.15	55	6	3	40	F	828	50	95.0%	0.8	180	\$6.06	\$4.46	\$10.52
Quality Control/Shop Area		228	1.15		4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Paint Room		230V	1.15		12	3	40	F	1,656	50	95.0%	1.6	359	\$12.12	\$8.91	\$21.04
Machine Shop Office	10'1"	230	1.15	35	3	2	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Machine Shop Office (Exit Sign)		604	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Machine Shop Breakroom	11'9"	228	1.15	65	7	4	40	F	1,288	50	95.0%	1.2	279	\$9.43	\$6.93	\$16.36
Receiving Room (Exit Sign)		604	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Machine Shop (Exit Sign)		604	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Mechanical Room		230V	1.15		1	3	40	F	138	5	0.0%	0.0	3	\$0.00	\$0.07	\$0.07
Mechanical Room		106	1		2	1	100	I	200	5	0.0%	0.0	4	\$0.00	\$0.11	\$0.11
Sand Blast Room	11'9"	230	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Receiving Room	11'9"	230	1.15	45	15	3	40	F	2,070	50	95.0%	2.0	449	\$15.15	\$11.14	\$26.29
Tritium Room	12'	230	1.15	50	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Tritium Room Storage		230	1.15		1	2	40	F	92	10	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
Tritium Installation Room #1	12'	228	1.15	30	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Tritium Installation Room #2	12'	216	1.15	40	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Tritium Storage Room	12'	216	1.15	40	4	4	40	F	736	10	0.0%	0.0	32	\$0.00	\$0.79	\$0.79
Tritium Final Area	12'	230	1.15	45	15	4	40	F	2,760	50	95.0%	2.6	599	\$20.21	\$14.85	\$35.06
Dark Room (Abandon)																
Second Floor																
Small Parts Work Area	12'	228	1.15	65	47	3	40	F	6,486	50	95.0%	6.2	1,407	\$47.48	\$34.91	\$82.39
Exterior																
Exterior		103	1		16	1	100	I	1,600	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		103	1		1	1	300	I	300	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
									34,706			30	6,938	\$231	\$172	\$403

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:

FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:

F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #:

U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG14.WK4

**Lighting Model
Letterkenny Army Depot
Building 19
Table Designation**

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #2: LAMP TYPE:

F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SSDATA\BILDG19.WK4

Lighting Model
Letterkenny Army Depot
Building TS20-1
Table Designation

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SSDATA\BLDG7201.WK4

Lighting Model
Letterkenny Army Depot
Building 31
Table Designation

[illegible]

\$7.706
\$0.0248

FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

F = FLUORESCENT

HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG31.WK4

**Lighting Model
Letterkenny Army Depot
Building 32
Table Designation**

Room Area or Description	Ceiling Height Ft.	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (f.c.)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Warehouse</i>																
Warehouse	23'	302	1.15	4	137	1	175	MV	27571	50	95.0%	26.2	5,983	\$201.84	\$148.38	\$350.22
Warehouse		103	1		4	1	200	I	800	50	95.0%	0.8	174	\$5.86	\$4.31	\$10.16
Warehouse		301	1.15		5	1	175	MV	1,006	50	95.0%	1.0	218	\$7.37	\$5.42	\$12.78
Exit Doors		103	1		4	1	200	I	800	50	95.0%	0.8	174	\$5.86	\$4.31	\$10.16
Receiving Area		230	1.15		3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Office	7'-6"	230	1.15	55	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
<i>Exterior</i>																
Exterior		505			8	1			0	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
TOTALS									30,776			29	6,678	\$225	\$166	\$391

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG32.WK4

Lighting Model
Letterkenny Army Depot
Building 33N
Table Designation

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SSDATA\BLDG33N.WK4

Lighting Model
Letterkenny Army Depot
Building 34
Table Designation

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SSDATA\BLDG34.WK4

G:\PROJECTS\4130.01\SSDATA\BLDG34.WK4

Lighting Model
Letterkenny Army Depot
Building 37
Table Designation

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248
NOTE #1: LUMINAIRE FACTOR:	
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.	
NOTE #2: LAMP TYPE:	
F = FLUORESCENT HPS = HIGH PRESSURE SODIUM I = INCANDESCENT MV = MERCURY	
NOTE #3: LUMINAIRE TYPE ARMY #:	U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG37.WK4

**Lighting Model
Letterkenny Army Depot
Building 41
Table Designation**

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #2: LAMP TYPE:

G:\PROJECTS\4130.01\SSDATA\BLDG41.WK4

**Lighting Model
Letterkenny Army Depot
Building 42S
Table Designation**

Room Area or Description	Ceiling Height Ft	Luminaire Type Arm#	Luminaire Factor I	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Warehouse																
Warehouse South	23'	301	1.15		15	1	175	MV	3019	50	95.0%	2.9	655	\$22.10	\$16.25	\$38.35
Warehouse South		228	1.15		124	4	40	F	22816	50	95.0%	21.7	4951	\$167.03	\$122.79	\$289.82
Warehouse South		230	1.15		11	3	40	F	1518	50	95.0%	1.4	329	\$11.11	\$8.17	\$19.28
Warehouse South		230	1.15		17	2	40	F	1564	50	95.0%	1.5	339	\$11.45	\$8.42	\$19.87
Break Room	8'10"	228	1.15		6	4	40	F	1104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Exit Door		103	1		1	1	200	I	200	50	95.0%	0.2	43	\$1.46	\$1.08	\$2.54
Office	7'5"	206	1.15	35	9	4	40	F	1656	50	95.0%	1.6	359	\$12.12	\$8.91	\$21.04
Mens Bathroom		218	1.15		4	2	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61
Womens Bathroom		218	1.15		4	2	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61
Janitors Closet		103	1		1	1	75	I	75	5	0.0%	0.0	2	\$0.00	\$0.04	\$0.04
Exterior																
Exterior Flood		505			8	1			0	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Main Door Entrance		103	1		1	1	1000	I	1000	80	0.0%	0.0	347	\$0.00	\$8.61	\$8.61
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
															\$0.00	\$0.00
	</															

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG42.WK4

Lighting Model
Letterkenny Army Depot
Building 43
Table Designation

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KW = \$0.0248

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SS\DATA\BLDG43.WK4

**Lighting Model
Letterkenny Army Depot
Building 44
Table Designation**

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

07-Apr-95

Lighting Model
Latterkenny Army Depot
Building 47
Table Designation

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #:
U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\TABLDG47S.WK4

Lighting Model
Letterkenny Army Depot
Building 51
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Warehouse</i>																
Entrance Lobby		206	1.15		1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Main Office	9'10"	206	1.15		4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Warehouse Processing	21'	230	1.15	40	96	3	40	F	13,248	50	95.0%	12.6	2,875	\$96.98	\$71.30	\$168.28
Warehouse Proc. Workstation		230	1.15		1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
Warehouse Work Room	9'10"	228	1.15	60	21	4	40	F	3,864	50	95.0%	3.7	838	\$28.29	\$20.79	\$49.08
Warehouse Break Room	9'10"	228	1.15	80	9	4	40	F	1,656	50	95.0%	1.6	359	\$12.12	\$8.91	\$21.04
Warehouse Processing Storage		301	1.15		32	1	150	HPS	5,520	50	95.0%	5.2	1,198	\$40.41	\$29.71	\$70.12
Warehouse Milvan Storage	21'	301	1.15	40	105	1	150	HPS	18,113	50	95.0%	17.2	3,930	\$132.60	\$97.47	\$230.07
Warehouse Milvan Exit Door		103	1		2	1	200	I	400	50	95.0%	0.4	87	\$2.93	\$2.15	\$5.08
Warehouse Milvan Processing	21'	230	1.15		51	3	40	F	7,038	50	95.0%	6.7	1,527	\$51.52	\$37.88	\$89.40
Warehouse Processing	21'	228	1.15		15	4	40	F	2,760	50	95.0%	2.6	599	\$20.21	\$14.85	\$35.06
Warehouse Milvan Office	9'4"	206	1.15	30	6	2	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Warehouse Milvan Mens Room	9'5"	206	1.15		2	2	40	F	184	30	50.0%	0.1	24	\$0.71	\$0.59	\$1.30
Warehouse Mil. Womens Room	9'5"	206	1.15		2	2	40	F	184	30	50.0%	0.1	24	\$0.71	\$0.59	\$1.30
Warehouse Mil. Work Station		228	1.15		2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Warehouse Radio Active Room		228	1.15		6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Self Service Entrance Lobby		206	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Self Service Office	9'10"	228	1.15	40	15	2	40	F	1,380	50	95.0%	1.3	299	\$10.10	\$7.43	\$17.53
Self Service Parts Room	9'10"	228	1.15	40	14	2	40	F	1,288	50	95.0%	1.2	279	\$9.43	\$6.93	\$16.36
Self Service Shelf Area	9'10"	228	1.15	60	69	2	40	F	6,348	50	95.0%	6.0	1,378	\$46.47	\$34.16	\$80.63
Self Service Shelf Area		230	1.15		12	2	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Self Service Rear Corridor	10'	230	1.15		10	3	40	F	1,380	50	95.0%	1.3	299	\$10.10	\$7.43	\$17.53
Self Service Rear Mens Room	10'	101	1		3	1	200	I	600	30	50.0%	0.3	78	\$2.31	\$1.94	\$4.25
Self Service Rear Womens Room	10'	101	1		2	1	200	I	400	30	50.0%	0.2	52	\$1.54	\$1.29	\$2.83
Self Service Rear Locker Room	10'	101	1		3	1	100	I	300	30	50.0%	0.2	39	\$1.16	\$0.97	\$2.12
Self Service Rear Office	9'9"	228	1.15	30	24	4	40	F	4,416	50	95.0%	4.2	958	\$32.33	\$23.77	\$56.09
Boiler Room	19'7"	230	1.15		2	2	40	F	184	5	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
Boiler Room	19'7"	231	1.15		4	2	75	F	690	5	0.0%	0.0	15	\$0.00	\$0.37	\$0.37
<i>Exterior</i>																
Exterior		505			8	1			74,231	0	0.0%	0.0	69	\$0.00	\$0.00	\$0.00
			TOTALS													
									74,231				15,793	\$531	\$392	\$923

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG51.WK4

Lighting Model
Letterkenny Army Depot
Building 52
Table Designation

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #2: LAMP TYPE:

G:\PROJECTS\4130.01\SSDATA\BLDG52.WK4

**Lighting Model
Letterkenny Army Depot
Building 53
Table Designation**

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SS\DATA\BLDG53.WK4

**Lighting Model
Letterkenny Army Depot
Building 54
Table Designation**

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SSDATA\BLDG54.WK4

**Lighting Model
Letterkenny Army Depot
Building 55
Table Designation**

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248
NOTE #1: LUMINAIRE FACTOR:	FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.
NOTE #2: LAMP TYPE:	F = FLUORESCENT HPS = HIGH PRESSURE SODIUM I = INCANDESCENT MV = MERCURY VAPOR
NOTE #3: LUMINAIRE TYPE ARMY #:	U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

07-APR-95

Lighting Model
Letterkenny Army Depot
Building 57S
Table Designation

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG57S.WK4

**Lighting Model
Letterkenny Army Depot
Building 102
Table Designation**

INCREMENTAL DEMAND COST \$/KW =	\$7.706	
INCREMENTAL USAGE COST \$/KWH =	\$0.0248	
NOTE #1: LUMINAIRE FACTOR:	<p>FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.</p>	
NOTE #2: LAMP TYPE:	<p>F = FLUORESCENT HPS = HIGH PRESSURE SODIUM I = INCANDESCENT MV = MERCURY VAPOR</p>	
NOTE #3: LUMINAIRE TYPE ARMY #:	<p>U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.</p>	

G:\PROJECTS\4130.01\SSDATA\BLDG102.WK4

**Lighting Model
Letterkenny Army Depot
Building 199
Table Designation**

INCREMENTAL DEMAND COST \$/KW =	\$7.706	
INCREMENTAL USAGE COST \$/KWH =	\$0.0248	
NOTE #1: LUMINAIRE FACTOR:	FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.	
NOTE #2: LAMP TYPE:	F = FLUORESCENT HPS = HIGH PRESSURE SODIUM I = INCANDESCENT MV = MERCURY VAPOR	
NOTE #3: LUMINAIRE TYPE ARMY #:	U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.	

G:\PROJECTS\4130.01\SSDATA\BLDG199.WK4

Lighting Model
Letterkenny Army Depot
Building 200
Table Designation

07-Apr-95

INCREMENTAL DEMAND COST \$/KW =
INCREMENTAL USAGE COST \$/KWH =

NOTE #1: LUMINAIRE FACTOR:

NOTE #2: LAMP TYPE:

F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG200.WK4

Lighting Model
Letterkenny Army Depot
Building 211
Table Designation

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #2: LAMP TYPE:

G:\PROJECTS\4130.01\SSDATA\BLDG211.WK4

Lighting Model	Letterkenny Army Depot Building 247	Table Designation
1	1	1
2	2	2
3	3	3
4	4	4
5	5	5
6	6	6
7	7	7
8	8	8
9	9	9
10	10	10
11	11	11
12	12	12
13	13	13
14	14	14
15	15	15
16	16	16
17	17	17
18	18	18
19	19	19
20	20	20
21	21	21
22	22	22
23	23	23
24	24	24
25	25	25
26	26	26
27	27	27
28	28	28
29	29	29
30	30	30
31	31	31
32	32	32
33	33	33
34	34	34
35	35	35
36	36	36
37	37	37
38	38	38
39	39	39
40	40	40
41	41	41
42	42	42
43	43	43
44	44	44
45	45	45
46	46	46
47	47	47
48	48	48
49	49	49
50	50	50
51	51	51
52	52	52
53	53	53
54	54	54
55	55	55
56	56	56
57	57	57
58	58	58
59	59	59
60	60	60
61	61	61
62	62	62
63	63	63
64	64	64
65	65	65
66	66	66
67	67	67
68	68	68
69	69	69
70	70	70
71	71	71
72	72	72
73	73	73
74	74	74
75	75	75
76	76	76
77	77	77
78	78	78
79	79	79
80	80	80
81	81	81
82	82	82
83	83	83
84	84	84
85	85	85
86	86	86
87	87	87
88	88	88
89	89	89
90	90	90
91	91	91
92	92	92
93	93	93
94	94	94
95	95	95
96	96	96
97	97	97
98	98	98
99	99	99
100	100	100

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #2: LAMP TYPE:

G:\PROJECTS\4130.01\SSDATA\BLDG247.WK4

Lighting Model
Letterekeny Army Depot
Building 320
Table Designation

Room Area or Description	Celling Height Ft	Luminaire Type Arm#	Luminaire Factor I	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent OF Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$	
Maintenance	28'	301	1.15	30	32	1	400	HPS	14,720	50	95.0%	14.0	3,194	\$107.76	\$79.22	\$186.98	
		301	1.15		7	1	400	MV	3,220	168	95.0%	3.1	2,348	\$23.57	\$58.22	\$81.80	
		602	1.15		10	1	6	F	69				15	\$0.51	\$0.37	\$0.88	
	7'6"	206	1.15		3	4	40	F	552	50	95.0%	0.1	120	\$4.04	\$2.97	\$7.01	
	28"	230	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17	
	9'10"	206	1.15	30	47	2	40	F	4,324	168	95.0%	4.1	3,153	\$31.65	\$78.19	\$109.84	
		602	1.15		1	1	26	F	30	50	95.0%	0.0	6	\$0.22	\$0.16	\$0.38	
	9'10"		1.15	40	6	2	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01	
	9'10"	206	1.15		6	3	40	F	828	30	50.0%	0.4	108	\$3.19	\$2.67	\$5.86	
	9'	115	1		1	1	100	I	100	30	50.0%	0.1	13	\$0.39	\$0.32	\$0.71	
	9'	101	1		1	1	100	I	100	30	50.0%	0.1	13	\$0.39	\$0.32	\$0.71	
	9'	220	1.15		3	2	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61	
	9'	215	1.15		4	2	40	F	276	168	95.0%	0.3	201	\$2.02	\$4.99	\$7.01	
	9'	602	1.15		1	1	6	F	7				1	\$0.03	\$0.02	\$0.05	
	9'	218	1.15		11	1	40	F	506	168	95.0%	0.5	369	\$3.70	\$9.15	\$12.85	
	9'	602	1.15		1	1	6	F	7				1	\$0.03	\$0.02	\$0.05	
	9'	228	1.15		1	4	40	F	184	30	50.0%	0.1	24	\$0.71	\$0.59	\$1.30	
	9'	115	1		4	1	100	I	400	30	50.0%	0.2	52	\$1.54	\$1.29	\$2.83	
	9'	218	1.15		11	1	1	100	I	100	30	50.0%	0.1	13	\$0.39	\$0.32	\$0.71
	Exterior	9'	602	1.15		1	1	40	F	506	30	50.0%	0.3	66	\$1.95	\$1.63	\$3.58
9'		228	1.15		1	4	40	F	184	30	50.0%	0.1	24	\$0.71	\$0.59	\$1.30	
115		1		4	1	100	I	400	30	50.0%	0.2	52	\$1.54	\$1.29	\$2.83		
115		1		1	1	100	I	100	30	50.0%	0.1	13	\$0.39	\$0.32	\$0.71		
Exterior		124	1		8	1	60	I	480	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00	
Exterior					4		150	HPS	0	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00	

INCREMENTAL DEMAND COST \$/KW =
INCREMENTAL USAGE COST \$/KWH =

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:

F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG320.WK4

**Lighting Model
Letterkenny Army Depot
Building 349
Table Designation**

	TOTAL \$	18,260	14	8,106	\$312
					\$701
					\$111
					\$312

<p> \$7,706 \$0,0248 </p>
--

FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

07 Apr 05

Lighting Model
Letterkenny Army Depot
Building 350
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Office #1																
Reception	8'	206	1.15	70	11	4	40	F	2,024	90	95.0%	1.9	791	\$14.82	\$19.61	\$34.42
Reception (Exit Sign)		602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Copy Room	8'	206	1.15	60	2	4	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26
Managers Office	8'	206	1.15	70	4	4	40	F	736	90	95.0%	0.7	287	\$5.39	\$7.13	\$12.52
Managers Office (Exit Sign)		602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Corridor to Shop	8'	206	1.15		3	4	40	F	552	90	95.0%	0.5	216	\$4.04	\$5.35	\$9.39
Boiler Room		215	1.15		1	2	40	F	92	5	0.0%	0.0	2	\$0.00	\$0.05	\$0.05
Mens Room	8'	206	1.15		5	4	40	F	920	54	95.0%	0.9	216	\$6.74	\$5.35	\$12.08
Womens Room	8'	206	1.15		5	4	40	F	920	54	95.0%	0.9	216	\$6.74	\$5.35	\$12.08
Conference Room	8'	206	1.15	70	12	4	40	F	2,208	63	95.0%	2.1	604	\$16.16	\$14.97	\$31.14
Conference Room (Exit Sign)		602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Office #2																
Reception Area	8'	206	1.15	50	8	4	40	F	1,472	90	95.0%	1.4	575	\$10.78	\$14.26	\$25.04
Managers Office	8'	206	1.15	65	1	4	40	F	184	90	95.0%	0.2	72	\$1.35	\$1.78	\$3.13
Computer PLC I/O Room		103	1		7	1	100	I	700	90	95.0%	0.7	273	\$5.12	\$6.78	\$11.91
Mens Room		103	1		16	1	100	I	1,600	54	95.0%	1.5	375	\$11.71	\$9.30	\$21.01
Womens Room		103	1		16	1	100	I	1,600	54	95.0%	1.5	375	\$11.71	\$9.30	\$21.01
Corridor to Shop		103	1		2	1	100	I	200	90	95.0%	0.2	78	\$1.46	\$1.94	\$3.40
Office #3																
Breakroom	11'6"	103	1	15	7	1	100	I	700	90	95.0%	0.7	273	\$5.12	\$6.78	\$11.91
New Bathroom (Under Const.)																
Work Area	8'	206	1.15	20	6	4	40	F	1,104	90	95.0%	1.0	431	\$8.08	\$10.69	\$18.78
Separate Office Area	11'6"	228	1.15	45	4	4	40	F	736	90	95.0%	0.7	287	\$5.39	\$7.13	\$12.52
ASRS plus Office Area Corridor		228	1.15		3	4	40	F	552	90	95.0%	0.5	216	\$4.04	\$5.35	\$9.39
ASRS plus Ofc. Area (Exit Sign)		602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
ASRS plus Office Computer Rm.	8'	206	1.15	50	8	4	40	F	1,472	90	95.0%	1.4	575	\$10.78	\$14.26	\$25.04
ASRS plus Office (Exit Sign)		602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Corridor bwn. ASRS&Breakrm.		103	1		1	1	100	I	100	90	95.0%	0.1	39	\$0.73	\$0.97	\$1.70
Office #4																
Corridor to Shop		103	1		3	1	100	I	300	90	95.0%	0.3	117	\$2.20	\$2.91	\$5.10
Mens Room		103	1		7	1	100	I	700	54	95.0%	0.7	164	\$3.12	\$4.07	\$9.19
Office Area	11'6"	230	1.15	40	5	2	40	F	460	90	95.0%	0.4	180	\$3.37	\$4.46	\$7.82
Library Conference Room	11'6"	230	1.15	40	2	3	40	F	276	63	95.0%	0.3	75	\$2.02	\$1.87	\$3.89
Book Storage	11'6"	230	1.15	30	3	3	40	F	414	10	0.0%	0.0	18	\$0.00	\$0.45	\$0.45
Book Storage		228	1.15		1	3	40	F	138	10	0.0%	0.0	6	\$0.00	\$0.15	\$0.15
Quality Control Room	11'5"	228	1.15	20	6	3	40	F	828	90	95.0%	0.8	323	\$6.06	\$8.02	\$14.08
Annex Office Area #6																
Planning Production Fabrication	8'	215	1.15	55	12	2	40	F	1,104	90	95.0%	1.0	431	\$8.08	\$10.69	\$18.78
Trades Branch Conference Rm.	8'	215	1.15	45	12	2	40	F	1,104	63	95.0%	1.0	302	\$8.08	\$7.49	\$15.57
Trades Office Room #1	8'	215	1.15	40	12	2	40	F	1,104	90	95.0%	1.0	431	\$8.08	\$10.69	\$18.78
Trades Office Room #2	8'	215	1.15	45	12	2	40	F	1,104	90	95.0%	1.0	431	\$8.08	\$10.69	\$18.78
Ladies Room		215	1.15		3	2	40	F	276	54	95.0%	0.3	65	\$2.02	\$1.60	\$3.62
Mens Room		215	1.15		6	2	40	F	552	54	95.0%	0.5	129	\$4.04	\$3.21	\$7.25
Janitors Closet		101	1		1	1	100	I	100	5	0.0%	0.0	2	\$0.00	\$0.05	\$0.05
Machine Room		101	1		1	1	100	I	100	5	0.0%	0.0	2	\$0.00	\$0.05	\$0.05

Lighting Model
Letterkenny Army Depot
Building 350
Table Designation

[illegible]

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG350.WK4

Lighting Model
Letterkenny Army Depot
Building 370
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type	Luminaire Factor I	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Equipment Repair																
Shop Area/Computer Area	15'4"	228	1.15	50	52	4	40	F	9,568	90	95.0%	9.1	3,737	\$70.04	\$92.68	\$162.73
Shop Area Office		228	1.15		5	4	40	F	920	90	95.0%	0.9	359	\$6.74	\$8.91	\$15.65
Phonix Area*		228	1.15	80	87	4	30	F	12,006	90	95.0%	11.4	4,690	\$87.89	\$116.30	\$204.19
Phonix Aux./Computer Room*		228	1.15		16	4	30	F	2,208	90	95.0%	2.1	862	\$16.16	\$21.39	\$37.55
Test Room		228	1.15		4	4	40	F	736	90	95.0%	0.7	287	\$5.39	\$7.13	\$12.52
Test Room/Workstation		228	1.15		2	4	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26
Shop Area Entrance		103	1		1	1	100	I	100	90	95.0%	0.1	39	\$0.73	\$0.97	\$1.70
Phonix Aux. Shop Area*	11'5"	228	1		87	3	30	F	7,830	90	95.0%	7.4	3,058	\$57.32	\$75.85	\$133.17
Phonix Aux. Breakroom*		228	1		12	4	28	F	1,344	90	95.0%	1.3	525	\$9.84	\$13.02	\$22.86
Shop Area		228	1.15		318	4	40	F	58,512	90	95.0%	55.6	22,855	\$428.55	\$566.80	\$995.15
Mens Room		228	1.15		3	4	40	F	552	54	95.0%	0.5	129	\$4.04	\$3.21	\$7.25
Mens Room (Shower)		103	1		1	1	100	I	100	5	0.0%	0.0		2	\$0.00	\$0.05
Mens Room (Entrance)		103	1		1	1	100	I	100	54	95.0%	0.1	23	\$0.73	\$0.58	\$1.31
Ladies Room		103	1		4	1	100	I	400	54	95.0%	0.4	94	\$2.93	\$2.32	\$5.25
Corridor to Mens & Ladies Rm*		228	1		2	3	30	F	180	90	95.0%	0.2	70	\$1.32	\$1.74	\$3.06
Corridor to Mens & Ladies Room		103	1		1	1	100	I	100	90	95.0%	0.1	39	\$0.73	\$0.97	\$1.70
Shop Area Task Lighting		230	1.15		4	2	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26
Shop Area Task Lighting		215	1.15		2	2	40	F	184	90	95.0%	0.2	72	\$1.35	\$1.78	\$3.13
* Refer to Note #4																
TOTALS																
										95,576			37,131	\$609	\$921	\$1,620

\$7.706
\$0.0248

FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

BASED ON MANUFACTURER DATA, THE LAMP /BALLAST POWER INPUT FOR THREE F32T8 LAMPS WITH ELECTRONIC BALLAST EQUALS APPROXIMATELY 90 WATTS. THE LAMP/BALLAST POWER INPUT FOR FOUR F32T8 LAMPS WITH ELECTRONIC BALLAST EQUALS APPROXIMATELY 112 WATTS.

Lighting Model
Letterkenny Army Depot
Building 412
Table Designation

INCREMENTAL DEMAND COST \$/KW =	\$7.706	
INCREMENTAL USAGE COST \$/KWH =	\$0.0248	
NOTE #1: LUMINAIRE FACTOR:	<p>FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.</p>	
NOTE #2: LAMP TYPE:	<p>F = FLUORESCENT HPS = HIGH PRESSURE SODIUM I = INCANDESCENT MV = MERCURY VAPOR</p>	
NOTE #3: LUMINAIRE TYPE ARMY #:	<p>U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.</p>	

G:\PROJECTS\4130.0\SSDATA\BLDG412.WK4

**Lighting Model
Letterkenny Army Depot
Building 416
Table Designation**

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SSDATA\BILDG416.WK4

**Lighting Model
Letterkenny Army Depot
Building 417
Table Designation**

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248
NOTE #1: LUMINAIRE FACTOR:	FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.
NOTE #2: LAMP TYPE:	F = FLUORESCENT HPS = HIGH PRESSURE SODIUM I = INCANDESCENT MV = MERCURY VAPOR
NOTE #3: LUMINAIRE TYPE ARMY #:	U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG417.WK4

G:\PROJECTS\4130.01\SSDATA\BLDG417.WK4

Lighting Model	Letterkenny Army Depot Building 418	Table Designation
1	2	3

INCREMENTAL DEMAND COST \$/KW =	\$7.706	
INCREMENTAL USAGE COST \$/KWH =	\$0.0248	
NOTE #1: LUMINAIRE FACTOR:	<p>FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.</p>	
NOTE #2: LAMP TYPE:	<p>F = FLUORESCENT HPS = HIGH PRESSURE SODIUM I = INCANDESCENT MV = MERCURY VAPOR</p>	
NOTE #3: LUMINAIRE TYPE ARMY #:	<p>U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.</p>	

G:\PROJECTS\4130.01\SSDATA\B\LDG418.WK4

Lighting Model
Letterkenny Army Depot
Building 421
Table Designation

Room Area or Description	Celling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (f.c)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Administration																
Main Office Area North End	8'	206	1.15	40	28	4	40	F	5,152	50	95.0%	4.9	1,118	\$37.72	\$27.73	\$65.44
Administration																
Main Office Area North End	8'	206	1.15	40	28	4	40	F	5,152	50	95.0%	4.9	1,118	\$37.72	\$27.73	\$65.44
Property/Accountability Office	8'	206	1.15	65	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Equipment Mgt. Office	8'	206	1.15	45	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
North Exit Lobby	8'	206	1.15	45	1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Ladies Room	8'	206	1.15	45	2	4	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61
Conference Room	8'	206	1.15	45	2	4	40	F	368	35	75.0%	0.3	56	\$2.13	\$1.39	\$3.51
Mens Room	8'	206	1.15	45	2	4	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61
Vending Area	8'	206	1.15	45	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Ck. Depot Prop. Div. Reception	9'	206	1.15	25	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Managers Office	8'	206	1.15	45	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Ck. Depot Prop. Div. Office	9'	206	1.15	60	4	3	552	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Main Office South End	98"	206	1.15	40	24	4	40	F	4,416	50	95.0%	4.2	958	\$32.33	\$23.77	\$56.09
Contracting Office Area	99"	206	1.15	30	14	4	40	F	2,576	50	95.0%	2.4	559	\$18.86	\$13.86	\$32.72
Contracting Office Conf. Room	99"	206	1.15	60	6	3	40	F	828	35	75.0%	0.6	126	\$4.79	\$3.12	\$7.90
Janitors Closet		220	1.15	45	1	1	40	F	46	5	0.0%	0.0	1	\$0.00	\$0.02	\$0.02
Mens Room		228	1.15	45	2	4	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61
Mens Room		220	1.15	45	1	1	40	F	46	30	50.0%	0.0	6	\$0.18	\$0.15	\$0.33
Cont. Office Purch. Office Area		206	1.15	45	26	4	40	F	4,784	50	95.0%	4.5	1,038	\$35.02	\$25.75	\$60.77
Support Division Chief Office	99"	206	1.15	45	5	4	40	F	920	50	95.0%	0.9	200	\$6.74	\$4.95	\$11.69
Support Division Chief Office	99"	206	1.15	45	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Managers Office	99"	206	1.15	45	1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
File/Copy Room	911"	206	1.15	30	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
File/Copy Room on Files		220	1.15	45	4	1	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Womens Room		220	1.15	45	2	4	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61
Womens Room		220	1.15	45	1	1	40	F	46	30	50.0%	0.0	6	\$0.18	\$0.15	\$0.33
Acquisition Chief	910"	206	1.15	45	1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Main Entrance Lobby	910"	206	1.15	25	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Imprest Office	910"	206	1.15	45	1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Receptionist	910"	206	1.15	40	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Office	910"	206	1.15	45	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Bid Room #2	910"	206	1.15	55	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Office	910"	206	1.15	90	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Office (left of Acquisition Chief)	910"	206	1.15	30	1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Exterior																
Exterior (no lamps)		103	1		16	1	100	I	1,600	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		502	1.15		3	1	150	HPS	518	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
TOTALS									29,902			25	5,807	\$196	\$144	\$340
INCREMENTAL DEMAND COST \$/KWH = \$7.706																
INCREMENTAL USAGE COST \$/KWH = \$0.0248																

NOTE #1: LUMINAIRE TYPE: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

NOTE #2: LAMP TYPE: F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.0\ISSUES\BULBDG421.WK4

07-Apr-95

Lighting Model
Letterkenny Army Depot
Building 424
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Cable and Harness</i>																
Work Area	19'10"	230	1.15	50	12	3	40	F	1,656	90	95.0%	1.6	647	\$12.12	\$16.04	\$28.16
File Area	9'9"	206	1.15	40	5	3	40	F	690	90	95.0%	0.7	270	\$5.05	\$6.68	\$11.74
Work Station	9'9"	206	1.15	40	5	3	40	F	690	90	95.0%	0.7	270	\$5.05	\$6.68	\$11.74
Cable Termination Area	9'9"	206	1.15	50	6	2	40	F	552	90	95.0%	0.5	216	\$4.04	\$5.35	\$9.39
Cable Termination Area	9'9"	230	1.15	50	1	2	40	F	92	90	95.0%	0.1	36	\$0.67	\$0.89	\$1.56
Cable Tent Station	9'9"	206	1.15	35	3	3	40	F	414	90	95.0%	0.4	162	\$3.03	\$4.01	\$7.04
Assembly Area	9'9"	206	1.15	40	21	3	40	F	2,898	90	95.0%	2.8	1,132	\$21.22	\$28.07	\$49.29
Assembly Area Desk Lighting	9'9"	215	1.15	40	3	2	40	F	276	90	95.0%	0.3	108	\$2.02	\$2.67	\$4.69
Break Room	9'9"	206	1.15	30	3	3	40	F	276	90	95.0%	0.4	162	\$3.03	\$4.01	\$7.04
Break Room	9'9"	206	1.15	30	3	2	40	F	276	90	95.0%	0.3	108	\$2.02	\$2.67	\$4.69
Office (Day)	9'9"	206	1.15		4	3	40	F	552	90	95.0%	0.5	216	\$4.04	\$5.35	\$9.39
Work Area	19'10"	228	1.15		12	3	40	F	1,656	90	95.0%	1.6	647	\$12.12	\$16.04	\$28.16
Carpentry Work Shop		302	1.15		4	1	150	HPS	690	90	95.0%	0.7	270	\$5.05	\$6.68	\$11.74
Carpentry Work Shop		302	1.15		1	1	175	MV	201	90	95.0%	0.2	79	\$1.47	\$1.95	\$3.42
Carpentry Work Shop		301	1.15		8	1	400	HPS	3,680	90	95.0%	3.5	1,437	\$26.94	\$35.65	\$62.59
Rubber Mat Storage Room	19'10"	230V	1.15	40	12	3	40	F	1,656	90	95.0%	1.6	647	\$12.12	\$16.04	\$28.16
Upholstery Work Shop	19'10"	228	1.15		32	3	40	F	4,416	90	95.0%	4.2	1,725	\$32.33	\$42.78	\$75.11
Upholstery Work Shop	19'10"	230	1.15		72	3	40	F	9,936	90	95.0%	9.4	3,881	\$72.74	\$96.25	\$168.99
Upholstery Work Shop	19'10"	103	1		42	1	100	I	4,200	90	95.0%	4.0	1,641	\$30.75	\$40.68	\$71.43
Unpacking	12'5"	230V	1.15		3	3	40	F	414	90	95.0%	0.4	162	\$3.03	\$4.01	\$7.04
Unpacking	12'5"	228	1.15		28	4	40	I	552	90	95.0%	0.5	216	\$4.04	\$5.35	\$9.39
Womens Room		103	1		1	1	100	I	100	54	95.0%	0.1	23	\$0.73	\$0.58	\$1.31
Mens Room		103	1		1	1	100	I	100	54	95.0%	0.1	23	\$0.73	\$0.58	\$1.31
Janitors Room		230	1.15		2	2	40	F	184	5	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
Office	8'5"	206	1.15	70	2	4	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26
<i>Exterior</i>																
Exterior		103	1		2	1	100	I	200	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		103	1		7	1	200	I	1,400	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
			TOTALS						38,263			35	14,222	\$267	\$353	\$620

INCREMENTAL DEMAND COST \$/KW = \$7.706
 INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
 FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
 AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
 F = FLUORESCENT
 HPS = HIGH PRESSURE SODIUM
 I = INCANDESCENT
 MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #:
 U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
 STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG424.WK4

Lighting Model
Letterkenny Army Depot
Building 428
Table Designation

Room Area or Description	Celling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent OF Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Counseling																
Counseling Managers Office	7'5"	228	1.15	50	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Corridor to Managers Office	7'5"	220	1.15		6	2	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Copy Room	7'	220	1.15	55	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Womens Room		201	1	1	1	1	100	I	100	30	50.0%	0.1	13	\$0.39	\$0.32	\$0.71
Mens Room		101	1		1	1	100	I	100	30	50.0%	0.1	13	\$0.39	\$0.32	\$0.71
Main Entrance Corridor	7'5"	220	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Counselors Office	7'5"	220	1.15	50	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Counselors Office	7'5"	220	1.15	45	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Conference Room (Day)	7'5"	220	1.15	60	8	2	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
TOTALS									2,592			2	545	\$18	\$14	\$32

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

Lighting Model
Letterkenny Army Depot
Building 431
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Administration</i>																
Main Entrance Lobby	20'8"	228	1.15	15	8	4	40	F	1,472	50	95.0%	1.4	319	\$10.78	\$7.92	\$18.70
TDME Office Area	11'8"	228	1.15	60	25	4	40	F	4,600	50	95.0%	4.4	998	\$33.68	\$24.76	\$58.43
Executive Secretary	11'8"	228	1.15	30	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Computer Room	11'8"	206	1.15		2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Mens Room		228	1.15		1	4	40	F	184	30	50.0%	0.1	24	\$0.71	\$0.59	\$1.30
Womens Room		228	1.15		1	4	40	F	184	30	50.0%	0.1	24	\$0.71	\$0.59	\$1.30
TDME Chief Office	11'8"	228	1.15	45		4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
TDME Chief Lab Calibration	11'8"	228	1.15		3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Lab #1		206	1.15		12	4	40	F	2,208	50	95.0%	2.1	479	\$16.16	\$11.88	\$28.05
Lab #1 (Entrance Lobby)		303	1.15		1	4	20	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Conference Room 1 & 2	9'10"	228	1.15	50	6	4	40	F	1,104	35	75.0%	0.8	168	\$6.38	\$4.16	\$10.54
Lab #2		206	1.15		12	4	40	F	2,208	50	95.0%	2.1	479	\$16.16	\$11.88	\$28.05
Lab #2 (Entrance Lobby)		303	1.15		1	2	20	F	46	50	95.0%	0.0	10	\$0.34	\$0.25	\$0.58
Corridor Lab #3 & #4	20'8"	228	1.15		9	4	40	F	1,656	50	95.0%	1.6	359	\$12.12	\$8.91	\$21.04
Lab #3		206	1.15		12	4	40	F	2,208	50	95.0%	2.1	479	\$16.16	\$11.88	\$28.05
Lab #3 (Entrance Lobby)		303	1.15		1	4	20	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Supply Section		228	1.15		10	4	40	F	1,840	50	95.0%	1.7	399	\$13.47	\$9.90	\$23.37
* Lab #4	10'9"	206	1.15	110	16	4	40	F	2,944	50	95.0%	2.8	639	\$21.55	\$15.84	\$37.40
Lab #4 (Entrance Lobby)	10'9"	206	1.15		1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Corridor around Lab #4		230	1.15		4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Storage Shelf Area Light (lab#4)	2'5"	206	1.15		7	4	40	F	1,288	50	95.0%	1.2	279	\$9.43	\$6.93	\$16.36
Lab #5 Section 1		206	1.15		6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Lab #5 Section 2 (Locked)																
Lab #5 Temp. Storage (Locked)																
ACL Office	7'5"	206	1.15	50	5	4	40	F	920	50	95.0%	0.9	200	\$6.74	\$4.95	\$11.69
Break Room	20'8"	230	1.15	30	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Corridor around ACL Office	20'8"	230	1.15		4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
<i>Exterior</i>																
Exterior		508	1		4	1	500	I	2,000	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		502	1.15		2	1	150	HPS	345	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
All Labs Need Special Light Levels.																
			TOTALS						30,727			27	6,055	\$205	\$150	\$355

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR: FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE: F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

Lighting Model
Letterkenny Army Depot
Building 438
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Arm#	Luminaire Factor I	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent OF Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Repair Shop</i>																
Shipping Area	16'8"	103	1	35	28	1	300	I	8,400	50	95.0%	8.0	1,823	\$61.49	\$45.21	\$106.70
Shipping Area		215	1.15		3	2	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Mens Room		103	1		2	1	300	I	600	30	50.0%	0.3	78	\$2.31	\$1.94	\$4.25
Ladies Room		103	1		2	1	300	I	600	30	50.0%	0.3	78	\$2.31	\$1.94	\$4.25
Office		103	1		2	1	300	I	600	50	95.0%	0.6	130	\$4.39	\$3.23	\$7.62
<i>Exterior</i>																
Exterior		103	1		3	1	300	I	900	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
TOTALS									11,376			9	2,169	\$73	\$54	\$126

INCREMENTAL DEMAND COST \$/KW =
INCREMENTAL USAGE COST \$/KWH =

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG438.WK4

**Lighting Model
Letterkenny Army Depot
Building 441
Table Designation**

Room Area or Description	Celling Height Ft	Luminaire Type Arm#	Luminaire Factor I	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Warehouse</i>																
Outside Office	7'7"	206	1.15	30	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Warehouse	21'	103	1		33	1	300	I	9,900	50	95.0%	9.4	2,148	\$72.47	\$53.28	\$125.75
Warehouse Parts Bay	21'	228	1.15		2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
<i>Exterior</i>																
Exterior		103	1		24	1	300	I	7,200	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
TOTALS									17,652			10	2,268	\$77	\$56	\$133

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HP'S = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG441.WK4

Lighting Model
Letterkenny Army Depot
Building 500
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>First Floor</i>																
Command Wing Entrance	7'7"	206	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Conference Room #3	9'	206	1.15	60	4	4	40	F	736	35	75.0%	0.6	112	\$4.25	\$2.77	\$7.03
G. Patterson Office	8'	206	1.15	50	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Depot Commander	8'	206	1.15	50	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Commander Secretary	8'	206	1.15	120	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Commander Office	8'	206	1.15	80	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Depot Sergeant Majors Office	8'	206	1.15	50	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Kitchen	8'	101	1		1	1	60	I	60	50	95.0%	0.1	13	\$0.44	\$0.32	\$0.76
Copy Room	8'	215	1.15	70	3	2	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Public Affairs Office	8'	206	1.15	30	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Admin. Prgm. Coordinators Ofc.	8'	206	1.15	65	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Protocol Office	8'	206	1.15	95	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Ladies Room		206	1.15		2	3	40	F	276	30	50.0%	0.1	36	\$1.06	\$0.89	\$1.95
Mens Room		206	1.15		2	3	40	F	276	30	50.0%	0.1	36	\$1.06	\$0.89	\$1.95
Corridor		206	1.15		8	2	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Command Corridor (Exit Sign)		n/a	1		1	1	25	I	25	168	95.0%	0.0	18	\$0.18	\$0.05	\$0.64
Closet		101	1		1	1	60	I	60	10	0.0%	0.0	3	\$0.00	\$0.06	\$0.06
P. Gieseking Office		206	1.15	65	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Rear Office	8'	206	1.15	65	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Entrance to Rear Office	8'	206	1.15		1	3	40	F	138	50	95.0%	0.1	30	\$0.10	\$0.74	\$1.75
Legal Office Corridor	8'	206	1.15		10	3	40	F	1,380	50	95.0%	1.3	299	\$10.10	\$7.43	\$17.53
Legal Office (Exit Sign)		n/a	1		3	1	25	I	75	168	95.0%	0.1	55	\$0.55	\$1.36	\$1.91
Legal Office 15 Reception	8'	206	1.15	50	6	3	40	F	828	50	95.0%	0.8	180	\$6.06	\$4.46	\$10.52
Front Office 15A	8'	206	1.15	65	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Rear Office 15B	8'	206	1.15	40	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Conference Room #1	8'	206	1.15		2	3	40	F	276	35	75.0%	0.2	42	\$1.60	\$1.04	\$2.63
Conference Room #1	8'	116	1	60	10	1	75	I	750	35	75.0%	0.6	114	\$4.33	\$2.83	\$7.16
Conference Room #1	8'	206	1.15		6	3	40	F	828	35	75.0%	0.6	126	\$4.79	\$3.12	\$7.90
Conference Room #1	8'	102	1		2	1	75	I	150	35	75.0%	0.1	23	\$0.87	\$0.57	\$1.43
Office #17	8'	206	1.15	35	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Computer Room	8'	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Mens Room	8'	206	1.15		1	3	40	F	138	30	50.0%	0.1	18	\$0.53	\$0.45	\$0.98
Mens Room	8'	101	1		1	1	100	I	100	30	50.0%	0.1	13	\$0.39	\$0.32	\$0.71
Police Room	8'	206	1.15		3	3	40	F	414	168	95.0%	0.4	302	\$3.03	\$7.49	\$10.52
Police Sign in Room	8'	206	1.15	40	4	3	40	F	552	90	95.0%	0.5	216	\$4.04	\$5.35	\$9.39
Womens Room	8'	206	1.15		1	3	40	F	138	30	50.0%	0.1	18	\$0.53	\$0.45	\$0.98
Womens Room	8'	101	1		1	1	100	I	100	30	50.0%	0.1	13	\$0.39	\$0.32	\$0.71
Employment Info. Office	8'	206	1.15	40	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Room #23 (Locked)	8'															
Room #25 (Office)	8'	206	1.15	40	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Room #24 (Locked)	8'															
Copy Room	8'	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Room #26 (Office)	8'	206	1.15	40	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office	8'	206	1.15	60	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Dispensary Waiting Room	8'	206	1.15	60	4	3	40	F	552	90	95.0%	0.5	216	\$4.04	\$5.35	\$9.39
Dispensary Corridor	8'	206	1.15		14	2	40	F	1,288	90	95.0%	1.2	503	\$9.43	\$12.48	\$21.91
Dispensary (Exit Sign)	8'	602	1.15		4	2	7	F	64	168	95.0%	0.1	47	\$0.47	\$1.16	\$1.64
Room #47 (Office)	8'	206	1.15	40	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Room #31 Open Office Area	8'	206	1.15	95	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02

Lighting Model
Letterkenny Army Depot
Building 500
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Office	8'	206	1.15		1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
Women's Room (Part of #31)	8'	240	1.15		1	2	40	F	92	5	0.0%	0.0	2	\$0.00	\$0.05	\$0.05
Treatment Room #1 Room #46	8'	206	1.15	70	2	4	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26
Treatment Room #2 Room #45	8'	206	1.15	70	2	4	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26
Pharmacy	8'	206	1.15	60	1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Restroom	8'	206	1.15		1	2	40	F	92	30	50.0%	0.0	12	\$0.35	\$0.30	\$0.65
Laboratory Room #33	8'	206	1.15	70	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Radiology Room #44 (Locked)																
Physical Therapy Room #34	8'	206	1.15	40	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Waiting Room	8'	206	1.15		2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Waiting Room Restroom	8'	206	1.15		1	3	40	F	138	30	50.0%	0.1	18	\$0.55	\$0.45	\$0.98
Storage Closet	8'	215	1.15		2	4	40	F	184	10	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
Clean Utility Room (Rm. #35)	8'	215	1.15	35	2	4	40	F	368	5	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
Break Room (Room #36)	8'	206	1.15	100	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Occupational Health Room #43	8'	206	1.15	50	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Occupational Health Rm. #43A	8'	206	1.15	55	1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Occupational Health Rm. #43A	8'	116	1		2	1	100	I	200	50	95.0%	0.2	43	\$1.46	\$1.08	\$2.54
Occupational Health Rm. #43B	8'	206	1.15	25	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Occupational Health Rm. #43C	8'	206	1.15	25	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Occupational Health Room #37	8'	206	1.15	50	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Occupational Health Room #38	8'	206	1.15		2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Office Room #42	8'	206	1.15	50	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Occupational Health Room #39	8'	206	1.15	50	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Emergency Treatment Rm. #40	8'	206	1.15	75	6	4	40	F	1,104	90	95.0%	1.0	431	\$8.08	\$10.69	\$18.78
Restroom	8'	206	1.15		1	2	40	F	92	30	50.0%	0.0	12	\$0.35	\$0.30	\$0.65
Conference Room (Room #41)	8'	206	1.15	35	5	4	40	F	920	35	75.0%	0.7	140	\$5.32	\$3.47	\$8.78
Emergency Rm. Entrance Lobby	8'	206	1.15		1	2	40	F	92	168	95.0%	0.1	67	\$0.67	\$1.66	\$2.34
Emer. Rm. Ent. Lobby (Exit Sign)	8'	602	1.15		1	2	7	F	16	168	95.0%	0.0	12	\$0.12	\$0.29	\$0.41
Second Floor																
Room #3 (Office)	8'	206	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Auditorium	9'9"	215	1.15	20	27	2	40	F	2,484	35	75.0%	1.9	377	\$14.36	\$9.36	\$23.71
Auditorium (Exit Sign)		n/a	1		1	1	25	I	25	168	95.0%	0.0	18	\$0.18	\$0.45	\$0.64
Auditorium Projection Room		215	1.15		3	2	40	F	276	10	0.0%	0.0	12	\$0.00	\$0.30	\$0.30
Conference Room (Locked)		206	1.15		2	3	40	F	276	35	75.0%	0.2	42	\$1.60	\$1.04	\$2.63
Center Bldg. Open Office Area	8'	206	1.15	35	26	4	40	F	4,784	50	95.0%	4.5	1,038	\$35.02	\$25.75	\$60.77
Employee Relations Office	8'	206	1.15	100	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Office #10	8'	206	1.15	80	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Cr. Bldg. Open Ofc. (Exit Sign)		n/a	1		1	1	25	I	25	168	95.0%	0.0	18	\$0.18	\$0.45	\$0.64
Conference Room (in use)																
Room #1 (Locked)																
Computer Room	8'	228	1.15	30	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Room #7 (Office)	8'	206	1.15	80	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Basement Level																
Entrance/Vending Area	8'	206	1.15		2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Ent/Vending Area (Exit Sign)	8'	602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Corridor	8'	206	1.15		10	3	40	F	1,380	50	95.0%	1.3	299	\$10.10	\$7.43	\$17.53
Corridor (Exit Sign)		602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Room #2 (Office)	8'	206	1.15	75	5	3	40	F	690	50	95.0%	0.7	150	\$5.05	\$3.71	\$8.76

Lighting Model
Letterkenny Army Depot
Building 500
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (F.C)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent OF Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Room #4 (Office)	8'	206	1.15	60	6	3	40	F	828	50	95.0%	0.8	180	\$6.06	\$4.46	\$10.52
Room #5 (Office)	8'	206	1.15	100	12	3	40	F	1,656	50	95.0%	1.6	359	\$12.12	\$8.91	\$21.04
Room #7 (Conference Room)	8'	206	1.15	60	2	3	40	F	276	35	75.0%	0.2	42	\$1.60	\$1.04	\$2.63
Room #3A (Internal Review)	8'	206	1.15	60	6	3	40	F	828	35	75.0%	0.6	126	\$4.79	\$3.12	\$7.90
Room #3 (Open Work Space)	8'	206	1.15	50	12	3	40	F	1,656	50	95.0%	1.6	359	\$12.12	\$8.91	\$21.04
Room #6 (Locked)																
Room #8 (Locked-Mechanical)																
Room #9 (Mechanical Room)		103	1		1	1	100	I	100	5	0.0%	0.0	2	\$0.00	\$0.05	\$0.05
DPCA Office Coordinator		206	1.15		5	3	40	F	690	50	95.0%	0.7	150	\$5.05	\$3.71	\$8.76
Room #11 (Open Office Area)	8'	206	1.15	65	10	3	40	F	1,380	50	95.0%	1.3	299	\$10.10	\$7.43	\$17.53
Room #11A (Files)	8'	206	1.15	45	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Room #12	8'	206	1.15	25	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Room #13 (Copy Room)	8'	228	1.15	20	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Room #14-15 (Office)	8'	206	1.15	40	10	4	40	F	1,840	50	95.0%	1.7	399	\$13.47	\$9.90	\$23.37
Womens Room		101	1		2	1	100	I	200	30	50.0%	0.1	26	\$0.77	\$0.65	\$1.42
Mens Room		101	1		2	1	100	I	200	30	50.0%	0.1	26	\$0.77	\$0.65	\$1.42
DPCA Office Corridor (Exit Sign)		n/a	1		1	1	25	I	25	168	95.0%	0.0	18	\$0.18	\$0.45	\$0.64
Storage Room		206	1.15	30	8	4	40	F	1,472	10	0.0%	0.0	64	\$0.00	\$1.58	\$1.58
Open Office Area Room #16	8'	206	1.15	35	32	3	40	F	4,416	50	95.0%	4.2	958	\$32.33	\$23.77	\$56.09
Room #16 (File Down Lighting)		n/a	1.15		6	1	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Room #16 (File Down Lighting)		n/a	1.15		3	1	15	F	52	50	95.0%	0.0	11	\$0.38	\$0.28	\$0.66
Room #16 (Rear Office)	8'	206	1.15	50	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Opt. Ofc. Area Rm#16(Exit Sign)		n/a	1		1	1	25	I	25	168	95.0%	0.0	18	\$0.18	\$0.45	\$0.64
Stairwell #1 Dispensary Side		114	1		3	2	60	I	360	168	95.0%	0.3	262	\$2.64	\$6.51	\$9.15
Stairwell #1 Dispensary Side		215	1.15		1	2	40	F	92	168	95.0%	0.1	67	\$0.67	\$1.66	\$2.34
Stairwell #2 Police Area		114	1		1	2	60	I	120	168	95.0%	0.1	87	\$0.88	\$2.17	\$3.05
Stairwell #2 Police Area		215	1.15		1	2	40	F	92	168	95.0%	0.1	67	\$0.67	\$1.66	\$2.34
Stairwell #2 Police Area		206	1.15		2	2	40	F	184	168	95.0%	0.2	134	\$1.35	\$3.33	\$4.67
Stairwell #3 Legal Office		114	1		2	2	60	I	240	168	95.0%	0.2	175	\$1.76	\$4.34	\$6.10
Stairwell #3 Legal Office		206	1.15		2	4	40	F	368	168	95.0%	0.3	268	\$2.69	\$6.65	\$9.35
Stairwell #4 Command Area		104	1		1	2	100	I	200	168	95.0%	0.2	146	\$1.46	\$3.62	\$5.08
Stairwell #4 Command Area		114	1		1	2	60	I	120	168	95.0%	0.1	87	\$0.88	\$2.17	\$3.05
			TOTALS						63,520			56	14,765	\$429	\$366	\$795

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR: FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

Lighting Model
Letterkenny Army Depot
Building 521
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Basement Floor																
Open Area		206	1.15		2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Open Area		215	1.15		3	2	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Storage Room		230	1.15		230	3	40	F	552	10	0.0%	0.0	24	\$0.00	\$0.59	\$0.59
Locker Room		206	1.15		2	4	40	F	368	10	0.0%	0.0	16	\$0.00	\$0.40	\$0.40
Furnance Room		230	1.15		1	3	40	F	138	5	0.0%	0.0	3	\$0.00	\$0.07	\$0.07
Weight Room		206	1.15		4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Pool Table Room		206	1.15		6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Stairs to First Floor		206	1.15		1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Stairs to First Wall Light		n/a	1.15		1	1	9	F	10	168	95.0%	0.0	8	\$0.08	\$0.19	\$0.26
First Floor																
General Office Area	9'	206	1.15	45	18	2	40	F	1,656	90	95.0%	1.6	647	\$12.12	\$16.04	\$28.16
General Office (Exit Sign)		604	1		1	1	15	I	15	168	95.0%	0.0	11	\$0.11	\$0.27	\$0.38
Chief Office	9'	206	1.15	65	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Research Area/Library	9'	206	1.15	40	2	3	40	F	276	90	95.0%	0.3	108	\$2.02	\$2.67	\$4.69
Plans Review Conference Room	9'	206	1.15	50	6	2	40	F	552	35	75.0%	0.4	84	\$3.19	\$2.08	\$5.27
Copier/Fax Machine Room	9'	206	1.15	45	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Storage Room	8'	206	1.15		2	4	40	F	368	10	0.0%	0.0	16	\$0.00	\$0.40	\$0.40
Bunkroom	8'	206	1.15	30	1	4	40	F	184	10	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
Bunkroom Toilet	8'	215	1.15		1	2	40	F	92	5	0.0%	0.0	2	\$0.00	\$0.05	\$0.05
Mens Room	8'	206	1.15		1	3	40	F	138	30	50.0%	0.1	18	\$0.53	\$0.45	\$0.98
Assistance Chief Office	8'	206	1.15	60	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Watch Room	8'	206	1.15		2	4	40	F	368	168	95.0%	0.3	268	\$2.69	\$6.65	\$9.35
Watch Room		n/a	1		5	1	20	I	100	168	95.0%	0.1	73	\$0.73	\$1.81	\$2.54
Radio Equipment Room	8'	206	1.15	80	2	4	40	F	368	168	95.0%	0.3	268	\$2.69	\$6.65	\$9.35
Union Office	8'	206	1.15	75	1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Union Office Wall Light		n/a	1.15		1	1	9	F	10	168	95.0%	0.0	8	\$0.08	\$0.19	\$0.26
Smokers Lounge	8'	206	1.15		1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Ladies Room	8'	206	1.15		1	3	40	F	138	30	50.0%	0.1	18	\$0.53	\$0.45	\$0.98
Kitchen Area	8'	206	1.15	90	2	4	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61
Kitchen Area Under Counter		n/a	1.15		2	1	20	F	46	30	50.0%	0.0	6	\$0.18	\$0.15	\$0.33
Dining Area	8'	206	1.15	110	4	4	40	F	736	30	50.0%	0.4	96	\$2.84	\$2.38	\$5.21
Corridor	8'	206	1.15		5	2	40	F	460	50	95.0%	0.4	100	\$3.37	\$2.48	\$5.84
Corridor (Exit Sign)		604	1		1	1	15	I	15	168	95.0%	0.0	11	\$0.11	\$0.27	\$0.38
Corridor Wall Light		n/a	1.15		1	1	9	F	10	168	95.0%	0.0	8	\$0.08	\$0.19	\$0.26
Stairs to Second Floor		215	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Stairs to Second Floor		206	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Stairs to Second Floor Wall Light		n/a	1.15		2	1	9	F	21	168	95.0%	0.0	15	\$0.15	\$0.37	\$0.53
Second Floor																
Bunkroom A		206	1.15		4	4	40	F	736	10	0.0%	0.0	32	\$0.00	\$0.79	\$0.79
Mens Shower		206	1.15		5	3	40	F	690	5	0.0%	0.0	15	\$0.00	\$0.37	\$0.37
Ladies Shower		206	1.15		5	3	40	F	690	5	0.0%	0.0	15	\$0.00	\$0.37	\$0.37
Day Room (under construction)																
Lt. Bunkroom A		206	1.15		1	4	40	F	184	10	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
Lt. Bunkroom A		115	1		1	1	60	I	60	10	0.0%	0.0	3	\$0.00	\$0.06	\$0.06
Lt. Bunkroom B		206	1.15		1	4	40	F	184	10	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
Corridor		206	1.15		1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34

**Lighting Model
Letterkenny Army Depot
Building 521
Table Designation**

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

07-Apr-95

Lighting Model
Letterkenny Army Depot
Building 522
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (fC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
First Floor																
Main Entrance	9'5"	206	1.15		1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Lobby	9'5"	206	1.15	30	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Lobby		114	1		2	1	100	I	200	50	95.0%	0.2	43	\$1.46	\$1.08	\$2.54
Mens Room	10'	117	1		1	2	60	I	120	30	50.0%	0.1	16	\$0.46	\$0.39	\$0.85
Commanding Generals Office	9'5"	206	1.15	70	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Commanding General Conf. Rm.	9'5"	206	1.15	115	9	4	40	F	1,656	35	75.0%	1.2	252	\$9.57	\$6.24	\$15.81
Comm. Gen. Toilet Rm & Shower	9'5"	117	1		2	2	60	I	240	5	0.0%	0.0	5	\$0.00	\$0.13	\$0.13
Left Reception Area	9'5"	206	1.15	50	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Reception Area	9'5"	206	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Kitchen Area		117	1		1	2	60	I	120	50	95.0%	0.1	26	\$0.88	\$0.65	\$1.52
Rear Office #1 (not occupied)	9'5"	206	1.15	50	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Rear Office #2 (not occupied)	9'5"	206	1.15	55	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Rear Office #2 (not occupied)		206	1.15		2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Right Reception Area	9'5"	206	1.15	30	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Womens Room		101	1		1	1	100	I	100	30	50.0%	0.1	13	\$0.39	\$0.32	\$0.71
Storage Room	9'5"	206	1.15		2	4	40	F	368	10	0.0%	0.0	0	\$0.00	\$0.40	\$0.40
Office of the Chief of Staff Recp.	9'5"	206	1.15	50	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Office of the Chief of Staff	9'5"	206	1.15	50	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Secretary's Ofc. to the General	9'5"	206	1.15	70	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Secretary's Ofc. to the General	9'5"	206	1.15	50	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Second Floor																
Corridor	9'5"	206	1.15		8	2	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Conference Room	9'5"	206	1.15	60	10	4	40	F	1,840	35	75.0%	1.4	279	\$10.63	\$6.93	\$17.57
Conference Projection Room	9'5"	206	1.15		2	2	40	F	184	10	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
Corridor to Projection Room	9'5"	206	1.15		1	2	40	F	92	10	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
Kitchen Sink	9'5"	n/a	1.15		1	1	15	F	17	10	0.0%	0.0	1	\$0.00	\$0.02	\$0.02
Mens Room		101	1		1	1	60	I	60	30	50.0%	0.0	8	\$0.23	\$0.19	\$0.42
Mens Room		114	1		1	1	60	I	60	30	50.0%	0.0	8	\$0.23	\$0.19	\$0.42
Protocol Office	9'5"	206	1.15	45	5	2	40	F	460	50	95.0%	0.4	100	\$3.37	\$2.48	\$5.84
Liaison Office		206	1.15		1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Inspector Gen. Admin. Office	9'5"	206	1.15	45	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Inspector General Reception	9'5"	206	1.15	35	3	2	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Inspector General Office	9'5"	206	1.15	30	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Copy Room	9'5"	228	1.15		2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Womens Room		114	1		1	1	60	I	60	30	50.0%	0.0	8	\$0.23	\$0.19	\$0.42
Womens Room		117	1		1	2	60	I	120	30	50.0%	0.1	16	\$0.46	\$0.39	\$0.85
Exterior		106	1		1	1	45	I	45	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		n/a	1		1	1	75	I	75	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		506	1.15		1	1	400	MV	460	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
TOTALS									15,569			12	2,818	\$96	\$70	\$166
INCREMENTAL DEMAND COST \$/KW =			\$7.706													
INCREMENTAL USAGE COST \$/KWH =			\$0.0248													

NOTE #2: LAMP TYPE: F = FLUORESCENT I = INCANDESCENT
HPS = HIGH PRESSURE SODIUM MV = MERCURY VAPOR

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG522.WK4

07-Apr-95

Lighting Model
Letterkenny Army Depot
Building 523
Table Designation

Room Area or Description	Ceiling Height Ft.	Luminaire Type Army #	Luminaire Factor	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Administration</i>																
Descom Office A	8'2"	206	1.15	90	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Descom Office B	8'2"	206	1.15	70	6	2	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Descom Office C	8'2"	206	1.15	50	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Mens Room		114	1		1	1	60	I	60	30	50.0%	0.0	8	\$0.23	\$0.19	\$0.42
Library	8'2"	206	1.15	35	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Janitors Closet		101	1		1	1	200	I	200	5	0.0%	0.0	4	\$0.00	\$0.11	\$0.11
Kitchen	8'2"	206	1.15	40	1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
<i>Kelly Office (Locked)</i>																
Womens Room		101	1		1	1	200	I	200	30	50.0%	0.1	26	\$0.77	\$0.65	\$1.42
Conference Room A	8'2"	206	1.15	110	8	3	40	F	1,104	35	75.0%	0.8	168	\$6.38	\$4.16	\$10.54
Conference Room B	8'2"	206	1.15	70	2	4	40	F	368	35	75.0%	0.3	56	\$2.13	\$1.39	\$3.51
Horn Office	8'2"	206	1.15	35	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Myers Office	8'2"	206	1.15	35	4	3	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Barnes Office	8'2"	206	1.15	50	6	3	40	F	828	50	95.0%	0.8	180	\$6.06	\$4.46	\$10.52
Sheffield Office	8'2"	206	1.15	60	4	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Grayson Office	8'2"	206	1.15	50	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Helsel Office	8'2"	206	1.15	50	4	4	40	F	736	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Cornelius Office	8'2"	206	1.15	50	4	2	40	F	368	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Hoover Office	8'2"	206	1.15	45	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Gerhart Office	8'2"	206	1.15	50	6	2	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Creamer Office	8'2"	230	1.15		11	2	40	F	1,012	50	95.0%	1.0	220	\$7.41	\$5.45	\$12.85
<i>Exterior</i>																
Exterior		123	1		1	1	60	I	60	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		106	1		1	1	75	I	75	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		118	1		1	1	60	I	60	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		112	1		1	1	75	I	75	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
TOTALS									10,160			9	1,989	\$68	\$49	\$117

INCREMENTAL DEMAND COST \$/KW = \$7.706
 INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR: FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
 AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
 F = FLUORESCENT
 HPS = HIGH PRESSURE SODIUM
 I = INCANDESCENT
 MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG523.WK4

**Lighting Model
Letterkenny Army Depot
Building 524
Table Designation**

Room Area or Description	Ceiling Height Ft.	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Conference Center</i>																
Entrance Lobby	9'9"	206	1.15	25	7	2	40	F	644	50	95.0%	0.6	140	\$4.71	\$3.47	\$8.18
Special Video Conf. Room.			1.15		36	2	40	F	3,312	35	75.0%	2.5	503	\$19.14	\$12.48	\$31.62
Left Side Conference Room		215	1.15		1	2	40	F	92	10	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
Mens Restroom		206	1.15		1	2	40	F	92	30	50.0%	0.0	12	\$0.35	\$0.30	\$0.65
Womens Restroom		206	1.15		1	2	40	F	92	30	50.0%	0.0	12	\$0.35	\$0.30	\$0.65
Right Side Conference Room		215	1.15		2	2	40	F	184	10	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
Back Side Conference Room		215	1.15		1	2	40	F	92	10	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
<i>Exterior</i>																
Exterior		126	1		1	1	60	I	60	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
TOTALS									4,568			3	683	\$25	\$17	\$41

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG524.WK4

Lighting Model
Letterkenny Army Depot
Building 529
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
First Floor																
Bar Table Area	8'3"	206	1.15	35	19	4	40	F	3,496	60	95.0%	3.3	910	\$25.59	\$22.58	\$48.17
Bar Table Area		112	1		16	1	75	I	1,200	60	95.0%	1.1	312	\$8.78	\$7.75	\$16.53
Bar Table Area Pool Table Lgts.		n/a	1		2	3	60	I	360	60	95.0%	0.3	94	\$2.64	\$2.32	\$4.96
A/C Room					1	1	100	I	100	5	0.0%	0.0	2	\$0.00	\$0.05	\$0.05
Bar Counter	8'3"	101	1		1	4	40	F	368	60	95.0%	0.3	96	\$2.69	\$2.38	\$5.07
Food Counter	8'3"	206	1.15		4	4	40	F	736	60	95.0%	0.7	192	\$5.39	\$4.75	\$10.14
Bar (Exit Sign)		602	1.15		1	2	7	F	16	168	95.0%	0.0	12	\$0.12	\$0.29	\$0.41
Restroom Lobby		215	1.15		2	2	40	F	184	60	95.0%	0.2	48	\$1.35	\$1.19	\$2.54
Restroom		206	1.15		1	2	40	F	92	60	95.0%	0.1	24	\$0.67	\$0.59	\$1.27
Womens Room		206	1.15		1	2	40	F	92	60	95.0%	0.1	24	\$0.67	\$0.59	\$1.27
Kitchen (Exit Sign)		604	1		1	2	7	F	14	168	95.0%	0.0	10	\$0.10	\$0.25	\$0.36
Kitchen (Exit Sign)		602	1		2	2	7	F	28	168	95.0%	0.0	20	\$0.20	\$0.51	\$0.71
Kitchen Dish Room	8'	206	1.15	70	6	3	40	F	828	60	95.0%	0.8	216	\$6.06	\$5.35	\$11.41
Dumb Waiter Room	8'	206	1.15		1	4	40	F	184	60	95.0%	0.2	48	\$1.35	\$1.19	\$2.54
Supply Closet	8'	215	1.15		1	2	40	F	92	10	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
Dumb Waiter (Exit Sign)		602	1		1	2	7	I	14	168	95.0%	0.0	10	\$0.10	\$0.25	\$0.36
Supply Closet (Exit Sign)		604	1		1	2	7	I	14	168	95.0%	0.0	10	\$0.10	\$0.25	\$0.36
Freezer Store Room	7'3"	230	1.15	50	2	2	40	F	184	10	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
Freezer Store Room (Exit Sign)		604	1		1	2	7	I	14	168	95.0%	0.0	10	\$0.10	\$0.25	\$0.36
Golf Shop Lunch Room	8'	206	1.15	20	6	2	40	F	552	60	95.0%	0.5	144	\$6.06	\$5.35	\$11.41
Golf Equipment Shop	8'	206	1.15	30	9	2	40	F	828	60	95.0%	0.8	216	\$6.06	\$5.35	\$11.41
Golf Equipment Shop Office	8'	206	1.15		1	2	40	F	92	60	95.0%	0.1	24	\$0.67	\$0.59	\$1.27
Golf Equipment Shop Office	8'	206	1.15		1	4	40	F	184	60	95.0%	0.2	48	\$1.35	\$1.19	\$2.54
Golf Eqpt. Shop Entrance Lobby	8'	206	1.15		2	2	40	F	184	60	95.0%	0.2	48	\$1.35	\$1.19	\$2.54
Mens Room	8'	215	1.15		2	2	40	F	184	30	50.0%	0.1	24	\$0.71	\$0.59	\$1.30
Womens Room	8'	215	1.15		2	2	40	F	184	30	50.0%	0.1	24	\$0.71	\$0.59	\$1.30
Second Floor																
Stairwell		120														
Gallery	9'8"	110	1		1	1	60	I	60	60	95.0%	0.1	16	\$0.44	\$0.39	\$0.83
Corridor to Mens Room	7'2"	240	1.15		8	1	75	I	600	60	95.0%	0.6	156	\$4.39	\$3.87	\$8.27
Mens Room		206	1.15		2	4	40	F	368	60	95.0%	0.3	96	\$2.69	\$2.38	\$5.07
Food Prep Room	7'9"	206	1.15	130	5	4	40	F	920	60	95.0%	0.9	240	\$6.74	\$5.94	\$12.68
Womens Restroom Mirror		n/a	1		9	1	40	I	360	60	95.0%	0.3	94	\$2.64	\$2.32	\$4.96
Womens Restroom		206	1.15		4	2	40	F	368	60	95.0%	0.3	96	\$2.69	\$2.38	\$5.07
Handicap Restroom		206	1.15		1	4	40	F	184	60	95.0%	0.2	48	\$1.35	\$1.19	\$2.54
Linen Closet		215	1.15		1	2	40	F	92	10	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
Coat Room		206	1.15		2	4	40	F	368	10	0.0%	0.0	16	\$0.00	\$0.40	\$0.40
Second Floor Entrance Lobby		206	1.15		2	4	40	F	368	60	95.0%	0.3	96	\$2.69	\$2.38	\$5.07
Second Flr. Entrance (Exit Sign)		602	1		1	2	7	I	14	168	95.0%	0.0	10	\$0.10	\$0.25	\$0.36
Dining Room	9'8"	206	1.15	50	14	4	40	F	2,576	60	95.0%	2.4	671	\$18.86	\$16.64	\$35.49
Dining Room		116	1		67	1	100	I	6,700	60	95.0%	6.4	1,745	\$49.05	\$43.27	\$92.32
Bar Dining Area	8'8"	116	1		11	1	100	I	1,100	60	95.0%	1.0	286	\$8.05	\$7.10	\$15.16
Over Bar Counter	8'8"	116	1		12	1	100	I	1,200	60	95.0%	1.1	312	\$8.78	\$7.75	\$16.53
Bar Dining Area	8'8"	110	1		3	1	75	I	225	60	95.0%	0.2	59	\$1.65	\$1.45	\$3.10
Bar Dining Area (Exit Sign)		602	1		1	2	7	I	14	168	95.0%	0.0	10	\$0.10	\$0.25	\$0.36
Dining Room (Exit Sign)		602	1		1	2	7	I	14	168	95.0%	0.0	10	\$0.10	\$0.25	\$0.36

**Lighting Model
Letterkenny Army Depot
Building 529
Table Designation**

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #2: LAMP TYPE:

G:\PROJECTS\4130.01\SS\DATA\BILDG529.WK4

Lighting Model
Letterkenny Army Depot
Building 530
Table Designation

Room Area or Description	Ceiling Height Ft.	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Cable TV for Housing</i>																
Open Office Area	12'2"	230	1.15	30	16	2	40	F	1,472	50	95.0%	1.4	319	\$10.78	\$7.92	\$18.70
<i>Exterior</i>																
Exterior (None)																
TOTALS									1,472			1	319	\$11	\$8	\$19

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG530.WK4

Lighting Model
Letterkenny Army Depot
Building 536
Table Designation

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SS\DATA\BLDG536.WK4

Lighting Model
Letterkenny Army Depot
Building 581
Table Designation

Room Area or Description	Ceiling Height Ft.	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
First Floor																
Main Entrance Lobby		121	1	1	1	1	60	I	60	50	95.0%	0.1	13	\$0.44	\$0.32	\$0.76
Conference Room	78"	228	1.15	30	6	4	40	F	1,104	35	75.0%	0.8	168	\$5.38	\$4.16	\$10.54
Dir. Resource Mgrs. Office	78"	228	1.15	65	6	4	40	F	1,104	50	75.0%	1.0	240	\$8.08	\$5.94	\$14.02
Dir. Resource Mgrs. Resp. Area	78"	228	1.15		5	4	40	F	920	50	95.0%	0.9	200	\$6.74	\$4.95	\$11.69
Telephone Closet	78"	228	1.15		3	4	40	F	552	5	0.0%	0.0	12	\$0.00	\$0.30	\$0.30
SIDS Office	73"	206	1.15	110	8	4	40	F	1,472	50	95.0%	1.4	319	\$10.78	\$7.92	\$18.70
Closet A		101	1		1	1	100	I	100	10	0.0%	0.0	4	\$0.00	\$0.11	\$0.11
Closet B		101	1		1	1	100	I	100	10	0.0%	0.0	4	\$0.00	\$0.11	\$0.11
LEAD Valve Engin. Area	73"	228	1.15	80	8	4	40	F	1,472	50	95.0%	1.4	319	\$10.78	\$7.92	\$18.70
Corridor	73"	228	1.15		5	2	40	F	460	50	95.0%	0.4	100	\$3.37	\$2.48	\$5.84
Womens Room		101	1		1	1	60	I	60	30	50.0%	0.0	8	\$0.23	\$0.19	\$0.42
Womens Room		228	1.15		2	4	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61
Janitors Closet		101	1		1	1	100	I	100	5	0.0%	0.0	2	\$0.00	\$0.05	\$0.05
Mens Room		101	1		1	1	60	I	60	30	50.0%	0.0	8	\$0.23	\$0.19	\$0.42
Mens Room		228	1.15		2	4	40	F	368	30	50.0%	0.2	48	\$1.42	\$1.19	\$2.61
Mens Room Sink Lighting		220	1.15		1	1	40	F	46	30	50.0%	0.0	6	\$0.18	\$0.15	\$0.33
Breakroom	710"	228	1.15	30	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
LEAD Valve Engin. Office	73"	228	1.15	50	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Copy Room	710"	228	1.15	30	1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Copy Room		228	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Open Office Area	74"	228	1.15	30	16	4	40	F	2,944	50	95.0%	2.8	639	\$21.55	\$15.84	\$37.40
Second Floor																
Stairway to Second Floor		n/a														
Room #1 Office	710"	228	1.15	40	2	3	60	I	360	50	95.0%	0.3	78	\$2.64	\$1.94	\$4.57
Room #1 Conference Area	710"	228	1.15	30	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Room #4 Conference Room	710"	228	1.15	40	2	4	40	F	368	35	75.0%	0.3	56	\$2.13	\$1.39	\$3.51
Room #3 Office	710"	228	1.15	80	3	4	40	F	552	35	75.0%	0.4	84	\$3.19	\$2.08	\$5.27
Room #6 Storage Closet	710"	228	1.15	30	2	4	40	F	368	10	0.0%	0.0	16	\$0.00	\$0.40	\$0.40
Room #5 & #7 Office	710"	101	1		1	1	75	I	75	10	0.0%	0.0	3	\$0.00	\$0.08	\$0.08
Room #9 Office	710"	228	1.15	30	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Room #11 Office	710"	228	1.15	20	1	4	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Room #12 Office	710"	228	1.15	45	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Room #14 Office	710"	228	1.15	40	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Room #14A Office	710"	228	1.15	30	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Room #15 Office	710"	228	1.15	30	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Room #17 Conference Room	710"	228	1.15	40	3	4	40	F	552	35	75.0%	0.4	84	\$3.19	\$2.08	\$5.27
Room #20	710"	228	1.15	45	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Room #20A	710"	228	1.15	45	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Room #19 Smoke Room	710"	228	1.15	50	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Room #8 & #10	74"	228	1.15	30	5	4	40	F	920	50	95.0%	0.9	200	\$6.74	\$4.95	\$11.69
Corridor		228	1.15		11	4	40	F	2,024	50	95.0%	1.9	439	\$14.82	\$10.89	\$25.71

Lighting Model
Letterkeeny Army Depot
Building 581
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Exterior																
Exterior (Entrance)		115	1		1	1	75	I	75	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		101	1		1	1	200	I	200	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior (Out of Service)		106	1		1	1	60	I	60	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		106	1		2	1	75	I	150	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
			TOTALS						23,894			20	4,595	\$155	\$114	\$269

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #:
U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG581.WK4

Lighting Model
Letterkenny Army Depot
Building 616
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Police Building</i>																
Police Conference Room	7'10"	230	1.15	10	4	2	40	F	368	168	95.0%	0.3	268	\$2.69	\$6.65	\$9.35
Police Conference Room	7'10"	228	1.15		4	4	40	F	736	168	95.0%	0.7	537	\$5.39	\$13.31	\$18.70
			TOTALS						1,104			1	805	\$8	\$20	\$28

INCREMENTAL DEMAND COST \$/KW = \$7.706
 INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
 FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
 AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
 F = FLUORESCENT
 HPS = HIGH PRESSURE SODIUM
 I = INCANDESCENT
 MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #:
 U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
 STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSADATA\BLDG616.WK4

Lighting Model
Letterkenny Army Depot
Building 618
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
First Floor																
Hunting & Fishing Office	75"	206	1.15	65	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
Room #7	75"	206	1.15		2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Water Office	75"	206	1.15	100	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Keefer Office	75"	206	1.15	95	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Merritt Office	75"	206	1.15	90	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Room #4 (Locked)																
Middle Exit Door		115	1		1	1	60	I	60	50	95.0%	0.1	13	\$0.44	\$0.32	\$0.76
Handicap Restroom	75"	206	1.15		1	3	40	F	138	30	50.0%	0.1	18	\$0.53	\$0.45	\$0.98
Mens Room	75"	206	1.15		2	3	40	F	276	30	50.0%	0.1	36	\$1.06	\$0.89	\$1.95
Hoke Office	75"	206	1.15	80	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Coffee Mess	75"	206	1.15	90	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Copy Room	75"	206	1.15	95	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Room #11 Office	75"	206	1.15	70	3	3	40	F	414	50	95.0%	0.4	90	\$3.03	\$2.23	\$5.26
GIS Room (Locked)																
Corridor	710"	206	1.15		8	2	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Corridor Exit		602	1		2	2	15	I	60	168	95.0%	0.1	44	\$0.44	\$1.08	\$1.52
Second Floor																
Warnock Office	75"	206	1.15	90	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Quinn Office	75"	206	1.15	90	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Conference Room	75"	206	1.15		3	3	40	F	414	35	75.0%	0.3	63	\$2.39	\$1.56	\$3.95
Espein Office	75"	206	1.15	90	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Williams Office	75"	206	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Gieseking Office	75"	206	1.15	40	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Haz Waste Conference Room	75"	206	1.15	70	5	3	40	F	690	35	75.0%	0.5	105	\$3.99	\$2.60	\$6.59
Yocum Office	75"	206	1.15	70	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Room #20 (Locked)																
Corridor	75"	206	1.15		8	2	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Exit Signs		602	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Yeager Office	75"	206	1.15	85	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Cassner	75"	206	1.15	40	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Stairwell to Second Floor		206	1.15		1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
Womens Room		206	1.15		2	3	40	F	276	30	50.0%	0.1	36	\$1.06	\$0.89	\$1.95
Exterior																
Exterior		106	1		6	1	200	I	1,200	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
TOTALS										9,446		7	1,704	\$56	\$42	\$99
INCREMENTAL DEMAND COST \$/KW = \$7.706																
INCREMENTAL USAGE COST \$/KWH = \$0.0248																

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

Lighting Model
Interkenny Army Depot
Building 619
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Dining Area																
Storage Room	9'5"	206	1.15	60	3	3	40	F	414	10	0.0%	0.0	18	\$0.00	\$0.45	\$0.45
Rear Dining Area	10'	206	1.15	55	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Rear Dining Area	10'	206	1.15		1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
Serving Area	9'6"	206	1.15	45	7	2	40	F	644	50	95.0%	0.6	140	\$4.71	\$3.47	\$8.18
Open Dining Area	10'	206	1.15	35	27	3	40	F	3,726	50	95.0%	3.5	809	\$27.28	\$20.05	\$47.33
Mens Room		206	1.15		2	3	40	F	276	30	50.0%	0.1	36	\$1.06	\$0.89	\$1.95
Mens Room Sink		218	1.15		1	1	40	F	46	30	50.0%	0.0	6	\$0.18	\$0.15	\$0.33
Womens Room		206	1.15		2	3	40	F	276	30	50.0%	0.1	36	\$1.06	\$0.89	\$1.95
Womens Room Sink		218	1.15		1	1	40	F	46	30	50.0%	0.0	6	\$0.18	\$0.15	\$0.33
Staff Office	9'6"	206	1.15	50	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Exit Sign		602	1		2	2	15	I	60	168	95.0%	0.1	44	\$0.44	\$1.08	\$1.52
Entrance Lobby		206	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Boiler Room		103	1		2	1	300	I	600	5	0.0%	0.0	13	\$0.00	\$0.32	\$0.32
Exterior																
Exterior		106	1		1	1	67	I	67	80	0.0%	0.0	23	\$0.00	\$0.58	\$0.58
Exterior		502	1.15		2	1	150	HPS	345	80	0.0%	0.0	120	\$0.00	\$2.97	\$2.97
Exterior		101	1		1	1	60	I	60	80	0.0%	0.0	21	\$0.00	\$0.52	\$0.52

\$7.706
\$0.0248

FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG619.WK4

**Lighting Model
Letterkenny Army Depot
Building 628
Table Designation**

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SS\DATA\BLDG628.WK4

**Lighting Model
Letterkenny Army Depot
Building 637
Table Designation**

INCREMENTAL DEMAND COST \$/KW =	\$7.706	
INCREMENTAL USAGE COST \$/KWH =	\$0.0248	
NOTE #1: LUMINAIRE FACTOR:	<p>FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.</p>	
NOTE #2: LAMP TYPE:	<p>F = FLUORESCENT HSP = HIGH PRESSURE SODIUM I = INCANDESCENT MV = MERCURY VAPOR</p>	
NOTE #3: LUMINAIRE TYPE ARMY #:	<p>U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.</p>	

G:\PROJECTS\4130.01\SSDATA\BLDG637.WK4

Lighting Model
Letterkenny Army Depot
Building 639
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Physical Fitness Center</i>																
Gym Entrance	8'1"	230	1.15		1	2	40	F	92	168	95.0%	0.1	67	\$0.67	\$1.66	\$2.34
Gym Entrance	8'1"	220	1.15		1	1	40	F	46	168	95.0%	0.0	34	\$0.34	\$0.83	\$1.17
Gym Office	8'1"	228	1.15	70	2	4	40	F	368	168	95.0%	0.3	268	\$2.69	\$6.65	\$9.35
LEAD Store Room	8'1"	101	1		2	1	75	I	150	10	0.0%	0.0	7	\$0.00	\$0.16	\$0.16
LEAD Store Room	8'1"	230	1.15	40	1	2	40	F	92	10	0.0%	0.0	4	\$0.00	\$0.10	\$0.10
Basketball Court	17'	103	1	10	24	1	300	I	7,200	168	95.0%	6.8	5,250	\$52.71	\$130.19	\$182.90
Exit Sign		602	1		1	1	15	I	15	168	95.0%	0.0	11	\$0.11	\$0.27	\$0.38
Corridor to Restroom	8'1"	206	1.15		2	2	40	F	184	168	95.0%	0.2	134	\$1.35	\$3.33	\$4.67
Corridor to Mens Locker Room	8'1"	206	1.15		1	2	40	F	92	168	95.0%	0.1	67	\$0.67	\$1.66	\$2.34
Mens Locker Room	8'1"	206	1.15		4	4	40	F	736	168	95.0%	0.7	537	\$5.39	\$13.31	\$18.70
Mens Shower Room	8'1"	215	1.15		4	2	40	F	368	168	95.0%	0.3	268	\$2.69	\$6.65	\$9.35
Mens Rear Locker Room	8'1"	206	1.15		1	4	40	F	184	168	95.0%	0.2	134	\$1.35	\$3.33	\$4.67
Corridor to Womens Locker Rm.	8'1"	206	1.15		1	2	40	F	92	168	95.0%	0.1	67	\$0.67	\$1.66	\$2.34
Womens Locker Room	8'1"	206	1.15		4	4	40	F	736	168	95.0%	0.7	537	\$5.39	\$13.31	\$18.70
Womens Shower Room	8'1"	215	1.15		4	2	40	F	368	168	95.0%	0.3	268	\$2.69	\$6.65	\$9.35
Womens Rear Locker Room	8'1"	206	1.15		1	4	40	F	184	168	95.0%	0.2	134	\$1.35	\$3.33	\$4.67
Corridor to Sauna	8'1"	206	1.15		3	2	40	F	276	168	95.0%	0.3	201	\$2.02	\$4.99	\$7.01
Rear Entrance Lobby		216	1.15		1	2	40	F	92	168	95.0%	0.1	67	\$0.67	\$1.66	\$2.34
Weight Room Restroom		206	1.15		2	2	40	F	184	101	95.0%	0.2	81	\$1.35	\$3.00	\$3.35
Weight Room		230	1.15		14	3	40	F	1,932	168	95.0%	1.8	1,409	\$14.14	\$34.93	\$49.08
Weight Room (note #1)		230	1.15		5	2	30	F	300	168	95.0%	0.3	219	\$2.20	\$5.42	\$7.62
Weight Room Nautilus (note #4)		206	1		12	2	30	F	720	168	95.0%	0.7	525	\$5.27	\$13.02	\$18.29
Weight Room Abandoned Ofc.		206	1.15		2	2	40	F	184	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Raquetball Court	20'	206	1.15	70	12	6	40	F	3,312	84	95.0%	3.1	1,207	\$24.25	\$29.94	\$54.19
Libec. Closet in Basketball Area		101	1		2	1	100	I	200	10	0.0%	0.0	9	\$0.00	\$0.22	\$0.22
Upstairs Store Room		230	1.15		2	3	40	F	276	10	0.0%	0.0	12	\$0.00	\$0.30	\$0.30
<i>Exterior</i>																
Exterior		104	1		3	1	75	I	225	80	0.0%	0.0	78	\$0.00	\$1.94	\$1.94
Exterior		106	1		4	1	75	I	300	80	0.0%	0.0	104	\$0.00	\$2.58	\$2.58
Exterior		502	1.15		2	1	150	HPS	345	80	0.0%	0.0	120	\$0.00	\$2.97	\$2.97
TOTALS										19,253			17	11,818	\$293	\$421

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:

FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #4: ELECTRONIC BALLAST:

BASED ON MANUFACTURER DATA, THE
LAMP/BALLAST POWER INPUT FOR TWO
F32T8 LAMPS WITH ELECTRONIC BALLAST
EQUALS APPROXIMATELY 60 WATTS.

NOTE #2: LAMP TYPE:

F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #:

U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG639.WK4

Lighting Model
Letterkenny Army Depot
Building 640
Table Designation

	Room Area or Description	Ceiling Height Ft.	Luminaire Type Arm#	Luminaire Factor I	Light Levels (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
	<i>Camper Check-In</i>																
	Main Entrance Area	8'	206	1.15	40	2	4	40	F	368	20	50.0%	0.2	32	\$1.42	\$0.79	\$2.21
	Office #1	8'	206	1.15	95	1	4	40	F	184	20	50.0%	0.1	16	\$0.71	\$0.40	\$1.11
	Office #2	8'	206	1.15	95	1	4	40	F	184	20	50.0%	0.1	16	\$0.71	\$0.40	\$1.11
	Mens Room	8'	206	1.15		2	4	40	F	368	20	50.0%	0.2	32	\$1.42	\$0.79	\$2.21
	Womens Room	8'	206	1.15		2	4	40	F	368	20	50.0%	0.2	32	\$1.42	\$0.79	\$2.21
	Laundry Room	8'	206	1.15	80	1	4	40	F	184	20	50.0%	0.1	16	\$0.71	\$0.40	\$1.11
	TOTALS									1,656			1	144	\$6	\$4	\$10

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HP'S = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\TABLDG640.WK4

Lighting Model
Letterkenny Army Depot
Building 645
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type	Luminaire Factor I	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$	
Day Care	8'	206	1.15		1	2	40	F	92	90	95.0%	0.1	36	\$0.67	\$0.89	\$1.56	
		602	1		2	2	7	I	28	168	95.0%	0.0	20	\$0.20	\$0.51	\$0.71	
	8'	206	1.15	40	16	2	40	F	1,472	90	95.0%	1.4	575	\$10.78	\$14.26	\$25.04	
			602	1		3	2	15	I	90	168	95.0%	0.1	66	\$0.66	\$1.63	\$2.29
	8'	206	1.15		1	2	40	F	92	54	95.0%	0.1	22	\$0.67	\$0.53	\$1.21	
		206	1.15		1	2	40	F	92	54	95.0%	0.1	22	\$0.67	\$0.53	\$1.21	
	8'	206	1.15		1	2	40	F	92	90	95.0%	0.1	36	\$0.67	\$0.89	\$1.56	
		206	1.15		2	2	40	F	184	54	95.0%	0.2	43	\$1.35	\$1.07	\$2.42	
	8'	206	1.15		4	2	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26	
		206	1.15		1	2	40	F	92	54	95.0%	0.1	22	\$0.67	\$0.53	\$1.21	
	8'	206	1.15		3	2	40	F	276	90	95.0%	0.3	108	\$2.02	\$2.67	\$4.69	
Exterior																	
Exterior		123	1		4	1	100	I	400	80	0.0%	0.0	139	\$0.00	\$3.44	\$3.44	
Exterior		502	1.15		1	1	150	HPS	173	80	0.0%	0.0	60	\$0.00	\$1.49	\$1.49	

\$7.706
\$0.0248

FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

F = FLUORESCENT

HPS = HIGH PRESSURE SODIUM
I I = INCANDESCENT
MV = MERCURY VAPOR

U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SS\DATA\BLDG645.WK4

Lighting Model
Letterkenny Army Depot
Building 646
Table Designation

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #2: LAMP TYPE:

F = FLUORESCENT
HSP = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SSDATA\BLDG646.WK4

Lighting Model
Letterkenny Army Depot
Building 663
Table Designation

Room Area or Description	Ceiling Height Ft.	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (Ft.C)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$	
<i>Administration & Trades</i>																	
Main Entrance Lobby		206	1.15	4	4	4	40	F	736	90	95.0%	0.7	287	\$5.39	\$7.13	\$12.52	
Open Office Area	94"	206	1.15	35	47	3	40	F	6,486	90	95.0%	6.2	2,533	\$47.48	\$62.83	\$110.31	
Office	92"	206	1.15	60	2	3	40	F	276	90	95.0%	0.3	108	\$2.02	\$2.67	\$4.69	
Office	94"	206	1.15	40	3	3	40	F	414	90	95.0%	0.4	162	\$3.03	\$4.01	\$7.04	
Director of Public Works	94"	206	1.15	60	3	2	40	F	276	90	95.0%	0.3	108	\$2.02	\$2.67	\$4.69	
Director of Public Works	94"	206	1.15	40	1	4	40	F	184	90	95.0%	0.2	72	\$1.35	\$1.78	\$3.13	
Conference Room	94"	206	1.15	40	7	3	40	F	966	63	95.0%	0.9	264	\$7.07	\$6.55	\$13.62	
Business Managers Office	94"	206	1.15	40	206	3	40	F	43	414	90	95.0%	0.4	162	\$3.03	\$4.01	\$7.04
Mens Room	94"	206	1.15	40	2	3	40	F	276	54	95.0%	0.3	65	\$2.02	\$1.60	\$3.62	
Womens Room	94"	206	1.15	40	2	3	40	F	276	54	95.0%	0.3	65	\$2.02	\$1.60	\$3.62	
Computer Room	94"	230	1.15	40	1	2	40	F	92	90	95.0%	0.1	36	\$0.67	\$0.89	\$1.56	
Copy Room	94"	215	1.15	40	1	4	40	F	184	54	95.0%	0.2	43	\$1.35	\$1.07	\$2.42	
Print Room	94"	215	1.15	25	1	4	40	F	184	54	95.0%	0.2	43	\$1.35	\$1.07	\$2.42	
Corridor to Drawing Files Area	94"	206	1.15	40	2	3	40	F	276	90	95.0%	0.3	108	\$2.02	\$2.67	\$4.69	
Drawing Files Area	94"	114	1	1	3	1	300	I	900	54	95.0%	0.9	211	\$6.59	\$5.23	\$11.82	
Drawing Files Area	94"	228	1.15	40	8	4	40	F	1,472	54	95.0%	1.4	345	\$10.78	\$8.56	\$19.33	
Housing Office (Locked)																	
Engineering Office Area		206	1.15	30	8	4	40	F	1,472	90	95.0%	1.4	575	\$10.78	\$14.26	\$25.04	
Drafting Office Area		228	1.15	40	34	4	40	F	6,256	90	95.0%	5.9	2,444	\$45.80	\$60.60	\$106.40	
Receiving - Supply Area		230	1.15	25	14	2	40	F	1,288	90	95.0%	1.2	503	\$9.43	\$12.48	\$21.91	
Corridor to Snack Bar		206	1.15	40	1	2	40	F	92	90	95.0%	0.1	36	\$0.67	\$0.89	\$1.56	
Corridor to Snack Bar		220	1.15	40	3	1	75	F	259	90	95.0%	0.2	101	\$1.89	\$2.51	\$4.40	
Office	96"	206	1.15	40	4	2	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26	
Electrical Supply		114	1	1	9	1	300	I	2,700	90	95.0%	2.6	1,055	\$19.77	\$26.15	\$45.92	
Electrical Supply		230	1.15	40	2	3	40	F	276	90	95.0%	0.3	108	\$2.02	\$2.67	\$4.69	
Electrical Supply		220	1.15	40	7	1	75	F	604	90	95.0%	0.6	236	\$4.42	\$5.81	\$10.27	
Operations & Maint. Room	96"	206	1.15	45	12	4	40	F	2,208	90	95.0%	2.1	862	\$16.16	\$21.39	\$37.55	
Operations & Maint. Conf. Room	96"	206	1.15	45	2	3	40	F	276	63	95.0%	0.3	75	\$2.02	\$1.87	\$3.89	
Work Planning & Control Office	96"	206	1.15	45	12	4	40	F	2,208	90	95.0%	2.1	862	\$16.16	\$21.39	\$37.55	
Production Division Office #1	96"	206	1.15	55	1	2	40	F	92	90	95.0%	0.1	36	\$0.67	\$0.89	\$1.56	
Production Division Office #1	96"	206	1.15	30	2	2	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26	
Production Division Office #2	96"	206	1.15	30	2	2	40	F	184	90	95.0%	0.2	72	\$1.35	\$1.78	\$3.13	
Production Division Office #3	96"	206	1.15	50	4	2	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26	
Lunch Area	96"	206	1.15	50	8	4	40	F	1,472	90	95.0%	1.4	575	\$10.78	\$14.26	\$25.04	
Lower Level Womens Room		101	1	1	2	1	200	I	400	54	95.0%	0.4	94	\$2.93	\$2.32	\$5.25	
Lower Level Womens Room		106	1	1	1	1	100	I	100	54	95.0%	0.1	23	\$0.73	\$0.58	\$1.31	
Lower Level Mens Room		114	1	1	2	1	300	I	600	54	95.0%	0.6	141	\$4.39	\$3.49	\$7.88	
Lower Level Mens Room		106	1	1	1	1	100	I	100	54	95.0%	0.1	23	\$0.73	\$0.58	\$1.31	
Lower Level Mens Room		101	1	1	2	1	200	I	400	54	95.0%	0.4	94	\$2.93	\$2.32	\$5.25	
Snack Bar (Locked)																	
Corridor Outside Snack Bar		114	1	1	3	1	300	I	900	90	95.0%	0.9	352	\$6.59	\$8.72	\$15.31	
Heating & Plumbing Shop Area	96"	206	1.15	50	19	4	40	F	3,496	90	95.0%	3.3	1,366	\$25.59	\$33.87	\$59.46	
Heating Branch Office Front Rm		206	1.15	40	6	4	40	F	1,104	90	95.0%	1.0	431	\$8.08	\$10.69	\$18.78	
Heating Branch Office Back Rm		206	1.15	40	2	4	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26	
Heating Supply Cage		230	1.15	40	4	4	40	F	736	90	95.0%	0.7	287	\$5.39	\$7.13	\$12.52	
Welding Shop Area	96"	230	1.15	40	30	3	40	F	4,140	90	95.0%	3.9	1,617	\$30.31	\$40.10	\$70.41	
Welding Shop Area		230V	1.15	50	8	2	40	F	736	90	95.0%	0.7	287	\$5.39	\$7.13	\$12.52	
Computer Room	910"	206	1.15	50	5	3	40	F	552	90	95.0%	0.5	216	\$4.04	\$5.35	\$9.39	
Dispatch Corridor	910"	230	1.15	40	4	3	40	F	138	90	95.0%	0.1	54	\$1.01	\$1.34	\$2.35	

Lighting Model
Letterkenny Army Depot
Building 663
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Dispatch Office	9'10"	206	1.15	20	2	4	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26
Building & Structural Office	9'10"	206	1.15	20	4	2	40	F	368	90	95.0%	0.3	144	\$2.69	\$3.56	\$6.26
S. C. Office	10'1"	228	1.15	30	3	3	40	F	414	90	95.0%	0.4	162	\$3.03	\$4.01	\$7.04
Carpenter Shop Area		230V	1.15	30	28	3	40	F	3,864	90	95.0%	3.7	1,509	\$28.29	\$37.43	\$65.72
Carpenter Supply Room		230V	1.15		4	3	40	F	552	90	95.0%	0.5	216	\$4.04	\$5.35	\$9.39
Lunch Room	10'1"	230V	1.15	25	4	3	40	F	552	90	95.0%	0.5	216	\$4.04	\$5.35	\$9.39
Restroom		230	1.15		1	2	40	F	92	54	95.0%	0.1	22	\$0.67	\$0.53	\$1.21
TOTALS												51	20,122	\$394	\$499	\$893

INCREMENTAL DEMAND COST \$/KW = \$7.706
 INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
 FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
 AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
 F = FLUORESCENT
 HPS = HIGH PRESSURE SODIUM
 I = INCANDESCENT
 MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #:
 U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
 STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG663.WK4

Lighting Model
Letterkenny Army Depot
Building 664
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>First Floor</i>																
Entrance Lobby	7'7"	230	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Corridor to Restroom	7'7"	228	1.15		4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Issue Center Office	7'7"	206	1.15	90	9	4	40	F	1,656	50	95.0%	1.6	359	\$12.12	\$8.91	\$21.04
Empty Office	7'7"	206	1.15		4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Restroom		101	1		1	1	75	I	75	30	50.0%	0.0	0	\$0.29	\$0.24	\$0.53
Open Office Area	7'7"	206	1.15	80	9	4	40	F	1,656	50	95.0%	1.6	359	\$12.12	\$8.91	\$21.04
Locker Room		230	1.15		2	3	40	F	276	30	50.0%	0.1	36	\$1.06	\$0.89	\$1.95
Locker/Shower Room		230	1.15		5	2	40	F	460	30	50.0%	0.2	60	\$1.77	\$1.49	\$3.26
Locker/Shower Room		103	1		1	1	60	I	60	30	50.0%	0.0	8	\$0.23	\$0.19	\$0.42
Bed Area (Abandoned)		230	1.15		2	2	40	F	184	10	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
Open Office Area Closet A		206	1.15		2	2	40	F	184	10	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
Open Office Area Closet B		206	1.15		2	2	40	F	184	10	0.0%	0.0	8	\$0.00	\$0.20	\$0.20
Middle Bldg. Exit Lobby		103	1		3	1	75	I	225	50	95.0%	0.2	49	\$1.65	\$1.21	\$2.86
Theatre (Locked)																
Custodial Service (Locked)																
<i>Second Floor</i>																
Chaplain's Office	7'	215	1.15	20	1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
Reading Room	7'	204	1.15	45	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Administrative Office	7'	204	1.15	15	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Library	7'	204	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Restroom #1	7'	n/a	1.15		1	2	20	F	46	30	50.0%	0.0	6	\$0.18	\$0.15	\$0.33
Restroom #2	7'	n/a	1.15		1	2	20	F	46	30	50.0%	0.0	6	\$0.18	\$0.15	\$0.33
Class Room	7'	204	1.15	20	1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Sunday School Room	7'	204	1.15	30	5	2	40	F	460	50	95.0%	0.4	100	\$3.37	\$2.48	\$5.84
Kitchen	7'	n/a	1.15		1	2	32	F	74	50	95.0%	0.1	16	\$0.54	\$0.40	\$0.93
Kitchen		n/a	1.15	20	1	2	22	F	51	50	95.0%	0.1	11	\$0.37	\$0.27	\$0.64
Library Stacks	8'2"	230	1.15	115	36	2	40	F	3,312	50	95.0%	3.1	719	\$24.25	\$17.82	\$42.07
Restroom		n/a	1.15		1	1	32	F	37	30	50.0%	0.0	5	\$0.14	\$0.12	\$0.26
Restroom		n/a	1.15		1	1	22	F	25	30	50.0%	0.0	3	\$0.10	\$0.08	\$0.18
Library Check-Out	8'2"	215	1.15	35	2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Copy Room	8'2"	n/a	1.15	30	1	1	32	F	37	50	95.0%	0.0	8	\$0.27	\$0.20	\$0.47
Copy Room		n/a	1.15		1	1	22	F	25	50	95.0%	0.0	5	\$0.19	\$0.14	\$0.32
Reading Room	8'	215	1.15	30	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Closet	8'	103	1		2	1	75	I	150	10	0.0%	0.0	7	\$0.00	\$0.16	\$0.16
Childrens Room	8'	215	1.15	50	1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
Closet	8'	101	1		1	1	100	I	100	10	0.0%	0.0	4	\$0.00	\$0.11	\$0.11
Office	8'	215	1.15	50	2	3	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
TOTALS									12,450			11	2,474	\$82	\$61	\$143

INCREMENTAL DEMAND COST \$/KW = \$7.706
 INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:

FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
 AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES
 STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

NOTE #2: LAMP TYPE:

F = FLUORESCENT
 HPS = HIGH PRESSURE SODIUM
 I = INCANDESCENT
 MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SSDATA\BLDG664.WK4

07-Apr-95

**Lighting Model
Letterkenny Army Depot
Building 2260
Table Designation**

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG2260.WK4

Lighting Model
Letterkenny Army Depot
Building 2329
Table Designation

INCREMENTAL DEMAND COST \$/KW =	\$7.706	
INCREMENTAL USAGE COST \$/KWH =	\$0.0248	
NOTE #1: LUMINAIRE FACTOR:	FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED	
NOTE #2: LAMP TYPE:	F = FLUORESCENT HPS = HIGH PRESSURE SODIUM I = INCANDESCENT MV = MERCURY VAPOR	
NOTE #3: LUMINAIRE TYPE ARMY #:	U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES, STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991	

G:\PROJECTS\4130.01\SSDATA\BLDG2329.WK4

Lighting Model
Letterkenny Army Depot
Building 2755
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor I	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Warehouse																
Main Entrance Lobby	8'3"	117	1	1	1	2	60	I	120	50	95.0%	0.1	26	\$0.88	\$0.65	\$1.52
Open Office Area	8'3"	206	1.15	45	12	4	40	F	2,208	50	95.0%	2.1	479	\$16.16	\$11.88	\$28.05
Main Corridor	8'3"	206	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
File Room	8'10"	206	1.15	50	3	4	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Main Exit Sign		602	1		1	2	7	I	14	168	95.0%	0.0	10	\$0.10	\$0.25	\$0.36
Corridor to Rest Room	8'10"	206	1.15		3	2	40	F	276	50	95.0%	0.3	60	\$2.02	\$1.49	\$3.51
Corridor to Exit Sign		602	1		1	2	7	I	14	168	95.0%	0.0	10	\$0.10	\$0.25	\$0.36
Breakroom	13'	230	1.15	30	6	2	40	F	552	50	95.0%	0.5	120	\$4.04	\$2.97	\$7.01
Breakroom Sink		101	1		1	1	60	I	60	50	95.0%	0.1	13	\$0.44	\$0.32	\$0.76
Womens Room		220	1.15		1	1	40	F	46	30	50.0%	0.0	6	\$0.18	\$0.15	\$0.33
Womens Room		215	1.15		1	2	40	F	92	30	50.0%	0.0	12	\$0.35	\$0.30	\$0.65
Womens Room Shower		116	1		1	1	60	I	60	30	50.0%	0.0	8	\$0.23	\$0.19	\$0.42
Womens Room Mirror		n/a	1.15		1	1	20	F	46	30	50.0%	0.0	6	\$0.18	\$0.15	\$0.33
Mens Room		220	1.15		2	1	40	F	92	30	50.0%	0.0	12	\$0.35	\$0.30	\$0.65
Mens Room Shower		215	1.15		2	2	40	F	92	30	50.0%	0.0	12	\$0.35	\$0.30	\$0.65
Mens Room Shower (Not Used)		116	1		2	1	60	I	120	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Mens Room Mirror		n/a	1.15		1	1	40	F	46	30	50.0%	0.0	6	\$0.18	\$0.15	\$0.33
Warehouse Area Building #1	16'	702	1.15	40	10	1	150	HPS	1,725	50	95.0%	1.6	374	\$12.63	\$9.28	\$21.91
Lab Room	10'	709	1.15		5	3	40	F	690	50	95.0%	0.7	150	\$5.05	\$3.71	\$8.76
Warehouse Area Bay #1 Exit		EXP	1		2	2	15	I	60	168	95.0%	0.1	44	\$0.44	\$1.08	\$1.52
Warehouse Area Bay #2	16'	709	1.15		16	1	150	HPS	2,760	168	95.0%	2.6	2,012	\$20.21	\$49.91	\$70.11
Warehouse Area Bay #2 Exit		EXP	1		2	2	15	I	60	168	95.0%	0.1	44	\$0.44	\$1.08	\$1.52
Warehouse Area Bay #3	16'	709	1.15	30	16	1	150	HPS	2,760	168	95.0%	2.6	599	\$20.21	\$14.85	\$35.06
Warehouse Area Bay #3 Exit		EXP	1		2	2	15	I	60	168	95.0%	0.1	44	\$0.44	\$1.08	\$1.52
Warehouse Area Bay #9	16'	709	1.15	30	16	1	150	HPS	2,760	168	95.0%	2.6	599	\$20.21	\$14.85	\$35.06
Warehouse Area Bay #9 Exit		EXP	1		1	2	15	I	30	168	95.0%	0.0	22	\$0.22	\$0.54	\$0.76
Warehouse Area Bay #5	16'	709	1.15		17	1	175	MV	3,421	50	95.0%	3.3	742	\$25.05	\$18.41	\$43.46
Warehouse Area Bay #5A	12'	709	1.15	5	2	1	175	MV	403	50	95.0%	0.4	87	\$2.95	\$2.17	\$5.11
Warehouse Area Bay #5B	12'	709	1.15	5	2	1	175	MV	403	50	95.0%	0.4	87	\$2.95	\$2.17	\$5.11
Warehouse Area Bay #5C	12'	709	1.15	5	2	1	175	MV	403	50	95.0%	0.4	87	\$2.95	\$2.17	\$5.11
Warehouse Area Bay #5 Exit		EXP	1		2	2	15	I	60	168	95.0%	0.1	44	\$0.44	\$1.08	\$1.52
Exterior																
Exterior		503	1.15		3	1	150	HPS	518	80	0.0%	0.0	180	\$0.00	\$4.46	\$4.46
Exterior		720	1.15		9	1	150	HPS	1,553	80	0.0%	0.0	539	\$0.00	\$13.37	\$13.37
TOTALS									22,146			19	6,574	\$144	\$163	\$307

INCREMENTAL DEMAND COST \$/KWH = \$7.706
 INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR: FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
 AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED

NOTE #2: LAMP TYPE: F = FLUORESCENT
 HPS = HIGH PRESSURE SODIUM
 I = INCANDESCENT
 MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES
 STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991

Lighting Model
Letterkenny Army Depot
Building 3311
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (Fc)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
<i>Administration</i>																
Entrance Lobby		220	1.15		1	1	40	F	40	46	50	95.0%	0.0	10	\$0.34	\$0.58
Entrance Corridor	99"	220	1.15		8	1	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Director's Office	97"	228	1.15	75	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Director Surveillance Office	97"	215	1.15	30	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Office #1	911"	228	1.15	70	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Conference Room	94"	206	1.15	95	8	4	40	F	1,472	35	75.0%	1.1	224	\$8.51	\$5.55	\$14.05
Office #2	99"	228	1.15	70	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Open Office Area	99"	228	1.15	50	30	4	40	F	5,520	50	95.0%	5.2	1,198	\$40.41	\$29.71	\$70.12
Office #3	97"	228	1.15	50	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Office #4	98"	228	1.15	45	12	4	40	F	2,208	50	95.0%	2.1	479	\$16.16	\$11.88	\$28.05
Office #5	910"	228	1.15	65	12	4	40	F	2,208	50	95.0%	2.1	479	\$16.16	\$11.88	\$28.05
Vault		101	1		1	1	100	I	100	10	0.0%	0.0	4	\$0.00	\$0.11	\$0.11
Exit Corridor		218	1.15		2	1	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Copy and Mail Room	74"	228	1.15	30	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Womens Room	106"	220	1.15		2	1	40	F	92	30	50.0%	0.0	12	\$0.35	\$0.30	\$0.65
Womens Room	81"	220	1.15		2	1	40	F	92	30	50.0%	0.0	12	\$0.35	\$0.30	\$0.65
Mens Room	106"	220	1.15		2	1	40	F	92	30	50.0%	0.0	12	\$0.35	\$0.30	\$0.65
Mens Room	81"	220	1.15		2	1	40	F	92	30	50.0%	0.0	12	\$0.35	\$0.30	\$0.65
Office #6	910"	228	1.15	30	9	4	40	F	1,656	50	95.0%	1.6	359	\$12.12	\$8.91	\$21.04
Office #7	10"	228	1.15	25	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Office #8	10"	228	1.15	25	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Office #9	77"	228	1.15	60	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Office #9		218	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Vending Area	104"	228	1.15	20	6	4	40	F	1,104	50	95.0%	1.0	240	\$8.08	\$5.94	\$14.02
Vending Area		228	1.15		1	2	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Exit Lobby (no lamp)		101	1		0	0	0	I	0	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Smoke Room	710"	230	1.15	20	1	3	40	F	138	50	95.0%	0.1	30	\$1.01	\$0.74	\$1.75
Smoke Room	710"	220	1.15		2	1	40	F	92	50	95.0%	0.1	20	\$0.67	\$0.50	\$1.17
Ice Room		101	1		1	1	200	I	200	10	0.0%	0.0	9	\$0.00	\$0.22	\$0.22
Boiler Room		103	1		1	1	300	I	300	5	0.0%	0.0	7	\$0.00	\$0.16	\$0.16
Surveillance Office #1	105"	228	1.15	70	18	4	40	F	3,312	50	95.0%	3.1	719	\$24.25	\$17.82	\$42.07
Surveillance Office #2	105"	228	1.15	60	4	4	40	F	736	50	95.0%	0.7	160	\$5.39	\$3.96	\$9.35
Office #10	73"	103	1	15	1	1	100	I	100	50	95.0%	0.1	22	\$0.73	\$0.54	\$1.27
Office #10		220	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Office #11	73"	220	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Office #12	73"	230	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Office #13	73"	206	1.15	70	2	4	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Entrance #13 & #14	73"	220	1.15		2	2	40	F	184	50	95.0%	0.2	40	\$1.35	\$0.99	\$2.34
Office #14	73"	220	1.15	45	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Office #15	73"	220	1.15	45	4	2	40	F	368	50	95.0%	0.3	80	\$2.69	\$1.98	\$4.67
Mechanical Room		230	1.15		2	3	40	F	276	5	0.0%	0.0	6	\$0.00	\$0.15	\$0.15
Mechanical Room		230	1.15		1	2	40	F	92	5	0.0%	0.0	2	\$0.00	\$0.05	\$0.05

Lighting Model
Letterkenny Army Depot
Building 3311
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Exterior																
Exterior		103	1		2	1	200	I	400	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
Exterior		107	1		1	1	200	I	200	0	0.0%	0.0	0	\$0.00	\$0.00	\$0.00
TOTALS												26	5,851	\$197	\$145	\$342

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #: U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991

G:\PROJECTS\4130.01\SSDATA\BLDG3311.WK4

**Lighting Model
Letterkenny Army Depot
Building 3315
Table Designation**

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #1: LUMINAIRE FACTOR:
FOR BALLASTED FIXTURES, A BALLAST FACTOR OF 1.15 IS USED
AND FOR INCANDESCENT FIXTURES A FACTOR OF 1 IS USED.

NOTE #2: LAMP TYPE:
F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

NOTE #3: LUMINAIRE TYPE ARMY #:
U.S. ARMY CORPS OF ENGINEERS, LIGHTING FIXTURES,
STANDARD DETAIL NO. 40-06-04, FEBRUARY 1991.

G:\PROJECTS\4130.01\SSDATA\BLDG3315.WK4

**Lighting Model
Letterkenny Army Depot
Building 3321
Table Designation**

INCREMENTAL DEMAND COST \$/KW = \$7.706
INCREMENTAL USAGE COST \$/KWH = \$0.0248

NOTE #2: LAMP TYPE:

F = FLUORESCENT
 HP'S = HIGH PRESSURE SODIUM
 I = INCANDESCENT
 MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SS\DATA\BLDG3321.WK4

Lighting Model	Letterkenny Army Depot Building 5426	Table Designation
----------------	---	-------------------

INCREMENTAL DEMAND COST \$/KW =	\$7.706
INCREMENTAL USAGE COST \$/KWH =	\$0.0248

NOTE #2: LAMP TYPE:

F = FLUORESCENT
HPS = HIGH PRESSURE SODIUM
I = INCANDESCENT
MV = MERCURY VAPOR

G:\PROJECTS\4130.01\SSDATA\BLDG5426.WK4

Lighting Model
Letterkenny Army Depot
Road/Parking Lot Lighting
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (FC)	# Of Luminares	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Exterior Lighting																
Building #1399		403	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #1398		403	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #1398		402	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #2323		403	1.15		3	1	250	HPS	863	80	0.0%	0.0	299	\$0.00	\$7.43	\$7.43
Kenny Gardens		403	1.15		4	1	250	HPS	1,150	80	0.0%	0.0	399	\$0.00	\$9.90	\$9.90
Kenny Gardens		402	1.15		3	1	250	MV	863	80	0.0%	0.0	299	\$0.00	\$7.43	\$7.43
South Patrol Road		402	1.15		4	1	250	HPS	1,150	80	0.0%	0.0	399	\$0.00	\$9.90	\$9.90
Building #616		402	1.15		2	1	250	MV	575	80	0.0%	0.0	200	\$0.00	\$4.95	\$4.95
Building #616		403	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #619		402	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #619		403	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Gate #17		403	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Gate #17		n/a	1.15		1	1	180	LYT	201	80	0.0%	0.0	70	\$0.00	\$1.73	\$1.73
Pennsylvania Avenue		402	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Pennsylvania Avenue		402	1.15		5	1	250	HPS	1,438	80	0.0%	0.0	499	\$0.00	\$12.38	\$12.38
Travel Camp		n/a	1.15		1	1	150	MV	173	80	0.0%	0.0	60	\$0.00	\$1.49	\$1.49
Building #646		n/a	1.15		1	1	180	LYT	207	80	0.0%	0.0	72	\$0.00	\$1.78	\$1.78
Salvage Yard		402	1.15		2	1	250	HPS	575	80	0.0%	0.0	200	\$0.00	\$4.95	\$4.95
Sergeant Major's House		403	1.15		1	1	175	HPS	201	80	0.0%	0.0	70	\$0.00	\$1.73	\$1.73
Guard Shack, Ammo Area Ent.		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Ammo Packing Area		402	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Ammo Packing Area		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Ammo Packing Area		n/a	1.15		1	1	250	LYT	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #3311		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #3315		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #3238		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #3245		403	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #3253 (Flood)		507	1.15		4	1	150	HPS	690	80	0.0%	0.0	240	\$0.00	\$5.94	\$5.94
Building #3253 (Dual Flood)		507	1.15		4	1	150	HPS	690	80	0.0%	0.0	240	\$0.00	\$5.94	\$5.94
Building #365		403	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #360		403	1.15		3	1	250	MV	863	80	0.0%	0.0	299	\$0.00	\$7.43	\$7.43
Building #349		507	1.15		3	1	250	MV	863	80	0.0%	0.0	299	\$0.00	\$7.43	\$7.43
Building #370		n/a	1.15		5	1	250	LYT	1,035	80	0.0%	0.0	359	\$0.00	\$8.91	\$8.91
Building #370		505	1.15		14	1	400	MV	6,440	80	0.0%	0.0	2,236	\$0.00	\$55.45	\$55.45
Building #370		503	1.15		4	1	400	HPS	1,840	80	0.0%	0.0	639	\$0.00	\$15.84	\$15.84
Building #370 Guard Shack		507	1.15		2	1	250	HPS	575	80	0.0%	0.0	200	\$0.00	\$4.95	\$4.95
Building #330 North		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
California Avenue		n/a	1.15		3	1	250	SYT	863	80	0.0%	0.0	299	\$0.00	\$7.43	\$7.43
California Avenue		402	1.15		9	1	250	MV	2,588	80	0.0%	0.0	898	\$0.00	\$22.28	\$22.28
Building #330 South Dock #2		507	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #320 South		507	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #320 South		507	1.15		3	1	175	HPS	604	80	0.0%	0.0	210	\$0.00	\$5.20	\$5.20
Building #320 Parking		n/a	1.15		2	1	180	LYT	414	80	0.0%	0.0	144	\$0.00	\$3.56	\$3.56
Gate #6 (twin)		n/a	1.15		8	4	80	F	2,944	80	0.0%	0.0	1,022	\$0.00	\$25.35	\$25.35
Gate #6		n/a	1.15		2	1	180	LYT	414	80	0.0%	0.0	144	\$0.00	\$3.56	\$3.56
Building #350 Parking Lot		n/a	1.15		4	1	180	LYT	828	80	0.0%	0.0	287	\$0.00	\$7.13	\$7.13
Building #350 Parking Lot		507	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Credit Union		507	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Overcash Drive		402	1.15		21	1	250	MV	6,038	80	0.0%	0.0	2,096	\$0.00	\$51.99	\$51.99

Lighting Model
Letterkenny Army Depot
Read/Parking Lot Lighting
Table Designation

Room Area or Description	Ceiling Height Ft	Luminaire Type Army #	Luminaire Factor 1	Light Levels Meas (FC)	# Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Lamp Type	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Monthly Demand (Kw)	Monthly Usage (Kwh)	Monthly Cost \$
Overcash Drive		402	1.15		2	1	250	HPS	575	80	0.0%	0.0	200	\$0.00	\$4.95	\$4.95
Overcash Drive		n/a	1.15		3	1	180	LYT	621	80	0.0%	0.0	216	\$0.00	\$5.35	\$5.35
Overcash Drive		507	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #51 South		507	1.15		1	1	1000	MV	1,150	80	0.0%	0.0	399	\$0.00	\$9.90	\$9.90
Washington Avenue		402	1.15		3	1	250	HPS	863	80	0.0%	0.0	299	\$0.00	\$7.43	\$7.43
Washington Avenue		402	1.15		6	1	250	MV	1,725	80	0.0%	0.0	599	\$0.00	\$14.85	\$14.85
Michigan Avenue		402	1.15		3	1	250	MV	863	80	0.0%	0.0	299	\$0.00	\$7.43	\$7.43
Michigan Avenue		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #1 East Parking		n/a	1.15		4	1	180	LYT	828	80	0.0%	0.0	287	\$0.00	\$7.13	\$7.13
Building #1 East Parking		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #238 Parking Lot		n/a	1.15		2	1	180	LYT	414	80	0.0%	0.0	144	\$0.00	\$3.56	\$3.56
Oregon Avenue		402	1.15		3	1	250	MV	863	80	0.0%	0.0	299	\$0.00	\$7.43	\$7.43
Building #57 South Parking		507	1.15		3	1	250	MV	863	80	0.0%	0.0	299	\$0.00	\$7.43	\$7.43
Arkansas Avenue		507	1.15		5	1	250	MV	1,438	80	0.0%	0.0	499	\$0.00	\$12.38	\$12.38
Arkansas Avenue		403	1.15		1	1	175	MV	201	80	0.0%	0.0	70	\$0.00	\$1.73	\$1.73
Kansas Avenue		507	1.15		4	1	250	MV	1,150	80	0.0%	0.0	399	\$0.00	\$9.90	\$9.90
Texas Avenue		402	1.15		2	1	250	MV	575	80	0.0%	0.0	200	\$0.00	\$4.95	\$4.95
Building #500		507	1.15		1	1	400	MV	460	80	0.0%	0.0	160	\$0.00	\$3.96	\$3.96
Building #521 Parking Lot		n/a	1.15		1	1	180	LYT	207	80	0.0%	0.0	72	\$0.00	\$1.78	\$1.78
Building #521 Parking Lot		n/a	1.15		1	1	180	SYT	207	80	0.0%	0.0	72	\$0.00	\$1.78	\$1.78
Building #521 Parking Lot		n/a	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Gate #1		n/a	1.15		1	1	180	LYT	207	80	0.0%	0.0	72	\$0.00	\$1.78	\$1.78
Gate #1		n/a	1.15		2	4	80	F	736	80	0.0%	0.0	256	\$0.00	\$6.34	\$6.34
Gate #1		n/a	1.15		3	4	80	F	1,104	80	0.0%	0.0	383	\$0.00	\$9.51	\$9.51
Coffey Avenue		n/a	1.15		1	1	180	LYT	207	80	0.0%	0.0	72	\$0.00	\$1.78	\$1.78
Coffey Avenue		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Coffey Avenue		402	1.15		5	1	250	MV	1,438	80	0.0%	0.0	499	\$0.00	\$12.38	\$12.38
Kenny Hills		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
529 Parking Lot		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
522 Parking Lot		n/a	1.15		1	1	180	LYT	207	80	0.0%	0.0	72	\$0.00	\$1.78	\$1.78
Access Road to Golf Club		402	1.15		2	1	250	MV	575	80	0.0%	0.0	200	\$0.00	\$4.95	\$4.95
Building #505		403	1.15		1	1	500	HPS	575	80	0.0%	0.0	200	\$0.00	\$4.95	\$4.95
Visitors Residents		403	1.15		1	1	500	HPS	575	80	0.0%	0.0	200	\$0.00	\$4.95	\$4.95
Building #37 Parking Lot		507	1.15		2	1	250	MV	575	80	0.0%	0.0	200	\$0.00	\$4.95	\$4.95
Building #37 Parking Lot		403	1.15		1	1	175	MV	201	80	0.0%	0.0	70	\$0.00	\$1.73	\$1.73
Building #37 Parking Lot		403	1.15		1	1	175	HPS	201	80	0.0%	0.0	70	\$0.00	\$1.73	\$1.73
Building #421 Parking Lot		n/a	1.15		1	1	180	LYT	207	80	0.0%	0.0	72	\$0.00	\$1.78	\$1.78
Carbaugh Avenue		n/a	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Bldgs#16, 417 & 418 Parking Lot		402	1.15		3	1	250	MV	863	80	0.0%	0.0	299	\$0.00	\$7.43	\$7.43
Bldgs#16, 417 & 418 Parking Lot		402	1.15		2	1	250	HPS	575	80	0.0%	0.0	200	\$0.00	\$4.95	\$4.95
Bldgs#16, 417 & 418 Parking Lot		n/a	1.15		1	1	1000	LYT	1,150	80	0.0%	0.0	399	\$0.00	\$9.90	\$9.90
Building #433		402	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #424		402	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #426		402	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
New Jersey Avenue		402	1.15		3	1	250	MV	863	80	0.0%	0.0	299	\$0.00	\$7.43	\$7.43
Wisconsin Avenue		402	1.15		4	1	250	MV	1,150	80	0.0%	0.0	399	\$0.00	\$9.90	\$9.90
Wisconsin Avenue		402	1.15		1	1	250	HPS	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Wisconsin Avenue		507	1.15		1	1	1000	HPS	1,150	80	0.0%	0.0	399	\$0.00	\$9.90	\$9.90
Building #3 Parking Lot		402	1.15		1	1	250	MV	288	80	0.0%	0.0	100	\$0.00	\$2.48	\$2.48
Building #S-353		507	1.15		1	1	1000	HPS	1,150	80	0.0%	0.0	399	\$0.00	\$9.90	\$9.90

ATTACHMENT 9.5

Energy Conservation Opportunities

ECO-1

Incandescent Exit Signs to Fluorescent Exit Signs

Existing. Twenty-two of the buildings at the Letterkenny Army Depot contain approximately 95 incandescent exit signs of various mounting and directional types. Included with the 95 exit signs are 8 decorative exit sign luminaires in building 500. The attached data table for ECO-1 lists the areas which currently utilize these luminaires. The existing exit signs utilize six watt (6), seven watt (7), fifteen watt (15), twenty watt (20) and twenty-five watt (25) incandescent lamps. The total watts for the existing exit signs is 2,423 watts. The exit signs operate 24 hours per day and contribute approximately 95% of their connected load to the demand. The annual electric demand, usage, and cost for these fixtures are as follows:

Electric Demand	=	27.6 kW/yr (2.3 kW/mo x 12 mo/yr)
Electric Usage	=	21,204 kWh/yr (1,767 kWh/mo x 12 mo/yr)
Electric Cost	=	\$740 (27.6 kW/yr x \$7.706/kW) + (21,204 kWh/yr x \$.0248/kWh) = \$739, use \$740

Proposed. Remove and replace all existing 87 exit sign interior housings with a fluorescent retrofit system. Reference the attached data table for ECO-1. Replace the remaining 8 decorative fixtures with a PL-5, lamp/ballast retrofit. The fluorescent PL retrofit system for the exit signs consists of a single ballast and 1 seven (7) watt compact fluorescent lamp. The new exit signs will consume 8 watts of electricity per luminaire and the PL-5 will consume 6 watts per luminaire. The new luminaires generally have a long life expectancy. The exit sign fluorescent lamps have an average life of 15,000 hours plus, which is about three times the life of the incandescent lamps they are replacing. The annual electric demand, usage and cost of the proposed ECO is noted below:

Electric Demand	=	8.4 kW/yr (.7 kW/mo x 12 mo/yr)
Electric Usage	=	6,528 kWh/yr (544 kW/mo x 12 mo/yr)
Electric Cost	=	\$230 (8.4 kW/yr x \$7.706/kW) + (6,528 kWh/yr x \$.0248/kWh) = \$227, use \$230

Implementation Cost. The expected construction cost for implementing the project is expected to be \$4,900. The breakdown is noted below and shown on the attached ECO data table.

Material	\$2,300
Labor	\$2,600
Engineering	<u>\$ 0</u>

Total \$4,900

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

Electric Demand	=	19.2 kW/yr (27.6 - 8.4)
Electric Usage	=	14,676 kWh/yr (21,204 - 6,528)
Energy Cost	=	\$510/yr (\$740 - \$230)
Annual Energy Savings	=	50.1 mmBtu/yr
Energy Usage	=	50.1 mmBtu/yr (14,676 kWh/yr x 3,413 Btu/kWh) ÷ 1,000,000 Btu/mmBtu

Maintenance Savings.

By retrofitting the existing incandescent exit signs with fluorescent lamps, a maintenance savings will result because the fluorescent lamps have a three times longer life than incandescent lamps. The annual maintenance savings is noted below:

Data

Incandescent Lamp Life	=	5,000 hours
Fluorescent Lamp Life	=	15,000 hours
Operation Period Per Year	=	8,760 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes
Incandescent Lamp Cost	=	\$4 each
Fluorescent Lamp Cost	=	\$10 each
Total Quantity Exit Signs	=	95

Calculation

$$\begin{array}{lcl} \text{Maintenance} & = & \$18.70 (20 \times 1/3 + 4) \times \\ \text{(Incandescent)} & & 8,760/5,000 \end{array}$$

$$\begin{array}{lcl} \text{Maintenance} & = & \$9.70 (20 \times 1/3 + 10) \times \\ \text{(Fluorescent)} & & 8,760/15,000 \end{array}$$

$$\begin{array}{lcl} \text{Annual Recurring} & = & \$860 (18.7 - 9.7) \times 95 = \\ \text{Maintenance Savings} & & \$855, \text{ use } \$860 \end{array}$$

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations, construction supervision, and annual recurring maintenance costs in addition to construction cost and engineering services. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 3.76 years with a savings to investment ratio of 4.64.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO1

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO-1

ANALYSIS DATE: 04-19-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	4900.	
B. SIOH	\$	270.	
C. DESIGN COST	\$	0.	
D. TOTAL COST (1A+1B+1C)	\$	5170.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$	5170.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR (2)	ANNUAL \$ SAVINGS (3)	DISCOUNT FACTOR (4)	DISCOUNTED SAVINGS (5)
A. ELECT	\$ 7.27	50.	\$ 364.	18.17	\$ 6618.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 150.	17.22	\$ 2583.
N. TOTAL		50.	\$ 514.		\$ 9201.

3. NON ENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)		\$ 860.
(1) DISCOUNT FACTOR (TABLE A)	17.22	
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$ 14809.

B. NON RECURRING SAVINGS (+) / COSTS (-)

ITEM	SAVINGS (+) COST (-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS (+) / COST (-) (4)
d. TOTAL	\$ 0.			0.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS (+) / COST (-) (3A2+3Bd4) \$ 14809.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 1374.

5. SIMPLE PAYBACK PERIOD (1G/4) 3.76 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 24010.

7. SAVINGS TO INVESTMENT RATIO (SIR) = $(6 / 1G) =$ 4.64
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 9.63 %

ECO-1
Letterkenny Army Depot
Incandescent Exit Signs to Fluorescent Exit Signs

Room	NO Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Existing				Proposed				Implementation								
				Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost (\$)	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost (\$)	Mat. Cost (\$)	Labor Cost (\$)	Eng. Cost (\$)	Total Cost (\$)	Energy Savings (\$)
Office Area																				
Building 1																				
Corridor A (Exit Sign)	1	1	20	168	95%	0.0	15	\$1.76	\$4.34	\$6.10	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$3.64
Building 2-5																				
Administration																				
South Entrance Lobby Exit	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Building 3																				
Computer Area																				
EOC Open Office Area Exit (V)	1	2	7	14	168	95%	0.0	\$1.29	\$2.08	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.82
Raised Rm. Co. Rm. #3 (Exit Sign)	3	2	15	90	168	95%	0.1	\$7.91	\$19.64	\$27.55	Fluorescent Exit Sign Retrofit Kit	8	0.0	18	\$7.36	\$75	\$84	\$0	\$159	\$20.19
Conference Rm. (Exit) (Vacant)	1	2	7	14	168	95%	0.0	\$1.29	\$2.08	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.82
Raised Rm. Co. Rm. #7 (Exit Sign)	3	2	15	90	168	95%	0.1	\$7.91	\$19.64	\$27.55	Fluorescent Exit Sign Retrofit Kit	8	0.0	18	\$7.36	\$75	\$84	\$0	\$159	\$20.19
South East Area																				
Stairwell Lobby Exit Sign	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
South West Area																				
Corridor 5-10-B (Exit Sign)	2	2	15	60	168	95%	0.1	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38
North East Area																				
Corridor 22-14-1 Exit Sign	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Conference 26-E (Exit Sign)	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Open Office Area (Exit Sign)	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Building 5N																				
Administration																				
Open Office Area (Exit Sign)	2	2	15	60	168	95%	0.1	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38
West Entrance Lobby (Exit Sign)	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Building 6N																				
Administration																				
Exit Sign	8	2	15	240	168	95%	0.2	\$21.08	\$52.08	\$73.16	Fluorescent Exit Sign Retrofit Kit	8	0.1	47	\$19.63	\$200	\$224	\$0	\$424	\$53.53
Building 14																				
First Floor																				
Receiving Room (Exit Sign)	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Machine Shop Office (Exit Sign)	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Machine Shop (Exit Sign)	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Building 19																				
Warehouse																				
Exit Sign	2	2	15	60	168	95%	0.1	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38
Building 102																				
Lab																				
Exit Signs	4	2	6	48	168	95%	0.0	\$4.22	\$10.42	\$14.63	Fluorescent Exit Sign Retrofit Kit	8	0.0	23	\$9.82	\$100	\$112	\$0	\$212	\$4.82
Building 350																				
Office #1																				
Conference Room (Exit Sign)	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Managers Office (Exit Sign)	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Reception (Exit Sign)	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Office #3																				
ASRS plus Otc. Area (Exit Sign)	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
ASRS plus Office (Exit Sign)	1	2	15	30	168	95%	0.0	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Annex Office Area #6																				
Exit Sign	2	2	15	60	168	95%	0.1	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38
Annex Otc. Corridor (Exit Sign)	2	2	15	60	168	95%	0.1	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38
Building 412																				
Training & Conf. Center																				
Conference Room Exit Sign	3	2	15	90	168	95%	0.1	\$7.91	\$19.53	\$27.44	Fluorescent Exit Sign Retrofit Kit	8	0.0	18	\$7.36	\$75	\$84	\$0	\$159	\$20.07

ECO-1
Letterkenny Army Depot
Incandescent Exit Signs to Fluorescent Exit Signs

		Existing										Proposed				Implementation					
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost (\$)	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost (\$)	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$
Building 416																					
Administration																					
Main Entrance (Exit Sign)	1	2	6	12	168	95%	0.0	9	\$1.05	\$2.60	\$3.66	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.20
Rear (Exit Sign)	1	2	6	12	168	95%	0.0	9	\$1.05	\$2.60	\$3.66	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.20
Building 417																					
Personnel Barracks																					
Corridor Exit Sign	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.81
Building 418																					
Personnel Barracks																					
Corridor Exit Sign	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.81
Building 500																					
First Floor																					
Command Corridor (Exit Sign)	1	1	25	25	168	95%	0.0	18	\$2.20	\$5.42	\$7.62	PL-5 Lamp/Ballast Retrofit, Twin	6	0.0	4	\$1.75	\$18	\$20	\$0	\$38	\$5.87
Legal Office (Exit Sign)	3	1	25	75	168	95%	0.1	55	\$6.59	\$16.27	\$22.86	PL-5 Lamp/Ballast Retrofit, Twin	6	0.0	13	\$5.26	\$54	\$60	\$0	\$114	\$17.60
Second Floor																					
Auditorium (Exit Sign)	1	1	25	25	168	95%	0.0	18	\$2.20	\$5.42	\$7.62	PL-5 Lamp/Ballast Retrofit, Twin	6	0.0	4	\$1.75	\$18	\$20	\$0	\$38	\$5.87
Ctr. Bldg. Open Ofc. (Exit Sign)	1	1	25	25	168	95%	0.0	18	\$2.20	\$5.42	\$7.62	PL-5 Lamp/Ballast Retrofit, Twin	6	0.0	4	\$1.75	\$18	\$20	\$0	\$38	\$5.87
Basement Floor																					
Int./Vending Area (Exit Sign)	1	2	15	30	168	95%	0.0	22	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Om. Ofc. Area Rmfl(Exit Sign)	1	2	25	50	168	95%	0.0	18	\$2.20	\$5.42	\$7.62	PL-5 Lamp/Ballast Retrofit, Twin	6	0.0	4	\$1.75	\$18	\$20	\$0	\$38	\$5.87
DPCA Office Corridor (Exit Sign)	1	1	25	25	168	95%	0.0	18	\$2.20	\$5.42	\$7.62	PL-5 Lamp/Ballast Retrofit, Twin	6	0.0	4	\$1.75	\$18	\$20	\$0	\$38	\$5.87
Corridor (Exit Sign)	1	2	15	30	168	95%	0.0	22	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Building 521																					
First Floor																					
General Office (Exit Sign)	1	1	15	15	168	95%	0.0	11	\$1.32	\$3.25	\$4.57	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$2.12
Corridor (Exit Sign)	1	1	15	15	168	95%	0.0	11	\$1.32	\$3.25	\$4.57	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$2.12
Building 529																					
First Floor																					
Supply Closet (Exit Sign)	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.81
Drain Water (Exit Sign)	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.81
Freezer Store Room (Exit Sign)	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.81
Second Floor																					
Bar Dining Area (Exit Sign)	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.81
Second Flr. Entrance (Exit Sign)	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.81
Dining Room (Exit Sign)	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.81
Building 618																					
First Floor																					
Corridor Exit	2	2	15	60	168	95%	0.1	44	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38
Second Floor																					
Exit Sign	1	2	15	30	168	95%	0.0	22	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69
Building 619																					
Dining Area																					
Exit Sign	2	2	15	60	168	95%	0.1	44	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38
Building 639																					
Physical Fitness Center																					
Exit Sign	1	1	15	15	168	95%	0.0	11	\$1.32	\$3.25	\$4.57	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$2.12
Building 645																					
Day Care																					
Play Area Exit Sign	3	2	15	90	168	95%	0.1	66	\$7.91	\$19.53	\$27.44	Fluorescent Exit Sign Retrofit Kit	8	0.0	18	\$7.36	\$75	\$84	\$0	\$159	\$20.07
Entrance Lobby Exit Sign	2	2	7	28	168	95%	0.0	20	\$2.46	\$6.08	\$8.54	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.63
Building 646																					
Youth Center																					
Open Area Exit Sign	2	2	15	60	168	95%	0.1	44	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38
Entrance Area Exit Sign	1	2	15	30	168	95%	0.0	22	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69

ECO-1
Letterkenny Army Depot
Incandescent Exit Signs to Fluorescent Exit Signs

Room	NO. Of Luminaires	Existing					Proposed					Implementation															
		Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$						
Warehouse Building 2755																											
Warehouse Area Bay #3 Exit	2	2	15	60	168	95%	0.1	44	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38						
Warehouse Area Bay #2 Exit	2	2	15	60	168	95%	0.1	44	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38						
Warehouse Area Bay #0 Exit	1	2	15	30	168	95%	0.0	22	\$2.64	\$6.51	\$9.15	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$6.69						
Warehouse Area Bay #1 Exit	2	2	15	60	168	95%	0.1	44	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38						
Warehouse Area Bay #5 Exit	2	2	15	60	168	95%	0.1	44	\$5.27	\$13.02	\$18.29	Fluorescent Exit Sign Retrofit Kit	8	0.0	12	\$4.91	\$50	\$56	\$0	\$106	\$13.38						
Main Exit Sign	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.81						
Corridor to Exit Sign	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	Fluorescent Exit Sign Retrofit Kit	8	0.0	6	\$2.45	\$25	\$28	\$0	\$53	\$1.81						
TOTALS		95		2423				1767		\$210		\$530		\$740				\$2,300		\$2,600		\$0		\$4,900		\$510	
APROJECTS4136.01SSRECOECO 1.WK4																											
16-May-95																											

G:\PROJECTS\134130\01\SS\ECOECO_1.WK4

ECO-2

Incandescent Exit Signs to LED Exit Signs

Existing.

Twenty-two of the buildings at the Letterkenny Army Depot contain approximately 87 incandescent exit signs of various mounting and directional types. The attached data table for ECO-2 lists the areas which currently utilize these luminaires. The existing exit signs utilize six watt (6), seven watt (7), fifteen watt (15), and twenty watt (20) incandescent lamps. The total watts for the existing exit signs is 2,223 watts. The exit signs operate 24 hours per day and contribute approximately 95% of their connected load to the demand. The annual electric demand, usage, and cost for these fixtures are as follows:

Electric Demand = 25.2 kW/yr (2.1 kW/mo x 12 mo/yr)

Electric Usage = 19,452 kWh/yr (1,621 kWh/mo x 12 mo/yr)

Electric Cost = \$680 (25.2 kW/yr x \$7.706/kW) + (19,452 kWh/yr x \$.0248/kWh) = \$677, use \$680

Proposed.

Remove and replace all existing 87 exit sign interior housings with a LED retrofit system. Reference the attached data table for ECO-2. The LED retrofit system for the exit signs consists of a LED panel which consumes about 2 watts. The new luminaires generally have a 25 year plus life expectancy. The annual electric demand, usage and cost of the proposed ECO is noted below:

Electric Demand	=	2.4 kW/yr (.2 kW/mo x 12 mo/yr)
Electric Usage	=	1,524 kWh/yr (127 kWh/mo x 12 mo/yr)
Electric Cost	=	\$60 (2.4 kW/yr x \$7.706/kW) + (1,524 kWh/yr x \$.0248/kWh) = \$56, use \$60

Implementation Cost. The expected construction cost for implementing the project is expected to be \$6,400. The breakdown is noted below and shown on the attached data table.

Material	\$3,900
Labor	\$2,400
Engineering	\$ <u>0</u>
Total	\$6,300, use \$6,400

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

Electric Demand	=	22.8 kW/yr (25.2 - 2.4)
Electric Usage	=	17,928 kWh/yr (19,452 - 1,524)
Energy Cost	=	\$620/yr (\$680 - \$60)
Annual Energy Savings	=	61.2 mmBtu/yr
Energy Usage	=	61.2 mmBtu/yr (17,928 kWh/yr x 3,413 Btu/kWh) ÷ 1,000,000 Btu/mmBtu

Maintenance Savings.

By retrofitting the existing incandescent exit signs with an LED board, a maintenance savings will result. The annual maintenance savings is noted below:

Data

Incandescent Lamp Life	=	5,000 hours
LED Board Life	=	25 years
Operation Period Per Year	=	8,760 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes
Incandescent Lamp Cost	=	\$4 each
Total Quantity Exit Signs	=	87

Calculation

$$\begin{array}{lcl} \text{Maintenance} & = & \$18.70 (20 \times 1/3 + 4) \times \\ \text{(Incandescent)} & & 8,760/5,000 \end{array}$$

$$\begin{array}{lcl} \text{Maintenance} & = & \$0.00 \\ \text{(LED)} & & \end{array}$$

$$\begin{array}{lcl} \text{Annual Recurring} & = & \$1,600 (18.7 \times 87) = \\ \text{Maintenance Savings} & & \$1,627, \text{ use } \$1,600 \end{array}$$

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations, construction supervision, and annual recurring maintenance costs in addition to construction cost. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 3.03 years with a savings to investment ratio of 5.74.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO2

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO2

ANALYSIS DATE: 03-27-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	6400.	
B. SIOH	\$	350.	
C. DESIGN COST	\$	0.	
D. TOTAL COST (1A+1B+1C)	\$	6750.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$	6750.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	61.	\$ 445.	18.17	\$ 8084.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 180.	17.22	\$ 3100.
N. TOTAL		61.	\$ 625.		\$ 11184.

3. NON ENERGY SAVINGS(+) / COST(-)

A. ANNUAL RECURRING (+/-)		\$ 1600.
(1) DISCOUNT FACTOR (TABLE A)	17.22	
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$ 27552.

B. NON RECURRING SAVINGS(+) / COSTS(-)

ITEM	SAVINGS(+) COST(-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS(+)/ COST(-) (4)
d. TOTAL	\$ 0.			0.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ 27552.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 2225.

5. SIMPLE PAYBACK PERIOD (1G/4) 3.03 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 38736.

7. SAVINGS TO INVESTMENT RATIO (SIR) = $(6 / 1G) =$ 5.74
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 10.56 %

ECO-2
Letterkenny Army Depot
Incandescent Exit Signs to LED Exit Signs

Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Existing				New Luminaire Description	Proposed				Implementation					
					Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month		Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost	Mat. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings	
Building 1																			
Office Area	1	1	20	20	168	95%	0.0	15	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$5.49
Corridor A (Exit Sign)																			
Building 2-S																			
Administration	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
South Entrance Lobby Exit																			
Building 3																			
Computer Area																			
EOC Open Office Area Exit (V)	1	2	7	14	168	95%	0.0	10	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$3.66
Raised Pk. Co. Rm #3 (Exit Sign)	3	2	15	90	168	95%	0.1	66	LED Exit Sign Retrofit Kit		2	0.0	4	\$1.83	\$135	\$84	\$0	\$219	\$25.72
Conference Rm. (Exit) (Vacant)	1	2	7	14	168	95%	0.0	10	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$3.66
Raised Pk. Co. Rm. #7 (Exit Sign)	3	2	15	90	168	95%	0.1	66	LED Exit Sign Retrofit Kit		2	0.0	4	\$1.83	\$135	\$84	\$0	\$219	\$25.72
South East Area																			
Stairwell Lobby Exit Sign	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
South West Area																			
Corridor 2-10-B (Exit Sign)	2	2	15	60	168	95%	0.1	44	LED Exit Sign Retrofit Kit		2	0.0	3	\$1.22	\$90	\$56	\$0	\$146	\$17.07
North East Area																			
Corridor 22-14-J Exit Sign	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
Conference 26-F (Exit Sign)	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
Open Office Area (Exit Sign)	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
Building 5N																			
Administration																			
Open Office Area (Exit Sign)	2	2	15	60	168	95%	0.1	44	LED Exit Sign Retrofit Kit		2	0.0	3	\$1.22	\$90	\$56	\$0	\$146	\$17.07
West Entrance Lobby (Exit Sign)	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
Building 6N																			
Administration																			
Exit Sign	8	2	15	240	168	95%	0.2	175	LED Exit Sign Retrofit Kit		2	0.0	12	\$4.88	\$360	\$224	\$0	\$584	\$68.28
Building 14																			
First Floor																			
Receiving Room (Exit Sign)	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
Machine Shop Office (Exit Sign)	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
Machine Shop (Exit Sign)	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
Building 19																			
Warehouse																			
Exit Sign	2	2	15	60	168	95%	0.1	44	LED Exit Sign Retrofit Kit		2	0.0	3	\$1.22	\$90	\$56	\$0	\$146	\$17.07
Building 102																			
Lab																			
Exit Sign	4	2	6	48	168	95%	0.0	35	LED Exit Sign Retrofit Kit		2	0.0	6	\$2.44	\$180	\$112	\$0	\$292	\$12.19
Building 350																			
Office #1																			
Conference Room (Exit Sign)	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
Managers Office (Exit Sign)	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
Reception (Exit Sign)	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
Office #3																			
ASRS Plus Ofc. Area (Exit Sign)	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
ASRS Plus Ofc. Area (Exit Sign)	1	2	15	30	168	95%	0.0	22	LED Exit Sign Retrofit Kit		2	0.0	1	\$0.61	\$45	\$28	\$0	\$73	\$8.54
Annex Office Area #6																			
Exit Sign	2	2	15	60	168	95%	0.1	44	LED Exit Sign Retrofit Kit		2	0.0	3	\$1.22	\$90	\$56	\$0	\$146	\$17.07
Annex Ofc. Corridor (Exit Sign)	2	2	15	60	168	95%	0.1	44	LED Exit Sign Retrofit Kit		2	0.0	3	\$1.22	\$90	\$56	\$0	\$146	\$17.07
Building 412																			
Training & Conf. Center																			
Conference Room Exit Sign	3	2	15	90	168	95%	0.1	66	LED Exit Sign Retrofit Kit		2	0.0	4	\$1.83	\$135	\$84	\$0	\$219	\$25.61

ECO-2
Letterkenny Army Depot
Incandescent Exit Signs to LED Exit Signs

Existing											Proposed										Implementation				
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw/Hr Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/Hr Per Month	Annual Cost \$	Mat Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$	Energy Savings \$				

ECO-2
Letterkenny Army Depot
Incandescent Exit Signs to LED Exit Signs

Room	NO. Of Luminaires	Existing					Proposed					Implementation					Energy Savings \$
		Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	
Building 2755																	
Warehouse																	
Warehouse Area Bay #3 Exit	2	2	15	60	168	95%	0.1	44	\$5.27	\$13.02	\$18.29	LED Exit Sign Retrofit Kit	2	0.0	3	\$1.22	\$17.07
Warehouse Area Bay #2 Exit	2	2	15	60	168	95%	0.1	44	\$5.27	\$13.02	\$18.29	LED Exit Sign Retrofit Kit	2	0.0	3	\$1.22	\$17.07
Warehouse Area Bay #9 Exit	1	2	15	30	168	95%	0.0	22	\$2.64	\$6.51	\$9.15	LED Exit Sign Retrofit Kit	2	0.0	1	\$0.61	\$8.54
Warehouse Area Bay #1 Exit	2	2	15	60	168	95%	0.1	44	\$5.27	\$13.02	\$18.29	LED Exit Sign Retrofit Kit	2	0.0	3	\$1.22	\$17.07
Warehouse Area Bay #5 Exit	2	2	15	60	168	95%	0.1	44	\$5.27	\$13.02	\$18.29	LED Exit Sign Retrofit Kit	2	0.0	3	\$1.22	\$17.07
Main Exit Sign	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	LED Exit Sign Retrofit Kit	2	0.0	1	\$0.61	\$3.66
Corridor to Exit Sign	1	2	7	14	168	95%	0.0	10	\$1.23	\$3.04	\$4.27	LED Exit Sign Retrofit Kit	2	0.0	1	\$0.61	\$3.66
TOTALS	87			2223			2.1	1621	\$200	\$480	\$680			0.2	127	\$60	\$620

G:\PROJECTS\4130\ISSUES\ECO_2.WK4

16 May 95

ECO-3

Incandescent Area Light over Paper Exit Sign

Existing.

Thirteen of the warehouse buildings at the Letterkenny Army Depot contain approximately 47 incandescent luminaires with 200 watt lamps illuminating paper exit signs. The attached data table for ECO-3 lists the areas which currently utilize these luminaires. The total watts for the existing lamps is 9,400 watts. The lamps operate an average of 50 hours per week and contribute approximately 95% of their connected load to the demand. The annual electric demand, usage, and cost for these fixtures are as follows:

$$\text{Electric Demand} = 106.8 \text{ kW/yr } (8.9 \text{ kW/mo } \times 12 \text{ mo/yr})$$

$$\text{Electric Usage} = 26,148 \text{ kWh/yr } (2,179 \text{ kWh/mo } \times 12 \text{ mo/yr})$$

$$\begin{aligned} \text{Electric Cost} &= \$1,500 (106.8 \text{ kW/yr } \times \$7.706/\text{kW}) + (26,148 \text{ kWh/yr } \times \$0.0248/\text{kWh}) = \\ & \$1,471, \text{ use } \$1,500 \end{aligned}$$

Proposed.

Remove and replace all existing 47 incandescent luminaires with LED exit signs. Reference the attached data table for ECO-3. The LED exit sign will consume 2 watts of electricity per luminaire. The new luminaires generally have a 25-year plus life expectancy. The average life of 200 watt incandescent lamp is 750 hours, which makes this project a maintenance saver. The annual electric demand, usage and cost of the proposed ECO is noted below:

$$\text{Electric Demand} = 1.2 \text{ kW/yr } (.1 \text{ kW/mo } \times 12 \text{ mo/yr})$$

$$\text{Electric Usage} = 264 \text{ kWh/yr } (22 \text{ kWh/mo } \times 12 \text{ mo/yr})$$

$$\begin{aligned} \text{Electric Cost} &= \$20 (1.2 \text{ kW/yr} \times \$7.706/\text{kW}) \\ &\quad + (264 \text{ kWh/yr} \times \\ &\quad \$0.0248/\text{kWh}) = \$16, \text{ use } \$20 \end{aligned}$$

Implementation Cost. The expected construction cost for implementing the project is expected to be \$4,600. The breakdown is noted below and shown on the attached ECO data table.

Material	\$2,700
Labor	\$1,900
Engineering	<u>\$ 0</u>
Total	\$4,600

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

$$\text{Electric Demand} = 105.6 \text{ kW/yr} (106.8 - 1.2)$$

$$\text{Electric Usage} = 25,884 \text{ kWh/yr} (26,148 - 264)$$

$$\begin{aligned} \text{Energy Cost} &= \$1,500/\text{yr} (\$1,500 - \$20) = \\ &\quad \$1,480, \text{ use } \$1,500 \end{aligned}$$

$$\text{Annual Energy Saved} = 88.3 \text{ mmBtu/yr}$$

$$\begin{aligned} \text{Energy Usage} &= 88.3 \text{ mmBtu/yr} (25,884 \\ &\quad \text{kWh/yr} \times 3,413 \text{ Btu/kWh}) \div \\ &\quad 1,000,000 \text{ Btu/mmBtu} \end{aligned}$$

Maintenance Savings. By replacing the existing incandescent lamps with LED exit signs, a maintenance savings will result. The annual maintenance is noted below:

Data

Incandescent Lamp Life	=	750 hours
LED Board Life	=	25 years
Operation Period Per Year	=	2,600 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes
Incandescent Lamp Cost	=	\$1 each
Total Quantity of Lamps	=	47

Calculation.	Maintenance (Incandescent)	=	$\$26.58 (20 \times 1/3 + 1) \times 2,600/750$
	Maintenance (LED)	=	\$0.00
	Annual Recurring Maintenance Savings	=	$\$1,200 (26.58 - 0) \times 47 =$ \$1,249, use \$1,200

Discussion. A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations, construction supervision, and annual recurring maintenance costs in addition to construction cost. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 1.83 years with a savings to investment ratio of 9.54.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO3

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO3

ANALYSIS DATE: 03-27-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	4600.		
B. SIOH	\$	253.		
C. DESIGN COST	\$	0.		
D. TOTAL COST (1A+1B+1C)	\$	4853.		
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$		0.	
F. PUBLIC UTILITY COMPANY REBATE	\$		0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$			4853.

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	88.	\$ 642.	18.17	\$ 11664.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 810.	17.22	\$ 13948.
N. TOTAL		88.	\$ 1452.		\$ 25612.

3. NON ENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)		\$	1200.
(1) DISCOUNT FACTOR (TABLE A)		17.22	
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$	20664.

B. NON RECURRING SAVINGS (+) / COSTS (-)

ITEM	SAVINGS (+) COST (-) (1)	YR OC (2)	DISCNT FACTOR (3)	DISCOUNTED SAVINGS (+) / COST (-) (4)
------	--------------------------------	-----------------	-------------------------	---

d. TOTAL	\$	0.		0.
----------	----	----	--	----

C. TOTAL NON ENERGY DISCOUNTED SAVINGS (+) / COST (-) (3A2+3Bd4)	\$	20664.
--	----	--------

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$	\$	2652.
--	----	-------

5. SIMPLE PAYBACK PERIOD (1G/4)	1.83 YEARS
---------------------------------	------------

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C)	\$	46276.
--	----	--------

7. SAVINGS TO INVESTMENT RATIO (SIR) = (6 / 1G) =	9.54
(IF < 1 PROJECT DOES NOT QUALIFY)	

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR):	12.83 %
---	---------

ECO-3
Letterkenny Army Depot
Incandescent Area Light over Paper Exit Sign to LED Exit Sign

Room			Existing										Proposed					Implementation					Energy Savings \$
			NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	
Building 31																							
Warehouse																							
Exit Door	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	\$121.94	LED Exit Sign, Single Face	2	0.0	2	\$1.22	\$232	\$160	\$0	\$392		\$120.72	
Building 32																							
Warehouse																							
Exit Door	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	\$121.94	LED Exit Sign, Single Face	2	0.0	2	\$1.22	\$232	\$160	\$0	\$392		\$120.72	
Building 34																							
Warehouse																							
Exit Door	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	\$121.94	LED Exit Sign, Single Face	2	0.0	2	\$1.22	\$232	\$160	\$0	\$392		\$120.72	
Building 41																							
Warehouse																							
Exit Door	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	\$121.94	LED Exit Sign, Single Face	2	0.0	2	\$1.22	\$232	\$160	\$0	\$392		\$120.72	
Building 42S																							
Warehouse																							
Exit Door	1	1	200	200	50	95%	0.2	43	\$17.57	\$12.92	\$30.49	LED Exit Sign, Single Face	2	0.0	0	\$0.30	\$58	\$40	\$0	\$98		\$30.18	
Building 43																							
Warehouse																							
Exit Doors - One Blocked Off	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	\$121.94	LED Exit Sign, Single Face	2	0.0	2	\$1.22	\$232	\$160	\$0	\$392		\$120.72	
Building 44																							
Warehouse																							
Exit Door	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	\$121.94	LED Exit Sign, Single Face	2	0.0	2	\$1.22	\$232	\$160	\$0	\$392		\$120.72	
Building 47																							
Warehouse																							
Exit Door, South	3	1	200	600	90	95%	0.6	234	\$52.71	\$69.75	\$122.45	LED Exit Sign, Single Face	2	0.0	2	\$1.22	\$174	\$120	\$0	\$294		\$121.23	
Exit Door, North	1	1	200	200	90	95%	0.2	78	\$17.57	\$23.25	\$40.82	LED Exit Sign, Single Face	2	0.0	1	\$0.41	\$58	\$40	\$0	\$98		\$40.41	
Building 51																							
Warehouse																							
Warehouse Milvan Exit Door	2	1	200	400	50	95%	0.4	87	\$35.14	\$25.83	\$60.97	LED Exit Sign, Single Face	2	0.0	1	\$0.61	\$116	\$80	\$0	\$196		\$60.36	
Building 52																							
Warehouse																							
Exit Door	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	\$121.94	LED Exit Sign, Single Face	2	0.0	2	\$1.22	\$232	\$160	\$0	\$392		\$120.72	
Building 53																							
Warehouse																							
Exit Door	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	\$121.94	LED Exit Sign, Single Face	2	0.0	2	\$1.22	\$232	\$160	\$0	\$392		\$120.72	
Building 54																							
Warehouse																							
Exit Door	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	\$121.94	LED Exit Sign, Single Face	2	0.0	2	\$1.22	\$232	\$160	\$0	\$392		\$120.72	
Building 55																							
Warehouse																							
Exit Door	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	\$121.94	LED Exit Sign, Single Face	2	0.0	2	\$1.22	\$232	\$160	\$0	\$392		\$120.72	
TOTALS			47					8.9	2179	\$830	\$650	\$1,500			0.1	22	\$20	\$2,700	\$1,900	\$0	\$4,600		\$1,500
G:\PROJECTS\4130\01\ISSUES\DOCCO_3.WK4																							16-May-28

G:\PROJECTS\4130\JUSSECO\ECO_3.WK4

16 May 95

ECO-4A

Incandescent Area Lighting Lamp Retrofit

Existing.

Twenty-four of the buildings at Letterkenny Army Depot utilize approximately 306 incandescent luminaires of various wattages and types. The attached data table for ECO-4A lists the areas which currently utilize these incandescent fixtures. The annual electric demand, usage, and cost are as follows:

Electric Demand	=	300 kW/yr (25 kW/mo x 12 mo/yr)
Electric Usage	=	87,792 kWh/yr (7,316 kW/mo x 12 mo/yr)
Electric Cost	=	\$4,500 (300 kW/yr x \$7.706/kW) + (87,792 kWh/yr x \$0.0248 kWh) = \$4,489, use \$4,500

Proposed.

The attached ECO-4A data table provides an option for an energy efficient lamp replacement in the existing areas which currently utilize incandescent fixtures. The retrofit is expected to have the following annual electric demand, usage, and cost:

Electric Demand	=	172.8 kW/yr (14.4 kW/mo x 12 mo/yr)
Electric Usage	=	48,120 kWh/yr (4,010 kW/mo x 12 mo/yr)
Electric Cost	=	\$2,500 (172.8 kW/yr x \$7.706/kW) + (48,120 kWh/yr x \$0.0248/kWh) = \$2,525 use \$2,500

Implementation Cost. The expected construction cost for the project is \$9,700. The cost breakdown is noted below and shown on the attached ECO data table.

Material	\$6,300
Labor	\$3,400
Engineering	<u>\$ 0</u>
Total	\$9,700

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

Electric Demand	=	127.2 kW (300 - 172.8)
Electric Usage	=	39,672 kWh (87,792 - 48,120)
Energy Cost	=	\$2,000 (\$4,500 - \$2,500)
Annual Energy Savings	=	135.4 mmBtu
Energy Usage	=	135.4 mmBtu (39,672 kWh x 3,413 Btu/kWh ÷ 1,000,000 Btu/mmBtu)

Maintenance Savings. By retrofitting the existing incandescent lamps with fluorescent and halogen lamps, a maintenance savings will result because the fluorescent lamps have a three times longer life than incandescent lamps. The annual maintenance savings is noted below:

Data

Incandescent Lamp Life Avg	=	1,000 hours
Fluorescent Lamp Life Avg	=	10,000 hours
Operation Period Per Year Avg	=	2,475 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes
Incandescent Lamp Cost	=	\$1 each
Fluorescent Lamp Cost	=	\$10 each
Total Quantity	=	306

Calculation

$$\begin{array}{lcl} \text{Maintenance} & = & \$18.98 (20 \times 1/3 + 1) \times \\ \text{(Incandescent)} & & 2,475/1,000 \end{array}$$

$$\begin{array}{lcl} \text{Maintenance} & = & \$4.13 (20 \times 1/3 + 10) \times \\ \text{(Fluorescent)} & & 2,475/10,000 \end{array}$$

$$\begin{array}{lcl} \text{Annual Recurring} & = & \$4,500 (18.98 - 4.13) \times 306 \\ \text{Maintenance Savings} & = & \$4,544, \text{ use } \$4,500 \end{array}$$

Discussion.

The retrofit is estimated to provide a reduction in cooling costs and an increase in heating costs; however, these are expected to offset each other. The construction costs are based on the project being performed by an outside contractor. The Depot could implement the project as part of its continuing operation and maintenance program where fixtures could be changed out by maintenance personnel. This approach would reduce some of the labor cost but would extend out the energy savings time frame.

This ECO project will maintain existing light levels while using less energy. The use of fluorescent and halogen lamps has the potential of providing maintenance savings because of their longer lamp life.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations, construction supervision, annual recurring maintenance costs, and fixture replacement costs. The fixture replacement costs are based on the assumption that the existing fixtures will need to be replaced within the next 10 years. The fixture replacement was assumed to occur in three phases, year 5, year 7, and year 10. The replacement dollar amounts were taken from ECO-4B. The total construction cost for ECO-4B was divided by three and the dollars escalated 5, 7, and 10 years into the future assuming a 4% yearly increase. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 2.39 years with a saving to investment ratio of 6.72.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO4A

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) LCCID 1.080

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO4A

ANALYSIS DATE: 03-27-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	9700.	
B. SIOH	\$	535.	
C. DESIGN COST	\$	0.	
D. TOTAL COST (1A+1B+1C)	\$	10235.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$		10235.

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	135.	\$ 984.	18.17	\$ 17886.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 980.	17.22	\$ 16876.
N. TOTAL		135.	\$ 1964.		\$ 34761.

3. NON ENERGY SAVINGS(+) / COST(-)

A. ANNUAL RECURRING (+/-)		\$ 4500.
(1) DISCOUNT FACTOR (TABLE A)	17.22	
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$ 77490.

B. NON RECURRING SAVINGS(+) / COSTS(-)

ITEM	SAVINGS(+) COST(-) (1)	YR OC (2)	DISCNT FACTOR (3)	DISCOUNTED SAVINGS(+)/ COST(-) (4)
1. FIXTURE 1	\$ -16500.	5	.86	-14190.
2. FIXTURE 2	\$ -17850.	7	.81	-14459.
3. FIXTURE 3	\$ -20100.	10	.74	-14874.

d. TOTAL	\$ -54450.	-43523.
----------	------------	---------

C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4)	\$ 33968.
--	-----------

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS \text{ ECONOMIC LIFE}))$	\$ 4286.
--	----------

5. SIMPLE PAYBACK PERIOD (1G/4)	2.39 YEARS
---------------------------------	------------

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C)	\$ 68729.
--	-----------

7. SAVINGS TO INVESTMENT RATIO (SIR) = (6 / 1G) =	6.72
(IF < 1 PROJECT DOES NOT QUALIFY)	

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR):	11.26 %
---	---------

ECO-4A
Letterkenny Army Depot
Incandescent Area Lighting Lamp Retrofit

Existing										Proposed					Implementation						
Room	No. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw/Hr Per Month	Annual Demand (Kw)	Annual Usage (Kw/Hr)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/Hr Per Month	Annual Cost \$	Misc. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$

ECO-4A
Letterkenny Army Depot
Incandescent Area Lighting Lamp Retrofit

Room		Existing										Proposed				Implementation					Energy Savings	
		NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$		
Building 500																						
First Floor																						
Mens Room	1	1	100	100	30	50%	0.1	13	\$4.62	\$3.87	\$8.50	PL-28 Lamp/Ballast Retrofit, Quad	32	0.0	4	\$2.74	\$33	\$10	\$0	\$43	\$5.76	
Occupational Health Rm #43A	2	1	100	200	50	95%	0.2	43	\$17.57	\$12.92	\$30.49	90 Watt Halogen Lamp	90	0.2	39	\$27.44	\$16	\$20	\$0	\$36	\$3.05	
Conference Room #1	10	1	75	750	35	75%	0.6	114	\$52.02	\$33.90	\$85.92	PL-27 Lamp/Ballast Retrofit, Quad	25	0.2	38	\$28.98	\$310	\$100	\$0	\$410	\$56.94	
Conference Room #1	2	1	75	150	35	75%	0.1	23	\$10.40	\$6.78	\$17.18	50 Watt Halogen Lamp	50	0.1	15	\$11.46	\$10	\$20	\$0	\$30	\$5.73	
Kitchen	1	1	60	60	30	95%	0.1	13	\$5.27	\$3.87	\$9.15	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	3	\$2.28	\$16	\$10	\$0	\$26	\$6.87	
Women's Room	1	1	100	100	30	50%	0.1	13	\$4.62	\$3.87	\$8.50	PL-28 Lamp/Ballast Retrofit, Quad	32	0.0	4	\$2.74	\$33	\$10	\$0	\$43	\$5.76	
Basement Level																						
Stairwell #4 Command Area	1	2	60	120	168	95%	0.1	87	\$10.54	\$26.04	\$36.58	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	22	\$9.11	\$32	\$20	\$0	\$52	\$27.47	
Stairwell #2 Police Area	1	2	60	120	168	95%	0.1	87	\$10.54	\$26.04	\$36.58	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	22	\$9.11	\$32	\$20	\$0	\$52	\$27.47	
Women's Room	2	1	100	200	30	50%	0.1	26	\$9.25	\$7.75	\$17.00	PL-28 Lamp/Ballast Retrofit, Quad	32	0.0	8	\$5.47	\$66	\$20	\$0	\$86	\$11.52	
Stairwell #1 Dispensary Side	3	2	60	360	168	95%	0.3	262	\$31.63	\$78.12	\$109.74	PL-13 Lamp/Ballast Retrofit, Quad	15	0.1	65	\$27.34	\$96	\$60	\$0	\$156	\$82.40	
Stairwell #4 Command Area	1	2	100	200	168	95%	0.2	146	\$17.57	\$43.40	\$60.97	PL-28 Lamp/Ballast Retrofit, Quad	32	0.1	47	\$19.63	\$66	\$20	\$0	\$86	\$11.34	
Mens Room	2	1	100	200	30	50%	0.1	26	\$9.25	\$7.75	\$17.00	PL-28 Lamp/Ballast Retrofit, Quad	32	0.0	8	\$5.47	\$66	\$20	\$0	\$86	\$11.32	
Stairwell #3 Legal Office	2	2	60	240	168	95%	0.2	175	\$21.08	\$52.08	\$73.16	PL-13 Lamp/Ballast Retrofit, Quad	15	0.1	44	\$18.23	\$64	\$40	\$0	\$104	\$54.93	
Building 521																						
First Floor																						
Watch Room	5	1	20	100	168	95%	0.1	73	\$8.78	\$21.70	\$30.48	PL-5 Lamp/Ballast Retrofit	6	0.0	21	\$8.76	\$90	\$100	\$0	\$190	\$21.72	
Building 522																						
First Floor																						
Kitchen Area	1	2	60	120	50	95%	0.1	26	\$10.54	\$7.75	\$18.29	50 Watt Halogen Lamp	50	0.1	22	\$15.24	\$10	\$20	\$0	\$30	\$3.05	
Lobby	2	1	100	200	50	95%	0.2	43	\$17.57	\$12.92	\$30.49	PL-28 Lamp/Ballast Retrofit, Quad	32	0.1	14	\$9.82	\$66	\$20	\$0	\$86	\$20.67	
Women's Room	1	2	60	120	30	50%	0.1	16	\$5.55	\$4.65	\$10.20	50 Watt Halogen Lamp	50	0.1	13	\$8.50	\$10	\$20	\$0	\$30	\$1.70	
Women's Room	1	1	100	100	30	50%	0.1	13	\$4.62	\$3.87	\$8.50	PL-28 Lamp/Ballast Retrofit, Quad	32	0.0	4	\$2.74	\$33	\$10	\$0	\$43	\$5.76	
Second Floor																						
Women's Room	1	2	60	120	30	50%	0.1	16	\$5.55	\$4.65	\$10.20	50 Watt Halogen Lamp	50	0.1	13	\$8.50	\$10	\$20	\$0	\$30	\$1.70	
Women's Room	1	1	60	60	30	50%	0.0	8	\$2.77	\$2.32	\$5.10	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	2	\$1.27	\$16	\$10	\$0	\$26	\$3.83	
Mens Room	1	1	60	60	30	50%	0.0	8	\$2.77	\$2.32	\$5.10	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	2	\$1.27	\$16	\$10	\$0	\$26	\$3.83	
Building 523																						
Administration																						
Mens Room	1	1	60	60	30	50%	0.0	8	\$2.77	\$2.32	\$5.10	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	2	\$1.27	\$16	\$10	\$0	\$26	\$3.83	
Building 529																						
First Floor																						
Bar Table Area Pool Table Lgts.	2	3	60	360	60	95%	0.3	94	\$31.63	\$27.90	\$59.52	PL-13 Lamp/Ballast Retrofit, Quad	15	0.1	23	\$14.83	\$96	\$60	\$0	\$156	\$44.69	
Bar Table Area	16	1	75	1200	60	95%	1.1	312	\$105.42	\$92.99	\$198.41	PL-22 Lamp/Ballast Retrofit, Quad	25	0.4	105	\$66.93	\$496	\$160	\$0	\$656	\$131.48	
Second Floor																						
Galley	8	1	75	600	60	95%	0.6	156	\$52.71	\$46.50	\$99.21	PL-22 Lamp/Ballast Retrofit, Quad	25	0.2	53	\$33.47	\$248	\$80	\$0	\$328	\$65.74	
Bar Dining Area	3	1	75	225	60	95%	0.2	59	\$19.77	\$17.44	\$37.20	PL-22 Lamp/Ballast Retrofit, Quad	25	0.1	20	\$12.55	\$93	\$30	\$0	\$123	\$24.65	
Over Bar Counter	12	1	100	1200	60	95%	1.1	312	\$105.42	\$92.99	\$198.41	90 Watt Halogen Lamp	90	1.0	281	\$178.57	\$96	\$120	\$0	\$216	\$19.84	
Bar Dining Area	11	1	100	1100	60	95%	1.0	286	\$96.63	\$85.24	\$181.88	90 Watt Halogen Lamp	90	0.9	258	\$163.69	\$88	\$110	\$0	\$198	\$18.19	
Dining Room	67	1	100	6700	60	95%	6.4	1745	\$388.58	\$519.22	\$1108	90 Watt Halogen Lamp	90	5.7	1,570	\$997.02	\$556	\$670	\$0	\$1,226	\$110.78	
Women's Restroom Mirror	9	1	40	360	60	95%	0.3	94	\$31.63	\$27.90	\$59.52	PL-7 Lamp/Ballast Retrofit	8	0.1	19	\$11.98	\$162	\$180	\$0	\$342	\$47.54	
Building 581																						
First Floor																						
Main Entrance Lobby	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	50 Watt Halogen Lamp	50	0.0	11	\$7.62	\$5	\$10	\$0	\$15	\$1.52	
Mens Room	1	1	60	60	30	50%	0.0	8	\$2.77	\$2.32	\$5.10	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	2	\$1.27	\$16	\$10	\$0	\$26	\$3.83	
Women's Room	1	1	60	60	30	50%	0.0	8	\$2.77	\$2.32	\$5.10	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	2	\$1.27	\$16	\$10	\$0	\$26	\$3.83	
Second Floor																						
Stairway to Second Floor	2	3	60	360	50	95%	0.3	78	\$31.63	\$23.25	\$54.87	50 Watt Halogen Lamp	50	0.3	65	\$45.73	\$30	\$60	\$0	\$90	\$9.15	
Building 618																						
First Floor																						
Middle Exit Door	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	50 Watt Halogen Lamp	50	0.0	11	\$7.62	\$5	\$10	\$0	\$15	\$1.52	

ECO-4A
Letterkenny Army Depot
Incandescent Area Lighting Lamp Retrofit

Existing										Proposed					Implementation							
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$	
Building 637																						
Chapel																						
Entrance Lobby	3	1	75	225	40	75%	0.2	39	\$15.60	\$11.62	\$27.23	PL-22 Lamp/Ballast Retrofit, Quad	25	0.1	13	\$9.19	\$93	\$30	\$0	\$123	\$18.04	
Altar	3	1	300	900	40	75%	0.7	156	\$62.42	\$46.50	\$108.92	170 Watt Elliptical Reflector Flood	120	0.3	62	\$43.57	\$90	\$60	\$0	\$150	\$63.35	
Second Level	1	1	60	60	40	75%	0.0	10	\$4.16	\$3.10	\$7.26	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	3	\$1.81	\$16	\$10	\$0	\$26	\$5.45	
Second Level	4	1	60	240	40	75%	0.2	42	\$16.64	\$12.40	\$29.04	50 Watt Halogen Lamp	50	0.2	35	\$24.20	\$20	\$40	\$0	\$60	\$4.84	
Entrance Lobby	1	1	60	60	40	75%	0.0	10	\$4.16	\$3.10	\$7.26	50 Watt Halogen Lamp	50	0.0	9	\$6.05	\$5	\$10	\$0	\$15	\$1.21	
Back Area of Chapel	1	1	75	75	40	75%	0.1	13	\$5.20	\$3.87	\$9.08	PL-22 Lamp/Ballast Retrofit, Quad	25	0.0	4	\$3.06	\$31	\$10	\$0	\$41	\$6.01	
Back Area of Chapel	3	1	60	180	40	75%	0.1	31	\$12.48	\$9.30	\$21.78	50 Watt Halogen Lamp	50	0.1	26	\$18.15	\$15	\$30	\$0	\$45	\$3.63	
Building 663																						
Administration & Trades																						
Lower Level Mens Room	1	1	100	100	54	95%	0.1	23	\$8.78	\$6.97	\$15.76	90 W. Incandescent Lamp	90	0.1	21	\$14.18	\$1	\$10	\$0	\$11	\$1.58	
Lower Level Womens Room	1	1	100	100	54	95%	0.1	23	\$8.78	\$6.97	\$15.76	90 W. Incandescent Lamp	90	0.1	21	\$14.18	\$1	\$10	\$0	\$11	\$1.58	
Building 664																						
First Floor																						
Locker/Shower Room	1	1	60	60	30	50%	0.0	8	\$2.77	\$2.32	\$5.10	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	2	\$1.27	\$16	\$10	\$0	\$26	\$3.83	
Middle Bldg. Exit Lobby	3	1	75	225	50	95%	0.2	49	\$19.77	\$14.53	\$34.30	PL-22 Lamp/Ballast Retrofit, Quad	25	0.1	16	\$11.57	\$93	\$30	\$0	\$123	\$22.73	
Restroom	1	1	75	75	30	50%	0.0	10	\$3.47	\$2.91	\$6.37	PL-22 Lamp/Ballast Retrofit, Quad	25	0.0	3	\$2.15	\$31	\$10	\$0	\$41	\$4.22	
Building 2160																						
Administration																						
Entrance Lobby	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	50 Watt Halogen Lamp	50	0.0	11	\$7.62	\$5	\$10	\$0	\$15	\$1.52	
Ladies Room Entrance	1	1	60	60	30	50%	0.0	8	\$2.77	\$2.32	\$5.10	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	2	\$1.27	\$16	\$10	\$0	\$26	\$3.83	
Building 2755																						
Warehouse																						
Main Entrance Lobby	1	2	60	120	50	95%	0.1	26	\$10.54	\$7.75	\$18.29	50 Watt Halogen Lamp	50	0.1	22	\$15.24	\$10	\$20	\$0	\$30	\$3.05	
Womens Room Shower	1	1	60	60	30	50%	0.0	8	\$2.77	\$2.32	\$5.10	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	2	\$1.27	\$16	\$10	\$0	\$26	\$3.83	
Breakroom Sink	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	PL-13 Lamp/Ballast Retrofit, Quad	15	0.0	3	\$2.28	\$16	\$10	\$0	\$26	\$6.87	
Building 3311																						
Administration																						
Office #10	1	1	100	100	50	95%	0.1	22	\$8.78	\$6.46	\$15.24	PL-28 Lamp/Ballast Retrofit, Quad	32	0.0	7	\$4.91	\$33	\$10	\$0	\$43	\$10.33	
Building 3315																						
Warehouse																						
Entrance	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	50 Watt Halogen Lamp	50	0.0	11	\$7.62	\$5	\$10	\$0	\$15	\$1.52	
Exit Lobby	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	50 Watt Halogen Lamp	50	0.0	11	\$7.62	\$5	\$10	\$0	\$15	\$1.52	
Exit Lobby	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	50 Watt Halogen Lamp	50	0.0	11	\$7.62	\$5	\$10	\$0	\$15	\$1.52	
Key Area	2	1	100	200	50	95%	0.2	43	\$17.57	\$12.92	\$30.49	90 Watt Halogen Lamp	90	0.2	39	\$27.44	\$16	\$20	\$0	\$36	\$3.05	
TOTALS										306			28380		14.4	4010	\$2,500	\$6,300	\$3,400	\$0	\$9,700	\$2,000
PROJECTS4130.01SSREC/OMCO 4A.WK4 16-Nov-95																						

C:\PROJECTS\4130\ISSUES\ECO-4A.WK4

16 May 99

ECO-4B

Incandescent Area Lighting Fixture Replacement

Existing. Thirty-four of the buildings at Letterkenny Army Depot utilize approximately 354 incandescent luminaires of various wattages and types. The attached data table for ECO-4B lists the areas which currently utilize these incandescent fixtures. The annual electric demand, usage, and cost are as follows:

Electric Demand = 435.6 kW/yr (36.3 kW/mo x 12 mo/yr)

Electric Usage = 123,024 kWh/yr (10,252 kWh/mo x 12 mo/yr)

Electric Cost = \$6,400 (435.6 kW/yr x \$7.706/kW) + (123,024 kWh/yr x \$0.0248 kWh) = \$6,407, use \$6,400

Proposed. The attached ECO-4B data table provides an option for an energy efficient luminaire replacement in the existing areas which currently utilize incandescent fixtures. The retrofit is expected to have the following annual electric demand, usage, and cost:

Electric Demand = 174 kW/yr (14.5 kW/mo x 12 mo/yr)

Electric Usage = 48,456 kWh/yr (4,038 kW/mo x 12 mo/yr)

Electric Cost = \$2,500 (174 kW/yr x \$7.706/kW) + (48,456 kWh/yr x \$0.0248/kWh) = \$2,542, use \$2,500

Implementation Cost. The expected construction cost for the project is \$24,000. The cost breakdown is noted below and shown on the attached ECO data table.

Material	\$ 9,500
Labor	\$11,900
Engineering	<u>\$ 2,600</u>
Total	\$24,000

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

Electric Demand	=	261.6 kW (435.6 - 174)
Electric Usage	=	74,568 kWh (123,024 - 48,456)
Energy Cost	=	\$3,900 (\$6,400 - \$2,500)
Annual Energy Savings	=	254.5 mmBtu
Energy Usage	=	254.5 mmBtu (74,568 kWh x 3,413 Btu/kWh ÷ 1,000,000 Btu/mmBtu)

Maintenance Savings. By retrofitting the existing incandescent luminaires, a maintenance savings will result. The annual maintenance savings resulting from the implementation of this project is noted below:

Data

Incandescent Lamp Life Avg	=	1,000 hours
Fluorescent Lamp Life Avg	=	10,000 hours
Operation Period Per Year	=	2,475 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes
Incandescent Lamp Cost	=	\$1 each
Fluorescent Lamp Cost	=	\$10 each
Total Quantity	=	354

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO4B

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO4B

ANALYSIS DATE: 04-19-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	21400.		
B. SIOH	\$	1177.		
C. DESIGN COST	\$	2600.		
D. TOTAL COST (1A+1B+1C)	\$	25177.		
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.		
F. PUBLIC UTILITY COMPANY REBATE	\$	0.		
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$		25177.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	255.	\$ 1850.	18.17	\$ 33618.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 2000.	17.22	\$ 34440.
N. TOTAL		255.	\$ 3850.		\$ 68058.

3. NON ENERGY SAVINGS(+) / COST(-)

A. ANNUAL RECURRING (+/-)		\$ 5300.
(1) DISCOUNT FACTOR (TABLE A)	17.22	
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$ 91266.

B. NON RECURRING SAVINGS(+) / COSTS(-)

ITEM	SAVINGS(+) COST(-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS(+)/ COST(-) (4)
------	------------------------------	-----------------	------------------------	--

d. TOTAL	\$ 0.			0.
----------	-------	--	--	----

C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ 91266.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 9150.

5. SIMPLE PAYBACK PERIOD (1G/4) 2.75 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 159324.

7. SAVINGS TO INVESTMENT RATIO (SIR) = $(6 / 1G) = 6.33$
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 11.00 %

ECO-4B
Letterkenny Army Depot
Incandescent Area Lighting Fixture Replacement

Existing										Proposed				Implementation						Energy Savings
Room	NO. Of Luminaires	Lamps Per Luminaire	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	
Building 3																				
North East Area	14	1	90	1260	35	75%	0.9	191	\$56.96	\$144.34	Down Light with 75 Watt ER30 Lamp	75	0.8	159	\$120.29	\$308	\$462	\$92	\$862	\$24.06
Conference 26 F																				
Building 5N																				
Administration																				
Women's Room	1	1	60	60	30	50%	0.0	8	\$2.77	\$5.10	Down Light with PQ13	15	0.0	2	\$1.27	\$22	\$33	\$7	\$62	\$3.83
Mens Room	1	1	60	60	30	50%	0.0	8	\$2.77	\$5.10	Down Light with PQ13	15	0.0	2	\$1.27	\$22	\$33	\$7	\$62	\$3.83
Building 10																				
North East Area	1	1	100	100	50	95%	0.1	22	\$8.78	\$6.46	Round Surface Mt. w/ 2 PL13 Lamps	30	0.0	6	\$4.56	\$27	\$35	\$7	\$69	\$10.69
Exit Lobby 5-A																				
North West Area	19	1	75	1425	50	95%	1.4	309	\$125.18	\$217.21	Down Light with PQ13	15	0.3	62	\$43.30	\$418	\$627	\$125	\$1170	\$173.91
Main Entrance Lobby	2	1	75	150	35	75%	0.1	23	\$10.40	\$6.78	Down Light with PQ13	15	0.0	5	\$3.43	\$44	\$66	\$13	\$123	\$13.76
Conference Room 1-K																				
Building 14																				
First Floor																				
Entrance Lobby	1	1	100	100	50	95%	0.1	22	\$8.78	\$6.46	Round Surface Mt. w/ 2 PL13 Lamps	30	0.0	6	\$4.56	\$27	\$35	\$7	\$69	\$10.69
Ladies Room	1	1	100	100	30	50%	0.1	13	\$4.62	\$3.87	Round Surface Mt. w/ 2 PL13 Lamps	30	0.0	4	\$2.54	\$27	\$35	\$7	\$69	\$5.96
Corridor to Mens Room	1	1	100	100	50	95%	0.1	22	\$8.78	\$6.46	Round Surface Mt. w/ 2 PL13 Lamps	30	0.0	6	\$4.56	\$27	\$35	\$7	\$69	\$10.69
Mens Room	1	1	100	100	30	50%	0.1	13	\$4.62	\$3.87	Round Surface Mt. w/ 2 PL13 Lamps	30	0.0	4	\$2.54	\$27	\$35	\$7	\$69	\$5.96
Corridor to Ladies Room	1	1	100	100	50	95%	0.1	22	\$8.78	\$6.46	Round Surface Mt. w/ 2 PL13 Lamps	30	0.0	6	\$4.56	\$27	\$35	\$7	\$69	\$10.69
Building 19																				
Warehouse																				
Mens Rest Room	2	1	200	400	30	50%	0.2	52	\$18.49	\$15.50	Two-Lamp 4-Foot Industrial Strip	58	0.1	15	\$9.86	\$78	\$66	\$17	\$161	\$24.14
Women's Rest Room	2	1	200	400	30	50%	0.2	52	\$18.49	\$15.50	Two-Lamp 4-Foot Industrial Strip	58	0.1	15	\$9.86	\$78	\$66	\$17	\$161	\$24.14
Building 31																				
Warehouse																				
Warehouse	2	1	200	400	50	95%	0.4	87	\$35.14	\$25.83	Two-Lamp 4-Foot Industrial Strip	58	0.1	25	\$17.68	\$78	\$66	\$17	\$161	\$45.29
Building 32																				
Warehouse																				
Warehouse	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	Two-Lamp 4-Foot Industrial Strip	58	0.2	50	\$35.36	\$156	\$132	\$35	\$323	\$86.58
Building 33N																				
Warehouse																				
Fenced Area in Warehouse	1	1	200	200	50	95%	0.2	43	\$17.57	\$12.92	Two-Lamp 4-Foot Industrial Strip	58	0.1	13	\$8.84	\$39	\$33	\$9	\$81	\$21.61
Building 34																				
Warehouse																				
Warehouse	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	Two-Lamp 4-Foot Industrial Strip	58	0.2	50	\$35.36	\$156	\$132	\$35	\$323	\$86.58
Building 41																				
Warehouse																				
Warehouse - Stud. Inc.	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	Two-Lamp 4-Foot Industrial Strip	58	0.2	50	\$35.36	\$156	\$132	\$35	\$323	\$86.58
Building 44																				
Warehouse																				
Warehouse	4	1	200	800	50	95%	0.8	174	\$70.28	\$51.66	Two-Lamp 4-Foot Industrial Strip	58	0.2	50	\$35.36	\$156	\$132	\$35	\$323	\$86.58
Building 47																				
Warehouse																				
Mens Room South	2	1	200	400	54	95%	0.4	9	\$35.14	\$27.79	Two-Lamp 4-Foot Industrial Strip	58	0.1	27	\$18.28	\$78	\$66	\$17	\$161	\$19.65
Women's Room South	2	1	200	400	54	95%	0.4	9	\$35.14	\$27.79	Two-Lamp 4-Foot Industrial Strip	58	0.1	27	\$18.28	\$78	\$66	\$17	\$161	\$19.65
Building 51																				
Warehouse																				
Self Service Rest Mens Room	3	1	200	600	30	50%	0.3	78	\$27.74	\$23.25	Two-Lamp 4-Foot Industrial Strip	58	0.1	23	\$14.79	\$117	\$99	\$26	\$242	\$36.20
Self Service Rest Locker Room	3	1	100	300	30	50%	0.2	39	\$13.87	\$11.62	Round Surface Mt. w/ 2 PL13 Lamps	30	0.0	12	\$7.62	\$81	\$105	\$22	\$208	\$17.87
Self Service Rest Women's Room	2	1	200	400	30	50%	0.2	52	\$18.49	\$15.50	Two-Lamp 4-Foot Industrial Strip	58	0.1	15	\$9.86	\$78	\$66	\$17	\$161	\$24.14

ECO-4B
Letterkenny Army Depot
Incandescent Area Lighting Fixture Replacement

Existing										Proposed				Implementation							
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$
Warehouse Building 247																					
Stair to Offices	1	1	75	75	50	95%	0.1	16	\$6.59	\$4.84	\$11.43	Round Surface Mt. w/ 2-PL9 Lamps	21	0.0	4	\$3.16	\$27	\$35	\$7	\$69	\$8.28
Building 320																					
Maintenance																					
Women's Locker Room Lobby	1	1	100	100	30	50%	0.1	13	\$4.62	\$3.87	\$8.50	Down Light with 75 Watt ER30 Lamp	75	0.0	10	\$6.37	\$22	\$33	\$7	\$62	\$2.12
Main Office Mens Room :	1	1	100	100	30	50%	0.1	13	\$4.62	\$3.87	\$8.50	Down Light with 75 Watt ER30 Lamp	75	0.0	10	\$6.37	\$22	\$33	\$7	\$62	\$2.12
Women's Locker Room Office	4	1	100	400	30	50%	0.2	52	\$18.49	\$15.50	\$33.99	Down Light with 75 Watt ER30 Lamp	75	0.2	39	\$25.50	\$88	\$132	\$26	\$246	\$8.50
Mens Locker Room Lobby	1	1	100	100	30	50%	0.1	13	\$4.62	\$3.87	\$8.50	Down Light with 75 Watt ER30 Lamp	75	0.0	10	\$6.37	\$22	\$33	\$7	\$62	\$2.12
Mens Locker Room Office	4	1	100	400	30	50%	0.2	52	\$18.49	\$15.50	\$33.99	Down Light with 75 Watt ER30 Lamp	75	0.2	39	\$25.50	\$88	\$132	\$26	\$246	\$8.50
Shower Room	1	1	100	100	30	50%	0.1	13	\$4.62	\$3.87	\$8.50	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	4	\$2.54	\$27	\$35	\$7	\$69	\$5.96
Building 350																					
Office #2																					
Computer PLC I/O Room	7	1	100	700	90	95%	0.7	273	\$61.49	\$81.37	\$142.86	Round Surface Mt. w/ 2-PL13 Lamps	30	0.2	82	\$42.72	\$189	\$245	\$52	\$486	\$100.15
Mens Room	16	1	100	1600	54	95%	1.5	375	\$140.56	\$111.59	\$252.15	Round Surface Mt. w/ 2-PL13 Lamps	30	0.5	112	\$75.39	\$432	\$560	\$119	\$1,111	\$176.76
Women's Room	16	1	100	1600	54	95%	1.5	375	\$140.56	\$111.59	\$252.15	Round Surface Mt. w/ 2-PL13 Lamps	30	0.5	112	\$75.39	\$432	\$560	\$119	\$1,111	\$176.76
Corridor to Shop	2	1	100	200	90	95%	0.2	78	\$17.57	\$23.25	\$40.82	Round Surface Mt. w/ 2-PL13 Lamps	30	0.1	23	\$12.20	\$54	\$70	\$15	\$139	\$28.61
Office #3																					
Breakroom	7	1	100	700	90	95%	0.7	273	\$61.49	\$81.37	\$142.86	Round Surface Mt. w/ 2-PL13 Lamps	30	0.2	82	\$42.72	\$189	\$245	\$52	\$486	\$100.15
Corridor down ASRS&Breakrm.	1	1	100	100	90	95%	0.1	39	\$8.78	\$11.62	\$20.41	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	12	\$6.10	\$27	\$35	\$7	\$69	\$14.31
Office #4																					
Corridor to Shop	3	1	100	300	90	95%	0.3	117	\$26.35	\$34.87	\$61.23	Round Surface Mt. w/ 2-PL13 Lamps	30	0.1	35	\$18.31	\$81	\$105	\$22	\$208	\$42.92
Mens Room	7	1	100	700	54	95%	0.7	164	\$61.49	\$48.82	\$110.52	Round Surface Mt. w/ 2-PL13 Lamps	30	0.2	49	\$32.98	\$189	\$245	\$52	\$486	\$77.33
Building 370																					
Equipment Repair																					
Corridor to Mens & Ladies Room	1	1	100	100	90	95%	0.1	39	\$8.78	\$11.62	\$20.41	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	12	\$6.10	\$27	\$35	\$7	\$69	\$14.31
Ladies Room	4	1	100	400	54	95%	0.4	94	\$35.14	\$27.90	\$63.04	Round Surface Mt. w/ 2-PL13 Lamps	30	0.1	28	\$18.85	\$108	\$140	\$30	\$278	\$41.19
Shop Area Entrance	1	1	100	100	90	95%	0.1	39	\$8.78	\$11.62	\$20.41	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	12	\$6.10	\$27	\$35	\$7	\$69	\$14.31
Mens Room (Entrance)	1	1	100	100	54	95%	0.1	23	\$8.78	\$6.97	\$15.76	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	7	\$4.71	\$27	\$35	\$7	\$69	\$11.05
Building 412																					
Training & Conf. Center	1	1	200	200	50	95%	0.2	43	\$17.57	\$12.92	\$30.49	Two-Lamp 4-Foot Industrial Strip	58	0.1	13	\$8.84	\$39	\$33	\$9	\$81	\$21.64
Rear Exit Lobby																					
Building 424																					
Cable & Harness																					
Mens Room	1	1	100	100	54	95%	0.1	23	\$8.78	\$6.97	\$15.76	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	7	\$4.71	\$27	\$35	\$7	\$69	\$11.05
Women's Room	1	1	100	100	54	95%	0.1	23	\$8.78	\$6.97	\$15.76	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	7	\$4.71	\$27	\$35	\$7	\$69	\$11.05
Building 428																					
Counseling																					
Women's Room	1	1	100	100	30	50%	0.1	13	\$4.62	\$3.87	\$8.50	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	4	\$2.54	\$27	\$35	\$7	\$69	\$5.96
Mens Room	1	1	100	100	30	50%	0.1	13	\$4.62	\$3.87	\$8.50	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	4	\$2.54	\$27	\$35	\$7	\$69	\$5.96
Building 438																					
Repair Shop																					
Mens Room	2	1	300	600	30	50%	0.3	78	\$27.74	\$23.25	\$50.99	Two-Lamp 4-Foot Industrial Strip	58	0.1	15	\$9.86	\$78	\$66	\$17	\$161	\$41.13
Ladies Room	2	1	300	600	30	50%	0.3	78	\$27.74	\$23.25	\$50.99	Two-Lamp 4-Foot Industrial Strip	58	0.1	15	\$9.86	\$78	\$66	\$17	\$161	\$41.13
Office	2	1	300	600	50	95%	0.6	130	\$52.71	\$38.75	\$91.46	Two-Lamp 4-Foot Industrial Strip	58	0.1	25	\$17.68	\$78	\$66	\$17	\$161	\$73.77

ECO-4B

Page 3 of 4

ECO-4B
Letterkenny Army Depot
Incandescent Area Lighting Fixture Replacement

Existing										Proposed				Implementation							
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On Peak	Usage Kw/Hr Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/Hr Per Month	Annual Cost	Mat. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings
Building 663																					
Administration & Trades																					
Lower Level Womens Room	2	1	200	400	54	95%	0.4	94	\$35.14	\$27.90	\$63.04	Two-Lamp 4-Foot Industrial Strip	58	0.1	27	\$18.28	\$78	\$66	\$17	\$161	\$44.76
Lower Level Mens Room	1	1	100	100	54	95%	0.1	23	\$8.78	\$6.97	\$15.76	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	7	\$4.71	\$27	\$35	\$7	\$69	\$11.05
Corridor Outside Snack Bar	3	1	300	900	90	95%	0.9	352	\$79.06	\$104.62	\$183.68	Two-Lamp 4-Foot Industrial Strip	58	0.2	68	\$35.51	\$117	\$99	\$28	\$242	\$148.17
Lower Level Mens Room	2	1	200	400	54	95%	0.4	94	\$35.14	\$27.90	\$63.04	Two-Lamp 4-Foot Industrial Strip	58	0.1	27	\$18.28	\$78	\$66	\$17	\$161	\$44.76
Electrical Supply	9	1	300	2,700	90	95%	2.6	1055	\$237.19	\$313.85	\$551.05	Two-Lamp 4-Foot Industrial Strip	58	0.5	204	\$106.54	\$351	\$297	\$78	\$726	\$444.51
Drawing Files Area	3	1	300	900	54	95%	0.9	211	\$79.06	\$62.77	\$141.83	Two-Lamp 4-Foot Industrial Strip	58	0.2	41	\$27.42	\$117	\$99	\$26	\$242	\$114.41
Lower Level Womens Room	1	1	100	100	54	95%	0.1	23	\$8.78	\$6.97	\$15.76	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	7	\$4.71	\$27	\$35	\$7	\$69	\$11.05
Lower Level Mens Room	2	1	300	600	54	95%	0.6	141	\$52.71	\$41.85	\$94.56	Two-Lamp 4-Foot Industrial Strip	58	0.1	27	\$18.28	\$78	\$66	\$17	\$161	\$76.28
Building 664																					
First Floor																					
Locker/Shower Room	1	1	60	60	30	50%	0.0	8	\$2.77	\$2.32	\$5.10	Round Surface Mt. w/ 1-PL13 Lamp	15	0.0	2	\$1.27	\$22	\$33	\$7	\$62	\$3.83
Middle Bldg. Exit Lobby	3	1	75	225	50	95%	0.2	49	\$19.77	\$14.53	\$34.30	Round Surface Mt. w/ 2-PL9 Lamps	21	0.1	13	\$9.47	\$81	\$105	\$22	\$208	\$24.83
Restroom	1	1	75	75	30	50%	0.0	10	\$3.47	\$2.91	\$6.37	Round Surface Mt. w/ 2-PL9 Lamps	21	0.0	3	\$1.76	\$27	\$35	\$7	\$69	\$4.61
Building 2260																					
Administration																					
Entrance Lobby	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	Down Light with PQ13	15	0.0	3	\$2.28	\$22	\$33	\$7	\$62	\$6.87
Ladies Room Entrance	1	1	60	60	30	50%	0.0	8	\$2.77	\$2.32	\$5.10	Round Surface Mt. w/ 1-PL13 Lamp	15	0.0	2	\$1.27	\$22	\$33	\$7	\$62	\$3.83
Building 2755																					
Warehouse																					
Main Entrance Lobby	1	2	60	120	50	95%	0.1	26	\$10.54	\$7.75	\$18.29	Down Light with PQ13	15	0.0	3	\$2.28	\$22	\$33	\$7	\$62	\$16.01
Womens Room Shower	1	1	60	60	30	50%	0.0	8	\$2.77	\$2.32	\$5.10	Round Surface Mt. w/ 1-PL13 Lamp	15	0.0	2	\$1.27	\$22	\$33	\$7	\$62	\$3.83
Breakroom Sink	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	Round Surface Mt. w/ 1-PL13 Lamp	15	0.0	3	\$2.28	\$22	\$33	\$7	\$62	\$6.87
Building 3311																					
Administration																					
Office #10	1	1	100	100	50	95%	0.1	22	\$8.78	\$6.46	\$15.24	Round Surface Mt. w/ 2-PL13 Lamps	30	0.0	6	\$4.56	\$27	\$35	\$7	\$69	\$10.69
Building 3315																					
Warehouse																					
Entrance	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	Down Light with PQ13	15	0.0	3	\$2.28	\$22	\$33	\$7	\$62	\$6.87
Exit Lobby	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	Down Light with PQ13	15	0.0	3	\$2.28	\$22	\$33	\$7	\$62	\$6.87
Exit Lobby	1	1	60	60	50	95%	0.1	13	\$5.27	\$3.87	\$9.15	Down Light with PQ13	15	0.0	3	\$2.28	\$22	\$33	\$7	\$62	\$6.87
Key Area	2	1	100	200	50	95%	0.2	43	\$17.57	\$12.92	\$30.49	Down Light with 75 Watt ER-30 Lamp	75	0.1	33	\$22.86	\$44	\$66	\$13	\$123	\$7.62
TOTALS		354		42020			36.3	10252	\$3,400	\$3,100	\$6,400			14.5	4038	\$2,500	\$9,500	\$11,900	\$2,600	\$24,000	\$3,900
PROJECT-TS4130-01SSRCEBECO_4B.WK4																					
16-May-99																					

G:\PROJECTS\4130.01\SSR\ECOECO_4B.WK4
16 May 99

ECO-5 HID Lighting

Existing. Six of the buildings at the Letterkenny Army Depot contain approximately 187 incandescent luminaires at mounting heights of 20 feet above the floor or more. The attached data table for ECO-5 lists the areas which currently utilize these luminaires. The luminaires range in operation from 168 hours to 40 hours per week, most contributing approximately 95% of their connected load to the demand. The annual electric demand, usage, and cost for these fixtures are as follows:

Electric Demand	=	525.6 kW/yr (43.8 kW/mo x 12 mo/yr)
Electric Usage	=	215,112 kWh/yr (17,926 kWh/mo x 12 mo/yr)
Electric Cost	=	\$9,400 (525.6 kW/yr x \$7.706/kW) + (215,112 kWh/yr x \$.0248/kWh) = \$9,385, use \$9,400

Proposed. Remove and replace all existing incandescent luminaires and replace with high-pressure sodium or metal halide luminaires. Reference the attached data table for ECO-5. The new luminaires have a long life expectancy. The lamps for metal halide average 10,000 hours of operation. The high-pressure sodium lamps average 24,000 hours of operation. The metal halide and high-pressure sodium lamps have a life of 13 and 32 times respectively when compared to the life of the incandescent lamps they are replacing. The annual electric demand, usage, and cost of the proposed ECO is noted below:

Electric Demand	=	140.4 kW/yr (11.7 kW/mo x 12 mo/yr)
Electric Usage	=	59,424 kWh/yr (4,952 kWh/mo x 12 mo/yr)
Electric Cost	=	\$2,600 (140.4 kW/yr x \$7.706/kW) + (59,424 kWh/yr x \$.0248/kWh) = \$2,555, use \$2,600

Implementation Cost. The expected construction cost for implementing the project is expected to be \$41,000. The breakdown is noted below and shown on the attached ECO data table.

Material	\$29,000
Labor	\$ 7,200
Engineering	<u>\$ 4,400</u>
Total	\$40,600, use \$41,000

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

Electric Demand	=	385.2 kW/yr (525.6 - 140.4)
Electric Usage	=	155,688 kWh/yr (215,112 - 59,424)
Energy Cost	=	\$6,800/yr (\$9,400 - \$2,600)
Annual Energy Savings	=	531.4 mmBtu/yr
Energy Usage	=	531.4 mmBtu/yr (155,688 kWh/yr x 3,413 Btu/kWh) ÷ 1,000,000 Btu/mmBtu

Maintenance Savings.

By retrofitting the existing incandescent luminaires with HID luminaires, a maintenance savings will result. The annual maintenance savings is noted below:

Data

Incandescent Lamp Life	=	750 hours
HID Lamp Life Avg	=	16,000 hours
Operation Period Per Year	=	4,873 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes
Incandescent Lamp Cost	=	\$1 each
HID Lamp Cost	=	\$65 each
Total Quantity Incandescent	=	187
Total Quantity HID	=	74

Calculation

Maintenance (Incandescent)	=	$\$49.81 (20 \times 1/3 + 1) \times 4,873/750$
Maintenance (Fluorescent)	=	$\$21.83 (20 \times 1/3 + 65) \times 4,873/16,000$
Annual Recurring Maintenance Savings	=	$\$7,700 (49.81 \times 187) - (21.83 \times 74) = \$7,699, \text{ use } \$7,700$

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations, construction supervision, and annual recurring maintenance costs in addition to construction cost. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 2.88 years with a savings to investment ratio of 6.06.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO5

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO5

ANALYSIS DATE: 04-19-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	36200.	
B. SIOH	\$	1991.	
C. DESIGN COST	\$	4400.	
D. TOTAL COST (1A+1B+1C)	\$	42591.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$	42591.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	531.	\$ 3863.	18.17	\$ 70196.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 3000.	17.22	\$ 51660.
N. TOTAL		531.	\$ 6863.		\$ 121856.

3. NON ENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)		\$ 7900.
(1) DISCOUNT FACTOR (TABLE A)	17.22	
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$ 136038.

B. NON RECURRING SAVINGS (+) / COSTS (-)

ITEM	SAVINGS (+) COST (-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS (+) / COST (-) (4)
d. TOTAL	\$ 0.			0.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS (+) / COST (-) (3A2+3Bd4) \$ 136038.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 14763.

5. SIMPLE PAYBACK PERIOD (1G/4) 2.88 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 257894.

7. SAVINGS TO INVESTMENT RATIO (SIR) = $(6 / 1G) =$ 6.06
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 10.80 %

ECO-5
Letterkenny Army Depot
HID Lighting

Room	NO. Of Luminaires	Existing										Proposed										Implementation					Energy Savings \$
		Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw On Peak Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Qty of Luminaires	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw On Peak Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Inv. Cost \$	Total Cost \$						
Warehouse - North	17	1	300	5100	90	95%	4.8	1992	\$448	\$593	\$1,041	150 Watt HPS, High Bay Aisle Lighter	7	173	1.1	472	\$246.44	\$2,800	\$700	\$420	\$3,920	\$794.42					
Warehouse - South	17	1	300	5100	90	95%	4.8	1992	\$448	\$593	\$1,041	150 Watt HPS, High Bay Aisle Lighter	7	173	1.1	472	\$246.44	\$2,800	\$700	\$420	\$3,920	\$794.42					
Boiler Plant	17	1	300	5100	168	95%	4.8	3719	\$448	\$1,107	\$1,555	175 Watt MH, Low Bay	8	201	1.5	1,174	\$490.78	\$3,200	\$800	\$480	\$4,480	\$1,064.02					
Second Level Boiler Room	26	1	300	7800	40	75%	5.9	1354	\$541	\$403	\$944	175 Watt MH, Low Bay	12	201	1.8	419	\$292.26	\$4,800	\$1,200	\$720	\$6,720	\$651.65					
Air Compressor Room	26	1	300	7800	40	75%	5.9	1354	\$541	\$403	\$944	175 Watt MH, Low Bay	12	201	1.8	419	\$292.26	\$4,800	\$1,200	\$720	\$6,720	\$651.65					
Cable & Harness	42	1	100	4200	90	95%	4.0	1641	\$369	\$488	\$857	100 Watt MH, High Bay	9	115	1.0	404	\$211.23	\$3,150	\$675	\$459	\$4,284	\$645.95					
Upholstery Work Shop	42	1	100	4200	90	95%	4.0	1641	\$369	\$488	\$857	100 Watt MH, High Bay	9	115	1.0	404	\$211.23	\$3,150	\$675	\$459	\$4,284	\$645.95					
Boiler Shop	28	1	300	8400	50	95%	8.0	1823	\$738	\$542	\$1,280	150 Watt HPS, Low Bay	12	173	2.0	449	\$315.53	\$4,800	\$1,200	\$720	\$6,720	\$964.87					
Shipping Area	28	1	300	8400	50	95%	8.0	1823	\$738	\$542	\$1,280	150 Watt HPS, Low Bay	12	173	2.0	449	\$315.53	\$4,800	\$1,200	\$720	\$6,720	\$964.87					
Warehouse	33	1	300	9900	50	95%	9.4	2148	\$870	\$639	\$1,509	150 Watt HPS, Low Bay	14	173	2.3	524	\$368.11	\$5,600	\$1,400	\$840	\$7,840	\$1,140.92					
Warehouse	33	1	300	9900	50	95%	9.4	2148	\$870	\$639	\$1,509	150 Watt HPS, Low Bay	14	173	2.3	524	\$368.11	\$5,600	\$1,400	\$840	\$7,840	\$1,140.92					
Physical Fitness	24	1	300	7200	168	95%	6.8	5250	\$633	\$1,562	\$2,195	150 Watt MH, High Bay, Gymnasium	12	173	2.0	1,599	\$631.01	\$4,800	\$1,200	\$720	\$6,720	\$1,563.80					
Basketball Court	24	1	300	7200	168	95%	6.8	5250	\$633	\$1,562	\$2,195	150 Watt MH, High Bay, Gymnasium	12	173	2.0	1,599	\$631.01	\$4,800	\$1,200	\$720	\$6,720	\$1,563.80					
TOTALS	187			47700			43.8	17926	\$4,000	\$5,300	\$9,400				11.7	4932	\$2,600	\$29,000	\$7,200	\$4,400	\$41,000	\$6,800					

C:\PROJECTS\13041\SS\ECO\ECO_5.WK4

16-May-95

ECO-6 Efficient Fluorescent Lighting Retrofit

Existing. Seventy-two buildings at the Letterkenny Army Depot contain approximately 7,382 fluorescent luminaires of various types. The total watts for the existing luminaires is 1,030,607 watts. The luminaires operate between 30 and 168 hours per week and contribute approximately 50% to 95% of their connected load to the demand. The annual electric demand, usage, and cost for these fixtures are as follows:

Electric Demand	=	11,486 kW/yr (957.2 kW/mo x 12 mo/yr)
Electric Usage	=	3,588,264 kWh/yr (299,022 kWh/mo x 12 mo/yr)
Electric Cost	=	\$177,000 (11,486 kW/yr x \$7.706/kW) + (3,588,264 kWh/yr x \$.0248/kWh) = \$177,500, use \$177,000

Proposed. Remove the existing lamps and ballast and install T-8 lighting system with electronic ballast. Reference the attached data tables for ECO-6. The average electric usage per T-8 lamp with an electronic ballast is 31 watts. The T-8 lamps are thinner than the standard T-12 lamps but will fit into the existing pin connectors. The annual electric demand, usage, and cost of the proposed ECO is noted below:

Electric Demand	=	7,182 kW/yr (598.5 kW/mo x 12 mo/yr)
Electric Usage	=	2,238,540 kWh/yr (186,545 kWh/mo x 12 mo/yr)

Electric Cost	=	\$110,000 (7,182 kW/yr x \$7.706/kW) + (2,238,540 kWh/yr x \$.0248/kWh) = \$110,860, use \$110,000
---------------	---	--

Implementation Cost. The expected construction cost for implementing the project is expected to be \$628,000. The breakdown is noted below and shown on the attached ECO data sheet.

Material	\$295,000
Labor	\$283,000
Engineering	<u>\$ 50,000</u>
Total	\$628,000

Energy Savings. The annual electric demand, usage, and cost saved is noted below:

Electric Demand	=	4,304 kW/yr (11,486 - 7182)
Electric Usage	=	1,349,724 kWh/yr (3,588,264 - 2,238,540)
Energy Cost	=	\$67,000/yr (\$177,000 - \$110,000)
Annual Energy Savings	=	4,607 mmBtu/yr
Energy Usage	=	4,607 mmBtu/yr (1,349,724 kWh/yr x 3,413 Btu/kWh) ÷ 1,000,000 Btu/mmBtu

Maintenance Savings. The T-8 lamps have the same rated average life as the existing T-12 lamps, 20,000 hours; therefore, there is no annual recurring maintenance savings. The installation of T-8s will reduce the existing required lamp and ballast changes, since all new lamps and ballast are being installed.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO6

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO6

ANALYSIS DATE: 05-11-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	578000.	
B. SIOH	\$	31790.	
C. DESIGN COST	\$	50000.	
D. TOTAL COST (1A+1B+1C)	\$	659790.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$	659790.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	4607.	\$ 33493.	18.17	\$ 608566.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 33000.	17.22	\$ 568260.
N. TOTAL		4607.	\$ 66493.		\$ 1176826.

3. NON ENERGY SAVINGS(+) / COST(-)

A. ANNUAL RECURRING (+/-)		\$	0.
(1) DISCOUNT FACTOR (TABLE A)	17.22		
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$	0.

B. NON RECURRING SAVINGS(+) / COSTS(-)

ITEM	SAVINGS(+) COST(-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS(+) / COST(-) (4)
d. TOTAL	\$ 0.			0.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+) / COST(-) (3A2+3Bd4) \$ 0.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 66493.

5. SIMPLE PAYBACK PERIOD (1G/4) 9.92 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 1176826.

7. SAVINGS TO INVESTMENT RATIO (SIR) = $(6 / 1G) =$ 1.78
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 5.51 %

**Summary ECO6A - ECO6E
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit**

Room		Existing										Proposed										Implementation					Energy Savings \$
		NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage KwH Per Month	Annual Demand (Kw)	Annual Usage (KwH)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed KwH Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$						
ECO-4A Summary		3561			484254			453.7	141491	\$42,000	\$42,000	\$84,000			285.8	88571	\$53,000	\$141,000	\$137,000	\$24,000	\$302,000	\$31,000					
ECO-4B Summary		551			76,337			72.0	21347	\$6,000	\$6,000	\$13,000			44.1	13,016	\$8,000.00	\$22,000	\$21,000	\$4,000	\$47,000	\$5,000					
ECO-4C Summary		1272			190,118			174.3	61002	\$16,000	\$18,000	\$34,000			107.8	37,869	\$21,000.00	\$52,000	\$49,000	\$9,000	\$110,000	\$13,000					
ECO-4D Summary		894			128,800			117.7	30327	\$9,000	\$9,000	\$20,000			73.5	18,972	\$12,000.00	\$36,000	\$34,000	\$6,000	\$76,000	\$7,500					
ECO-4E Summary		1104			151,999			139.5	44856	\$13,000	\$13,000	\$26,000			87.3	28,116	\$16,000.00	\$44,000	\$42,000	\$7,000	\$93,000	\$10,000					
TOTALS		7382			1030607			957.2	299022	\$89,000	\$88,000	\$177,000			598.5	186545	\$110,000	\$295,000	\$283,000	\$50,000	\$628,000	\$67,000					
APPROPRIATE		APPROPRIATE																				22 May 95					

G:\PROJECTS\41300\USSECO\ECO_6.WK4

22 May 95

ECO-6A
Buildings 1 - 10
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Existing			Proposed										Implementation				Energy Savings \$
				Hours Per Week	Percent Of Kw On Peak	Demanded Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/Hr Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$		
Building 1																					
Office Area																					
Office	3	3	40	414	50	95%	89.8	\$36.37	\$26.74	\$63.11	3-F2T8 & 1-3L Electronic Ballast	88	0.3	57	\$40.24	\$120	\$120	\$21	\$261	\$72.86	
DPME Womens Room	1	3	40	138	50	95%	18.0	\$6.38	\$5.35	\$11.73	3-F2T8 & 1-3L Electronic Ballast	88	0.0	11	\$7.48	\$40	\$40	\$7	\$87	\$4.25	
DPME Mens Room	2	4	40	368	50	95%	47.9	\$17.01	\$14.26	\$31.27	3-F2T8 & 1-4L Electronic Ballast	112	0.1	29	\$19.04	\$90	\$90	\$15	\$185	\$12.24	
DPME Mens Room	1	3	40	138	50	95%	18.0	\$6.38	\$5.35	\$11.73	3-F2T8 & 1-3L Electronic Ballast	88	0.0	11	\$7.48	\$40	\$40	\$7	\$87	\$4.25	
DPME Womens Room	2	4	40	368	50	95%	47.9	\$17.01	\$14.26	\$31.27	3-F2T8 & 1-4L Electronic Ballast	112	0.1	29	\$19.04	\$90	\$90	\$15	\$185	\$12.24	
Chief Engineering Support Office	2	3	40	276	50	95%	39.9	\$14.26	\$11.73	\$26.74	3-F2T8 & 1-3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24	
Engineering Work Area	113	3	40	15594	50	95%	3383.9	\$1,369.91	\$1,007.05	\$2,376.96	3-F2T8 & 1-3L Electronic Ballast	88	9.4	2,158	\$1,515.74	\$4,520	\$4,520	\$782	\$9,822	\$861.22	
DPME Section Office	4	4	40	472	50	95%	119.8	\$44.49	\$35.06	\$84.14	3-F2T8 & 1-4L Electronic Ballast	112	0.9	76	\$136.58	\$360	\$360	\$59	\$719	\$87.80	
Production Engineering Office	8	4	40	552	50	95%	199.8	\$74.25	\$57.82	\$124.07	3-F2T8 & 1-4L Electronic Ballast	112	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24	
Chief Production Eng. Office	2	3	40	276	50	95%	39.9	\$14.26	\$11.73	\$26.74	3-F2T8 & 1-3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24	
Conference Room A	4	4	40	736	50	95%	111.8	\$41.04	\$33.77	\$76.09	3-F2T8 & 1-4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$90	\$15	\$185	\$12.24	
DPME File Room	1	4	40	184	50	95%	62.0	\$22.82	\$18.88	\$42.07	3-F2T8 & 1-4L Electronic Ballast	112	0.3	68	\$51.32	\$180	\$180	\$29	\$369	\$32.99	
DPME Work Area	18	4	40	2484	50	95%	24.0	\$9.08	\$7.65	\$16.61	3-F2T8 & 1-4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$45	\$7	\$92	\$10.97	
DPME Copy Room	1	3	40	138	50	95%	18.0	\$6.38	\$5.35	\$11.73	3-F2T8 & 1-3L Electronic Ballast	88	1.5	344	\$241.45	\$720	\$720	\$125	\$1,565	\$137.18	
Chief Requisition Office	3	3	40	414	50	95%	89.8	\$36.37	\$26.74	\$63.11	3-F2T8 & 1-3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$87	\$7.62	
Logistics Office	2	3	40	276	50	95%	39.9	\$14.26	\$11.73	\$26.74	3-F2T8 & 1-3L Electronic Ballast	88	0.3	57	\$40.24	\$120	\$120	\$21	\$261	\$72.86	
Production Planning Conf. Rm.	5	4	40	736	50	95%	111.8	\$41.04	\$33.77	\$76.09	3-F2T8 & 1-4L Electronic Ballast	112	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24	
Chief Production Office	2	3	40	276	50	95%	39.9	\$14.26	\$11.73	\$26.74	3-F2T8 & 1-3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24	
Manager Analysis Office	2	3	40	276	50	95%	39.9	\$14.26	\$11.73	\$26.74	3-F2T8 & 1-3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24	
Conference Room B	4	4	40	736	50	95%	111.8	\$41.04	\$33.77	\$76.09	3-F2T8 & 1-4L Electronic Ballast	112	0.3	68	\$51.32	\$180	\$180	\$29	\$369	\$32.99	
Corridor B	10	1	40	460	50	95%	99.8	\$36.37	\$26.74	\$63.11	3-F2T8 & 1-3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24	
Deputy Director Maint. Office	2	3	40	276	50	95%	39.9	\$14.26	\$11.73	\$26.74	3-F2T8 & 1-3L Electronic Ballast	88	0.3	57	\$40.24	\$120	\$120	\$21	\$261	\$72.86	
Director Maintenance Office	3	3	40	414	50	95%	89.8	\$36.37	\$26.74	\$63.11	3-F2T8 & 1-3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24	
Corridor A	16	1	40	736	50	95%	159.7	\$58.66	\$47.53	\$112.19	1-F2T8 & 1-2L Electronic Ballast	60	0.5	108	\$75.60	\$480	\$560	\$90	\$1,130	\$36.58	
Corridor A (Entrance Lobby)	2	2	40	92	50	95%	20	\$8.08	\$5.94	\$14.02	2-F2T8 & 1-2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
CP Office	2	2	40	184	50	95%	62.0	\$22.82	\$18.88	\$42.07	2-F2T8 & 1-2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76	
Balloon Office	4	4	40	1472	50	95%	319	\$120.31	\$95.06	\$224.37	4-F2T8 & 1-4L Electronic Ballast	112	0.9	194	\$136.58	\$360	\$360	\$59	\$719	\$87.80	
Print Room	13	4	40	2,392	50	95%	2,319	\$864.66	\$671.30	\$1,661.61	4-F2T8 & 1-4L Electronic Ballast	112	1.4	316	\$221.93	\$865	\$865	\$96	\$1,201	\$42.07	
IMA Support Office	6	4	40	1,104	50	95%	240	\$86.98	\$71.30	\$168.28	4-F2T8 & 1-4L Electronic Ballast	112	0.6	146	\$102.43	\$270	\$270	\$44	\$354	\$65.85	
Record Managers Office	4	4	40	736	50	95%	160	\$58.66	\$47.53	\$112.19	4-F2T8 & 1-4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$180	\$29	\$369	\$32.99	
Cafe Area	3	4	40	532	50	95%	120	\$44.49	\$35.06	\$84.14	4-F2T8 & 1-4L Electronic Ballast	112	0.3	73	\$51.72	\$135	\$135	\$22	\$277	\$32.92	
Receiving Bay	1	2	40	92	50	95%	20	\$8.08	\$5.94	\$14.02	2-F2T8 & 1-2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
Corridor to Rooms #2 #6	4	2	40	368	50	95%	80	\$32.33	\$23.77	\$56.09	2-F2T8 & 1-2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304	\$19.51	
CP Shop Area B	28	2	75	4,830	50	95%	1,048	\$384.31	\$311.92	\$736.23	2-F2T8 & 1-2L Electronic Ballast	104	2.8	632	\$443.87	\$1,120	\$980	\$182	\$2,282	\$292.36	
CP Shop Area A	63	2	75	10,868	50	95%	10.3	\$384.31	\$311.92	\$736.23	2-F2T8 & 1-2L Electronic Ballast	104	6.2	1,422	\$998.71	\$2,520	\$2,205	\$409	\$5,134	\$657.80	
CP Shop Area A	12	2	40	92	50	95%	20	\$8.08	\$5.94	\$14.02	2-F2T8 & 1-2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
CP Shop Area A	1	2	40	1,104	50	95%	240	\$86.98	\$71.30	\$168.28	2-F2T8 & 1-2L Electronic Ballast	60	0.7	156	\$109.75	\$420	\$420	\$73	\$913	\$58.53	
CP Shop Area B	1	2	40	92	50	95%	20	\$8.08	\$5.94	\$14.02	2-F2T8 & 1-2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
CP Exit Lobby	1	2	40	92	50	95%	20	\$8.08	\$5.94	\$14.02	2-F2T8 & 1-2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
CP Shop Area B	4	2	40	368	50	95%	80	\$32.33	\$23.77	\$56.09	2-F2T8 & 1-2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304	\$19.51	
Corridor to Cafe	6	4	20	552	50	95%	120	\$44.49	\$35.06	\$84.14	4-F17T8 & 2-2L Electronic Ballast	36	0.3	76	\$53.04	\$360	\$360	\$62	\$782	\$31.10	
Building 2																					
Administration																					
South Entrance #2 Open Office	12	3	40	1,656	50	95%	359	\$145.48	\$106.94	\$252.42	3-F2T8 & 1-3L Electronic Ballast	88	1.0	229	\$160.96	\$480	\$480	\$83	\$1,043	\$91.46	
G. Kirk Office	8	4	40	1,472	50	95%	319	\$120.31	\$95.06	\$224.37	4-F2T8 & 1-4L Electronic Ballast	112	0.9	194	\$136.58	\$360	\$360	\$59	\$719	\$87.80	
Conference Room	8	4	40	1,472	50	95%	319	\$120.31	\$95.06	\$224.37	4-F2T8 & 1-4L Electronic Ballast	112	0.7	136	\$102.65	\$360	\$360	\$59	\$719	\$87.80	
Movement Branch Mgmt. Office	4	4	40	736	50	95%	160	\$58.66	\$47.53	\$112.19	4-F2T8 & 1-4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$180	\$29	\$369	\$32.99	
Industrial Hygiene	36	4	40	6,624	50	95%	6.3	\$23.91	\$19.91	\$44.02	3-F2T8 & 1-3L Electronic Ballast	88	0.8	97	\$68.29	\$180	\$180	\$29	\$369	\$32.99	
South Entrance #2 Office	2	3	40	276	50	95%	39.9	\$14.26	\$11.73	\$26.74	3-F2T8 & 1-3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24	
Entrance Lobby South East	1	2	40	92	50	95%	20	\$8.08	\$5.94	\$14.02	2-F2T8 & 1-2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
Director's Conference Reception	9	4	40	1,656	50	95%	359	\$145.48	\$106.94	\$252.42	3-F2T8 & 1-3L Electronic Ballast	88	1.0	229	\$160.96	\$480	\$480	\$83	\$1,043	\$91.46	
South Entrance Lobby #1	5	3	40	690	50	95%	150	\$58.66	\$47.53	\$112.19	3-F2T8 & 1-3L Electronic Ballast	88	0.4	95	\$67.07	\$200	\$200	\$35	\$335	\$58.11	
South East Open Office Area	18	4	40	3,312	50	95%	3.1	\$29.95	\$23.89	\$50.84	4-F2T8 & 1-4L Electronic Ballast	112	1.9	494	\$307.29	\$810	\$720	\$132	\$1,662	\$197.55	
Middle Office	4	4	40	1,472	50	95%	319	\$120.31	\$95.06	\$224.37	4-F2T8 & 1-4L Electronic Ballast	112	0.9	194	\$136.58	\$360	\$360	\$59	\$719	\$87.80	
Open Office Area	98	4	40	18,032	50	95%	17.1	\$1,394.08	\$1,164.49	\$2,748.57	4-F2T8 & 1-4L Electronic Ballast	112	10.4	2,382	\$1,673.05	\$4,410	\$3,920	\$721	\$9,051	\$1,075.53	
Commanders Office	8	4	40	1,472	50	95%	319	\$120.31	\$95.06	\$224.37	4-F2T8 & 1-4L Electronic Ballast	112	0.9	194	\$136.58	\$360	\$360	\$59	\$719	\$87.80	
Directors Office	6	4	40	1,104	50	95%	240	\$86.98	\$71.30	\$168.28	4-F2T8 & 1-4L Electronic Ballast	112	0.6	146	\$102.43	\$270	\$270	\$44	\$354	\$65.85	
Entrance Lobby South West	1	2	40	92	50	95%	20	\$8.08	\$5.94	\$14.02	2-F2T8 & 1-2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	

ECO-6A
Buildings 1 - 10
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Existing			Proposed			Implementation			Energy Savings					
				Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost (\$)	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost (\$)	Max Labor Cost (\$)	Eng Cost (\$)	Total Cost (\$)		
Building 3																		
Computer Area																		
Library	25	3	40	3,450	126	95%	3.3	330.08	\$561.45	\$864.53	3-F32T8 & 1-3L Electronic Ballast	2.1	1,203	\$551.29	\$1,000	\$1,000	\$1,773	\$313.23
Computer Office 132	4	3	40	452	126	95%	0.5	48.49	\$89.83	\$138.32	3-F32T8 & 1-3L Electronic Ballast	0.3	192	\$88.21	\$160	\$28	\$348	\$50.12
Vault	8	4	40	1,472	84	95%	1.4	\$129.31	\$159.70	\$289.01	4-F32T8 & 1-4L Electronic Ballast	0.9	327	\$175.92	\$320	\$59	\$739	\$113.09
Raised Floor Computer Center	6	4	40	1,104	126	95%	1.0	\$96.98	\$170.66	\$276.65	4-F32T8 & 1-4L Electronic Ballast	0.6	367	\$168.40	\$240	\$44	\$554	\$108.25
Raised Floor Computer Rm. #1	34	4	40	6,256	126	95%	5.9	\$455.58	\$1,018.09	\$1,963.07	4-F32T8 & 1-4L Electronic Ballast	3.6	2,082	\$954.24	\$1,560	\$250	\$3,140	\$974.29
Raised Floor Computer Rm. #1	54	4	40	9,336	126	95%	9.4	\$433	\$1,018.09	\$1,963.07	4-F32T8 & 1-4L Electronic Ballast	5.7	3,307	\$1,515.56	\$2,430	\$397	\$4,987	\$974.29
Raised Floor Computer Rm. #2	76	4	40	13,984	126	95%	13.3	\$650	\$1,258.67	\$2,475.75	4-F32T8 & 1-4L Electronic Ballast	8.1	4,655	\$2,133.00	\$3,040	\$559	\$7,019	\$1,172.72
Raised Floor Computer Rm. #3	65	4	40	11,960	126	95%	11.4	\$540	\$1,258.67	\$2,475.75	4-F32T8 & 1-4L Electronic Ballast	6.9	3,981	\$1,824.28	\$2,925	\$478	\$6,003	\$1,172.72
Raised Floor Computer Rm. #6	76	4	40	13,984	126	95%	13.3	\$650	\$1,258.67	\$2,475.75	4-F32T8 & 1-4L Electronic Ballast	8.1	4,655	\$2,133.00	\$3,040	\$559	\$7,019	\$1,172.72
Raised Floor Comp. Ctr. Office	9	4	40	1,656	126	95%	1.6	\$96	\$269.50	\$414.97	4-F32T8 & 1-4L Electronic Ballast	1.0	551	\$252.59	\$405	\$66	\$831	\$162.38
Raised Floor Computer Rm. #5	64	4	40	11,776	126	95%	11.2	\$640	\$1,616.42	\$2,950.92	4-F32T8 & 1-4L Electronic Ballast	6.8	3,920	\$1,796.21	\$2,880	\$471	\$5,911	\$1,154.71
Raised Floor Computer Rm. #7	55	4	40	10,120	126	95%	9.6	\$534	\$1,646.92	\$2,535.95	4-F32T8 & 1-4L Electronic Ballast	5.9	3,469	\$1,543.60	\$2,475	\$404	\$5,079	\$992.32
Raised Floor Computer Rm. #6A	6	4	40	1,104	126	95%	1.0	\$96	\$170.66	\$276.65	4-F32T8 & 1-4L Electronic Ballast	0.6	367	\$168.40	\$240	\$44	\$554	\$108.25
Computer Office 132A	24	4	40	4,416	126	95%	4.2	\$245	\$387.94	\$1,106.60	4-F32T8 & 1-4L Electronic Ballast	2.6	1,470	\$673.58	\$1,080	\$176	\$2,716	\$433.02
South East Area																		
Office 1-K	6	3	40	828	50	95%	0.8	\$77.24	\$126.21	\$126.21	3-F32T8 & 1-3L Electronic Ballast	0.5	115	\$80.48	\$240	\$42	\$572	\$45.73
Office 6-F	2	3	40	276	50	95%	0.3	\$24.25	\$37.82	\$37.82	3-F32T8 & 1-3L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
Office 6-J	3	3	40	414	50	95%	0.4	\$36.37	\$63.11	\$63.11	3-F32T8 & 1-3L Electronic Ballast	0.3	57	\$40.24	\$120	\$21	\$261	\$27.86
Open Office Area 7-G	39	3	40	5,382	50	95%	5.1	\$1168	\$670.37	\$920.37	3-F32T8 & 1-3L Electronic Ballast	3.3	745	\$523.13	\$1,560	\$270	\$3,390	\$297.23
Room #120 4-F	2	2	40	184	50	95%	0.2	\$40	\$116.8	\$28.05	2-F32T8 & 1-2L Electronic Ballast	0.1	26	\$18.29	\$70	\$12	\$152	\$9.76
Office 5-F	4	3	40	552	50	95%	0.5	\$120	\$35.65	\$84.14	3-F32T8 & 1-3L Electronic Ballast	0.3	76	\$53.65	\$160	\$28	\$348	\$50.49
Automation Open Area 10-H	25	3	40	3,450	50	95%	3.3	\$303.08	\$525.88	\$1,018.09	3-F32T8 & 1-3L Electronic Ballast	2.1	477	\$235.34	\$1,000	\$173	\$2,173	\$190.53
Office 7-F	2	2	40	276	50	95%	0.3	\$60	\$17.82	\$42.07	2-F32T8 & 1-2L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
Office 2-J	5	3	40	690	50	95%	0.7	\$150	\$44.56	\$105.18	3-F32T8 & 1-3L Electronic Ballast	0.4	95	\$67.07	\$200	\$35	\$435	\$38.11
DMC Office 8-J	2	3	40	276	50	95%	0.3	\$60	\$17.82	\$42.07	2-F32T8 & 1-2L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
Room #130 10-I	3	3	40	414	50	95%	0.4	\$36.37	\$63.11	\$63.11	3-F32T8 & 1-3L Electronic Ballast	0.3	57	\$40.24	\$120	\$21	\$261	\$27.86
Open Office Area 13-G	24	3	40	3,312	50	95%	3.1	\$719	\$290.95	\$454.81	3-F32T8 & 1-3L Electronic Ballast	2.0	458	\$231.93	\$960	\$166	\$2,066	\$182.91
Office 1-H	3	3	40	414	50	95%	0.4	\$36.37	\$63.11	\$63.11	3-F32T8 & 1-3L Electronic Ballast	0.3	57	\$40.24	\$120	\$21	\$261	\$27.86
Office 1-G	1	3	40	138	50	95%	0.1	\$39	\$63.11	\$63.11	3-F32T8 & 1-3L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
DMC Open Area 4-F	70	3	40	9,660	50	95%	9.2	\$2,096	\$848.62	\$1,472.45	3-F32T8 & 1-3L Electronic Ballast	5.9	3,377	\$938.95	\$2,800	\$484	\$6,084	\$333.50
Men's Room 12-J	5	2	40	460	30	50%	0.6	\$21.77	\$17.82	\$39.09	2-F32T8 & 1-2L Electronic Ballast	0.2	47	\$30.50	\$175	\$30	\$380	\$13.60
Women's Room	6	2	40	552	30	50%	0.3	\$72	\$24.52	\$46.91	2-F32T8 & 1-2L Electronic Ballast	0.2	47	\$30.50	\$175	\$30	\$380	\$13.60
Office 1-J	2	2	40	276	50	95%	0.3	\$60	\$17.82	\$42.07	2-F32T8 & 1-2L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
Snack Bar 9-K	2	2	40	184	50	95%	0.2	\$40	\$116.8	\$28.05	2-F32T8 & 1-2L Electronic Ballast	0.1	26	\$18.29	\$70	\$12	\$152	\$9.76
Office 2-K	6	3	40	828	50	95%	0.8	\$180	\$77.24	\$126.21	3-F32T8 & 1-3L Electronic Ballast	0.5	115	\$80.48	\$240	\$42	\$572	\$45.73
Office 3-K	7	3	40	966	50	95%	0.9	\$210	\$84.86	\$147.23	3-F32T8 & 1-3L Electronic Ballast	0.6	134	\$93.90	\$280	\$48	\$608	\$53.35
Smokers Lounge 10-K	12	4	40	2,208	50	95%	2.1	\$473	\$193.97	\$336.56	4-F32T8 & 1-4L Electronic Ballast	1.3	292	\$204.86	\$540	\$88	\$1,108	\$131.70
Room #8 12-J	6	2	40	368	50	95%	0.3	\$80	\$24.52	\$46.91	2-F32T8 & 1-2L Electronic Ballast	0.2	52	\$36.58	\$140	\$24	\$304	\$19.51
Starwell Lobby 11-K	2	3	40	828	50	95%	0.8	\$180	\$77.24	\$126.21	3-F32T8 & 1-3L Electronic Ballast	0.5	115	\$80.48	\$240	\$42	\$572	\$45.73
Open Office 14-K	14	2	40	1,298	50	95%	1.2	\$279	\$113.15	\$196.33	2-F32T8 & 1-2L Electronic Ballast	0.8	182	\$128.04	\$80	\$14	\$174	\$15.24
Corridor 14-L	24	3	40	3,312	50	95%	3.1	\$719	\$290.95	\$454.81	3-F32T8 & 1-3L Electronic Ballast	2.0	458	\$231.93	\$960	\$166	\$2,066	\$182.91
Office 1-F	2	3	40	276	50	95%	0.3	\$60	\$17.82	\$42.07	2-F32T8 & 1-2L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
South West Area																		
Room #109 6-A	2	3	40	276	50	95%	0.3	\$60	\$17.82	\$42.07	2-F32T8 & 1-2L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
Office 5-A	2	3	40	276	50	95%	0.3	\$60	\$17.82	\$42.07	2-F32T8 & 1-2L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
Room #111 6-A	3	3	40	414	50	95%	0.4	\$36.37	\$63.11	\$63.11	3-F32T8 & 1-3L Electronic Ballast	0.3	57	\$40.24	\$120	\$21	\$261	\$27.86
Room #109 8-A	4	3	40	552	50	95%	0.5	\$120	\$35.65	\$84.14	3-F32T8 & 1-3L Electronic Ballast	0.3	76	\$53.65	\$160	\$28	\$348	\$50.49
Room #107 7-A	2	3	40	276	50	95%	0.3	\$60	\$17.82	\$42.07	2-F32T8 & 1-2L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
Office Rear 4-B	4	3	40	552	50	95%	0.5	\$120	\$35.65	\$84.14	3-F32T8 & 1-3L Electronic Ballast	0.3	76	\$53.65	\$160	\$28	\$348	\$50.49
Corridor 5-10-B	10	2	40	920	50	95%	0.9	\$200	\$80.82	\$140.23	2-F32T8 & 1-2L Electronic Ballast	0.6	130	\$91.46	\$350	\$61	\$761	\$48.78
Corridor 5-10-B	3	4	40	552	50	95%	0.5	\$120	\$35.65	\$84.14	3-F32T8 & 1-3L Electronic Ballast	0.3	76	\$53.65	\$160	\$28	\$348	\$50.49
Office 5-B	4	3	40	552	50	95%	0.5	\$120	\$35.65	\$84.14	3-F32T8 & 1-3L Electronic Ballast	0.3	76	\$53.65	\$160	\$28	\$348	\$50.49
Office Front 4-B	3	3	40	414	50	95%	0.4	\$36.37	\$63.11	\$63.11	3-F32T8 & 1-3L Electronic Ballast	0.3	57	\$40.24	\$120	\$21	\$261	\$27.86
Office A-2-D	2	3	40	276	50	95%	0.3	\$60	\$17.82	\$42.07	2-F32T8 & 1-2L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
Corridor 4-1-C	2	3	40	276	50	95%	0.3	\$60	\$17.82	\$42.07	2-F32T8 & 1-2L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
Office 2-C	2	3	40	276	50	95%	0.3	\$60	\$17.82	\$42.07	2-F32T8 & 1-2L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
Room #117 Front 2-B	4	3	40	552	50	95%	0.5	\$120	\$35.65	\$84.14	3-F32T8 & 1-3L Electronic Ballast	0.3	76	\$53.65	\$160	\$28	\$348	\$50.49
Office 4-B	3	3	40	414	50	95%	0.4	\$36.37	\$63.11	\$63.11	3-F32T8 & 1-3L Electronic Ballast	0.3	57	\$40.24	\$120	\$21	\$261	\$27.86
Office Rear 3-B	3	3	40	414	50	95%	0.4	\$36.37	\$63.11	\$63.11	3-F32T8 & 1-3L Electronic Ballast	0.3	57	\$40.24	\$120	\$21	\$261	\$27.86
Room #117 Rear 2-B	2	3	40	276	50	95%	0.3	\$60	\$17.82	\$42.07	2-F32T8 & 1-2L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24
Office Front 3-B	3	3	40	414	50	95%	0.4	\$36.37	\$63.11	\$63.11	3-F32T8 & 1-3L Electronic Ballast	0.3	57	\$40.24	\$120	\$21	\$261	\$27.86
Office 2-E	1	3	40	138	50	95%	0.1	\$39	\$63.11	\$63.11	3-F32T8 & 1-3L Electronic Ballast	0.2	38	\$26.83	\$80	\$14	\$174	\$15.24

ECO-6A
Buildings 1 - 10
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO. Of Luminaires	Existing				Proposed				Implementation											
		Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demanded Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Max. Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$	
North West Area																					
Office 19 E	5	3	40	600	50	95%	0.7	150	\$60.62	\$44.56	\$105.18	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	95	\$67.07	\$200	\$200	\$35	\$435	\$38.11
Office 26 E	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	95	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Office 26 D	6	4	40	1,044	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.43	\$270	\$240	\$44	\$554	\$65.85
Office 26 C	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49
Office 26 B	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Office 26 A	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Lobby 25 A	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	57	\$40.24	\$120	\$120	\$21	\$261	\$22.86
Office 19 A	7	3	40	1,288	50	95%	1.2	279	\$113.15	\$83.18	\$196.33	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.7	170	\$119.50	\$315	\$280	\$31	\$606	\$76.82
Office 23 A	4	3	40	666	50	95%	0.9	210	\$84.86	\$62.38	\$147.25	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.6	134	\$93.90	\$280	\$240	\$48	\$608	\$53.35
Office 21 D	6	4	40	1,044	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.43	\$270	\$240	\$44	\$554	\$65.85
Open Office Area 25 19 A	111	3	40	15,318	50	95%	14.6	3324	\$1,345.66	\$989.22	\$2,334.89	3 - F32T8 & 1 - 3L Electronic Ballast	88	9.3	2,120	\$1,488.91	\$4,440	\$4,440	\$768	\$9,648	\$845.97
North East Area																					
Office 21 G	6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.43	\$270	\$240	\$44	\$554	\$65.85
Office 16 K	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49
Office A 21 F	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$25.92
Office B 21 F	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$25.92
Office 21 H	2	3	40	276	50	95%	0.3	60	\$24.23	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24
Office 26 G	8	3	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.7	153	\$107.31	\$320	\$320	\$55	\$695	\$60.97
Office 26 F	2	3	40	276	50	95%	0.3	60	\$24.23	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24
Office 22 H	6	3	40	828	35	75%	0.6	126	\$57.43	\$37.43	\$84.86	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	80	\$60.49	\$240	\$240	\$42	\$522	\$43.27
Office 26 J	2	3	40	276	50	95%	0.3	60	\$24.23	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24
Open Office Area 20 F	40	3	40	5,200	50	95%	5.2	1198	\$484.92	\$356.48	\$841.40	3 - F32T8 & 1 - 3L Electronic Ballast	88	3.3	764	\$336.55	\$1,600	\$1,600	\$277	\$3,477	\$304.86
Corridor 23 J	2	3	40	276	50	95%	0.3	60	\$24.23	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24
Corridor 22 14 J	12	3	40	1,656	50	95%	1.6	359	\$145.48	\$106.94	\$252.42	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.0	229	\$160.06	\$480	\$480	\$83	\$1,043	\$91.46
Women's Room 15 J	7	2	40	644	30	50%	0.3	84	\$29.78	\$24.95	\$54.73	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	35	\$35.69	\$245	\$245	\$42	\$532	\$45.04
Men's Room 16 J	5	2	40	460	30	50%	0.2	60	\$21.27	\$17.82	\$39.09	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	35	\$35.69	\$245	\$245	\$42	\$532	\$45.04
Office 17 J	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	57	\$40.24	\$170	\$170	\$21	\$261	\$22.86
Office 21 J	4	3	40	552	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	57	\$40.24	\$170	\$170	\$21	\$261	\$22.86
Conference Room 70 J	16	4	40	2,944	35	75%	2.2	447	\$204.18	\$133.08	\$337.26	4 - F32T8 & 1 - 4L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49
Office 17 K	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.3	272	\$205.29	\$720	\$640	\$118	\$1,478	\$131.97
Office A 22 J	2	3	40	276	50	95%	0.3	60	\$24.23	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24
Office B 22 J	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	57	\$40.24	\$170	\$170	\$21	\$261	\$22.86
Open Office Area 26 18 K	40	3	40	5,200	50	95%	5.2	1198	\$484.92	\$356.48	\$841.40	3 - F32T8 & 1 - 3L Electronic Ballast	88	3.3	764	\$336.55	\$1,600	\$1,600	\$277	\$3,477	\$304.86
Open Office Area 25 J	14	3	40	1,932	50	95%	1.8	419	\$169.72	\$124.77	\$294.49	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.2	267	\$187.70	\$560	\$560	\$97	\$1,217	\$106.70
Open Office Area 25 F	57	3	40	7,866	50	95%	7.5	1707	\$691.02	\$507.98	\$1,199.00	3 - F32T8 & 1 - 3L Electronic Ballast	88	4.8	1,088	\$764.58	\$2,280	\$2,280	\$394	\$4,954	\$434.42
Building 4																					
Warehouse																					
Warehouse Packaging Office	8	2	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.5	104	\$73.17	\$280	\$280	\$48	\$608	\$59.02
Warehouse Packing Mens Room	8	2	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.5	104	\$73.17	\$280	\$280	\$48	\$608	\$59.02
Warehouse Pkg. Womens Room	8	2	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.5	104	\$73.17	\$280	\$280	\$48	\$608	\$59.02
Building 5																					
Administration																					
Reok Office	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$25.92
Open Office Area	126	2	40	11,592	50	95%	11.0	2515	\$1,018.34	\$748.60	\$1,766.94	2 - F32T8 & 1 - 2L Electronic Ballast	60	7.2	1,641	\$1,192.53	\$4,410	\$4,410	\$763	\$9,583	\$814.59
West Entrance Lobby	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$26.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76
Product Receipt Office	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Womens Room	1	2	40	92	30	50%	0.0	12	\$4.25	\$3.56	\$7.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76	\$2.72
Mens Room	1	2	40	92	30	50%	0.0	12	\$4.25	\$3.56	\$7.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76	\$2.72
Slater Office	9	4	40	1,656	50	95%	1.6	359	\$145.48	\$106.94	\$252.42	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.0	219	\$153.65	\$405	\$360	\$66	\$831	\$98.77

ECO-6A
Buildings 1 - 10
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO. Of Luminaires	Existing				Proposed				Implementation				Energy Savings						
		Lamps Per Luminaires	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw/Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/Per Month	Annual Cost	Mat. Cost	Labor Cost	Big Coat	Total Cost
Building 6																				
Administration	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	3- F32T8 & 1- 3L Electronic Ballast	88	0.5	115	\$80.48	\$240	\$240	\$42	\$522
Corridor to Restroom	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	57	\$40.24	\$160	\$160	\$28	\$228
Army Audit Agency	3	3	40	552	35	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	53	\$40.24	\$160	\$160	\$28	\$228
Ammunition Operation Conf.	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	57	\$40.24	\$160	\$160	\$28	\$228
Tucker Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	57	\$40.24	\$160	\$160	\$28	\$228
Army Reserve Division	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	57	\$40.24	\$160	\$160	\$28	\$228
AFRE Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174
Safety Division Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	57	\$40.24	\$160	\$160	\$28	\$228
Mens Room	5	3	40	690	30	50%	0.3	90	\$31.90	\$26.74	\$58.64	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	57	\$37.39	\$200	\$200	\$35	\$435
Women's Room	5	3	40	690	30	50%	0.3	90	\$31.90	\$26.74	\$58.64	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	57	\$37.39	\$200	\$200	\$35	\$435
Open Office Area	379	3	40	52,302	50	95%	49.7	11350	\$4,594.65	\$3,772.62	\$7,972.77	3- F32T8 & 1- 3L Electronic Ballast	88	31.7	7,237	\$5,083.77	\$15,160	\$2,623	\$32,943	\$2,888.50
Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174
North East Entrance Corridor	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	3- F32T8 & 1- 3L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$48
Director of Integrated Office	5	3	40	690	50	95%	0.7	150	\$60.62	\$44.56	\$105.18	3- F32T8 & 1- 3L Electronic Ballast	88	0.4	95	\$67.07	\$200	\$200	\$35	\$435
North East Entrance Corridor	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	3- F32T8 & 1- 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$57
Deputy Chief of Staff Reception	5	3	40	690	50	95%	0.7	150	\$60.62	\$44.56	\$105.18	3- F32T8 & 1- 3L Electronic Ballast	88	0.4	95	\$67.07	\$200	\$200	\$35	\$435
Deputy Chief of Staff Conf. Rm.	5	3	40	690	35	75%	0.5	105	\$67.85	\$31.19	\$79.05	3- F32T8 & 1- 3L Electronic Ballast	88	0.4	95	\$67.07	\$200	\$200	\$35	\$435
Conference Room	3	4	40	552	35	75%	0.4	90	\$38.28	\$24.95	\$63.24	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	57	\$40.24	\$160	\$160	\$28	\$228
Corridor to N. Exit	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	57	\$40.24	\$160	\$160	\$28	\$228
NHFG Local 1805 Office	3	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174
Chastain Office	3	2	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174
North East Entrance Lobby	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	3- F32T8 & 1- 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$57
Building 10																				
Computer Area																				
Computer Room	146	3	40	20,148	126	95%	19.1	11018	\$1,709.97	\$3,278.88	\$5,048.85	3- F32T8 & 1- 3L Electronic Ballast	88	12.2	7,026	\$3,219.55	\$5,840	\$1,010	\$12,690	\$1,829.29
Type Label	8	4	40	1,472	84	95%	1.4	537	\$129.31	\$159.70	\$289.01	3- F32T8 & 1- 4L Electronic Ballast	112	0.9	327	\$175.92	\$320	\$59	\$739	\$113.09
Classified Tag Library	8	2	40	736	84	95%	0.7	268	\$64.66	\$79.85	\$144.51	3- F32T8 & 1- 4L Electronic Ballast	60	0.5	175	\$93.24	\$280	\$48	\$608	\$50.26
Page Printing Room	22	3	40	3,036	126	95%	2.9	1660	\$266.71	\$494.08	\$760.79	3- F32T8 & 1- 3L Electronic Ballast	88	1.8	1,059	\$485.14	\$880	\$152	\$1,912	\$275.65
South East Area																				
Office B 9 A	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F32T8 & 1- 2L Electronic Ballast	60	0.3	78	\$54.87	\$210	\$210	\$36	\$456
Open Office Area 9-14 E	188	2	40	17,296	50	95%	16.4	3753	\$1,519.43	\$1,116.96	\$2,636.39	3- F32T8 & 1- 2L Electronic Ballast	60	10.7	2,498	\$1,719.38	\$6,580	\$1,138	\$14,298	\$29.27
Office 9-B	4	4	40	736	50	95%	0.7	160	\$64.66	\$79.85	\$144.51	3- F32T8 & 1- 4L Electronic Ballast	112	0.4	97	\$98.29	\$180	\$79	\$259	\$17.00
Office 10-B	2	4	40	138	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	3- F32T8 & 1- 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$12	\$12	\$9.76
Office 11-B	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	3- F32T8 & 1- 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304
Office A 9 A	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F32T8 & 1- 2L Electronic Ballast	60	0.3	78	\$54.87	\$210	\$210	\$36	\$456
Office 14 A	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	3- F32T8 & 1- 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304
Office B 10 A	3	2	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 2L Electronic Ballast	60	0.2	39	\$27.44	\$105	\$105	\$18	\$228
Office A 10 A	8	2	40	736	50	95%	0.7	160	\$64.66	\$79.85	\$144.51	3- F32T8 & 1- 2L Electronic Ballast	60	0.5	104	\$73.17	\$280	\$48	\$608	\$39.02
Office 11 A	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	3- F32T8 & 1- 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304
Conference Room 12 A	18	2	40	1,656	35	75%	1.2	252	\$144.85	\$74.86	\$189.71	3- F32T8 & 1- 2L Electronic Ballast	60	0.8	164	\$123.72	\$630	\$630	\$109	\$1,969
Entrance Lobby	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	3- F32T8 & 1- 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$9.76
South West Area																				
Open Office Area 9-16 J	214	2	40	19,688	50	95%	18.7	4272	\$1,729.56	\$1,711.44	\$3,000.99	3- F32T8 & 1- 2L Electronic Ballast	60	12.2	2,786	\$1,957.17	\$7,490	\$1,296	\$16,276	\$1,043.82
Office 9-K	3	2	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 2L Electronic Ballast	60	0.2	39	\$27.44	\$105	\$105	\$18	\$228
Office 10-K	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	3- F32T8 & 1- 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$57
Office 10-K	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	3- F32T8 & 1- 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304
Office 11-K	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	3- F32T8 & 1- 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304
Office 12-K	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	3- F32T8 & 1- 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304
Office 13-K	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F32T8 & 1- 2L Electronic Ballast	60	0.3	78	\$54.87	\$210	\$210	\$36	\$456
North East Area																				
Open Office Area 2-8 E	247	2	40	22,724	50	95%	21.6	4931	\$1,996.27	\$1,467.50	\$3,463.76	3- F32T8 & 1- 2L Electronic Ballast	60	14.1	3,716	\$2,258.98	\$8,645	\$1,496	\$18,786	\$1,204.79
Office 1-E	4	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	3- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185
Office 1-E	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$248
Office 1-D	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$248
Women's Room 3-B	12	2	40	1,104	30	95%	0.6	144	\$51.04	\$35.65	\$84.14	3- F32T8 & 1- 3L Electronic Ballast	88	0.4	94	\$61.19	\$200	\$200	\$35	\$435
Mens Room 3-A	2	40	736	30	50%	0.4	96	\$34.03	\$28.52	\$62.55	\$24.37	3- F32T8 & 1- 2L Electronic Ballast	60	0.2	62	\$40.79	\$280	\$48	\$608	\$21.76
Smokers Room 6-A	16	2	40	1,472	50	95%	1.4	319	\$129.31	\$95.06	\$224.37	3- F32T8 & 1- 2L Electronic Ballast	60	0.9	208	\$146.33	\$560	\$560	\$97	\$1,217
Computer Room 1-A	8	3	40	1,840	50	95%	1.7	399	\$161.64	\$118.83	\$280.47	3- F32T8 & 1- 3L Electronic Ballast	88	0.1	260	\$182.91	\$700	\$700	\$121	\$1,521
Cafe 5-B	2	3	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	3- F32T8 & 1- 3L Electronic Ballast	88	0.7	153	\$107.31	\$320	\$320	\$55	\$695
Vending Area 5-B	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	3- F32T8 & 1- 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304
Auditorium 6-B	8	2	40	736	35	75%	0.6	112	\$51.04	\$33.27	\$84.32	3- F32T8 & 1- 2L Electronic Ballast	60	0.4	72	\$54.99	\$280	\$280	\$48	\$608
Auditorium 6-B	12	3	40	1																

ECO-6A
Buildings 1 - 10
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO Of Luminaires	Existing					Proposed					Implementation					Energy Savings				
		Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$		Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$
North West Area																					
Office 5-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Office 8-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Office 7-K	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49
Office B 6-K	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49
Office A 6-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Office 3-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Office 4-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Office 1-G	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49
Office 2-K	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.5	115	\$80.48	\$240	\$240	\$42	\$572	\$45.73
Conference Room 1-K	6	3	40	828	35	75%	0.6	126	\$57.43	\$37.43	\$94.86	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	80	\$60.49	\$240	\$240	\$42	\$572	\$45.73
Office 1-H	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49
Office 1-F	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49
TOTALS	356			484254			453.7	141491	\$42,000	\$29,000	\$84,000			285.8	88571	\$53,000	\$141,000	\$137,000	\$24,000	\$302,000	\$31,000

PROJECT#130101SSRSCOE6A.WK4

22 May 95

ECO-6B
Buildings 14 - 57
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

				Existing										Proposed				Implementation									
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost (\$)	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost (\$)	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$						
Building 14	First Floor	Receiving Room	3	40	2070	50	95%	2.0	449.2	\$181.85	\$133.68	\$315.53	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.3	286	\$201.20	\$600	\$600	\$104	\$1,304	\$114.32					
		Sand Blast Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
		Machine Shop Breakroom	7	4	40	1288	50	95%	1.2	279.5	\$113.15	\$83.18	\$196.33	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.7	170	\$119.50	\$315	\$280	\$51	\$666	\$76.82				
		Machine Shop Office	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	39	\$27.44	\$105	\$105	\$18	\$228	\$14.63				
		Paint Room	12	3	40	1656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.0	229	\$160.96	\$480	\$480	\$83	\$1,063	\$91.46				
		Quality Control/Shop Area	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90				
		Quality Control/Shop Area	6	3	40	828	50	95%	0.8	179.7	\$72.74	\$53.47	\$126.21	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.5	115	\$80.48	\$240	\$240	\$42	\$522	\$45.73				
		Optical Shop	14	4	40	2576	50	95%	2.4	559.0	\$226.30	\$166.36	\$392.65	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.5	340	\$239.01	\$630	\$560	\$103	\$1,293	\$153.65				
		Building 19	Warehouse	Exterior Office	5	2	40	460	50	95%	0.4	\$40.41	\$29.71	\$70.12	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.3	65	\$45.73	\$175	\$175	\$30	\$380	\$24.39			
				Warehouse North Work Area	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$87	\$7.62		
				Warehouse Work Area	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97		
				Warehouse Office	3	2	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	39	\$27.44	\$105	\$105	\$18	\$228	\$14.63		
		Building 31	Warehouse	Receiving Area	2	4	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95			
				Warehouse Office	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76		
Building 32	Warehouse	Receiving Area	3	3	40	414	50	95%	0.4	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	57	\$40.24	\$120	\$120	\$21	\$261	\$22.86					
		Warehouse Office	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76				
Building 33N	Warehouse	Receiving Area	3	3	40	414	50	95%	0.4	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	57	\$40.24	\$120	\$120	\$21	\$261	\$22.86					
		Receiving Area	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76				
Building 34	Warehouse	Receiving Area	2	2	75	345	50	95%	0.3	\$30.31	\$22.28	\$52.59	2 - F32T8 & 1 - 2L Electronic Ballast	104	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76					
		Receiving Area	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112						\$0						
Building 37	Warehouse	Warehouse Elec. Dist. Equip.	1	3	40	138	50	95%	0.1	\$12.12	\$8.91	\$21.04	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$87	\$7.62					
		Office South	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76				
		Office North	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
		Modular																									
Building 41	Warehouse	Modular Office Powertrain #1	3	4	40	552	90	95%	0.5	\$48.49	\$64.17	\$112.66	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	131	\$68.57	\$135	\$120	\$22	\$277	\$44.08					
		Modular Office Powertrain #2	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$29	\$369	\$58.78				
		Modular Office Powertrain #3	3	4	40	552	90	95%	0.5	216	\$84.49	\$64.17	\$112.66	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	131	\$68.57	\$135	\$120	\$22	\$277	\$44.08				
		Motor Room Office	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$29	\$369	\$58.78				
		Motor Room Test Area	2	4	40	368	90	95%	0.3	144	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	87	\$45.72	\$90	\$80	\$15	\$185	\$21.95				
		Motor Room Box Office	3	4	40	552	90	95%	0.5	216	\$84.49	\$64.17	\$112.66	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	131	\$68.57	\$135	\$120	\$22	\$277	\$44.08				
		Building 37 Office	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$29	\$369	\$58.78				
		Building Supply 47	2	4	40	368	90	95%	0.3	144	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	87	\$45.72	\$90	\$80	\$15	\$185	\$21.95				
		Breakroom	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$29	\$369	\$58.78				
		Disassembly Office	5	2	40	460	90	95%	0.4	180	\$40.41	\$29.71	\$70.12	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.3	117	\$61.23	\$175	\$175	\$30	\$380	\$24.39				
Building 41	Warehouse	Transmission Office	4	4	40	736	90	95%	0.7	\$64.66	\$85.55	\$150.21	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$29	\$369	\$58.78					
		Warehouse																									
		Receiving Office	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88				
Building 41	Warehouse	Office	2	2	40	184	50	95%	0.2	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76					
		Office 1 & 1L	1	1	40	46	50	95%	0.0	\$4.04	\$2.97	\$7.01	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	7	\$4.73	\$30	\$30	\$6	\$71	\$2.29					

ECO-6B
Buildings 14 - 57
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	Existing										Proposed										Implementation				
	No. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw/Hr Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/Hr Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$				
Building 42S																									
Warehouse																									
Office	9	4	40	1,656	50	95%	1.6	359	\$145.48	\$106.94	\$252.42	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.0	219	\$153.65	\$405	\$360	\$66	\$831	\$98.77				
Men's Bathroom	4	2	40	368	30	50%	0.2	48	\$17.01	\$14.26	\$31.27	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	31	\$20.40	\$140	\$140	\$24	\$304	\$10.88				
Women's Bathroom	4	2	40	368	30	50%	0.2	48	\$17.01	\$14.26	\$31.27	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	31	\$20.40	\$140	\$140	\$24	\$304	\$10.88				
Break Room	6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.43	\$270	\$240	\$44	\$554	\$65.85				
Building 43																									
Warehouse																									
Office - 1 x 4 window differ	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95				
Lockers	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	57	\$40.24	\$120	\$120	\$21	\$261	\$22.86				
Building 44																									
Warehouse																									
Office Area	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49				
Building 47																									
Warehouse																									
Office - South	4	3	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	137	\$71.84	\$160	\$160	\$28	\$348	\$40.82				
Receiving South	2	4	40	276	90	95%	0.3	108	\$24.25	\$32.08	\$56.33	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	69	\$35.92	\$80	\$80	\$14	\$174	\$20.41				
Office - North	4	2	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	94	\$48.98	\$140	\$140	\$24	\$304	\$26.12				
Piling Area - North	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$29	\$369	\$58.78				
Piling Area - North	24	1	40	1,104	90	95%	1.0	431	\$96.98	\$128.33	\$225.32	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.7	291	\$151.84	\$720	\$840	\$135	\$1,695	\$73.47				
Building 51																									
Warehouse																									
Self Service Parts Room	14	2	40	1,168	50	95%	1.2	279	\$113.15	\$83.18	\$196.33	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.8	182	\$128.04	\$490	\$490	\$85	\$1,065	\$68.29				
Self Service Shelf Area	69	2	40	6,348	50	95%	6.0	1378	\$557.66	\$409.95	\$967.61	2 - F32T8 & 1 - 2L Electronic Ballast	60	3.9	898	\$631.05	\$2,415	\$2,415	\$418	\$5,248	\$336.56				
Self Service Shelf Area	12	2	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.7	156	\$109.75	\$420	\$420	\$73	\$913	\$58.53				
Entrance Lobby	1	4	40	1,840	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97				
Self Service Rear Corridor	10	3	40	1,380	50	95%	1.3	299	\$121.23	\$89.12	\$200.35	1 - F32T8 & 1 - 1L Electronic Ballast	88	0.8	191	\$134.14	\$400	\$400	\$69	\$869	\$76.21				
Self Service Entrance Lobby	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$9.88				
Self Service Rest Office	24	2	40	4,416	50	95%	4.2	958	\$387.94	\$285.18	\$673.12	4 - F32T8 & 1 - 4L Electronic Ballast	112	2.6	983	\$409.73	\$1,080	\$960	\$176	\$2,216	\$263.39				
Self Service Office	15	2	40	1,380	50	95%	1.3	299	\$121.23	\$89.12	\$200.35	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.9	195	\$137.18	\$525	\$525	\$91	\$1,141	\$73.17				
Warehouse Mil. Women's Room	2	4	40	1,840	50	95%	0.1	24	\$8.51	\$7.13	\$15.64	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	16	\$10.20	\$70	\$70	\$12	\$152	\$5.44				
Warehouse Radio Active Room	6	4	40	1,104	50	95%	1.6	359	\$145.48	\$106.94	\$252.42	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.43	\$270	\$240	\$44	\$554	\$65.85				
Warehouse Break Room	9	4	40	1,656	50	95%	1.6	359	\$145.48	\$106.94	\$252.42	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.0	219	\$153.65	\$405	\$360	\$66	\$831	\$98.77				
Warehouse Proc. Workstation	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	3 - F32T8 & 1 - 4L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$92	\$10.97				
Warehouse Work Room	21	4	40	3,684	50	95%	3.7	838	\$339.45	\$249.93	\$588.98	4 - F32T8 & 1 - 4L Electronic Ballast	112	2.2	510	\$358.51	\$945	\$840	\$154	\$1,939	\$230.47				
Warehouse Mil. Work Station	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95				
Warehouse Milvan Office	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.3	78	\$54.87	\$210	\$210	\$36	\$286	\$29.27				
Warehouse Milvan Men's Room	2	2	40	184	30	50%	0.1	24	\$8.51	\$7.13	\$15.64	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	16	\$10.20	\$70	\$70	\$12	\$152	\$5.44				
Main Office	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90				
Building 52																									
Warehouse																									
Warehouse Receiving	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88				
Warehouse Office	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95				
Building 53																									
Warehouse																									
Warehouse Receiving South	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49				
Warehouse Receiving North	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90				
Warehouse Battery Area	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$92	\$10.97				
Warehouse Office (2 lamps only)	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76				
Building 54																									
Warehouse																									
Warehouse Office	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304	\$19.51				
Warehouse Parts Area	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.3	78	\$54.87	\$210	\$210	\$36	\$286	\$29.27				
Building 55																									
Warehouse																									
Warehouse Battery Area	1	4	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97				

ECO-6B
Buildings 14 - 57
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room		NO. Of Luminaires	Existing					Proposed					Implementation					Energy Savings \$				
			Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$		Mtl. Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$
Warehouse																						
Office Area/Parts Area		23	4	40	4,232	90	95%	4.0	1653	\$371.77	\$491.94	\$863.71	4 - F32T8 & 1 - 4L Electronic Ballast	112	2.4	1,006	\$525.74	\$1,035	\$920	\$169	\$2,124	\$337.97
Tool Parts Room (Locked)		5	4	40	920	90	95%	0.9	359	\$80.82	\$106.94	\$187.76	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.5	219	\$114.29	\$225	\$200	\$76	\$462	\$73.47
Tool Parts Room (Locked)		11	3	40	1,518	90	95%	1.4	593	\$133.35	\$176.46	\$309.81	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.9	378	\$197.56	\$440	\$440	\$76	\$956	\$112.25
Bulk Warehouse Office #1		12	4	40	2,208	90	95%	2.1	862	\$193.97	\$256.66	\$450.63	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.3	525	\$274.30	\$540	\$480	\$88	\$1,108	\$176.33
Fire Equipment Cage Area		4	2	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	94	\$48.98	\$140	\$140	\$24	\$304	\$26.12
Ladies Room		3	2	40	276	54	95%	0.3	65	\$24.25	\$19.25	\$43.50	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$28.37	\$105	\$105	\$18	\$228	\$15.13
Bulk Warehouse Office #2		9	4	40	1,656	90	95%	1.6	647	\$145.48	\$192.50	\$337.97	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.0	394	\$205.72	\$405	\$360	\$66	\$554	\$88.17
Breakroom		6	4	40	1,104	90	95%	1.0	431	\$95.98	\$128.33	\$225.32	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	262	\$137.15	\$270	\$240	\$44	\$554	\$88.17
Equipment Operations Unit		15	4	40	2,760	90	95%	2.6	1078	\$242.46	\$320.83	\$563.29	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.6	656	\$342.87	\$675	\$600	\$110	\$1,385	\$220.42
Driver Exam Corridor		6	4	40	1,104	90	95%	1.0	431	\$95.98	\$128.33	\$225.32	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	262	\$137.15	\$270	\$240	\$44	\$554	\$88.17
Locker Room		4	2	40	368	54	95%	0.3	86	\$32.33	\$25.67	\$57.99	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	56	\$27.82	\$140	\$140	\$24	\$304	\$20.17
Office (Locked)		2	2	40	184	90	95%	0.2	72	\$16.16	\$21.39	\$37.55	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	47	\$24.49	\$70	\$70	\$12	\$152	\$13.06
Robertson Office		3	4	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	131	\$68.57	\$135	\$120	\$22	\$277	\$44.08
Office		2	2	40	184	90	95%	0.2	72	\$16.16	\$21.39	\$37.55	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	47	\$24.49	\$70	\$70	\$12	\$152	\$13.06
Office (Locked)		2	2	40	184	90	95%	0.2	72	\$16.16	\$21.39	\$37.55	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	47	\$24.49	\$70	\$70	\$12	\$152	\$13.06
Corridor Behind Office Area		1	4	40	184	90	95%	0.2	72	\$16.16	\$21.39	\$37.55	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$29	\$369	\$58.78
Office Area		4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$29	\$369	\$58.78
Office Area		3	4	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	131	\$68.57	\$135	\$120	\$22	\$277	\$44.08
TOTALS		551			76337			72.0	21347	\$7,000	\$6,000	\$13,000			44.1	1301.6	\$8,000	\$22,000	\$21,000	\$4,000	\$46,000	\$5,000
AP:\PROJECTS\T4130.01\SSRECOMCO_08.WK4																						
22 May 95																						

G:\PROJECTS\130.01\SS\ECODECO_6B.WK4

22 May '95

ECO-6C
Buildings 102-441
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO Of Luminaires	Existing					Proposed										Implementation					Energy Savings \$
		Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost	New Luminaires Description		Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost	Mat. Cost	Labor Cost	Eng. Cost	Total Cost	
Building 102																						
Lab	4	2	40	368	90	95%	0.3	143.7	332.33	342.78	\$75.11	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	94	\$48.98	\$140	\$140	\$24	\$304	\$26.12	
Front Lab Workstation	2	2	40	71.9	90	95%	0.2	71.9	\$16.16	\$37.55	\$7.51	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	47	\$24.49	\$70	\$70	\$12	\$152	\$13.06	
Entrance to Office	18	2	40	1656	90	95%	1.6	646.8	\$145.18	\$192.50	\$37.68	2 - F32T8 & 1 - 2L Electronic Ballast	60	1.0	422	\$220.42	\$630	\$630	\$109	\$1,369	\$117.26	
Main Lab Area	1	2	40	92	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	14	\$9.46	\$35	\$35	\$6	\$76	\$5.04	
Bathroom																						
Building 199																						
Warehouse	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$188.28	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.43	\$770	\$770	\$44	\$554	\$65.85	
Work Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
Office																						
Building 200																						
Lab	11	4	40	2024	50	95%	1.9	439.2	\$177.81	\$130.71	\$308.51	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.2	267	\$187.79	\$495	\$440	\$81	\$1,016	\$120.72	
Lab Area																						
Building 211																						
Administration																						
Kitchen	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
Women's Room	2	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76	\$7.72	
Mens Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76	\$7.72	
Main Office Area	5	4	40	920	50	95%	0.9	199.6	\$80.82	\$59.41	\$140.23	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.5	122	\$85.36	\$225	\$200	\$37	\$462	\$54.87	
Manager's Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$41.90	
Warehouse																						
Building 247																						
Receiving Area	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$41.90	
Office	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
Rear Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95	
Rear Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95	
Restroom	2	2	40	276	50	95%	0.2	59.9	\$24.25	\$17.82	\$42.07	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76	
Restroom	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76	\$7.72	
Kitchen	1	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97	
Receiving Area	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97	
Copy Room	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
Receiving Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
Receiving Area	6	1	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	40	\$28.55	\$180	\$210	\$34	\$424	\$13.72	
Receiving Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
Building 320																						
Maintenance																						
Division Office	6	3	40	828	30	50%	0.4	107.8	\$38.28	\$32.08	\$70.37	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	69	\$44.87	\$240	\$240	\$42	\$522	\$25.50	
Maint. Area Machine Shop	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
Women's Locker Room	1	4	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	\$15.64	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
Women's Locker Room	11	1	40	506	30	50%	0.3	68.9	\$23.40	\$19.61	\$41.00	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	44	\$28.98	\$330	\$385	\$62	\$777	\$14.02	
Maintenance Area Office	3	4	40	552	50	95%	0.3	119.8	\$38.49	\$33.63	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$32.92	
Maint. Locker Room Office	1	4	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	\$15.64	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	15	\$9.52	\$45	\$40	\$7	\$92	\$6.12	
Office No. 1	6	2	40	552	50	95%	0.5	119.8	\$38.49	\$33.63	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	78	\$54.87	\$210	\$210	\$36	\$456	\$29.27	
Mens Locker Room	11	1	40	506	168	95%	0.5	368.9	\$44.45	\$109.79	\$154.25	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.3	249	\$103.95	\$330	\$385	\$62	\$777	\$50.30	
Locker Area	3	2	40	276	168	95%	0.3	201.2	\$24.25	\$59.89	\$84.13	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	131	\$54.87	\$105	\$105	\$18	\$228	\$29.26	
Main Office Area	47	2	40	4324	168	95%	4.1	3152.7	\$379.86	\$938.25	\$1,318.10	2 - F32T8 & 1 - 2L Electronic Ballast	60	2.7	2,056	\$859.63	\$1,645	\$1,645	\$285	\$3,575	\$458.47	
Sink and Toilet Area	4	2	40	368	30	50%	0.2	47.9	\$17.01	\$14.26	\$31.27	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	31	\$20.40	\$140	\$140	\$24	\$304	\$10.88	
Building 349																						
Boiler Plant																						
Entrance Cage Area	9	2	40	828	168	95%	0.8	603.7	\$272.74	\$179.66	\$255.40	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.5	94	\$164.61	\$315	\$315	\$54	\$684	\$87.79	
Control Room	2	2	40	184	168	95%	0.2	134.2	\$16.16	\$9.93	\$56.09	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	87	\$36.58	\$70	\$70	\$12	\$152	\$19.51	
Boiler Room Ground Level	10	4	40	1840	168	95%	1.7	1341.6	\$161.64	\$99.25	\$60.90	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.1	817	\$341.41	\$450	\$400	\$74	\$924	\$219.48	
Boiler Room Ground Level	1	3	40	138	168	95%	0.1	100.6	\$12.12	\$29.94	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	64	\$26.83	\$40	\$40	\$7	\$87	\$15.24	
Breakroom	4	4	40	736	84	95%	0.7	268.3	\$64.66	\$79.83	\$144.51	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	163	\$87.96	\$180	\$160	\$29	\$369	\$56.55	
Boiler Room Ground Level	4	1	40	184	168	95%	0.2	134.2	\$16.16	\$9.93	\$56.09	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.1	90	\$37.90	\$120	\$120	\$22	\$282	\$18.29	

ECO-6C
Buildings 102-441
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost (\$)	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost (\$)	Implementation					Energy Savings (\$)															
																	Mat	Labor	Eng	Total																	
Building 350																																					
Office #1																																					
Men's Room	5	4	40	920	54	95%	0.9	215.6	\$80.82	\$64.17	\$144.99	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.5	131	\$88.25	\$225	\$200	\$37	\$462	\$56.73																
Conference Room	12	4	40	2208	63	95%	2.1	603.7	\$193.97	\$179.66	\$373.63	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.3	367	\$677.43	\$540	\$480	\$88	\$1,108	\$146.20																
Women's Room	5	4	40	920	54	95%	0.9	215.6	\$80.82	\$64.17	\$144.99	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.5	131	\$88.25	\$225	\$200	\$37	\$462	\$56.73																
Corridor to Shop	3	4	40	552	90	95%	0.5	287.5	\$88.49	\$85.55	\$186.04	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	131	\$68.57	\$180	\$160	\$20	\$277	\$44.08																
Managers Office	4	4	40	736	90	95%	0.7	287.5	\$88.49	\$85.55	\$186.04	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$20	\$277	\$44.08																
Copy Room	2	4	40	368	90	95%	0.3	143.7	\$42.78	\$42.78	\$75.11	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	87	\$45.72	\$90	\$80	\$10	\$185	\$29.39																
Reception	11	4	40	2024	90	95%	1.9	790.6	\$177.81	\$235.27	\$413.08	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.2	481	\$251.44	\$495	\$440	\$55	\$1,016	\$161.64																
Office #2																																					
Reception Area	8	4	40	1472	90	95%	1.4	755.0	\$129.31	\$171.11	\$300.42	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.9	350	\$182.87	\$360	\$320	\$40	\$720	\$117.56																
Managers Office	1	4	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	44	\$27.86	\$45	\$40	\$5	\$92	\$14.69																
Office #3																																					
Work Area	6	4	40	1104	90	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	262	\$137.15	\$270	\$240	\$30	\$540	\$88.17																
Separate Office Area	4	4	40	736	90	95%	0.7	287.5	\$88.49	\$85.55	\$186.04	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$20	\$277	\$44.08																
ASRS plus Office Area Corridor	3	4	40	552	90	95%	0.5	287.5	\$88.49	\$85.55	\$186.04	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	131	\$68.57	\$180	\$160	\$20	\$277	\$44.08																
ASRS plus Office Computer Rm.	8	4	40	1472	90	95%	1.4	755.0	\$129.31	\$171.11	\$300.42	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.9	350	\$182.87	\$360	\$320	\$40	\$720	\$117.56																
Office #4																																					
Office Area	5	2	40	460	90	95%	0.4	179.7	\$40.41	\$53.47	\$93.88	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.3	117	\$61.23	\$175	\$175		\$350	\$32.65																
Library Conference Room	2	3	40	276	63	95%	0.3	75.5	\$24.26	\$32.46	\$46.70	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	48	\$29.78	\$80	\$80		\$160	\$16.92																
Quality Control Room	6	3	40	828	90	95%	0.8	323.4	\$72.74	\$96.25	\$168.99	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.5	206	\$107.76	\$240	\$240		\$480	\$61.23																
Office #5																																					
Stairway to Shop	2	2	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	47	\$24.49	\$70	\$70		\$140	\$13.06																
Annex Office Corridor	7	2	40	644	90	95%	0.6	251.5	\$56.57	\$74.86	\$131.43	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.4	164	\$85.72	\$245	\$245		\$490	\$45.72																
Stairway to Shop	2	2	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	47	\$24.49	\$70	\$70		\$140	\$13.06																
Meeting Room	19	2	40	1748	63	95%	1.7	477.9	\$151.56	\$214.23	\$385.79	2 - F32T8 & 1 - 2L Electronic Ballast	60	1.1	312	\$192.91	\$665	\$665		\$1,330	\$102.88																
Planning Production Fabrication	12	2	40	1104	90	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.7	281	\$146.95	\$420	\$420		\$840	\$78.37																
Trades Branch Conference Rm.	12	2	40	1104	90	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.7	281	\$146.95	\$420	\$420		\$840	\$78.37																
Men's Room	6	2	40	552	63	95%	0.5	129.3	\$40.41	\$53.47	\$93.88	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.3	84	\$56.73	\$210	\$210		\$420	\$30.26																
Ladies Room	3	2	40	276	54	95%	0.3	61.7	\$24.26	\$32.46	\$46.70	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$28.37	\$105	\$105		\$210	\$15.13																
Trades Office Room #2	12	2	40	1104	90	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.7	281	\$146.95	\$420	\$420		\$840	\$78.37																
Trades Office Room #1	12	2	40	1104	90	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.7	281	\$146.95	\$420	\$420		\$840	\$78.37																
Stairway to Shop	2	2	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	47	\$24.49	\$70	\$70		\$140	\$13.06																
Building 370																																					
Equipment Repair																																					
Men's Room	3	4	40	552	54	95%	0.5	129.3	\$40.41	\$53.47	\$93.88	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	79	\$52.95	\$135	\$120	\$22	\$277	\$34.04																
Shop Area Task Lighting	4	2	40	368	90	95%	0.3	143.7	\$42.78	\$42.78	\$75.11	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	94	\$48.98	\$140	\$140		\$280	\$26.12																
Shop Area	318	4	40	5812	90	95%	55.6	2285.8	\$514.19	\$680.58	\$1194.77	4 - F32T8 & 1 - 4L Electronic Ballast	112	33.8	13,912	\$7,268.90	\$14,310	\$12,720	\$2,338	\$29,368	\$4,672.87																
Shop Area Office	5	4	40	920	90	95%	0.9	359.4	\$80.82	\$106.94	\$187.76	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.5	219	\$114.29	\$225	\$200	\$37	\$462	\$73.47																
Test Room/Workstation	2	4	40	368	90	95%	0.3	143.7	\$42.78	\$42.78	\$75.11	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	87	\$45.72	\$90	\$80	\$10	\$185	\$29.39																
Test Room	4	4	40	736	90	95%	0.7	287.5	\$88.49	\$85.55	\$186.04	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$20	\$277	\$44.08																
Shop Area Task Lighting	2	2	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	47	\$24.49	\$70	\$70		\$140	\$13.06																
Building 412																																					
Training & Conf. Center																																					
Computer Training Area	11	4	40	2024	50	95%	1.9	439.2	\$177.81	\$130.71	\$308.51	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.2	267	\$187.79	\$495	\$440	\$55	\$1,016	\$120.72																
Administration Area	11	4	40	2024	50	95%	1.9	439.2	\$177.81	\$130.71	\$308.51	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.2	267	\$187.79	\$495	\$440	\$55	\$1,016	\$120.72																
Center Class Room	14	4	40	2576	35	75%	1.9	391.3	\$178.66	\$116.45	\$295.11	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.2	238	\$179.63	\$630	\$560	\$103	\$1,293	\$115.48																
Conference Room	33	4	40	6072	35	75%	4.6	922.3	\$421.12	\$274.49	\$695.60	4 - F32T8 & 1 - 4L Electronic Ballast	112	2.8	561	\$423.41	\$1,485	\$1,370	\$243	\$3,048	\$272.19																
Men's Room	2	2	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	\$15.64	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	16	\$10.20	\$70	\$70		\$140	\$5.44																
Ladies Room	2	2	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	\$15.64	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	16	\$10.20	\$70	\$70		\$140	\$5.44																
Building 416																																					
Administration																																					
Men's Room	4	2	40	368	30	50%	0.2	47.9	\$17.01	\$14.26	\$31.27	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	31	\$20.40	\$140	\$140		\$280	\$10.88																
Women's Room	4	2	40	368	30	50%	0.2	47.9	\$17.01	\$14.26	\$31.27	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	31	\$20.40	\$140	\$140		\$280	\$10.88																
Managers Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$10	\$185	\$21.95																
Main Office Area	30	4	40	5520	50	95%	5.2	1197.8	\$484.92	\$356.48	\$841.40	4 - F32T8 & 1 - 4L Electronic Ballast	112	3.2	729	\$512.16	\$1,350	\$1,200	\$221	\$2,771	\$329.24																

Efficient Fluorescent Lighting Retrofit

Existing										Proposed				Implementation							
No. Of Luminaires	Room Description	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$		
Building 417																					
Personnel Barracks																					
9	Corridor	2	40	828	168	95%	603.7	\$72.74	\$170.66	2- F32T8 & 1 - 2L Electronic Ballast	60	0.5	394	\$164.61				\$684	\$87.79		
4	Room #13	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Kitchen #16	2	40	368	21	50%	33.5	\$9.98	\$27.00	2- F32T8 & 1 - 2L Electronic Ballast	60	0.1	22	\$17.61	\$140	\$140	\$24	\$304	\$9.39		
4	Room #14	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Room #17	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Room #12	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Room #18	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Men's Room/Shower	2	40	368	168	95%	268.3	\$79.85	\$112.18	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$39.02		
4	Room #19	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Room #11	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Room #20	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Women's Room	2	40	368	168	95%	268.3	\$79.85	\$112.18	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$39.02		
4	Day Room #15	3	40	552	40	75%	95.8	\$38.28	\$66.80	3- F32T8 & 1 - 3L Electronic Ballast	88	0.3	61	\$42.60	\$160	\$160	\$28	\$348	\$24.20		
Building 418																					
Personnel Barracks																					
9	Corridor	2	40	828	168	95%	603.7	\$72.74	\$170.66	2- F32T8 & 1 - 2L Electronic Ballast	60	0.5	394	\$164.61				\$684	\$87.79		
4	Room #13	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Kitchen #16	2	40	368	21	50%	33.5	\$9.98	\$27.00	2- F32T8 & 1 - 2L Electronic Ballast	60	0.1	22	\$17.61	\$140	\$140	\$24	\$304	\$9.39		
4	Room #14	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Room #17	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Room #12	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Room #18	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Men's Room/Shower	2	40	368	168	95%	268.3	\$79.85	\$112.18	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$39.02		
4	Room #19	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Room #11	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Room #20	2	40	368	40	75%	63.9	\$25.52	\$19.01	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$15.49		
4	Women's Room	2	40	368	168	95%	268.3	\$79.85	\$112.18	2- F32T8 & 1 - 2L Electronic Ballast	60	0.2	42	\$29.04	\$140	\$140	\$24	\$304	\$39.02		
4	Day Room #15	3	40	552	40	75%	95.8	\$38.28	\$66.80	3- F32T8 & 1 - 3L Electronic Ballast	88	0.3	61	\$42.60	\$160	\$160	\$28	\$348	\$24.20		
Building 421																					
Administration																					
28	Main Office Area North End	4	40	512	50	95%	118.0	\$452.59	\$332.71	4- F32T8 & 1 - 4L Electronic Ballast	112	3.0	681	\$788.01	\$1,260	\$1,120	\$206	\$2,586	\$307.29		
1	Women Room	1	40	46	30	50%	6.0	\$2.13	\$1.78	1- F32T8 & 1 - 1L Electronic Ballast	31	0.0	4	\$2.63	\$30	\$35	\$6	\$71	\$1.27		
2	Support Division Chief Office	2	40	184	50	95%	0.2	\$6.16	\$1.88	2- F32T8 & 1 - 2L Electronic Ballast	0.1	0.0	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76		
1	Managers Office	1	40	184	50	95%	0.2	\$6.16	\$1.88	4- F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97		
3	File/Copy Room	3	40	552	50	95%	0.5	\$48.49	\$35.65	1- F32T8 & 1 - 1L Electronic Ballast	112	0.3	73	\$51.22	\$35	\$120	\$22	\$277	\$32.92		
4	File/Copy Room on Files	4	40	184	50	95%	0.2	\$6.16	\$1.88	1- F32T8 & 1 - 1L Electronic Ballast	31	0.1	27	\$18.90	\$90	\$120	\$22	\$282	\$9.15		
2	Women's Room	2	40	368	30	50%	0.2	\$47.01	\$14.26	1- F32T8 & 1 - 1L Electronic Ballast	112	0.1	29	\$19.04	\$80	\$80	\$15	\$185	\$12.24		
3	Main Entrance Lobby	3	40	552	50	95%	0.5	\$48.49	\$35.65	1- F32T8 & 1 - 1L Electronic Ballast	112	0.3	73	\$51.22	\$35	\$120	\$22	\$277	\$32.92		
4	Acquisition Chief	4	40	184	50	95%	0.2	\$6.16	\$1.88	4- F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97		
26	Conf. Office North Office Area	4	40	4784	50	95%	4.5	\$108.1	\$308.95	4- F32T8 & 1 - 4L Electronic Ballast	112	2.8	632	\$443.87	\$1,170	\$1,040	\$191	\$2,401	\$285.34		
1	Receptionist	1	40	184	50	95%	0.2	\$6.16	\$1.88	4- F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97		
2	Office	2	40	184	50	95%	0.2	\$6.16	\$1.88	4- F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97		
3	Office	3	40	552	50	95%	0.5	\$48.49	\$35.65	4- F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$35	\$120	\$22	\$277	\$32.92		
3	Office	3	40	414	50	95%	0.4	\$36.37	\$26.74	3- F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24		
5	Support Division Chief Office	5	40	920	50	95%	0.9	\$80.82	\$59.41	3- F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$39.49		
2	Men's Room	2	40	368	30	50%	0.2	\$47.01	\$14.26	1- F32T8 & 1 - 1L Electronic Ballast	112	0.2	49	\$40.24	\$120	\$120	\$21	\$261	\$22.86		
2	Property Accountability Office	2	40	276	50	95%	0.3	\$24.25	\$17.82	1- F32T8 & 1 - 1L Electronic Ballast	112	0.5	122	\$85.14	\$95	\$80	\$35	\$185	\$21.95		
2	Vending Area	2	40	46	30	50%	0.0	\$2.13	\$1.78	1- F32T8 & 1 - 1L Electronic Ballast	31	0.0	4	\$2.63	\$30	\$35	\$6	\$71	\$1.27		
2	Equipment Mgt. Office	2	40	368	50	95%	0.3	\$80.82	\$59.41	4- F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$40.24	\$120	\$120	\$21	\$261	\$22.86		
2	North Exit Lobby	2	40	276	50	95%	0.3	\$24.25	\$17.82	3- F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24		
1	North Exit Lobby	1	40	184	50	95%	0.2	\$6.16	\$1.88	4- F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97		
2	Laundry Room	2	40	368	30	50%	0.2	\$47.01	\$14.26	4- F32T8 & 1 - 4L Electronic Ballast	112	0.2	34	\$25.60	\$90	\$80	\$15	\$185	\$12.24		
2	Conference Room	2	40	368	35	75%	0.3	\$56	\$25.52	\$16.64	4- F32T8 & 1 - 4L Electronic Ballast	112	0.2	39	\$25.60	\$90	\$80	\$15	\$185	\$12.24	
2	Men's Room	2	40	368	30	50%	0.2	\$47.01	\$14.26	4- F32T8 & 1 - 4L Electronic Ballast	112	0.2	34	\$25.60	\$90	\$80	\$15	\$185	\$12.24		
4	Managers Office	4	40	368	30	50%	0.2	\$47.01	\$14.26	4- F32T8 & 1 - 4L Electronic Ballast	112	0.2	34	\$25.60	\$90	\$80	\$15	\$185	\$12.24		
6	Managers Office	4	40	1,104	50	95%	1.0	\$96.98	\$71.30	\$168.28	4- F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.43	\$270	\$240	\$44	\$554	\$65.85	

ECO-6C
Buildings 102-441
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO. Of Luminaires	Existing					Proposed										Implementation				
		Watts Per Lume	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost	New Luminaires Description	Watts Per Lume	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost	Mat. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings	
C. Depot Prop. Div. Reception	4	40	160	50	95%	0.4	120	\$48.49	\$35.03	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$33.65	\$160	\$160	\$28	\$348	\$30.49	
Men's Room	2	40	80	30	95%	0.2	48	\$17.01	\$14.26	\$31.27	1 - F32T8 & 1 - 3L Electronic Ballast	112	0.1	29	\$19.04	\$90	\$80	\$15	\$185	\$12.24	
C. Depot Prop. Div. Office	4	40	160	50	95%	0.5	120	\$48.49	\$35.03	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$33.65	\$160	\$160	\$28	\$348	\$30.49	
Main Office South End	24	4	4,416	50	95%	4.2	958	\$387.94	\$285.18	\$673.12	4 - F32T8 & 1 - 4L Electronic Ballast	112	2.6	583	\$409.73	\$1,080	\$960	\$176	\$2,216	\$263.39	
Contracting Office Area	14	4	2,576	40	95%	2.4	359	\$226.30	\$166.36	\$392.65	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.5	340	\$239.01	\$650	\$560	\$103	\$1,263	\$153.65	
Contracting Office Conf. Room	6	3	828	35	75%	0.6	126	\$57.43	\$37.43	\$84.86	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	80	\$60.40	\$240	\$240	\$42	\$522	\$34.37	
Office (left of Acquisition Chief)	1	4	184	50	95%	0.2	40	\$16.16	\$11.90	\$28.07	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$11.00	
Building 41																					
Cable & Harness	3	3	414	90	95%	0.4	162	\$36.37	\$48.12	\$84.49	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	103	\$53.88	\$120	\$120	\$21	\$261	\$30.61	
Unpacking	4	3	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	137	\$71.84	\$160	\$160	\$28	\$348	\$40.82	
File Area	5	3	690	90	95%	0.7	270	\$60.62	\$80.21	\$140.82	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	172	\$89.80	\$200	\$200	\$35	\$435	\$51.02	
Cable Test Station	3	3	414	90	95%	0.4	162	\$36.37	\$48.12	\$84.49	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	103	\$53.88	\$120	\$120	\$21	\$261	\$30.61	
Work Station	5	3	690	90	95%	0.7	270	\$60.62	\$80.21	\$140.82	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	172	\$89.80	\$200	\$200	\$35	\$435	\$51.02	
Cable Termination Area	6	2	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.3	141	\$73.47	\$210	\$210	\$36	\$456	\$59.19	
Cable Termination Area	3	2	492	90	95%	0.1	36	\$8.08	\$10.69	\$18.78	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	23	\$12.25	\$35	\$35	\$6	\$76	\$6.53	
Assembly Area Desk Lighting	1	2	276	90	95%	0.3	108	\$24.25	\$36.87	\$59.16	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	70	\$36.74	\$105	\$105	\$18	\$228	\$19.59	
Break Room	21	3	2,598	90	95%	2.8	1132	\$254.38	\$336.87	\$591.46	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.8	722	\$377.16	\$840	\$840	\$145	\$1,825	\$214.30	
Break Room	3	3	414	90	95%	0.4	162	\$36.37	\$48.12	\$84.49	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	103	\$53.88	\$120	\$120	\$21	\$261	\$30.61	
Break Room	3	2	276	90	95%	0.3	108	\$24.25	\$36.87	\$59.16	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	70	\$36.74	\$105	\$105	\$18	\$228	\$19.59	
Office (Day)	4	3	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	137	\$71.84	\$160	\$160	\$28	\$348	\$40.82	
Office	2	4	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	87	\$45.72	\$90	\$80	\$15	\$185	\$29.39	
Building 418																					
Counseling	2	4	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95	
Corridor to Managers Office	6	2	552	50	95%	0.5	120	\$48.49	\$35.03	\$84.14	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.3	78	\$54.87	\$210	\$210	\$36	\$456	\$29.27	
Copied Room	2	2	492	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76	
Main Entrance Corridor	2	2	492	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76	
Counselors Office	2	2	492	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76	
Conference Room	2	2	492	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76	
Conference Room (Day)	8	2	736	50	95%	0.7	160	\$64.66	\$77.33	\$112.19	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.5	104	\$73.17	\$280	\$280	\$48	\$608	\$39.02	
Building 411																					
Administration	8	4	1,472	50	95%	1.4	319	\$129.31	\$95.06	\$224.37	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.9	194	\$136.58	\$360	\$320	\$59	\$739	\$87.80	
Main Entrance Lobby	1	4	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97	
Supply Section	10	4	1,840	50	95%	1.7	399	\$161.64	\$118.83	\$280.47	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.1	243	\$170.72	\$450	\$400	\$74	\$924	\$109.75	
Corridor around Lab #4	4	3	552	50	95%	0.5	120	\$48.49	\$35.03	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49	
TDME Office Area	25	4	4,000	50	95%	4.4	998	\$404.10	\$297.06	\$701.17	4 - F32T8 & 1 - 4L Electronic Ballast	112	2.7	608	\$426.80	\$1,125	\$1,000	\$184	\$2,309	\$274.37	
ACL Office	5	4	620	50	95%	0.9	200	\$80.82	\$59.41	\$140.23	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.5	122	\$85.36	\$225	\$200	\$37	\$462	\$34.87	
Women's Room	1	4	184	50	95%	0.1	24	\$8.51	\$7.13	\$15.64	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	15	\$9.52	\$45	\$40	\$7	\$92	\$6.12	
Executive Secretary	4	4	736	50	95%	0.7	160	\$64.66	\$77.33	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90	
Computer Room	2	4	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95	
Men's Room	1	4	184	30	50%	0.1	24	\$8.51	\$7.13	\$15.64	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	15	\$9.52	\$45	\$40	\$7	\$92	\$6.12	
TDME Chief Office	4	4	736	50	95%	0.7	160	\$64.66	\$77.33	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90	
TDME Chief Lab Calibration	3	4	552	50	95%	0.5	120	\$48.49	\$35.03	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$32.92	
Conference Room 1 & 2	6	4	1,104	35	75%	0.8	168	\$76.57	\$49.91	\$126.47	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.5	102	\$76.98	\$270	\$240	\$44	\$554	\$49.49	
Building 418																					
Repair Shop	3	2	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	39	\$27.44	\$105	\$105	\$18	\$228	\$14.63	
Shipping Area																					
Building 411																					
Warehouse	2	2	492	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76	
Warehouse Parts Bay	2	4	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95	
TOTALS	1272		190118			174.3	61002	\$16,000	\$18,000	\$34,000			107.8	37869	\$21,000	\$52,000	\$49,000	\$9,000	\$110,000	\$13,000	

G:\PROJECTS\4130.0\USSECO\ECO_6C.WK4

ECO-6D
Buildings 500 - 581
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO. Of Luminaires	Existing					Proposed					Implementation						
		Watts Per Lumen	Watts Per Lumen	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost (\$)	New Luminaire Description	Watts Per Lumen	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost (\$)	Mat. Labor Cost (\$)	Energy Savings (\$)	
Building 500																		
First Floor																		
Office	1	3	40	138	50	95%	29.9	\$12.12	\$8.91	\$21.04	3- F32T8 & 1- 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$7	\$7.62
Laboratory Room #33	14	4	40	736	50	95%	159.7	\$66.66	\$47.53	\$112.19	4- F32T8 & 1- 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$29	\$369
Restroom	2	4	40	128	90	95%	12.8	\$11.65	\$149.72	\$262.87	2- F32T8 & 1- 2L Electronic Ballast	60	0.8	328	\$171.44	\$490	\$85	\$1,065
Room #47 (Office)	2	4	40	92	50	50%	0.0	\$3.56	\$23.77	\$56.09	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Pharmacy	1	4	40	368	50	95%	79.9	\$42.33	\$11.88	\$28.05	4- F32T8 & 1- 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$7	\$21.95
Room #31 Open Office Area	6	4	40	184	50	95%	39.2	\$16.16	\$11.88	\$28.05	4- F32T8 & 1- 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$7	\$21.95
Treatment Room #7 Room #45	2	4	40	368	90	95%	143.7	\$96.98	\$71.30	\$168.28	4- F32T8 & 1- 4L Electronic Ballast	112	0.6	146	\$102.43	\$440	\$75	\$554
Treatment Room #1 Room #46	2	4	40	368	90	95%	143.7	\$96.98	\$71.30	\$168.28	4- F32T8 & 1- 4L Electronic Ballast	112	0.6	146	\$102.43	\$440	\$75	\$554
Physical Therapy Room #34	4	3	40	552	50	95%	119.8	\$48.49	\$35.65	\$84.14	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	87	\$45.72	\$90	\$15	\$185
Command Wing Entrance	2	4	40	184	50	95%	39.2	\$16.16	\$11.88	\$28.05	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	87	\$45.72	\$90	\$15	\$185
Waiting Room	2	3	40	276	50	95%	29.9	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.1	26	\$18.29	\$70	\$12	\$30.49
Waiting Room Restroom	1	3	40	138	50	95%	0.1	\$6.38	\$5.35	\$11.73	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$14	\$15.24
Occupational Health Room #38	2	4	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Emergency Rm. Entrance Lobby	1	2	40	92	168	95%	0.1	\$8.08	\$19.96	\$28.04	2- F32T8 & 1- 2L Electronic Ballast	60	0.1	44	\$18.29	\$35	\$6	\$21.95
Conference Room (Room #41)	5	4	40	920	35	75%	0.7	\$62.81	\$41.39	\$105.39	4- F32T8 & 1- 4L Electronic Ballast	112	0.4	85	\$64.15	\$225	\$37	\$462
Restroom	1	2	40	92	30	50%	0.0	\$4.25	\$3.56	\$7.82	2- F32T8 & 1- 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$6	\$2.72
Emergency Treatment Rm. #40	6	4	40	1104	90	95%	431.2	\$96.98	\$128.33	\$225.32	4- F32T8 & 1- 4L Electronic Ballast	112	0.6	262	\$137.15	\$270	\$29	\$354
Occupational Health Room #39	4	4	40	736	50	95%	1.0	\$66.66	\$47.53	\$112.19	4- F32T8 & 1- 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$29	\$369
Office Room #42	2	4	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Occupational Health Room #37	2	4	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Office	4	3	40	552	50	95%	0.5	\$119.8	\$48.49	\$35.65	4- F32T8 & 1- 4L Electronic Ballast	112	0.3	76	\$53.65	\$160	\$28	\$348
Occupational Health Rm. #43C	2	4	40	184	50	95%	0.2	\$16.16	\$11.88	\$28.05	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Occupational Health Rm. #43B	1	2	40	184	50	95%	0.2	\$16.16	\$11.88	\$28.05	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Occupational Health Rm. #43A	2	4	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Occupational Health Room #43	4	2	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Break Room (Room #36)	4	2	40	736	50	95%	0.7	\$66.66	\$47.53	\$112.19	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	52	\$17.07	\$45	\$7	\$21.95
Dispersary Waiting Room	4	3	40	552	50	95%	0.5	\$119.8	\$48.49	\$35.65	4- F32T8 & 1- 4L Electronic Ballast	112	0.3	76	\$53.65	\$160	\$28	\$348
Copy Room	2	3	40	276	50	95%	0.3	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	39	\$27.44	\$105	\$18	\$14.63
Room #26 (Office)	2	3	40	276	50	95%	0.3	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	39	\$27.44	\$105	\$18	\$14.63
Admin. Pym. Coordinators Ofc.	4	4	40	736	50	95%	0.7	\$66.66	\$47.53	\$112.19	4- F32T8 & 1- 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$29	\$369
P. Grounding Office	8	3	40	736	50	95%	0.7	\$66.66	\$47.53	\$112.19	4- F32T8 & 1- 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$29	\$369
Meat Room	2	3	40	276	30	50%	0.1	\$12.76	\$10.69	\$23.46	3- F32T8 & 1- 3L Electronic Ballast	88	0.0	104	\$73.17	\$280	\$48	\$308
Latrine Room	2	3	40	276	30	50%	0.1	\$12.76	\$10.69	\$23.46	3- F32T8 & 1- 3L Electronic Ballast	88	0.1	23	\$14.96	\$80	\$14	\$8.50
Protocol Office	3	2	40	552	50	95%	0.5	\$119.8	\$48.49	\$35.65	4- F32T8 & 1- 4L Electronic Ballast	112	0.3	76	\$53.65	\$160	\$28	\$348
Copy Room	3	2	40	276	50	95%	0.3	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	39	\$27.44	\$105	\$18	\$14.63
Public Affairs Office	4	4	40	736	50	95%	0.7	\$66.66	\$47.53	\$112.19	4- F32T8 & 1- 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$29	\$369
Entrance to Rear Office	1	3	40	184	50	95%	0.1	\$12.12	\$8.91	\$21.04	3- F32T8 & 1- 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$7	\$7.62
Depot Sergeant Majors Office	2	4	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Commander's Office	4	4	40	736	50	95%	0.7	\$66.66	\$47.53	\$112.19	4- F32T8 & 1- 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$29	\$369
Commander's Secretary	4	4	40	736	50	95%	0.7	\$66.66	\$47.53	\$112.19	4- F32T8 & 1- 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$29	\$369
G. Patterson Office	2	4	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Depot Commander	2	4	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Rear Office	6	3	40	276	50	95%	0.3	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$14	\$15.24
Legal Office 15 Reception	10	3	40	1380	50	95%	1.3	\$299.5	\$121.23	\$289.12	3- F32T8 & 1- 3L Electronic Ballast	88	0.5	115	\$80.48	\$240	\$42	\$522
Legal Office Corridor	2	3	40	276	50	95%	0.3	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$14	\$15.24
Computer Room	2	3	40	276	50	95%	0.3	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$14	\$15.24
Front Office 15A	1	3	40	138	50	95%	0.5	\$119.8	\$48.49	\$35.65	4- F32T8 & 1- 4L Electronic Ballast	112	0.3	68	\$51.32	\$180	\$29	\$369
Women's Room	1	3	40	138	50	95%	0.5	\$119.8	\$48.49	\$35.65	4- F32T8 & 1- 4L Electronic Ballast	112	0.3	68	\$51.32	\$180	\$29	\$369
Police Sign in Room	3	3	40	552	90	95%	0.5	\$63.38	\$41.77	\$122.66	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$28	\$348
Mess Room	3	3	40	552	90	95%	0.5	\$63.38	\$41.77	\$122.66	3- F32T8 & 1- 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$28	\$348
Office #17	1	3	40	138	50	95%	0.1	\$6.38	\$5.35	\$11.73	3- F32T8 & 1- 3L Electronic Ballast	88	0.0	11	\$7.48	\$40	\$7	\$4.25
Conference Room #3	2	4	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4- F32T8 & 1- 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$15	\$72
Conference Room #1	6	3	40	276	35	75%	0.6	\$111.8	\$33.27	\$78.42	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$14	\$15.24
Conference Room #1	2	3	40	276	35	75%	0.6	\$111.8	\$33.27	\$78.42	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$14	\$15.24
Rear Office 13B	4	3	40	552	50	95%	0.5	\$119.8	\$48.49	\$35.65	4- F32T8 & 1- 4L Electronic Ballast	112	0.3	68	\$51.32	\$180	\$29	\$369
Employment Info. Office	2	3	40	276	50	95%	0.3	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$14	\$15.24
Second Floor																		
Room #3 (Office)	2	3	40	276	50	95%	0.3	\$24.25	\$17.82	\$42.07	3- F32T8 & 1- 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$14	\$15.24
Office #10	4	4	40	736	50	95%	0.7	\$66.66	\$47.53	\$112.19	4- F32T8 & 1- 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$29	\$369

ECO-6D
Buildings 500 - 581
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost	Max. Cost	Labor Cost \$	Btg. Cost \$	Total Cost \$	Energy Savings \$
Computer Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Employee Relations Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Antiquities	27	4	40	2,884	35	75%	1.9	377.3	\$172.28	\$12.29	\$284.57	2 - F32T8 & 1 - 2L Electronic Ballast	60	1.2	246	\$185.59	\$945	\$945	\$163	\$2,053	\$98.98
Center Bldg. Open Office Area	26	4	40	4,784	50	95%	4.5	1,038.1	\$420.21	\$308.95	\$729.21	4 - F32T8 & 1 - 4L Electronic Ballast	112	2.8	632	\$443.87	\$1,170	\$1,040	\$191	\$2,401	\$285.34
Conference Room (Locked)	2	3	40	276	35	75%	0.2	41.9	\$19.14	\$12.48	\$31.62	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	27	\$20.16	\$80	\$80	\$14	\$174	\$11.46
Room #7 (Office)	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Basement Level																					
Starwell #2 Police Area	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	44	\$18.29	\$35	\$35	\$6	\$76	\$9.75
Starwell #3 Legal Office	2	4	40	368	168	95%	0.3	268.3	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	163	\$68.28	\$90	\$80	\$15	\$185	\$43.90
Room #16 (Rear Office)	4	3	40	552	50	95%	0.3	119.8	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	76	\$35.65	\$160	\$160	\$28	\$348	\$50.49
Starwell #1 Dispensary Side	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	44	\$18.29	\$35	\$35	\$6	\$76	\$9.75
Room #16 (Pile Down Lighting)	6	1	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.2	40	\$28.25	\$180	\$210	\$34	\$424	\$76.75
Open Office Area Room #16	32	3	40	4,416	50	95%	4.2	958.3	\$387.94	\$35.18	\$773.12	3 - F32T8 & 1 - 3L Electronic Ballast	88	2.7	611	\$429.24	\$1,280	\$1,280	\$221	\$2,781	\$243.88
Starwell #2 Police Area	2	2	40	184	168	95%	0.2	134.2	\$16.16	\$19.96	\$56.09	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	87	\$36.58	\$70	\$70	\$12	\$152	\$19.51
Room #15 (Office)	10	4	40	1,840	50	95%	1.7	399.3	\$161.64	\$118.83	\$280.47	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.1	243	\$170.72	\$450	\$400	\$74	\$924	\$109.75
Room #13 (Copy Room)	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Room #3A (Internal Review)	6	3	40	828	35	75%	0.6	125.8	\$57.43	\$37.43	\$94.86	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	80	\$60.49	\$240	\$240	\$42	\$522	\$34.37
Corridor	10	3	40	1,380	50	95%	1.3	299.5	\$121.23	\$89.12	\$210.35	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.8	191	\$134.14	\$400	\$400	\$69	\$869	\$76.21
Room #2 (Office)	5	3	40	690	50	95%	0.7	149.7	\$60.62	\$44.56	\$105.18	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	95	\$67.07	\$200	\$200	\$35	\$435	\$38.11
Room #4 (Office)	6	3	40	828	50	95%	0.8	179.7	\$72.74	\$53.47	\$126.21	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.5	115	\$80.48	\$240	\$240	\$42	\$522	\$45.73
Room #5 (Office)	12	3	40	1,656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.0	229	\$160.96	\$480	\$480	\$83	\$1,043	\$91.46
Room #7 (Conference Room)	2	3	40	276	35	75%	0.2	41.9	\$19.14	\$12.48	\$31.62	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	27	\$20.16	\$80	\$80	\$14	\$174	\$11.46
Room #3 (Open Work Space)	12	3	40	1,656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.0	229	\$160.96	\$480	\$480	\$83	\$1,043	\$91.46
Room #12	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.2	40	\$28.25	\$180	\$210	\$34	\$424	\$76.75
DPCA Office Coordinator	5	3	40	690	50	95%	0.7	149.7	\$60.62	\$44.56	\$105.18	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	95	\$67.07	\$200	\$200	\$35	\$435	\$38.11
Room #11 (Open Office Area)	10	3	40	1,380	50	95%	1.3	299.5	\$121.23	\$89.12	\$210.35	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.8	191	\$134.14	\$400	\$400	\$69	\$869	\$76.21
Room #1A (Plas)	4	3	40	552	50	95%	0.3	119.8	\$48.49	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	76	\$35.65	\$160	\$160	\$28	\$348	\$50.49
Entrance/Vending Area	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.2	40	\$28.25	\$180	\$210	\$34	\$424	\$76.75
Basement Floor																					
Open Area	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Open Area	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	39	\$27.44	\$105	\$105	\$18	\$228	\$14.63
Weight Room	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
Pool Table Room	6	4	40	1,104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.43	\$270	\$240	\$44	\$554	\$65.85
Stairs to First Floor	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97
First Floor																					
Smokers Lounge	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97
Ladies Room	1	3	40	138	30	50%	0.1	18.0	\$6.38	\$5.35	\$11.73	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.0	11	\$7.48	\$40	\$40	\$7	\$87	\$4.25
Kitchen Area	2	4	40	368	30	50%	0.2	47.9	\$17.01	\$14.26	\$31.27	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	29	\$19.04	\$90	\$80	\$15	\$185	\$12.24
Corridor	5	2	40	460	50	95%	0.4	99.8	\$40.41	\$29.71	\$70.12	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.3	65	\$45.73	\$175	\$175	\$30	\$380	\$24.39
Dining Area	4	4	40	736	30	50%	0.4	95.8	\$34.03	\$28.52	\$62.55	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	58	\$38.07	\$180	\$160	\$29	\$369	\$24.48
Stairs to Second Floor	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88
Stairs to Second Floor	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88
General Office Area	18	2	40	1,656	90	95%	1.6	646.8	\$145.48	\$106.94	\$252.42	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.0	422	\$268.28	\$630	\$630	\$109	\$1,369	\$117.56
Radio Equipment Room	2	4	40	368	168	95%	0.3	268.3	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	163	\$68.28	\$90	\$80	\$15	\$185	\$43.90
Computer/Fax Machine Room	1	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97
Chief Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Research Area/Library	4	2	40	736	30	50%	0.4	95.8	\$34.03	\$28.52	\$62.55	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	58	\$38.07	\$180	\$160	\$29	\$369	\$24.48
Plans Review Conference Room	2	3	40	276	90	95%	0.3	107.8	\$42.25	\$32.08	\$66.33	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	69	\$35.92	\$80	\$80	\$14	\$174	\$20.41
Wash Room	6	2	40	368	35	75%	0.4	83.8	\$38.28	\$24.95	\$63.24	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.3	55	\$41.24	\$210	\$210	\$36	\$546	\$22.00
Wash Room	2	4	40	368	168	95%	0.3	268.3	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	163	\$68.28	\$90	\$80	\$15	\$185	\$43.90
Mess Room	1	3	40	138	30	50%	0.1	18.0	\$6.38	\$5.35	\$11.73	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.0	11	\$7.48	\$40	\$40	\$7	\$87	\$4.25
Assistance Chief Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Second Floor																					
Corridor	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97

ECO-6D

Existing										Proposed										Implementation				
Room	NO Of Luminaires	Large Luminaire Per Watts	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$	Energy Savings \$				
Building 522																								
First Floor																								
Office of the Chief of Staff	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F3278 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90			
Office of the Chief of Staff Resp.	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F3278 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$120	\$120	\$22	\$277	\$32.92			
Rear Office #2 (not occupied)	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F3278 & 1 - 4L Electronic Ballast	112	0.2	49	\$40.44	\$90	\$80	\$15	\$185	\$21.95			
Secretary's Ofc. to the General	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	4- F3278 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.43	\$270	\$240	\$44	\$554	\$65.85			
Right Reception Area	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F3278 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$32.92			
Main Entrance	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F3278 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97			
Rear Office #2 (not occupied)	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F3278 & 1 - 4L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76			
Rear Office #1 (not occupied)	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	2- F3278 & 1 - 2L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90			
Lobby	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F3278 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76			
Reception Area	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F3278 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76			
Left Reception Area	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F3278 & 1 - 4L Electronic Ballast	112	0.2	49	\$40.44	\$90	\$80	\$15	\$185	\$21.95			
Commanding General Conf. Rm.	9	4	40	1656	35	75%	1.2	251.5	\$114.85	\$74.86	\$189.71	4- F3278 & 1 - 4L Electronic Ballast	112	0.8	173	\$115.48	\$405	\$360	\$66	\$831	\$74.23			
Communicating Generals Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F3278 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$32.92			
Secretary's Ofc. to the General	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F3278 & 1 - 4L Electronic Ballast	112	0.2	49	\$40.44	\$90	\$80	\$15	\$185	\$21.95			
Second Floor																								
Inspector Gen. Admin. Office	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	2- F3278 & 1 - 2L Electronic Ballast	60	0.2	39	\$27.44	\$105	\$105	\$18	\$228	\$14.63			
Capty Roon	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F3278 & 1 - 4L Electronic Ballast	112	0.2	49	\$40.44	\$90	\$80	\$15	\$185	\$21.95			
Inspector General Office	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2- F3278 & 1 - 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304	\$19.51			
Inspector General Reception	4	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F3278 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76			
Protocol Office	5	2	40	460	50	95%	0.4	99.8	\$40.41	\$29.71	\$70.12	2- F3278 & 1 - 2L Electronic Ballast	60	0.3	65	\$45.73	\$	\$175	\$30	\$380	\$24.39			
Liaison Office	6	2	40	460	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	4- F3278 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.43	\$270	\$240	\$44	\$554	\$65.85			
Protocol Office	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F3278 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97			
Conference Room	10	4	40	1840	35	75%	1.4	279.5	\$127.61	\$83.18	\$210.79	4- F3278 & 1 - 4L Electronic Ballast	112	0.8	170	\$128.31	\$450	\$400	\$74	\$924	\$82.48			
Corridor	8	2	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	2- F3278 & 1 - 2L Electronic Ballast	60	0.5	104	\$73.17	\$280	\$280	\$48	\$608	\$39.02			
Building 523																								
Administration																								
Cornelius Office	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2- F3278 & 1 - 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304	\$19.51			
Grayson Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F3278 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90			
Isabel Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F3278 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90			
Descom Office A	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F3278 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24			
Howser Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F3278 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24			
Burnes Office	6	3	40	638	50	95%	0.8	179.7	\$72.74	\$53.47	\$128.21	3- F3278 & 1 - 3L Electronic Ballast	88	0.5	115	\$80.48	\$240	\$240	\$42	\$522	\$45.73			
Gertman Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F3278 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24			
Quarrier Office	6	2	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	2- F3278 & 1 - 2L Electronic Ballast	60	0.3	78	\$54.87	\$210	\$210	\$36	\$456	\$39.27			
Sheffield Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F3278 & 1 - 4L Electronic Ballast	112	0.2	49	\$40.44	\$90	\$80	\$15	\$185	\$21.95			
Conference Room B	2	4	40	368	35	75%	0.3	59.9	\$25.52	\$16.64	\$42.16	4- F3278 & 1 - 4L Electronic Ballast	112	0.2	34	\$25.66	\$90	\$80	\$15	\$185	\$21.95			
Myers Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3- F3278 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$80	\$15	\$185	\$21.95			
Horn Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3- F3278 & 1 - 3L Electronic Ballast	88	0.3	76	\$53.65	\$160	\$160	\$28	\$348	\$30.49			
Descom Office B	6	2	40	552	50	95%	0.8	167.7	\$76.57	\$49.91	\$126.47	2- F3278 & 1 - 2L Electronic Ballast	60	0.3	78	\$54.87	\$210	\$210	\$36	\$456	\$32.27			
Conference Room A	8	3	40	1104	35	75%	0.8	167.7	\$76.57	\$49.91	\$126.47	3- F3278 & 1 - 3L Electronic Ballast	88	0.5	107	\$80.65	\$320	\$320	\$35	\$695	\$45.82			
Kichen	1	3	40	138	50	95%	0.1	29.9	\$12.10	\$8.91	\$21.05	3- F3278 & 1 - 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$87	\$7.62			
Library	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2- F3278 & 1 - 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304	\$19.51			
Descom Office C	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2- F3278 & 1 - 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304	\$19.51			
Corridor	11	2	40	1012	50	95%	1.0	219.6	\$88.90	\$65.35	\$154.26	2- F3278 & 1 - 2L Electronic Ballast	60	0.6	143	\$100.60	\$385	\$385	\$67	\$837	\$53.65			
Building 524																								
Conference Center																								
Entrance Lobby	7	2	40	644	50	95%	0.6	139.7	\$56.57	\$41.59	\$98.16	2- F3278 & 1 - 2L Electronic Ballast	60	0.4	91	\$64.02	\$245	\$245	\$42	\$532	\$34.14			
Mens Restroom	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2- F3278 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76	\$2.72			
Womens Restroom	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2- F3278 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76	\$2.72			

ECO-6D
Buildings 500 - 581
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

		Existing										Proposed										Implementation				
		NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Max. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$				

ECO-6D
Buildings 500 - 581
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

		Existing										Proposed			Implementation							
		NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw/Hr Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/Hr Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings
Second Floor																						
	Room #15 Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
	Room #17 Conference Room	3	4	40	552	35	75%	0.4	83.8	\$38.28	\$24.95	\$63.24	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	51	\$38.49	\$135	\$120	\$22	\$277	\$24.74
	Room #20A	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
	Room #20	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$32.92
	Room #14 Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
	Room #19 Smoke Room	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$32.92
	Room #8 & #10	5	4	40	920	50	95%	0.9	199.6	\$80.82	\$59.41	\$140.23	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.5	122	\$85.36	\$225	\$200	\$37	\$462	\$54.87
	Room #14A Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$32.92
	Room #11 Office	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97
	Room #12 Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$32.92
	Room #1 Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$32.92
	Room #9 Office	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92	\$10.97
	Room #5 & #7 Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$43.90
	Room #3 Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277	\$32.92
	Room #4 Conference Room	3	4	40	552	35	75%	0.4	83.8	\$38.28	\$24.95	\$63.24	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	51	\$38.49	\$135	\$120	\$22	\$277	\$24.74
	Room #1 Conference Area	2	4	40	368	35	75%	0.3	55.9	\$23.52	\$16.64	\$42.16	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	34	\$25.66	\$90	\$80	\$15	\$185	\$16.50
	Corridor	11	4	40	2024	50	95%	1.9	439.2	\$177.81	\$130.71	\$308.51	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.2	267	\$187.79	\$495	\$440	\$81	\$1,016	\$120.72
TOTALS		894			128800			117.7	30327	\$11,000	\$9,000	\$20,000			73.5	18972	\$12,000	\$36,000	\$34,000	\$6,000	\$77,000	\$7,500
G:\PROJECTS\1310-01\SSRECONECO_6D.WK4																						\$7,500

G:\PROJECTS\4130\JTS\SS\ECO-6D\WK4

ECO-6E
Buildings 616 - 5426
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Existing				Proposed				Implementation													
				Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw	Usage Kw/Hr Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/Hr Month	Annual Cost \$	Mt. Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$	Energy Savings \$				
Building 616																									
Police Building																									
Police Conference Room	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$79.85	\$112.18	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	175	\$73.16	\$140	\$140	\$24	\$304	\$39.02				
Police Conference Room	4	4	40	736	168	95%	0.7	536.6	\$64.66	\$159.70	\$224.36	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	377	\$136.57	\$180	\$180	\$29	\$369	\$87.79				
Building 618																									
First Floor																									
Hole Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Corridor	8	2	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.5	104	\$73.17	\$280	\$280	\$48	\$608	\$39.02				
Room #11 Office	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	57	\$40.24	\$120	\$120	\$21	\$261	\$22.86				
Copy Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Coffee Mess	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Handicap Restroom	1	3	40	138	30	50%	0.1	18.0	\$6.38	\$5.35	\$11.73	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.0	11	\$7.48	\$40	\$40	\$7	\$87	\$4.25				
Mens Room	2	3	40	276	30	50%	0.1	35.9	\$12.76	\$10.69	\$23.46	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	23	\$14.96	\$80	\$80	\$14	\$174	\$8.50				
Room #7	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Manit Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Kitchen Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Walter Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Hunting & Fishing Office	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	57	\$40.24	\$120	\$120	\$21	\$261	\$22.86				
Second Floor																									
Warneck Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Corridor	8	2	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.5	104	\$73.17	\$280	\$280	\$48	\$608	\$39.02				
Stairwell to Second Floor	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$87	\$7.62				
Casinet	2	3	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76				
Yeast Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Yeast Office	2	3	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76				
Quinn Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Itaz Waste Conference Room	5	3	40	690	35	75%	0.5	104.8	\$47.85	\$31.19	\$79.05	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Gueseking Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Williams Office	2	3	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76				
Epstein Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Conference Room	3	3	40	414	35	75%	0.3	62.9	\$28.71	\$18.72	\$47.43	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	40	\$30.24	\$120	\$120	\$21	\$261	\$17.18				
Women's Room	2	3	40	276	30	50%	0.1	35.9	\$12.76	\$10.69	\$23.46	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	23	\$14.96	\$80	\$80	\$14	\$174	\$8.50				
Building 619																									
Dining Area																									
Women's Room	2	3	40	276	30	50%	0.1	35.9	\$12.76	\$10.69	\$23.46	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	23	\$14.96	\$80	\$80	\$14	\$174	\$8.50				
Entrance Lobby	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88				
Staff Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Women's Room Sink	1	1	40	46	30	50%	0.0	6.0	\$2.13	\$1.78	\$3.91	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	4	\$2.63	\$30	\$30	\$6	\$71	\$1.27				
Mens Room Sink	1	1	40	46	30	50%	0.0	6.0	\$2.13	\$1.78	\$3.91	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	4	\$2.63	\$30	\$30	\$6	\$71	\$1.27				
Rear Dining Area	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$180	\$29	\$369	\$43.90				
Mens Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Open Dining Area	27	3	40	3726	90	95%	3.3	808.5	\$327.32	\$240.62	\$667.95	3 - F32T8 & 1 - 3L Electronic Ballast	88	2.3	\$16	\$362.17	\$1,080	\$1,080	\$187	\$2,347	\$205.78				
Serving Area	7	2	40	644	50	95%	0.6	139.7	\$56.57	\$41.59	\$98.16	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.4	91	\$64.02	\$245	\$245	\$42	\$532	\$34.14				
Rear Dining Area	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$87	\$7.62				
Building 628																									
First Floor																									
Information Security	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Badge Photo Room	4	3	40	552	50	95%	0.5	119.8	\$48.40	\$35.65	\$84.14	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	76	\$33.65	\$160	\$160	\$28	\$348	\$30.49				
Badge Photo Room File	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88				
Conference Room A	3	3	40	414	35	75%	0.3	62.9	\$28.71	\$18.72	\$47.43	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	40	\$30.24	\$120	\$120	\$21	\$261	\$17.18				
First Floor Corridor	5	3	40	690	50	95%	0.7	149.7	\$60.62	\$44.56	\$105.18	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	95	\$67.07	\$200	\$200	\$35	\$435	\$38.11				
Women's Restroom & Shower	3	3	40	414	90	50%	0.2	53.9	\$19.14	\$16.04	\$35.18	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	34	\$22.44	\$120	\$120	\$21	\$261	\$12.75				
Handicap Restroom	1	3	40	138	30	50%	0.1	18.0	\$6.38	\$5.35	\$11.73	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.0	11	\$7.48	\$40	\$40	\$7	\$87	\$4.25				
Copy Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Smoking Room	1	1	40	46	50	95%	0.0	10.0	\$4.04	\$2.97	\$7.01	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	7	\$4.73	\$30	\$30	\$6	\$71	\$2.29				
Automation Security Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Police Officers Room #3 Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Room #1 Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174	\$15.24				
Physical Security	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$87	\$7.62				

ECO-6E
Buildings 616 - 5426
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO. Of Lamps	Lamps Per Luminare	Watts Per Lamp	Existing				Proposed				Implementation										
				Total Watts	Hours Per Week	Percent On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminare Description	Watts Per Luminare	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Max. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$	
Second Floor																						
Stairway to Second Floor	1	2	40	80	50	95%	0.1	20.0	\$8.08	\$3.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76	\$4.88	
Corridor	5	3	40	600	92	95%	0.7	149.7	\$60.62	\$44.56	\$105.18	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	95	\$67.07	\$200	\$200	\$35	\$435	\$38.11	
Investigation Office Room #19	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.63	\$80	\$80	\$14	\$174	\$15.24	
Investigation Office Room #18	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	57	\$40.24	\$120	\$120	\$21	\$261	\$22.86	
Interview Room #17	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.63	\$80	\$80	\$14	\$174	\$15.24	
Secretary & Plans Div. Office	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	57	\$40.24	\$120	\$120	\$21	\$261	\$22.86	
Chief Secretary & Plans Div. Ofc.	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	57	\$40.24	\$120	\$120	\$21	\$261	\$22.86	
Mens Room & Shower	3	3	40	414	50	95%	0.2	53.9	\$19.14	\$16.04	\$35.18	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	34	\$22.44	\$80	\$80	\$14	\$174	\$15.24	
Director - PM Office Room #11	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.63	\$80	\$80	\$14	\$174	\$15.24	
Director's Secretary Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.63	\$80	\$80	\$14	\$174	\$15.24	
Building 637																						
Chapel	40	1	40	1840	40	75%	1.4	319.4	\$127.61	\$95.06	\$222.67	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.9	215	\$150.06	\$1,200	\$1,400	\$225	\$2,825	\$72.61	
Chapel Lighting	2	2	40	184	40	75%	0.1	31.9	\$12.76	\$9.51	\$22.27	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	21	\$14.52	\$70	\$70	\$12	\$152	\$7.75	
Corridor Behind Alter																						
Building 639																						
Physical Fitness Center																						
Rear Entrance Lobby	1	2	40	80	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	44	\$18.29	\$35	\$35	\$6	\$76	\$9.75	
Weight Room Restroom	2	2	40	184	101	95%	0.2	80.7	\$16.16	\$24.00	\$40.17	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	53	\$26.20	\$70	\$70	\$12	\$152	\$13.97	
Weight Room	14	3	40	1932	168	95%	1.8	1408.7	\$169.72	\$149.22	\$388.94	3 - F32T8 & 1 - 3L Electronic Ballast	88	1.2	898	\$375.56	\$560	\$560	\$97	\$1,217	\$213.38	
Gym Entrance	2	40	92	184	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	44	\$18.29	\$35	\$35	\$6	\$76	\$9.75	
Women's Rest Locker Room	1	4	40	184	168	95%	0.2	134.2	\$16.16	\$24.00	\$40.17	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.1	82	\$34.14	\$45	\$40	\$7	\$92	\$21.95	
Corridor to Sauna	3	2	40	276	168	95%	0.3	201.2	\$24.25	\$19.89	\$44.13	3 - F32T8 & 1 - 3L Electronic Ballast	60	0.2	131	\$44.87	\$105	\$105	\$18	\$228	\$29.26	
Corridor to Women's Locker Rm.	1	2	40	80	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	44	\$18.29	\$35	\$35	\$6	\$76	\$9.75	
Women's Shower Room	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$19.85	\$112.18	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	175	\$73.16	\$140	\$140	\$24	\$304	\$39.02	
Corridor to Mens Locker Room	1	2	40	80	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	44	\$18.29	\$35	\$35	\$6	\$76	\$9.75	
Gym Office	2	2	40	368	168	95%	0.3	268.3	\$32.33	\$19.85	\$112.18	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.2	163	\$36.58	\$90	\$80	\$15	\$185	\$43.90	
Corridor to Restroom	2	4	40	184	168	95%	0.2	134.2	\$16.16	\$24.00	\$40.17	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	87	\$36.57	\$70	\$70	\$12	\$152	\$10.51	
Mens Locker Room	4	4	40	736	168	95%	0.7	536.6	\$64.66	\$159.70	\$224.36	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	327	\$136.57	\$180	\$160	\$29	\$369	\$87.79	
Women's Locker Room	4	4	40	736	168	95%	0.7	536.6	\$64.66	\$159.70	\$224.36	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	327	\$136.57	\$180	\$160	\$29	\$369	\$87.79	
Mens Shower Room	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$19.85	\$112.18	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	175	\$73.16	\$140	\$140	\$24	\$304	\$39.02	
Mens Rest Locker Room	1	4	40	184	168	95%	0.2	134.2	\$16.16	\$24.00	\$40.17	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.1	82	\$34.14	\$45	\$40	\$7	\$92	\$21.95	
Gym Entrance	1	1	40	40	168	95%	0.0	33.5	\$4.04	\$9.98	\$14.02	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	23	\$9.45	\$30	\$35	\$6	\$71	\$4.57	
Building 640																						
Campier Check In																						
Main Entrance Area	2	4	40	368	20	50%	0.2	31.9	\$17.01	\$9.51	\$26.52	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	19	\$16.14	\$90	\$80	\$15	\$185	\$10.38	
Office #1	1	4	40	184	20	50%	0.1	16.0	\$8.51	\$4.75	\$13.26	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	10	\$8.07	\$45	\$40	\$7	\$92	\$5.19	
Office #2	1	4	40	184	20	50%	0.1	16.0	\$8.51	\$4.75	\$13.26	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	10	\$8.07	\$45	\$40	\$7	\$92	\$5.19	
Mens Room	2	4	40	368	20	50%	0.2	31.9	\$17.01	\$9.51	\$26.52	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	19	\$16.14	\$90	\$80	\$15	\$185	\$10.38	
Women's Room	2	4	40	368	20	50%	0.2	31.9	\$17.01	\$9.51	\$26.52	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	19	\$16.14	\$90	\$80	\$15	\$185	\$10.38	
Laundry Room	1	4	40	184	20	50%	0.1	16.0	\$8.51	\$4.75	\$13.26	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	10	\$8.07	\$45	\$40	\$7	\$92	\$5.19	
Building 645																						
Day Care																						
Entrance Lobby	1	2	40	80	90	95%	0.1	35.9	\$8.08	\$10.69	\$18.78	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	23	\$12.25	\$35	\$35	\$6	\$76	\$6.53	
Changing Area	2	2	40	184	54	95%	0.2	43.1	\$16.16	\$12.83	\$29.00	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	28	\$18.91	\$70	\$70	\$12	\$152	\$10.09	
Bedroom #3	1	2	40	80	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	14	\$9.46	\$35	\$35	\$6	\$76	\$5.04	
Baby Area	1	2	40	80	90	95%	0.3	143.7	\$32.33	\$26.74	\$63.11	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	94	\$48.08	\$140	\$140	\$24	\$304	\$26.12	
Bedroom #2	1	2	40	80	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	14	\$9.46	\$35	\$35	\$6	\$76	\$5.04	
Kitchen Area	1	2	40	80	90	95%	0.1	35.9	\$8.08	\$10.69	\$18.78	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	23	\$12.25	\$35	\$35	\$6	\$76	\$6.53	
Bedroom #1	1	2	40	80	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	14	\$9.46	\$35	\$35	\$6	\$76	\$5.04	
Play Area	16	2	40	1472	90	95%	1.4	319.4	\$127.61	\$95.06	\$222.67	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.9	375	\$195.93	\$560	\$560	\$97	\$1,217	\$104.49	
Staff Office	5	2	40	276	90	95%	0.3	107.8	\$24.25	\$19.89	\$44.13	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	70	\$36.74	\$105	\$105	\$18	\$228	\$29.26	

ECO-6E
Buildings 616 - 5426
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Existing				Proposed										Implementation				
				Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost	Mt. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings		
Building 646																						
Entrance Area	2	3	40	276	126	95%	150.9	\$24.25	\$44.92	\$69.16	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	96	\$44.10	\$80	\$80	\$14	\$174	\$25.06		
Lounge Area	5	3	40	690	126	95%	377.3	\$60.62	\$112.29	\$172.91	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	241	\$110.26	\$200	\$200	\$35	\$435	\$62.65		
Girls Room	2	3	40	184	76	95%	60.7	\$16.16	\$18.06	\$34.23	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	40	\$22.32	\$70	\$70	\$12	\$152	\$11.90		
Boys Room	2	3	40	184	76	95%	60.7	\$16.16	\$18.06	\$34.23	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	40	\$22.32	\$70	\$70	\$12	\$152	\$11.90		
Staff Office	2	3	40	276	126	95%	150.9	\$24.25	\$44.92	\$69.16	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	96	\$44.10	\$80	\$80	\$14	\$174	\$25.06		
Corridor to Play Room	1	2	40	92	126	95%	50.3	\$8.08	\$14.97	\$23.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	33	\$15.04	\$35	\$35	\$6	\$87	\$8.07		
Play Room	2	3	40	276	126	95%	150.9	\$24.25	\$44.92	\$69.16	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	96	\$44.10	\$80	\$80	\$14	\$174	\$25.06		
Open Area	20	2	40	1840	126	95%	17	\$106.2	\$299.44	\$461.08	2 - F32T8 & 1 - 2L Electronic Ballast	60	1.1	656	\$300.71	\$700	\$700	\$121	\$1,521	\$160.38		
Kitchen	1	3	40	138	126	95%	0.1	\$75.5	\$12.12	\$22.46	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	48	\$22.05	\$40	\$40	\$7	\$87	\$12.53		
Kitchen	2	2	40	184	126	95%	0.2	\$106.6	\$29.94	\$46.11	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	66	\$30.07	\$70	\$70	\$12	\$152	\$16.04		
Building 663																						
Administration & Trades	19	4	40	3496	90	95%	3.3	\$307.12	\$406.38	\$713.50	4 - F32T8 & 1 - 4L Electronic Ballast	112	2.0	831	\$434.31	\$855	\$760	\$140	\$1,755	\$279.20		
Headquarters & Plumbing Shop Area	4	4	40	736	90	95%	0.7	\$64.66	\$85.55	\$150.21	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$29	\$369	\$58.78		
Main Entrance Lobby	8	4	40	1472	90	95%	1.4	\$75.0	\$171.11	\$300.42	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	350	\$182.87	\$360	\$320	\$59	\$739	\$117.56		
Production Division Office #3	4	2	40	368	90	95%	0.3	\$43.7	\$32.33	\$42.78	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	94	\$48.98	\$140	\$140	\$24	\$304	\$26.12		
Production Division Office #2	2	2	40	184	90	95%	0.2	\$71.9	\$16.16	\$21.39	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	47	\$24.49	\$70	\$70	\$12	\$152	\$13.06		
Heating Branch Office Front Rm	6	4	40	1104	90	95%	1.0	\$43.2	\$96.98	\$128.33	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.6	262	\$137.15	\$270	\$240	\$44	\$554	\$88.17		
Heating Branch Office Back Rm	2	4	40	368	90	95%	0.3	\$43.7	\$32.33	\$42.78	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.2	87	\$45.72	\$90	\$80	\$15	\$185	\$29.39		
Production Division Office #1	1	2	40	92	90	95%	0.1	\$35.9	\$8.08	\$14.97	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	23	\$12.25	\$35	\$35	\$6	\$76	\$6.51		
Building & Structural Office	4	2	40	368	90	95%	0.3	\$43.7	\$32.33	\$42.78	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.2	87	\$45.72	\$90	\$80	\$15	\$185	\$29.39		
Lunch Room	4	3	40	552	90	95%	0.5	\$215.6	\$48.49	\$64.17	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	94	\$48.98	\$140	\$140	\$24	\$304	\$26.12		
Carder Supply Room	4	3	40	552	90	95%	0.5	\$215.6	\$48.49	\$64.17	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	94	\$48.98	\$140	\$140	\$24	\$304	\$26.12		
Carder Supply Room	4	3	40	552	90	95%	0.5	\$215.6	\$48.49	\$64.17	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	94	\$48.98	\$140	\$140	\$24	\$304	\$26.12		
S. C. Office	28	3	40	3684	90	95%	3.7	\$150.3	\$339.45	\$449.16	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	137	\$71.84	\$160	\$160	\$28	\$348	\$40.82		
Dispatch Office	3	3	40	414	90	95%	0.4	\$161.7	\$36.37	\$48.12	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	962	\$102.88	\$1,200	\$1,120	\$104	\$2,434	\$385.73		
Heating Supply Cage	2	4	40	368	90	95%	0.3	\$43.7	\$32.33	\$42.78	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.2	87	\$45.72	\$90	\$80	\$15	\$185	\$29.39		
Dispatch Corridor	4	4	40	736	90	95%	0.7	\$64.66	\$85.55	\$150.21	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	175	\$91.43	\$180	\$160	\$29	\$369	\$58.78		
Computer Room	1	3	40	138	90	95%	0.1	\$35.9	\$8.08	\$14.97	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	23	\$12.25	\$35	\$35	\$6	\$76	\$6.51		
Welding Shop Area	8	2	40	552	90	95%	0.5	\$215.6	\$48.49	\$64.17	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	94	\$48.98	\$140	\$140	\$24	\$304	\$26.12		
Welding Shop Area	8	2	40	552	90	95%	0.5	\$215.6	\$48.49	\$64.17	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	94	\$48.98	\$140	\$140	\$24	\$304	\$26.12		
Production Division Office #1	30	4	40	4140	90	95%	3.9	\$161.7	\$363.69	\$481.24	3 - F32T8 & 1 - 3L Electronic Ballast	112	2.5	1,031	\$538.80	\$1,200	\$1,200	\$208	\$2,608	\$366.14		
Operations & Maint. Control Room	2	4	40	368	90	95%	0.3	\$43.7	\$32.33	\$42.78	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.2	87	\$45.72	\$90	\$80	\$15	\$185	\$29.39		
Work Planning & Control Office	12	4	40	2708	90	95%	2.1	\$86.2	\$193.97	\$256.66	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	48	\$29.78	\$80	\$80	\$14	\$174	\$16.92		
Business Managers Office	3	3	40	414	90	95%	0.4	\$161.7	\$36.37	\$48.12	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	103	\$53.88	\$120	\$120	\$21	\$261	\$30.61		
Copy Room	1	4	40	184	54	95%	0.2	\$43.1	\$16.16	\$21.39	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.1	26	\$17.65	\$45	\$40	\$7	\$92	\$11.35		
Computer Room	1	2	40	92	54	95%	0.1	\$35.9	\$8.08	\$14.97	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	23	\$12.25	\$35	\$35	\$6	\$76	\$6.51		
Women's Room	2	3	40	276	54	95%	0.3	\$64.7	\$24.25	\$19.25	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	41	\$27.74	\$80	\$80	\$14	\$174	\$15.76		
Mens Room	2	3	40	276	54	95%	0.3	\$64.7	\$24.25	\$19.25	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	41	\$27.74	\$80	\$80	\$14	\$174	\$15.76		
Corridor to Drawing Files Area	7	3	40	966	63	95%	0.3	\$84.86	\$78.60	\$163.46	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.6	168	\$104.24	\$280	\$280	\$48	\$608	\$59.23		
Director of Public Works	2	3	40	276	90	95%	0.2	\$107.8	\$24.25	\$32.08	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	69	\$35.92	\$80	\$80	\$14	\$174	\$20.41		
Director of Public Works	1	4	40	184	90	95%	0.2	\$71.9	\$16.16	\$21.39	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.1	44	\$22.86	\$45	\$40	\$7	\$92	\$14.69		
Office	3	2	40	276	90	95%	0.3	\$107.8	\$24.25	\$32.08	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	70	\$36.74	\$105	\$105	\$18	\$228	\$19.59		
Office	3	3	40	414	90	95%	0.4	\$161.7	\$36.37	\$48.12	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.3	103	\$53.88	\$120	\$120	\$21	\$261	\$30.61		
Print Room	2	3	40	276	90	95%	0.3	\$107.8	\$24.25	\$32.08	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	69	\$35.92	\$80	\$80	\$14	\$174	\$20.41		
Drawing Files Area	8	4	40	1472	54	95%	1.4	\$43.0	\$129.31	\$102.67	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.9	210	\$141.20	\$360	\$320	\$57	\$92	\$11.35		
Open Office Area	47	3	40	6886	90	95%	6.2	\$233.4	\$569.78	\$735.95	3 - F32T8 & 1 - 3L Electronic Ballast	88	3.9	1,616	\$844.12	\$1,880	\$1,880	\$325	\$4,085	\$479.61		
Corridor to Office Bar	3	4	75	258.75	90	95%	0.2	\$101.1	\$22.73	\$30.08	1 - F96T8 & 1 - 1L Electronic Ballast	52	0.1	61	\$31.84	\$96	\$105	\$17	\$128	\$20.97		
Operations & Maint. Room	12	4	40	2708	90	95%	2.1	\$86.2	\$193.97	\$256.66	3 - F32T8 & 1 - 3L Electronic Ballast	112	1.3	525	\$274.30	\$540	\$480	\$88	\$1,108	\$176.33		
Electrical Supply	7	1	75	603.75	90	95%	0.6	\$235.8	\$35.04	\$70.18	1 - F96T8 & 1 - 1L Electronic Ballast	52	0.2	142	\$74.29	\$224	\$245	\$41	\$510	\$48.93		
Electrical Office	2	3	40	276	90	95%	0.3	\$107.8	\$24.25	\$32.08	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	69	\$35.92	\$80	\$80	\$14	\$174	\$20.41		
Office	4	2	40	368	90	95%	0.3	\$43.7	\$32.33	\$42.78	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	94	\$48.98	\$140	\$140	\$24	\$304	\$26.12		
Corridor to Snack Bar	1	2	40	92	90	95%	0.1	\$35.9	\$8.08	\$14.97	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	23	\$12.25	\$35	\$35	\$6	\$76	\$6.51		
Receiving - Supply Area	14	2	40	1288	90	95%	1.2	\$203.1	\$113.15	\$149.72	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.8	328	\$171.44	\$490	\$490	\$85	\$1,065	\$91.43		
Drafting Office Area	34	4	40	6256	90	95%	5.9	\$243.6	\$549.58	\$727.21	4 - F32T8 & 1 - 4L Electronic Ballast	112	3.6	1,487	\$772.18	\$1,530	\$1,560	\$250	\$4,096	\$499.61		
Engineering Office Area	8	4	40	1472	90	95%	1.4	\$75.0	\$171.11	\$300.42	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.9	590	\$317.87	\$560	\$520	\$97	\$739	\$117.56		
Restroom	1	2	40	92	54	95%	0.1	\$35.9	\$8.08	\$14.97	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	14	\$9.46	\$35	\$35	\$6	\$76	\$5.04		

ECO-6E
Buildings 616 - 5426
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO. Of Luminaires	Lamps Per Luminaire	Existing					Proposed					Implementation					Energy Savings \$	
			Watts Per Lamp	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw/Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$		Eng. Cost \$
Building 664																			
First Floor																			
Entrance Lobby	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76
Locker/Showers Room	5	4	40	460	30	50%	0.2	59.9	\$21.27	\$17.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	39	\$25.50	\$175	\$175	\$30	\$380
Corridor to Restroom	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$180	\$29	\$369
Locker Room	2	3	40	276	30	50%	0.1	35.9	\$12.76	\$10.69	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	23	\$14.96	\$80	\$80	\$14	\$174
Open Office Area	9	4	40	1656	50	95%	1.6	359.4	\$145.48	\$252.42	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.0	219	\$153.65	\$405	\$360	\$66	\$831
Empty Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$180	\$29	\$369
Issue Center Office	4	4	40	1656	50	95%	1.6	359.4	\$145.48	\$252.42	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.0	219	\$153.65	\$405	\$360	\$66	\$831
Second Floor																			
Literary Clerk Out	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152
Chaplain's Office	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$87
Reading Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174
Childrens Room	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$87
Literary Clerks	36	2	40	3312	50	95%	3.1	718.7	\$290.95	\$504.84	2 - F32T8 & 1 - 2L Electronic Ballast	60	2.1	469	\$329.24	\$1,260	\$1,260	\$218	\$2,738
Reading Room	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152
Administrative Office	1	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152
Library	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76
Class Room	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76
Sunday School Room	5	2	40	460	50	95%	0.4	99.8	\$30.41	\$29.71	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.3	65	\$45.73	\$175	\$175	\$30	\$380
Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.2	38	\$26.83	\$80	\$80	\$14	\$174
Building 2260																			
Administration																			
Ladies Room	2	4	40	368	30	50%	0.2	47.9	\$17.01	\$14.26	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	29	\$19.04	\$90	\$80	\$15	\$185
Mens Room	1	4	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	15	\$9.52	\$45	\$40	\$7	\$92
Mens Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76
Handicap Restroom	1	4	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	15	\$9.52	\$45	\$40	\$7	\$92
Distn. Branch Chief Reception	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$168.28	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.45	\$270	\$240	\$44	\$554
Open Office Area	52	4	40	9568	50	95%	9.1	2076.3	\$840.53	\$617.80	4 - F32T8 & 1 - 4L Electronic Ballast	112	5.5	1,264	\$887.74	\$2,340	\$2,080	\$382	\$4,802
Property Disposal Office	8	4	40	1472	50	95%	1.4	319.4	\$129.31	\$95.06	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.9	194	\$136.58	\$360	\$320	\$59	\$739
Distn. Branch Chief Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369
Exit Lobby	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.1	24	\$17.07	\$45	\$40	\$7	\$92
Building 2129																			
Penthouse																			
Penthouse Sink Area	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	39	\$27.44	\$105	\$105	\$18	\$228
Restroom	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76
Staff Office	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	39	\$27.44	\$105	\$105	\$18	\$228
Corridor	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152
Building 2755																			
Warehouse																			
Lab Room	5	3	40	690	50	95%	0.7	149.7	\$60.62	\$44.56	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.4	95	\$67.07	\$200	\$200	\$35	\$435
Corridor to Rest Room	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	39	\$27.44	\$105	\$105	\$18	\$228
Main Corridor	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.15	\$35	\$35	\$6	\$76
File Room	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.3	73	\$51.22	\$135	\$120	\$22	\$277
Mens Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76
Open Office Area	12	4	40	2208	50	95%	2.1	479.1	\$193.97	\$142.59	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.3	292	\$204.86	\$540	\$480	\$88	\$1,108
Mens Room Shower	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76
Women's Room	1	1	40	46	30	50%	0.0	6.0	\$2.13	\$1.78	2 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	4	\$2.63	\$30	\$35	\$6	\$71
Breakroom	6	2	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	4 - F32T8 & 1 - 4L Electronic Ballast	60	0.3	78	\$54.87	\$210	\$210	\$36	\$456
Mens Room Mirror	1	1	40	46	30	50%	0.0	6.0	\$2.13	\$1.78	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	4	\$2.63	\$30	\$35	\$6	\$71
Women's Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76

ECO-6E
Buildings 616 - 5426
Letterkenny Army Depot
Efficient Fluorescent Lighting Retrofit

Room	NO OF Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On 1588	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost (\$)	New Luminaire Description	Proposed Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost (\$)	Implementation				Energy Savings (\$)
																	Mat. Cost	Labor Cost	Eng. Cost	Total Cost	
Building 3311																					
Administration																					
Surveillance Office #1	18	4	40	3312	50	95%	3.1	718.7	290.95	2318.89	\$504.84	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.9	437	\$307.29	\$810	\$720	\$132	\$1662	\$197.55
Smoke Room	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3 - F32T8 & 1 - 3L Electronic Ballast	88	0.1	19	\$13.41	\$40	\$40	\$7	\$87	\$7.62
Smoke Room	2	1	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.1	13	\$9.45	\$60	\$70	\$11	\$141	\$4.57
Vending Area	4	2	40	50	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	13	\$9.45	\$35	\$35	\$6	\$76	\$4.88
Surveillance Office #2	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$41.90
Entrance Lobby	1	1	40	46	50	95%	0.0	10.0	\$4.04	\$2.97	\$7.01	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	7	\$4.73	\$30	\$35	\$6	\$71	\$2.29
Office #9	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76
Office #14	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304	\$19.51
Office #15	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304	\$19.51
Office #13 & #14	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Office #10	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76
Office #12	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76
Office #11	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76
Vending Area	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.45	\$270	\$240	\$44	\$554	\$65.85
Office #8	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Office #9	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Office #4	4	2	40	2208	50	95%	2.1	479.1	\$193.97	\$142.59	\$336.56	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.3	292	\$204.86	\$540	\$480	\$88	\$1108	\$131.70
Director's Office	12	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$41.90
Director Surveillance Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Office #1	4	4	40	1472	35	75%	1.1	223.6	\$102.09	\$66.54	\$168.63	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.7	136	\$102.65	\$360	\$320	\$59	\$739	\$65.99
Office #2	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.45	\$270	\$240	\$44	\$554	\$65.85
Open Office Area	30	4	40	5520	50	95%	5.2	1197.8	\$484.92	\$356.48	\$841.40	4 - F32T8 & 1 - 4L Electronic Ballast	112	3.2	729	\$120.16	\$1350	\$1200	\$221	\$2771	\$329.24
Office #3	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.6	146	\$102.45	\$270	\$240	\$44	\$554	\$65.85
Exit Corridor	2	1	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.1	13	\$9.45	\$60	\$70	\$11	\$141	\$4.57
Office #5	12	4	40	2208	50	95%	2.1	479.1	\$193.97	\$142.59	\$336.56	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.3	292	\$204.86	\$540	\$480	\$88	\$1108	\$131.70
Entrance Corridor	8	1	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.2	54	\$37.80	\$240	\$280	\$45	\$565	\$18.29
Copy and Mail Room	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.4	97	\$68.29	\$180	\$160	\$29	\$369	\$41.90
Women's Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	8	\$5.27	\$60	\$70	\$11	\$141	\$4.57
Women's Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	8	\$5.27	\$60	\$70	\$11	\$141	\$4.57
Men's Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	8	\$5.27	\$60	\$70	\$11	\$141	\$4.57
Men's Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	8	\$5.27	\$60	\$70	\$11	\$141	\$4.57
Men's Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.0	8	\$5.27	\$60	\$70	\$11	\$141	\$4.57
Office #6	9	4	40	1656	50	95%	1.6	399.4	\$145.48	\$106.94	\$252.42	4 - F32T8 & 1 - 4L Electronic Ballast	112	1.0	219	\$153.65	\$405	\$360	\$66	\$831	\$98.77
Office #7	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2 - F32T8 & 1 - 2L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Building 3315																					
Warehouse																					
Warehouse	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Office Area	12	2	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	156	\$109.75	\$200	\$200	\$73	\$913	\$58.53
Break Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Women's Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76	\$2.72
Men's Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76	\$2.72
Key Area	10	2	40	920	50	95%	0.9	199.6	\$80.82	\$59.41	\$140.23	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.6	130	\$91.46	\$350	\$350	\$61	\$761	\$48.78
Key Area	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.1	26	\$18.29	\$70	\$70	\$12	\$152	\$9.76
Building 3321																					
Hunter Check-In																					
Meeting Room	3	1	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	1 - F32T8 & 1 - 1L Electronic Ballast	31	0.1	20	\$14.18	\$90	\$105	\$17	\$212	\$6.86
Meeting Room	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.2	52	\$36.58	\$140	\$140	\$24	\$304	\$19.51
Meeting Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Locker Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.2	49	\$34.14	\$90	\$80	\$15	\$185	\$21.95
Building 5426																					
Warehouse																					
Office	7	4	40	1288	50	95%	1.2	279.5	\$113.15	\$83.18	\$196.33	4 - F32T8 & 1 - 4L Electronic Ballast	112	0.7	170	\$119.50	\$315	\$280	\$51	\$646	\$76.82
Men's Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76	\$2.72
Women's Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2 - F32T8 & 1 - 2L Electronic Ballast	60	0.0	8	\$5.10	\$35	\$35	\$6	\$76	\$2.72
TOTALS	1104			151099			139.5	44856	\$13,000	\$13,000	\$26,000				28116	\$16,000	\$44,000	\$42,000	\$7,000	\$84,000	\$10,000

G:\PROJECTS\130\ISSUES\ECO-6E.WK4

ECO-7 Fluorescent Lamp Retrofit

Existing. Seventy-two buildings at the Letterkenny Army Depot contain approximately 7,376 fluorescent luminaires of various types. The total watts for the existing luminaires is 1,030,055 watts. The luminaires operate between 35 and 168 hours per week and contribute approximately 50% to 95% of their connected load to the demand. The annual electric demand, usage, and cost for these fixtures are as follows:

Electric Demand	=	11,480 kW/yr (956.7 kW/mo 12 mo/yr)
Electric Usage	=	3,586,836 kWh/yr (298,903 kWh/mo x 12 mo/yr)
Electric Cost	=	\$177,000 (11,480 kW/yr x \$7.706/kW) + (3,586,836 kWh/yr x \$.0248/kWh) = \$177,418, use \$177,000

Proposed. Remove the existing F40T12 and F96T12 lamps and install energy efficient lower wattage lamps. Reference the attached data tables for ECO-7. By installing the lower wattage lamps, the resulting light output will be reduced. For a standard 40 watt lamp, replacing it with a 34 watt lamp will reduce the lumen output from 2,650 to 2,300, approximately 13%. For a standard 75 watt lamp, replacing it with a 60 watt lamp will reduce the lumen output from 5,350 to 4,750, approximately 11%. The annual electric demand, usage, and cost of the proposed ECO is noted below:

Electric Demand	=	9,736 kW/yr (811.3 kW/mo x 12 mo/yr)
Electric Usage	=	3,042,048 kWh/yr (253,504 kW/mo x 12 mo/yr)

Electric Cost	=	\$150,000 (9,736 kW/yr x \$7.706/kW) + (3,042,048 kWh/yr x \$.0248/kWh) = \$150,468, use \$150,000
---------------	---	--

Implementation Cost. The expected construction cost for implementing the project is expected to be \$145,000. The breakdown is noted below and shown on the attached ECO data sheet.

Material	\$ 90,000
Labor	\$ 55,000
Engineering	\$ <u>0</u>
Total	\$145,000

Energy Savings. The annual electric demand, usage, and cost saved is noted below:

Electric Demand	=	1,744 kW/yr (11,480 - 9,736)
Electric Usage	=	544,788 kWh/yr (3,586,836 - 3,042,048)
Energy Cost	=	\$27,000/yr (\$177,000 - \$150,000)
Annual Energy Savings	=	1,859 mmBtu/yr
Energy Usage	=	1,859 mmBtu/yr (544,788 kWh/yr x 3,413 Btu/kWh) ÷ 1,000,000 Btu/mmBtu

Maintenance Savings. The energy efficient lower wattage lamps have the same rated average life as the existing lamps, 20,000 hours; therefore, there is no annual recurring maintenance savings. The installation of new lamps will reduce the normal required lamp changes, since all new lamps are being installed.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO7

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO7

ANALYSIS DATE: 03-27-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	145000.		
B. SIOH	\$	7975.		
C. DESIGN COST	\$	0.		
D. TOTAL COST (1A+1B+1C)	\$	152975.		
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$		0.	
F. PUBLIC UTILITY COMPANY REBATE	\$		0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)				\$ 152975.

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	1859.	\$ 13515.	18.17	\$ 245566.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 13000.	17.22	\$ 223860.
N. TOTAL		1859.	\$ 26515.		\$ 469426.

3. NON ENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)		\$	0.
(1) DISCOUNT FACTOR (TABLE A)	17.22		
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$	0.

B. NON RECURRING SAVINGS (+) / COSTS (-)

ITEM	SAVINGS (+) COST (-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS (+) / COST (-) (4)
------	--------------------------------	-----------------	------------------------	---

d. TOTAL	\$	0.		0.
----------	----	----	--	----

C. TOTAL NON ENERGY DISCOUNTED SAVINGS (+) / COST (-) (3A2+3Bd4) \$ 0.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 26515.

5. SIMPLE PAYBACK PERIOD (1G/4) 5.77 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 469426.

7. SAVINGS TO INVESTMENT RATIO (SIR) = $(6 / 1G) =$ 3.07
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 7.83 %

Summary ECO7A - ECO7E
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room	NO Of Luminaires	Existing										Proposed					Implementation					Energy Savings \$
		Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$		
ECO-7A Summary	3555			483702			453.2	141371	\$42,000	\$42,000	\$84,000			384.5	119995	\$71,000	\$42,000	\$26,000	\$0	\$68,000	\$13,000	
ECO-7B Summary	551			76337			72.0	21347	\$7,000	\$6,000	\$13,000			60.0	17769	\$11,000	\$7,000	\$4,000	\$0	\$11,000	\$2,000	
ECO-7C Summary	1272			190118			174.3	61002	\$16,000	\$18,000	\$34,000			148.1	51852	\$29,000	\$17,000	\$10,000	\$0	\$27,000	\$5,000	
ECO-7D Summary	894			128800			117.7	30327	\$11,000	\$9,000	\$20,000			100.0	25778	\$17,000	\$11,000	\$7,000	\$0	\$18,000	\$3,000	
ECO-7E Summary	1104			151099			139.5	44856	\$13,000	\$13,000	\$26,000			118.5	38111	\$22,000	\$13,000	\$8,000	\$0	\$21,000	\$4,000	
TOTALS	7376			1030055			956.7	298903	\$89,000	\$88,000	\$177,000			811.3	253504	\$150,000	\$90,000	\$55,000	\$0	\$145,000	\$27,000	

CAPROJECTSH13610JUSSECOBECO.7.WK422-May-95

G:\PROJECTS\4130.01\SS\ECO\ECO 7A.WK4

22 May 95

ECO-7A
Buildings 1 - 10
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room	NO. Of Luminaires	Existing					Proposed					Implementation								
		Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demanded Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Latitude	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost	Lat	Year	Cost	Total Cost	Energy Savings \$
Building 1																				
Office Area																				
Office	3	3	40	414	50	95%	89.8	\$6.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$35.64	\$36	\$23	\$0	\$39	\$9.47
DPME Womens Room	1	3	40	138	30	50%	18.0	\$6.38	\$5.35	\$11.73	3- F40T12/EW Energy Saving Lamps	117	0.1	15	\$9.97	\$12	\$8	\$0	\$20	\$1.76
DPME Mens Room	2	4	40	368	30	50%	47.9	\$6.37	\$14.26	\$31.27	3- F40T12/EW Energy Saving Lamps	156	0.2	41	\$26.58	\$32	\$20	\$0	\$52	\$4.69
DPME Mens Room	1	3	40	138	30	50%	18.0	\$6.38	\$5.35	\$11.73	3- F40T12/EW Energy Saving Lamps	117	0.1	15	\$9.97	\$12	\$8	\$0	\$20	\$1.76
DPME Womens Room	2	4	40	368	30	50%	47.9	\$6.37	\$14.26	\$31.27	3- F40T12/EW Energy Saving Lamps	156	0.2	41	\$26.58	\$32	\$20	\$0	\$52	\$4.69
Chief Engineering Support Office	113	3	40	276	50	95%	39.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Engineering Work Area	8	4	40	1594	50	95%	148	\$136.91	\$107.05	\$237.66	3- F40T12/EW Energy Saving Lamps	117	12.6	2876	\$2,020.41	\$1,356	\$848	\$0	\$2,204	\$356.54
DPME Section Office	4	4	40	1472	50	95%	134	\$129.31	\$95.06	\$224.37	3- F40T12/EW Energy Saving Lamps	156	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$31.66
Production Engineering Office	4	3	40	552	50	95%	119.8	\$48.49	\$35.65	\$84.14	3- F40T12/EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Chief Production Eng. Office	2	3	40	276	50	95%	39.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Conference Room A	4	4	40	368	35	75%	79.9	\$32.33	\$23.77	\$56.09	4- F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
DPME Pile Room	1	4	40	184	50	95%	24.2	\$16.16	\$11.88	\$24.32	4- F40T12/EW Energy Saving Lamps	156	0.5	95	\$71.67	\$64	\$40	\$0	\$104	\$12.65
DPME Work Area	18	3	40	2484	50	95%	239.0	\$218.22	\$160.41	\$378.63	3- F40T12/EW Energy Saving Lamps	156	2.0	458	\$321.84	\$216	\$135	\$0	\$351	\$56.79
DPME Copy Room	1	3	40	138	50	95%	19.9	\$12.12	\$8.91	\$21.04	3- F40T12/EW Energy Saving Lamps	117	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$1.76
Chief Requisition Office	2	3	40	414	50	95%	39.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Logistics Office	2	3	40	276	50	95%	39.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Production Planning Conf. Rm.	2	3	40	276	50	95%	39.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Chief Production Office	5	4	40	920	50	95%	109.6	\$80.82	\$59.41	\$140.23	4- F40T12/EW Energy Saving Lamps	156	0.7	170	\$119.20	\$80	\$50	\$0	\$130	\$21.04
Chief Maintenance Office	2	3	40	276	50	95%	39.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Manager Analysis Office	2	3	40	276	50	95%	39.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Conference Room B	4	4	40	368	35	75%	79.9	\$32.33	\$23.77	\$56.09	4- F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Corridor B	10	1	40	460	50	95%	49.8	\$40.41	\$29.71	\$74.12	1- F40T12/EW Energy Saving Lamps	39	0.4	85	\$59.60	\$40	\$25	\$0	\$65	\$10.52
Deputy Director Mainf. Office	2	3	40	276	50	95%	39.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Director Maintenance Office	3	3	40	414	50	95%	39.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Corridor A	16	1	40	736	50	95%	159.7	\$64.66	\$47.53	\$112.19	1- F40T12/EW Energy Saving Lamps	78	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Corridor A (Entrance Lobby)	1	2	40	92	50	95%	0.1	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
Chrome Plate Area (CP)	2	2	40	184	50	95%	24.2	\$16.16	\$11.88	\$24.32	2- F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
CP Office	8	4	40	1472	50	95%	134	\$129.31	\$95.06	\$224.37	3- F40T12/EW Energy Saving Lamps	156	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$31.66
Editors Office	13	4	40	2,392	50	95%	210.13	\$154.47	\$104.61	\$264.61	4- F40T12/EW Energy Saving Lamps	156	1.9	441	\$309.92	\$208	\$130	\$0	\$338	\$54.69
Print Room	6	4	40	1,040	50	95%	110.2	\$96.98	\$71.30	\$168.28	4- F40T12/EW Energy Saving Lamps	156	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24
IMA Support Office	4	4	40	736	50	95%	80.8	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Revised Managers Office	4	4	40	736	50	95%	80.8	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Cafe Area	3	4	40	552	50	95%	62.5	\$48.49	\$35.65	\$84.14	4- F40T12/EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Receiving Bay	1	2	40	92	50	95%	0.1	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
Corridor to Rooms #2 #6	4	2	40	368	50	95%	49.8	\$40.41	\$29.71	\$74.12	2- F40T12/EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
CP Shop Area B	28	2	75	4,830	50	95%	466	\$424.31	\$311.92	\$736.23	2- F40T12/EW Energy Saving Lamps	138	3.7	838	\$588.98	\$428	\$260	\$0	\$688	\$147.22
CP Shop Area A	63	2	75	10,868	50	95%	1,033	\$954.69	\$701.81	\$1,656.51	2- F40T12/EW Energy Saving Lamps	138	8.3	1,887	\$1,252.21	\$964	\$590	\$0	\$1,554	\$311.30
CP Shop Area A	1	2	40	92	50	95%	0.1	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
CP Shop Area A	12	2	40	920	50	95%	103.3	\$954.69	\$701.81	\$1,656.51	2- F40T12/EW Energy Saving Lamps	78	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24
CP Shop Area B	1	2	40	92	50	95%	0.1	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
CP Shop Area B	1	2	40	92	50	95%	0.1	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
CP Shop Area B	4	2	40	368	50	95%	49.8	\$40.41	\$29.71	\$74.12	2- F40T12/EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Building 2																				
Administration																				
South Entrance #2 Open Office	12	3	40	1,656	50	95%	359	\$145.48	\$106.94	\$252.42	3- F40T12/EW Energy Saving Lamps	117	1.3	305	\$214.56	\$144	\$90	\$0	\$234	\$37.86
G. Kirk Office	8	4	40	1,472	50	95%	319	\$120.31	\$95.06	\$224.37	3- F40T12/EW Energy Saving Lamps	156	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$31.66
Conference Room	8	4	40	1,472	35	75%	114	\$109.09	\$66.54	\$168.28	4- F40T12/EW Energy Saving Lamps	156	0.9	190	\$134.34	\$128	\$80	\$0	\$208	\$31.66
Movement Branch Mgrs. Office	7	4	40	736	50	95%	80.8	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Movement Branch Open Office	36	4	40	6,624	50	95%	633	\$581.91	\$427.17	\$1,009.68	3- F40T12/EW Energy Saving Lamps	156	5.3	1,222	\$828.23	\$576	\$360	\$0	\$936	\$151.45
Industrial Hygiene	10	3	40	1,380	50	95%	299	\$121.23	\$89.12	\$224.37	3- F40T12/EW Energy Saving Lamps	117	1.1	255	\$178.80	\$120	\$75	\$0	\$195	\$31.55
South Entrance #2 Office	2	3	40	276	50	95%	39.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Entrance Lobby South East	1	2	40	92	50	95%	0.1	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
Director/Commander Reception	9	4	40	1,656	50	95%	359	\$145.48	\$106.94	\$252.42	3- F40T12/EW Energy Saving Lamps	117	1.3	305	\$214.56	\$144	\$90	\$0	\$234	\$37.86
South Entrance Lobby #1	5	3	40	690	50	95%	150	\$60.62	\$44.56	\$105.18	3- F40T12/EW Energy Saving Lamps	156	1.3	305	\$214.56	\$144	\$90	\$0	\$234	\$37.86
South Entrance Open Office Area	18	4	40	3,120	50	95%	319	\$120.31	\$95.06	\$224.37	3- F40T12/EW Energy Saving Lamps	156	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$31.66
Middle Office	8	4	40	1,472	50	95%	319	\$120.31	\$95.06	\$224.37	3- F40T12/EW Energy Saving Lamps	156	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$31.66
Open Office Area	98	4	40	18,032	50	95%	1,711	\$1,584.08	\$1,164.49	\$2,748.57	4- F40T12/EW Energy Saving Lamps	156	14.6	3,326	\$2,356.29	\$1,568	\$980	\$0	\$2,548	\$412.29
Commanders Office	8	4	40	1,472	50	95%	319	\$120.31	\$95.06	\$224.37	3- F40T12/EW Energy Saving Lamps	156	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$31.66
Directors Office	6	4	40	1,104	50	95%	240	\$96.98	\$71.30	\$168.28	4- F40T12/EW Energy Saving Lamps	156	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24
Entrance Lobby South West	1	2	40	92	50	95%	0.1	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10

ECO-7A
Buildings 1 - 10
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room	NO Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Existing				Proposed				Implementation				Energy Savings \$					
				Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Max Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$	
Building 3																					
Computer Area																					
Library	25	3	40	3,450	126	95%	3.3	1887	\$303.08	\$561.45	\$864.53	3-F40T12/2EW Energy Saving Lamps	117	2.8	1,604	\$734.85	\$300	\$188	\$0	\$488	\$129.68
Computer Office 132	4	3	40	552	126	95%	0.3	302	\$48.49	\$89.83	\$138.52	3-F40T12/2EW Energy Saving Lamps	117	0.4	257	\$117.58	\$48	\$30	\$0	\$78	\$20.75
Vault	8	4	40	1,472	84	95%	1.4	537	\$129.31	\$159.70	\$289.01	4-F40T12/2EW Energy Saving Lamps	156	1.2	456	\$235.66	\$128	\$80	\$0	\$208	\$43.35
Raised Ft. Tape Storage Rm. #8	6	4	40	1,104	126	95%	1.0	604	\$96.98	\$179.66	\$276.65	4-F40T12/2EW Energy Saving Lamps	156	0.9	513	\$235.15	\$96	\$60	\$0	\$156	\$41.50
Raised Floor Computer Rm. #1	34	4	40	6,256	126	95%	5.9	3421	\$545.58	\$1,018.09	\$1,563.67	4-F40T12/2EW Energy Saving Lamps	156	5.1	2,908	\$1,332.53	\$544	\$340	\$0	\$884	\$231.15
Raised Floor Computer Rm. #2	54	4	40	9,984	126	95%	9.3	5433	\$872.86	\$1,616.98	\$2,489.84	4-F40T12/2EW Energy Saving Lamps	156	8.3	4,618	\$2,116.37	\$864	\$540	\$0	\$1,404	\$373.48
Raised Floor Computer Rm. #3	76	4	40	13,984	126	95%	13.3	7647	\$1,228.47	\$2,275.75	\$3,504.22	4-F40T12/2EW Energy Saving Lamps	156	11.3	6,500	\$2,978.50	\$1,216	\$760	\$0	\$1,976	\$525.63
Raised Floor Computer Rm. #6	65	4	40	11,960	126	95%	11.4	6540	\$1,050.67	\$1,946.37	\$2,997.03	4-F40T12/2EW Energy Saving Lamps	156	9.7	5,559	\$2,547.48	\$1,040	\$650	\$0	\$1,690	\$449.55
Raised Floor Comp. Ctr. Office	9	4	40	1,656	126	95%	1.6	767	\$225.47	\$2,275.75	\$3,504.22	4-F40T12/2EW Energy Saving Lamps	156	1.3	770	\$352.73	\$144	\$90	\$0	\$234	\$62.25
Raised Floor Computer Rm. #5	64	4	40	11,776	126	95%	11.2	6440	\$1,034.50	\$1,916.42	\$2,950.92	4-F40T12/2EW Energy Saving Lamps	156	9.5	5,474	\$2,558.29	\$1,024	\$640	\$0	\$1,664	\$442.64
Raised Floor Computer Rm. #7	55	4	40	10,120	126	95%	9.6	5534	\$889.03	\$1,646.92	\$2,550.95	4-F40T12/2EW Energy Saving Lamps	156	8.2	4,704	\$2,155.56	\$880	\$550	\$0	\$1,430	\$380.39
Raised Floor Computer Rm. #6A	6	4	40	1,104	126	95%	1.0	604	\$96.98	\$179.66	\$276.65	4-F40T12/2EW Energy Saving Lamps	156	0.9	513	\$235.15	\$96	\$60	\$0	\$156	\$41.50
Computer Office 137A	24	4	40	4,416	126	95%	4.2	2415	\$387.94	\$718.66	\$1,106.60	4-F40T12/2EW Energy Saving Lamps	156	3.6	2,053	\$940.61	\$384	\$240	\$0	\$624	\$165.90
South East Area																					
Office 1-K	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	3-F40T12/2EW Energy Saving Lamps	117	0.7	153	\$107.28	\$72	\$45	\$0	\$117	\$18.93
Office 6-F	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Office 6-J	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3-F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47
Open Office Area 7-G	39	3	40	5,382	50	95%	5.1	1168	\$472.80	\$347.57	\$820.37	3-F40T12/2EW Energy Saving Lamps	117	4.3	993	\$497.31	\$468	\$293	\$0	\$761	\$123.05
Room #120-4-F	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$24.05	2-F40T12/2EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Office 5-F	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3-F40T12/2EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Automation Open Area 10-H	25	3	40	3,450	50	95%	3.3	749	\$303.08	\$222.80	\$525.88	3-F40T12/2EW Energy Saving Lamps	117	2.8	636	\$446.99	\$300	\$188	\$0	\$488	\$78.88
Office 7-F	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Office 2-J	2	3	40	690	50	95%	0.7	150	\$60.62	\$44.56	\$105.18	3-F40T12/2EW Energy Saving Lamps	117	0.6	127	\$89.40	\$60	\$38	\$0	\$98	\$15.78
DMC Office 8-J	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Room #130-10-J	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3-F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47
Open Office Area 13-G	24	3	40	3,132	50	95%	3.1	719	\$290.95	\$213.89	\$504.84	3-F40T12/2EW Energy Saving Lamps	117	2.7	611	\$429.11	\$288	\$180	\$0	\$468	\$75.73
Office 1-I	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3-F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47
Office 1-G	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	3-F40T12/2EW Energy Saving Lamps	117	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$3.16
DMC Open Area 4-F	70	3	40	9,660	50	95%	9.2	2086	\$488.62	\$623.84	\$1,472.45	3-F40T12/2EW Energy Saving Lamps	117	7.8	1,782	\$1,251.58	\$940	\$525	\$0	\$1,465	\$220.87
Men's Room 12-I	5	2	40	460	50	95%	0.2	60	\$21.27	\$17.82	\$39.09	2-F40T12/2EW Energy Saving Lamps	78	0.2	51	\$33.23	\$40	\$25	\$0	\$65	\$5.86
Women's Room	6	2	40	552	50	95%	0.3	72	\$24.52	\$21.39	\$46.91	2-F40T12/2EW Energy Saving Lamps	78	0.2	61	\$33.23	\$48	\$30	\$0	\$78	\$7.01
Office 1-J	2	2	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Shack Bar 9-K	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	3-F40T12/2EW Energy Saving Lamps	117	0.7	153	\$107.28	\$72	\$45	\$0	\$117	\$18.93
Office 2-K	3	3	40	966	50	95%	0.9	210	\$84.86	\$62.38	\$147.25	3-F40T12/2EW Energy Saving Lamps	117	0.8	178	\$125.16	\$84	\$53	\$0	\$137	\$22.09
Office 3-K	12	4	40	2,208	50	95%	2.1	479	\$193.97	\$142.59	\$336.56	4-F40T12/2EW Energy Saving Lamps	156	1.8	407	\$286.08	\$192	\$120	\$0	\$312	\$50.48
Smokers Lounge 10-K	6	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	2-F40T12/2EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Room #8-12-J	3	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	3-F40T12/2EW Energy Saving Lamps	117	0.7	153	\$107.28	\$72	\$45	\$0	\$117	\$18.93
Stairwell Lobby 11-K	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Open Office 14-K	14	2	40	1,268	50	95%	1.2	279	\$113.15	\$83.18	\$196.33	2-F40T12/2EW Energy Saving Lamps	78	1.0	238	\$168.88	\$112	\$70	\$0	\$182	\$29.45
Corridor 14-1-I	24	3	40	3,312	50	95%	3.1	719	\$290.95	\$213.89	\$504.84	3-F40T12/2EW Energy Saving Lamps	117	2.7	611	\$429.11	\$288	\$180	\$0	\$468	\$75.73
Office 1-F	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
South West Area																					
Room #109-6-A	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Office 5-A	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Room #111-6-A	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3-F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47
Room #105-8-A	2	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3-F40T12/2EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Office Rear 4-B	4	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Corridor 5-10-B	10	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3-F40T12/2EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Corridor 5-10-B	4	4	40	552	50	95%	0.9	200	\$80.82	\$59.41	\$140.23	4-F40T12/2EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Office 5-B	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3-F40T12/2EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Office Front 4-B	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3-F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47
Office A-2-D	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Corridor 4-1-C	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Office 2-C	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Room #117 Front 2-B	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Office 4-B	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Office Rear 3-B	2	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3-F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47
Room #117 Rear 2-B	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Office Front 3-B	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3-F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47
Office 2-E	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91											

ECO-7A
Buildings 1 - 10
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Existing										Proposed										Implementation				
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mid. Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$	Energy Savings \$			
North West Area																								
Office 19-E	5	3	40	690	50	95%	0.7	150	\$60.62	\$44.56	\$105.18	3-F40T12/2EW Energy Saving Lamp	117	0.6	127	\$89.40	\$60	\$38	\$0	\$98	\$15.78			
Office 26-E	4	4	40	736	50	95%	0.7	160	\$66.66	\$47.53	\$112.19	3-F40T12/2EW Energy Saving Lamp	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83			
Office 26-D	6	4	40	1,104	50	95%	1.0	240	\$98.98	\$71.30	\$168.28	3-F40T12/2EW Energy Saving Lamp	156	0.9	204	\$135.76	\$96	\$60	\$0	\$156	\$23.24			
Office 26-C	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3-F40T12/2EW Energy Saving Lamp	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62			
Office 26-B	4	4	40	736	50	95%	0.7	160	\$66.66	\$47.53	\$112.19	3-F40T12/2EW Energy Saving Lamp	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83			
Office 26-A	4	4	40	736	50	95%	0.7	160	\$66.66	\$47.53	\$112.19	3-F40T12/2EW Energy Saving Lamp	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83			
Lobby 25-A	7	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3-F40T12/2EW Energy Saving Lamp	117	0.3	76	\$33.64	\$36	\$23	\$0	\$59	\$9.47			
Office 19-A	4	3	40	966	50	95%	1.2	279	\$113.15	\$83.18	\$196.33	3-F40T12/2EW Energy Saving Lamp	156	1.0	238	\$166.88	\$112	\$70	\$0	\$182	\$29.45			
Office 23-A	7	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3-F40T12/2EW Energy Saving Lamp	117	0.8	178	\$125.16	\$84	\$53	\$0	\$137	\$22.09			
Office 21-D	6	4	40	1,104	50	95%	1.0	240	\$98.98	\$71.30	\$168.28	3-F40T12/2EW Energy Saving Lamp	156	0.9	204	\$135.76	\$96	\$60	\$0	\$156	\$23.24			
Open Office Area 25-19-A	111	3	40	15,318	50	95%	14.6	3324	\$1,345.66	\$989.22	\$2,334.89	3-F40T12/2EW Energy Saving Lamp	117	12.4	2,825	\$1,984.65	\$1,352	\$833	\$0	\$2,165	\$350.23			
North East Area																								
Office 21-G	6	4	40	1,104	50	95%	1.0	240	\$98.98	\$71.30	\$168.28	3-F40T12/2EW Energy Saving Lamp	156	0.9	204	\$135.76	\$96	\$60	\$0	\$156	\$23.24			
Office 16-K	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3-F40T12/2EW Energy Saving Lamp	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62			
Office A 21-F	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3-F40T12/2EW Energy Saving Lamp	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62			
Office 21-H	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamp	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31			
Office 26-H	8	3	40	1,104	50	95%	1.0	240	\$98.98	\$71.30	\$168.28	3-F40T12/2EW Energy Saving Lamp	117	0.9	204	\$135.76	\$96	\$60	\$0	\$156	\$23.24			
Office 26-G	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamp	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31			
Conference 26-F	6	3	40	828	35	75%	0.6	126	\$57.43	\$37.43	\$94.86	3-F40T12/2EW Energy Saving Lamp	117	0.5	107	\$80.63	\$72	\$45	\$0	\$117	\$14.23			
Office 22-H	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamp	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31			
Office 26-J	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3-F40T12/2EW Energy Saving Lamp	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31			
Open Office Area 20-F	40	3	40	5,280	50	95%	30	1,198	\$484.92	\$356.48	\$841.40	3-F40T12/2EW Energy Saving Lamp	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31			
Corridor 23-I	12	3	40	1,656	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamp	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31			
Corridor 22-14-J	7	2	40	644	30	50%	0.2	84	\$29.78	\$24.95	\$54.73	3-F40T12/2EW Energy Saving Lamp	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31			
Women's Room 15-J	5	2	40	460	30	50%	0.2	60	\$21.27	\$17.82	\$39.09	2-F40T12/2EW Energy Saving Lamp	117	1.3	305	\$214.56	\$144	\$90	\$0	\$234	\$37.86			
Mens Room 16-J	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3-F40T12/2EW Energy Saving Lamp	78	0.2	51	\$33.23	\$56	\$35	\$0	\$91	\$8.21			
Office 16-J	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3-F40T12/2EW Energy Saving Lamp	78	0.2	51	\$33.23	\$40	\$25	\$0	\$65	\$5.86			
Office 21-J	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3-F40T12/2EW Energy Saving Lamp	117	0.3	76	\$33.64	\$36	\$23	\$0	\$59	\$9.47			
Office 21-I	16	4	40	2,944	35	75%	2.2	447	\$204.18	\$133.08	\$337.26	3-F40T12/2EW Energy Saving Lamp	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62			
Conference Room 20-J	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	3-F40T12/2EW Energy Saving Lamp	156	1.9	380	\$286.67	\$256	\$160	\$0	\$416	\$50.59			
Office 17-K	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamp	117	0.7	153	\$107.28	\$72	\$45	\$0	\$117	\$18.93			
Office A 22-J	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3-F40T12/2EW Energy Saving Lamp	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31			
Office B 22-J	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3-F40T12/2EW Energy Saving Lamp	117	0.3	76	\$33.64	\$36	\$23	\$0	\$59	\$9.47			
Open Office Area 26-18-K	40	3	40	5,280	50	95%	30	1,198	\$484.92	\$356.48	\$841.40	3-F40T12/2EW Energy Saving Lamp	117	4.5	1,018	\$715.19	\$480	\$300	\$0	\$780	\$126.21			
Open Office Area 25-J	14	3	40	1,932	50	95%	1.8	419	\$169.72	\$124.77	\$294.49	3-F40T12/2EW Energy Saving Lamp	117	1.6	356	\$250.32	\$168	\$105	\$0	\$273	\$44.17			
Open Office Area 25-F	57	3	40	7,866	50	95%	7.5	1707	\$691.02	\$507.98	\$1,199.00	3-F40T12/2EW Energy Saving Lamp	117	6.4	1,451	\$1,019.15	\$684	\$428	\$0	\$1,112	\$179.85			
Building 4																								
Warehouse	8	2	40	736	50	95%	0.7	160	\$66.66	\$47.53	\$112.19	2-F40T12/2EW Energy Saving Lamp	78	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83			
Warehouse Packaging Office	8	2	40	736	30	50%	0.4	96	\$34.03	\$28.52	\$62.55	2-F40T12/2EW Energy Saving Lamp	78	0.3	81	\$53.17	\$64	\$40	\$0	\$104	\$9.38			
Warehouse Pkg. Women's Room	8	2	40	736	30	50%	0.4	96	\$34.03	\$28.52	\$62.55	2-F40T12/2EW Energy Saving Lamp	78	0.3	81	\$53.17	\$64	\$40	\$0	\$104	\$9.38			
Building 5																								
Administration																								
Reok Office	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3-F40T12/2EW Energy Saving Lamp	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62			
Open Office Area	126	2	40	11,392	50	95%	11.0	2515	\$1,018.34	\$748.60	\$1,766.94	2-F40T12/2EW Energy Saving Lamp	78	9.4	2,138	\$1,501.90	\$1,008	\$630	\$0	\$1,638	\$265.04			
West Entrance Lobby	2	4	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2-F40T12/2EW Energy Saving Lamp	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21			
Product Receipt Office	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	3-F40T12/2EW Energy Saving Lamp	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41			
Women's Room	1	2	40	92	30	50%	0.0	12	\$4.25	\$3.56	\$7.82	2-F40T12/2EW Energy Saving Lamp	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17			
Mens Room	1	2	40	92	30	50%	0.0	12	\$4.25	\$3.56	\$7.82	2-F40T12/2EW Energy Saving Lamp	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17			
Smoker Office	9	4	40	1,656	50	95%	1.6	359	\$145.48	\$106.94	\$252.42	2-F40T12/2EW Energy Saving Lamp	156	1.3	305	\$214.56	\$144	\$90	\$0	\$234	\$37.86			

ECO-7A
Buildings 1 - 10
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room	NO Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost (\$)	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost (\$)	Implementation				
																	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Energy Savings \$	
Building 6																					
Administration	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	3- F40T12/EW Energy Saving Lamps	117	0.7	153	\$107.28	\$72	\$45	\$0	\$117	\$18.93
Corridor to Restroom	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Army Audit Agency	4	3	40	552	35	75%	0.4	84	\$38.28	\$24.95	\$63.24	3- F40T12/EW Energy Saving Lamps	117	0.4	71	\$53.75	\$48	\$30	\$0	\$78	\$9.47
Annuniation Operation Conf	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Tucker Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Army Reserve Division	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$59	\$6.31
NFPP Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Safety Division Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Men's Room	5	3	40	690	30	50%	0.3	90	\$11.90	\$6.74	\$15.64	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Women's Room	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Open Office Area	379	3	40	52,020	50	95%	49.7	11350	\$4,594.65	\$3,777.62	\$7,972.27	3- F40T12/EW Energy Saving Lamps	117	42.2	9,647	\$6,776.43	\$4,548	\$2,843	\$0	\$7,391	\$1,195.84
Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$59	\$6.31
North East Entrance Corridor	1	3	40	138	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	3- F40T12/EW Energy Saving Lamps	117	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
Director of Integrated Office	5	3	40	690	50	95%	0.7	150	\$60.62	\$44.56	\$105.18	3- F40T12/EW Energy Saving Lamps	117	0.6	127	\$80.40	\$60	\$38	\$0	\$98	\$15.78
North East Entrance Corridor	1	3	40	138	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	3- F40T12/EW Energy Saving Lamps	117	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
Deputy Chief of Staff Reception	5	3	40	690	50	95%	0.7	150	\$60.62	\$44.56	\$105.18	3- F40T12/EW Energy Saving Lamps	117	0.6	127	\$80.40	\$60	\$38	\$0	\$98	\$15.78
Conf. Room	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Conf. Room	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Corridor to N. Exit	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
NF3-GL Local 1805 Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Chastain Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
North East Entrance Lobby	1	3	40	138	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	3- F40T12/EW Energy Saving Lamps	117	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
Building 10																					
Computer Room	146	3	40	20,148	126	95%	19.1	11018	\$1,769.97	\$3,278.88	\$5,048.85	3- F40T12/EW Energy Saving Lamps	117	16.3	9,365	\$4,291.52	\$1,752	\$1,095	\$0	\$2,847	\$757.33
Computer Room	8	4	40	1,272	84	95%	1.4	537	\$129.31	\$159.70	\$289.01	4- F40T12/EW Energy Saving Lamps	156	1.2	456	\$245.66	\$128	\$80	\$0	\$208	\$43.35
Classified Tape Library	22	3	40	3,036	126	95%	2.9	1660	\$64.66	\$94.08	\$160.79	3- F40T12/EW Energy Saving Lamps	117	2.5	1,411	\$466.67	\$264	\$165	\$0	\$429	\$114.12
Office B 9-A	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	2- F40T12/EW Energy Saving Lamps	78	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Open Office Area 9-14 E	188	2	40	17,296	50	95%	16.4	3753	\$1,519.43	\$1,116.96	\$2,636.39	2- F40T12/EW Energy Saving Lamps	78	14.0	3,190	\$2,400.93	\$1,504	\$940	\$0	\$2,444	\$395.46
Office 9-B	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Office 10-B	2	2	40	368	50	95%	0.2	40	\$32.33	\$23.77	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Office 11-B	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	2- F40T12/EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Office A 9-A	2	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Office 14-A	3	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Office B 10-A	3	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.2	51	\$35.76	\$24	\$15	\$0	\$59	\$6.31
Office 11-A	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Conference Room 12-A	18	2	40	1,656	35	75%	1.2	232	\$114.85	\$74.86	\$189.71	2- F40T12/EW Energy Saving Lamps	78	1.1	214	\$161.25	\$144	\$90	\$0	\$234	\$28.46
Entrance Lobby	2	2	40	368	50	95%	0.2	40	\$32.33	\$23.77	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
South West Area																					
Open Office Area 9-16 J	214	2	40	19,688	50	95%	18.7	4272	\$1,729.56	\$1,271.44	\$3,000.99	2- F40T12/EW Energy Saving Lamps	78	15.9	3,631	\$2,550.85	\$1,712	\$1,070	\$0	\$2,782	\$450.15
Office 9-K	3	2	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	78	0.2	51	\$35.76	\$24	\$15	\$0	\$59	\$6.31
Office 9-K	1	3	40	138	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	3- F40T12/EW Energy Saving Lamps	117	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
Office 10-K	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Office 11-K	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Office 12-K	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Office 13-K	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	2- F40T12/EW Energy Saving Lamps	78	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
North East Area																					
Open Office Area 2-8 E	247	2	40	22,724	50	95%	21.6	4931	\$1,994.27	\$1,467.50	\$3,463.76	2- F40T12/EW Energy Saving Lamps	78	18.3	4,191	\$2,944.20	\$1,976	\$1,235	\$0	\$3,211	\$519.36
Office 1-E	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Office 1-E	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F40T12/EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Office 1-D	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F40T12/EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Office 1-C	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.75	\$36	\$23	\$0	\$78	\$9.47
Women's Room 3-B	12	2	40	1,040	30	50%	0.6	144	\$51.04	\$42.78	\$93.82	2- F40T12/EW Energy Saving Lamps	78	0.5	122	\$70.75	\$96	\$60	\$0	\$156	\$24.62
Men's Room 3-A	2	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Smokers Room 6-A	16	2	40	1,472	50	95%	1.4	319	\$129.31	\$95.06	\$224.37	2- F40T12/EW Energy Saving Lamps	78	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$43.35
Computer Room 1-A	20	2	40	1,840	50	95%	1.7	399	\$168.83	\$118.83	\$280.47	2- F40T12/EW Energy Saving Lamps	78	1.5	339	\$238.40	\$160	\$100	\$0	\$260	\$33.66
Cade 5-B	8	3	40	1,040	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	3- F40T12/EW Energy Saving Lamps	117	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$24.62
Vending Area 5-B	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Auditorium 6-B	8	2	40	736	35	75%	1.2	232	\$114.85	\$74.86	\$189.71	3- F40T12/EW Energy Saving Lamps	78	0.5	95	\$161.25	\$144	\$90	\$0	\$234	\$28.46
Office 8-A	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	2- F40T12/EW Energy Saving Lamps	78	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62

ECO-7A
Buildings 1 - 10
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Existing					Proposed					Implementation					Energy Savings \$		
				Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$		Eng Cost \$	Total Cost \$
North West Area																					
Office 3 K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamp	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Office 8 K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamp	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Office 7 K	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F40T12/EW Energy Saving Lamp	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Office B 6 K	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F40T12/EW Energy Saving Lamp	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Office A 6 K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamp	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Office 3 K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamp	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Office 4 K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamp	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Office 1 G	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F40T12/EW Energy Saving Lamp	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Office 2 K	6	3	40	828	35	95%	0.8	180	\$72.74	\$37.47	\$126.21	3- F40T12/EW Energy Saving Lamp	117	0.7	153	\$107.28	\$72	\$45	\$0	\$117	\$18.93
Conference Room 1 K	6	3	40	828	35	75%	0.6	126	\$57.43	\$37.43	\$94.86	3- F40T12/EW Energy Saving Lamp	117	0.5	107	\$80.63	\$72	\$45	\$0	\$117	\$18.23
Office 1-H	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F40T12/EW Energy Saving Lamp	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Office 1-F	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F40T12/EW Energy Saving Lamp	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
TOTALS				483702			453.2	141371	\$42,000	\$42,000	\$84,000			384.5	11995	\$71,000	\$42,000	\$26,000	\$0	\$68,000	\$13,000
PROJECT NO. 130-USSECOECO 7A-WK4																					

G:\PROJECTS\3130JUN\SSCO\ECO-7A.WK4

22 May 95

ECO-7B
Buildings 14 - 57
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room	NO. Of Luminaires	Existing				Proposed				Implementation			
		Watts Per Lamp	Lamps Per Luminaire	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost	New Luminaires Description	Watts Per Luminaire	Proposed Demand (Kw)
Building 14													
First Floor													
Receiving Room	15	3	40	2070	50	95%	449.2	\$181.85	\$133.68	\$315.53	3- F40T12/2EW Energy Saving Lamps	117	1.7
Sand Blast Room	2	3	40	276	50	95%	39.9	\$24.25	\$17.82	\$42.07	3- F40T12/2EW Energy Saving Lamps	117	0.2
Machine Shop Breakroom	7	4	40	1288	50	95%	1.2	\$13.15	\$83.18	\$196.33	4- F40T12/2EW Energy Saving Lamps	156	1.0
Machine Shop Office	3	2	40	276	50	95%	39.9	\$24.25	\$17.82	\$42.07	2- F40T12/2EW Energy Saving Lamps	78	0.2
Paint Room	12	3	40	1656	50	95%	1.6	\$145.48	\$106.94	\$252.42	3- F40T12/2EW Energy Saving Lamps	117	1.3
Quality Control/Shop Area	4	4	40	736	50	95%	0.7	\$19.7	\$47.53	\$112.19	4- F40T12/2EW Energy Saving Lamps	156	0.6
Quality Control/Shop Area	6	3	40	828	50	95%	0.8	\$72.74	\$53.47	\$126.21	3- F40T12/2EW Energy Saving Lamps	117	0.7
Optical Shop	14	4	40	2576	50	95%	2.4	\$226.30	\$166.36	\$392.65	4- F40T12/2EW Energy Saving Lamps	156	2.1
Building 19													
Warehouse													
Exterior Office	5	2	40	460	50	95%	0.4	\$40.41	\$29.71	\$70.12	2- F40T12/2EW Energy Saving Lamps	78	0.4
Warehouse North Work Area	1	3	40	138	50	95%	0.1	\$12.12	\$8.91	\$21.04	3- F40T12/2EW Energy Saving Lamps	117	0.1
Warehouse Work Area	1	4	40	184	50	95%	0.2	\$16.16	\$11.88	\$28.05	4- F40T12/2EW Energy Saving Lamps	156	0.1
Building TS20-1													
Warehouse													
Breakroom	3	2	40	276	50	95%	0.3	\$24.25	\$17.82	\$42.07	2- F40T12/2EW Energy Saving Lamps	78	0.2
Office	2	4	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.3
Building 31													
Warehouse													
Receiving Area	2	3	40	276	50	95%	0.3	\$24.25	\$17.82	\$42.07	3- F40T12/2EW Energy Saving Lamps	117	0.2
Office	1	2	40	92	50	95%	0.1	\$8.08	\$5.94	\$14.02	2- F40T12/2EW Energy Saving Lamps	78	0.1
Building 32													
Warehouse													
Receiving Area	3	3	40	414	50	95%	0.4	\$36.37	\$26.74	\$63.11	3- F40T12/2EW Energy Saving Lamps	117	0.3
Office	2	2	40	184	50	95%	0.2	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1
Building 33N													
Warehouse													
Office	3	3	40	414	50	95%	0.4	\$36.37	\$26.74	\$63.11	3- F40T12/2EW Energy Saving Lamps	117	0.3
Receiving Area	2	2	40	184	50	95%	0.2	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1
Painted Area in Warehouse	2	2	75	345	50	95%	0.3	\$32.33	\$22.28	\$52.59	2- P96T12/2EW Energy Saving Lamps	138	0.1
Painted Area in Warehouse	2	4	40	368	50	95%	0.3	\$32.33	\$23.77	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.3
Building 34													
Warehouse													
Warehouse Elec. Dist. Equip.	1	3	40	138	50	95%	0.1	\$12.12	\$8.91	\$21.04	3- F40T12/2EW Energy Saving Lamps	117	0.1
Office South	2	2	40	184	50	95%	0.2	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1
Office North	2	3	40	276	50	95%	0.3	\$24.25	\$17.82	\$42.07	3- F40T12/2EW Energy Saving Lamps	117	0.2
Building 37													
Modular													
Modular Office-Powertrain #1	3	4	40	552	90	95%	0.5	\$48.49	\$64.17	\$112.66	4- F40T12/2EW Energy Saving Lamps	156	0.4
Modular Office-Powertrain #2	4	4	40	736	90	95%	0.7	\$64.66	\$85.55	\$150.21	4- F40T12/2EW Energy Saving Lamps	156	0.6
Modular Office-Powertrain #3	3	4	40	552	90	95%	0.5	\$48.49	\$64.17	\$112.66	4- F40T12/2EW Energy Saving Lamps	156	0.4
Motor Room Office	4	4	40	736	90	95%	0.7	\$64.66	\$85.55	\$150.21	4- F40T12/2EW Energy Saving Lamps	156	0.6
Motor Room Test Area	2	4	40	368	90	95%	0.3	\$32.33	\$24.78	\$57.11	4- F40T12/2EW Energy Saving Lamps	156	0.3
Motor Room Box Office	3	4	40	552	90	95%	0.5	\$48.49	\$64.17	\$112.66	4- F40T12/2EW Energy Saving Lamps	156	0.4
Building 37 Office	2	4	40	736	90	95%	0.7	\$64.66	\$85.55	\$150.21	4- F40T12/2EW Energy Saving Lamps	156	0.6
Building Supply 47	2	4	40	368	90	95%	0.3	\$32.33	\$24.78	\$57.11	4- F40T12/2EW Energy Saving Lamps	156	0.3
Breakroom	4	4	40	736	90	95%	0.7	\$64.66	\$85.55	\$150.21	4- F40T12/2EW Energy Saving Lamps	156	0.6
Disassembly Office	5	2	40	460	90	95%	0.4	\$40.41	\$33.47	\$81.88	2- F40T12/2EW Energy Saving Lamps	78	0.4
Transmission Office	4	4	40	736	90	95%	0.7	\$64.66	\$85.55	\$150.21	4- F40T12/2EW Energy Saving Lamps	156	0.6
Building 41													
Warehouse													
Receiving	1	2	40	92	50	95%	0.1	\$8.08	\$5.94	\$14.02	2- F40T12/2EW Energy Saving Lamps	78	0.1
Office	2	2	40	184	50	95%	0.2	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1
Office 1 x 4 - 1L	1	1	40	46	50	95%	0.0	\$4.04	\$2.97	\$7.01	1- F40T12/2EW Energy Saving Lamp	9	0.0

ECO-7B
Buildings 14 - 57
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Existing										Proposed										Implementation				
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Or Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$			

ECO-7B
Buildings 14 - 57
Letterkenny Army Depot
Fluorescent Lamp Retrofit

		Existing										Proposed				Implementation					
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$
Building 57S																					
Warehouse																					
Office Area/Parts Area	23	4	40	4,232	90	95%	4.0	1653	\$371.77	\$491.94	\$863.71	4- F40T12/EW Energy Saving Lamps	156	3.4	1,405	\$734.16	\$368	\$230	\$0	\$598	\$129.36
Tool Parts Room (Locked)	5	4	40	920	90	95%	0.9	359	\$80.82	\$106.94	\$187.76	4- F40T12/EW Energy Saving Lamps	156	0.7	305	\$159.60	\$80	\$50	\$0	\$130	\$28.16
Tool Parts Room (Locked)	11	3	40	1,518	90	95%	1.4	593	\$133.35	\$176.46	\$309.81	3- F40T12/EW Energy Saving Lamps	117	1.2	504	\$263.34	\$132	\$83	\$0	\$215	\$46.47
Bulk Warehouse Office #1	12	4	40	2,208	90	95%	2.1	862	\$193.97	\$256.66	\$450.63	4- F40T12/EW Energy Saving Lamps	156	1.8	733	\$383.04	\$192	\$120	\$0	\$312	\$67.59
Fire Equipment Cage Area	4	2	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	2- F40T12/EW Energy Saving Lamps	78	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27
Ladies Room	3	2	40	276	54	95%	0.3	65	\$24.25	\$19.25	\$43.50	2- F40T12/EW Energy Saving Lamps	78	0.2	55	\$36.97	\$24	\$15	\$0	\$39	\$6.52
Bulk Warehouse Office #2	9	4	40	1,656	90	95%	1.6	647	\$145.48	\$192.50	\$371.97	4- F40T12/EW Energy Saving Lamps	156	1.3	550	\$287.28	\$144	\$90	\$0	\$234	\$50.70
Breakroom	6	4	40	1,104	90	95%	1.0	431	\$96.98	\$128.33	\$225.32	4- F40T12/EW Energy Saving Lamps	156	0.9	367	\$191.52	\$96	\$60	\$0	\$156	\$33.80
Ladies Room	1	4	40	184	54	95%	0.2	43	\$16.16	\$12.83	\$29.00	4- F40T12/EW Energy Saving Lamps	156	0.1	37	\$24.65	\$16	\$10	\$0	\$26	\$4.35
Equipment Operations Unit	15	4	40	2,760	90	95%	2.6	1078	\$242.46	\$320.83	\$563.29	4- F40T12/EW Energy Saving Lamps	156	2.2	916	\$478.80	\$240	\$150	\$0	\$390	\$84.49
Driver Exam Corridor	6	4	40	1,104	90	95%	1.0	431	\$96.98	\$128.33	\$225.32	4- F40T12/EW Energy Saving Lamps	156	0.9	367	\$191.52	\$96	\$60	\$0	\$156	\$33.80
Locker Room	4	2	40	368	54	95%	0.3	86	\$32.33	\$25.67	\$77.99	2- F40T12/EW Energy Saving Lamps	78	0.3	73	\$49.30	\$32	\$20	\$0	\$52	\$8.70
Office (Locked)	2	2	40	184	90	95%	0.2	72	\$16.16	\$12.83	\$29.00	2- F40T12/EW Energy Saving Lamps	78	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63
Robertson Office	3	4	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	4- F40T12/EW Energy Saving Lamps	156	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$16.90
Office	2	2	40	184	90	95%	0.2	72	\$16.16	\$12.83	\$29.00	2- F40T12/EW Energy Saving Lamps	78	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63
Office (Locked)	2	2	40	184	90	95%	0.2	72	\$16.16	\$12.39	\$37.55	2- F40T12/EW Energy Saving Lamps	78	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63
Corridor Behind Office Area	1	4	40	184	90	95%	0.2	72	\$16.16	\$21.39	\$37.55	2- F40T12/EW Energy Saving Lamps	78	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63
Office Area	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	4- F40T12/EW Energy Saving Lamps	156	0.6	244	\$131.92	\$64	\$40	\$0	\$104	\$22.53
Office Area	3	4	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	4- F40T12/EW Energy Saving Lamps	156	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$16.90
TOTALS		551		76337			72.0	21347	\$7,000	\$6,000	\$13,000			60.0	17769	\$11,000	\$7,000	\$4,000	\$0	\$11,000	\$2,000
G:\PROJECTS\4130.01\SS&E\CO&E_7B.WK4																					

G:\PROJECTS\4130\USSECO\ECO.7B.WK4

22 May 99

ECO-7C
Buildings 102-441
Letterkenny Army Depot
Fluorescent Lamp Retrofit

		Existing										Proposed										Implementation				
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mtl. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$					
Building 102																										
Lab	4	2	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	2- F40T12EW Energy Saving Lamps	78	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27					
Front Lab Workstation	2	2	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	2- F40T12EW Energy Saving Lamps	78	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63					
Entrance to Office	18	2	40	1656	90	95%	1.6	646.8	\$145.18	\$192.50	\$375.68	2- F40T12EW Energy Saving Lamps	78	1.3	550	\$287.28	\$144	\$90	\$0	\$234	\$50.40					
Main Lab Area	1	2	40	92	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	2- F40T12EW Energy Saving Lamps	78	0.1	18	\$12.32	\$8	\$5	\$0	\$13	\$2.17					
Bathroom																										
Building 199																										
Warehouse	6	4	40	1104	50	95%	1.0	239.6	\$96.08	\$71.30	\$168.28	4- F40T12EW Energy Saving Lamps	156	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24					
Work Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10					
Office																										
Building 200																										
Lab																										
Lab Area	11	4	40	2024	50	95%	1.9	439.2	\$177.81	\$130.71	\$308.51	4- F40T12EW Energy Saving Lamps	156	1.6	373	\$262.24	\$176	\$110	\$0	\$286	\$46.28					
Building 211																										
Administration																										
Kitchen	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10					
Women's Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2- F40T12EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Mens Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2- F40T12EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Main Office Area	5	4	40	970	50	95%	0.9	199.6	\$80.82	\$59.41	\$140.23	4- F40T12EW Energy Saving Lamps	156	0.7	170	\$119.20	\$80	\$50	\$0	\$130	\$21.04					
Managers Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F40T12EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83					
Building 247																										
Warehouse																										
Receiving Area	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F40T12EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83					
Office	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10					
Rear Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2- F40T12EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Rest Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31					
Corridor to Office	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21					
Restroom	1	2	40	92	30	50%	0.2	12.0	\$4.25	\$3.56	\$7.82	2- F40T12EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Kitchen	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Receiving Area	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.01	3- F40T12EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21					
Copy Room	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12EW Energy Saving Lamps	78	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$3.16					
Receiving Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10					
Receiving Area	6	1	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	1- F40T12EW Energy Saving Lamp	39	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31					
Receiving Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10					
Building 320																										
Maintenance																										
Division Office	6	3	40	828	30	50%	0.4	107.8	\$38.28	\$32.08	\$70.37	3- F40T12EW Energy Saving Lamps	117	0.4	92	\$59.81	\$72	\$45	\$0	\$117	\$10.55					
Main Area Machine Shop	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10					
Women's Locker Room	1	4	40	184	30	50%	0.3	59.9	\$24.25	\$17.82	\$42.07	4- F40T12EW Energy Saving Lamps	156	0.1	20	\$13.29	\$16	\$10	\$0	\$26	\$2.35					
Women's Locker Room	11	4	40	506	90	50%	0.5	65.9	\$24.40	\$19.61	\$43.00	1- F40T12EW Energy Saving Lamp	39	0.2	56	\$36.55	\$44	\$28	\$0	\$72	\$6.45					
Maintenance Area Office	3	4	40	552	50	95%	0.3	119.8	\$48.49	\$35.65	\$84.14	4- F40T12EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62					
Mens Locker Room Office	1	4	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	\$15.64	4- F40T12EW Energy Saving Lamps	156	0.1	20	\$13.29	\$16	\$10	\$0	\$26	\$2.35					
Office No. 1	6	2	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F40T12EW Energy Saving Lamps	78	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62					
Mens Locker Room	11	1	40	506	168	95%	0.5	368.9	\$44.45	\$109.79	\$154.25	1- F40T12EW Energy Saving Lamp	39	0.4	314	\$131.11	\$44	\$28	\$0	\$72	\$23.14					
Toilet Area	3	2	40	276	168	95%	0.3	201.2	\$24.25	\$59.89	\$84.13	2- F40T12EW Energy Saving Lamps	78	0.2	171	\$71.51	\$24	\$15	\$0	\$39	\$12.62					
Main Office Area	47	2	40	4324	168	95%	4.1	3152.7	\$379.86	\$938.25	\$1318.10	2- F40T12EW Energy Saving Lamps	78	3.5	2,680	\$1,120.39	\$376	\$235	\$0	\$611	\$197.72					
Sink and Toilet Area	4	2	40	368	30	50%	0.2	47.9	\$17.01	\$14.26	\$31.27	2- F40T12EW Energy Saving Lamps	78	0.2	41	\$26.58	\$32	\$20	\$0	\$52	\$4.69					
Building 349																										
Boiler Plant																										
Entrance Cage Area																										
Control Room	9	2	40	828	168	95%	0.8	603.7	\$72.74	\$179.66	\$252.40	2- F40T12EW Energy Saving Lamps	78	0.7	513	\$214.54	\$72	\$45	\$0	\$117	\$37.86					
Boiler Room Ground Level	2	2	40	184	168	95%	0.2	134.2	\$16.16	\$39.93	\$56.09	2- F40T12EW Energy Saving Lamps	78	0.1	114	\$47.68	\$16	\$10	\$0	\$26	\$8.41					
Boiler Room Ground Level	10	4	40	1840	168	95%	1.7	1341.6	\$161.64	\$399.25	\$560.90	4- F40T12EW Energy Saving Lamps	156	1.5	1,140	\$476.76	\$160	\$100	\$0	\$260	\$84.13					
Boiler Room Ground Level	1	3	40	138	168	95%	0.1	100.6	\$12.12	\$29.94	\$42.07	3- F40T12EW Energy Saving Lamps	117	0.1	86	\$35.76	\$12	\$8	\$0	\$20	\$6.31					
Breakroom	4	4	40	736	84	95%	0.7	268.3	\$64.66	\$79.85	\$144.51	4- F40T12EW Energy Saving Lamps	156	0.6	228	\$122.83	\$64	\$40	\$0	\$104	\$21.08					
Boiler Room Ground Level	4	1	40	184	168	95%	0.2	134.2	\$16.16	\$39.93	\$56.09	1- F40T12EW Energy Saving Lamp	39	0.1	114	\$47.68	\$16	\$10	\$0	\$26	\$8.41					

ECO-7C
Buildings 102-441
Letterkenny Army Depot
Fluorescent Lamp Retrofit

		Existing										Proposed										Implementation									
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost (\$)	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost (\$)	Mat. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings (\$)										
Building 350																															
Office #1																															
Mens Room	5	4	40	920	54	95%	0.9	215.6	\$80.82	\$64.17	\$144.99	4- F40T12/2EW Energy Saving Lamps	156	0.7	183	\$123.24	\$80	\$50	\$0	\$130	\$21.75										
Conference Room	12	4	40	2208	63	95%	2.1	603.7	\$193.97	\$179.66	\$373.63	4- F40T12/2EW Energy Saving Lamps	156	1.8	513	\$317.59	\$192	\$120	\$0	\$312	\$56.05										
Womens Room	5	4	40	920	54	95%	0.9	215.6	\$80.82	\$64.17	\$144.99	4- F40T12/2EW Energy Saving Lamps	156	0.7	183	\$123.24	\$80	\$50	\$0	\$130	\$21.75										
Corridor to Shop	3	4	40	552	36	95%	0.5	151.6	\$48.49	\$64.17	\$112.66	4- F40T12/2EW Energy Saving Lamps	156	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$16.90										
Managers Office	4	4	40	736	90	95%	0.7	287.3	\$64.66	\$85.55	\$150.21	4- F40T12/2EW Energy Saving Lamps	156	0.6	244	\$127.68	\$64	\$40	\$0	\$104	\$22.53										
Copier Room	2	4	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	4- F40T12/2EW Energy Saving Lamps	156	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27										
Reception	11	4	40	2024	90	95%	1.9	790.6	\$177.81	\$235.27	\$413.08	4- F40T12/2EW Energy Saving Lamps	156	1.6	672	\$351.12	\$176	\$110	\$0	\$286	\$61.96										
Office #2																															
Reception Area	8	4	40	1472	90	95%	1.4	575.0	\$129.31	\$171.11	\$300.42	4- F40T12/2EW Energy Saving Lamps	156	1.2	489	\$255.36	\$128	\$80	\$0	\$208	\$45.06										
Managers Office	1	4	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	4- F40T12/2EW Energy Saving Lamps	156	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63										
Office #3																															
Work Area	6	4	40	1104	90	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	4- F40T12/2EW Energy Saving Lamps	156	0.9	367	\$191.52	\$96	\$60	\$0	\$156	\$33.80										
Separate Office Area	4	4	40	736	90	95%	0.7	287.3	\$64.66	\$85.55	\$150.21	4- F40T12/2EW Energy Saving Lamps	156	0.6	244	\$127.68	\$64	\$40	\$0	\$104	\$22.53										
ASRS plus Office Area Corridor	3	4	40	552	90	95%	0.5	215.6	\$48.49	\$64.17	\$112.66	4- F40T12/2EW Energy Saving Lamps	156	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$16.90										
ASRS plus Office Computer Rm	8	4	40	1472	90	95%	1.4	575.0	\$129.31	\$171.11	\$300.42	4- F40T12/2EW Energy Saving Lamps	156	1.2	489	\$255.36	\$128	\$80	\$0	\$208	\$45.06										
Office #4																															
New Bathroom (Under Coast)																															
Office Area	5	2	40	460	90	95%	0.4	179.7	\$40.41	\$53.47	\$93.88	2- F40T12/2EW Energy Saving Lamps	78	0.4	153	\$79.80	\$40	\$25	\$0	\$65	\$14.08										
Library Conference Room	2	3	40	276	63	95%	0.3	75.5	\$24.25	\$22.46	\$46.70	2- F40T12/2EW Energy Saving Lamps	117	0.2	64	\$39.70	\$24	\$15	\$0	\$39	\$7.01										
Quality Control Room	6	3	40	828	90	95%	0.8	323.4	\$72.74	\$96.25	\$168.99	3- F40T12/2EW Energy Saving Lamps	117	0.7	275	\$143.64	\$72	\$45	\$0	\$117	\$25.35										
Annex Office Area #6																															
Starway to Shop	2	2	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	2- F40T12/2EW Energy Saving Lamps	78	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63										
Annex Office Corridor	7	2	40	644	90	95%	0.6	251.5	\$56.57	\$74.86	\$131.43	2- F40T12/2EW Energy Saving Lamps	78	0.5	214	\$111.72	\$56	\$35	\$0	\$91	\$19.72										
Starway to Shop	2	2	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	2- F40T12/2EW Energy Saving Lamps	78	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63										
Meeting Room	19	2	40	1748	63	95%	1.7	477.9	\$153.56	\$142.23	\$295.79	2- F40T12/2EW Energy Saving Lamps	78	1.4	406	\$251.42	\$152	\$95	\$0	\$247	\$44.37										
Planning Production Fabrication	12	2	40	1104	90	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	2- F40T12/2EW Energy Saving Lamps	78	0.9	367	\$191.52	\$96	\$60	\$0	\$156	\$33.80										
Trades Branch Conference Rm	12	2	40	1104	63	95%	1.0	301.9	\$96.98	\$89.83	\$186.82	2- F40T12/2EW Energy Saving Lamps	78	0.9	257	\$158.79	\$96	\$60	\$0	\$156	\$33.80										
Mens Room	6	2	40	552	54	95%	0.5	129.4	\$48.49	\$38.55	\$112.66	2- F40T12/2EW Energy Saving Lamps	78	0.4	110	\$73.94	\$48	\$30	\$0	\$78	\$16.90										
Ladies Room	3	2	40	276	54	95%	0.3	64.7	\$24.25	\$19.25	\$43.50	2- F40T12/2EW Energy Saving Lamps	78	0.2	55	\$36.97	\$24	\$15	\$0	\$39	\$6.52										
Trades Office Room #2	12	2	40	1104	90	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	2- F40T12/2EW Energy Saving Lamps	78	0.9	367	\$191.52	\$96	\$60	\$0	\$156	\$33.80										
Trades Office Room #1	12	2	40	1104	90	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	2- F40T12/2EW Energy Saving Lamps	78	0.9	367	\$191.52	\$96	\$60	\$0	\$156	\$33.80										
Starway to Shop	2	2	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	2- F40T12/2EW Energy Saving Lamps	78	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63										
Building 370																															
Equipment Repair																															
Mens Room	3	4	40	552	54	95%	0.5	129.4	\$48.49	\$38.50	\$86.99	4- F40T12/2EW Energy Saving Lamps	156	0.4	110	\$73.94	\$48	\$30	\$0	\$78	\$13.05										
Shop Area Task Lighting	4	2	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	2- F40T12/2EW Energy Saving Lamps	78	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27										
Shop Area	318	4	40	5832	90	95%	55.6	22854.8	\$5140.19	\$6801.58	\$11942	4- F40T12/2EW Energy Saving Lamps	156	47.2	19427	\$10150.50	\$5088	\$3180	\$0	\$8268	\$1791.27										
Shop Area Office	5	4	40	920	90	95%	0.9	359.4	\$80.82	\$106.94	\$187.76	4- F40T12/2EW Energy Saving Lamps	156	0.7	305	\$159.60	\$80	\$50	\$0	\$130	\$28.16										
Test Room/Workstation	2	4	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	4- F40T12/2EW Energy Saving Lamps	156	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27										
Test Room	4	4	40	736	90	95%	0.7	287.3	\$64.66	\$85.55	\$150.21	4- F40T12/2EW Energy Saving Lamps	156	0.6	244	\$127.68	\$64	\$40	\$0	\$104	\$22.53										
Shop Area Task Lighting	2	2	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	2- F40T12/2EW Energy Saving Lamps	78	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63										
Building 412																															
Training & Conf. Center																															
Computer Training Area	11	4	40	2024	50	95%	1.9	439.2	\$177.81	\$130.71	\$308.51	4- F40T12/2EW Energy Saving Lamps	156	1.6	373	\$262.24	\$176	\$110	\$0	\$286	\$46.28										
Administration Area	11	4	40	2024	35	95%	1.9	439.2	\$177.81	\$130.71	\$308.51	4- F40T12/2EW Energy Saving Lamps	156	1.6	373	\$262.24	\$176	\$110	\$0	\$286	\$46.28										
Center Class Room	14	4	40	2576	35	75%	4.6	922.3	\$243.12	\$274.49	\$695.60	4- F40T12/2EW Energy Saving Lamps	156	3.9	784	\$591.26	\$528	\$350	\$0	\$858	\$104.34										
Conference Room	33	4	40	6072	35	75%	4.6	922.3	\$243.12	\$274.49	\$695.60	4- F40T12/2EW Energy Saving Lamps	156	3.9	784	\$591.26	\$528	\$350	\$0	\$858	\$104.34										
Mens Room	2	2	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	\$15.64	2- F40T12/2EW Energy Saving Lamps	78	0.1	20	\$13.29	\$16	\$10	\$0	\$26	\$2.35										
Ladies Room	2	2	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	\$15.64	2- F40T12/2EW Energy Saving Lamps	78	0.1	20	\$13.29	\$16	\$10	\$0	\$26	\$2.35										
Building 416																															
Administration																															
Mens Room	4	2	40	368	30	50%	0.2	47.9	\$17.01	\$14.26	\$31.27	2- F40T12/2EW Energy Saving Lamps	78	0.2	41	\$26.58	\$32	\$20	\$0	\$52	\$4.60										
Womens Room	4	2	40	368	30	50%	0.2	47.9	\$17.01	\$14.26	\$31.27	2- F40T12/2EW Energy Saving Lamps	78	0.2	41	\$26.58	\$32	\$20	\$0	\$52	\$4.60										
Managers Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.71	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41										
Main Office Area	30	4	40	5520	50	95%	5.2	1197.8	\$484.92	\$356.48	\$841.40	4- F40T12/2EW Energy Saving Lamps	156	4.5	1018	\$715.19	\$480	\$300	\$0	\$780	\$126.21										

**Buildings 102-441
Letterkenny Army Depot
Fluorescent Lamp Retrofit**

Existing										Proposed					Implementation									
Room	NO Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mt. Cost \$	Labor Cost \$	Bag Cost \$	Total Cost \$	Energy Savings \$			
Room Building 417	Personnel Barracks	Corridor	2	40	828	168	95%	0.8	603.7	\$72.74	\$179.66	\$252.40	2. F40T12EW Energy Saving Lamps	78	0.7	513	\$214.54	\$72	\$45	\$0	\$117	\$37.86		
		Room #13	2	40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
		Kitchen #16	2	40	368	21	50%	0.2	33.5	\$17.01	\$9.98	\$27.00	2. F40T12EW Energy Saving Lamps	78	0.2	29	\$22.95	\$32	\$20	\$0	\$52	\$4.05		
		Room #14	2	40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
		Room #17	2	40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
		Room #12	2	40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
		Room #18	2	40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
		Mens Room/Shower	2	40	368	168	95%	0.3	268.3	\$23.33	\$79.85	\$112.18	2. F40T12EW Energy Saving Lamps	78	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83		
		Room #19	2	40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
		Room #11	2	40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
		Room #20	2	40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
		Womens Room	2	40	368	168	95%	0.3	268.3	\$23.33	\$79.85	\$112.18	2. F40T12EW Energy Saving Lamps	78	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83		
		Day Room #15	2	40	552	40	75%	0.4	95.8	\$38.28	\$28.52	\$66.80	3. F40T12EW Energy Saving Lamps	117	0.4	81	\$56.78	\$48	\$30	\$0	\$78	\$10.02		
		Room Building 418	Personnel Barracks	Corridor	2	40	828	168	95%	0.8	603.7	\$72.74	\$179.66	\$252.40	2. F40T12EW Energy Saving Lamps	78	0.7	513	\$214.54	\$72	\$45	\$0	\$117	\$37.86
				Room #13	2	40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68
Kitchen #16	2			40	368	21	50%	0.2	33.5	\$17.01	\$9.98	\$27.00	2. F40T12EW Energy Saving Lamps	78	0.2	29	\$22.95	\$32	\$20	\$0	\$52	\$4.05		
Room #14	2			40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
Room #17	2			40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
Room #12	2			40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
Room #18	2			40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
Mens Room/Shower	2			40	368	168	95%	0.3	268.3	\$23.33	\$79.85	\$112.18	2. F40T12EW Energy Saving Lamps	78	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83		
Room #19	2			40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
Room #11	2			40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
Room #20	2			40	368	40	75%	0.3	63.9	\$25.52	\$19.01	\$44.53	2. F40T12EW Energy Saving Lamps	78	0.2	54	\$37.85	\$32	\$20	\$0	\$52	\$6.68		
Womens Room	2			40	368	168	95%	0.3	268.3	\$23.33	\$79.85	\$112.18	2. F40T12EW Energy Saving Lamps	78	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83		
Day Room #15	2			40	552	40	75%	0.4	95.8	\$38.28	\$28.52	\$66.80	3. F40T12EW Energy Saving Lamps	117	0.4	81	\$56.78	\$48	\$30	\$0	\$78	\$10.02		
Room Building 421	Administration			Main Office Area North End	28	4	5152	50	95%	4.9	1118.0	\$452.99	\$332.71	\$785.31	4. F40T12EW Energy Saving Lamps	156	4.2	950	\$667.51	\$448	\$280	\$0	\$728	\$17.80
				Womens Room	1	1	46	30	50%	0.0	6.0	\$2.13	\$1.78	\$3.91	1. F40T12EW Energy Saving Lamp	39	0.0	5	\$3.32	\$4	\$3	\$0	\$7	\$0.59
		Support Division Chief Office	2	4	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2. F40T12EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21		
		Managers Office	1	4	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4. F40T12EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21		
		File/Copy Room	3	4	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4. F40T12EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62		
		File/Copy Room on Piles	4	1	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	1. F40T12EW Energy Saving Lamp	39	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21	
		Womens Room	2	4	368	30	50%	0.2	47.9	\$17.01	\$14.26	\$31.27	4. F40T12EW Energy Saving Lamps	156	0.2	41	\$26.58	\$32	\$20	\$0	\$52	\$4.69		
		Main Entrance Lobby	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4. F40T12EW Energy Saving Lamps	156	0.2	41	\$26.58	\$32	\$20	\$0	\$52	\$4.69	
		Acquisition Chief	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4. F40T12EW Energy Saving Lamps	156	0.2	41	\$26.58	\$32	\$20	\$0	\$52	\$4.69	
		Chief Office Pugh. Office Area	26	4	40	4784	50	95%	4.5	1098.1	\$420.27	\$308.95	\$729.21	4. F40T12EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62	
		Impr. Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	4. F40T12EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21	
		Receptionist	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	4. F40T12EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21	
		Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3. F40T12EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31	
		Bid Room #2	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3. F40T12EW Energy Saving Lamps	117	0.3	78	\$35.64	\$24	\$15	\$0	\$39	\$6.31	
		Office	2	4	40	368	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3. F40T12EW Energy Saving Lamps	117	0.3	78	\$35.64	\$24	\$15	\$0	\$39	\$6.31	

ECO-7C
Buildings 102-441
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room	NO. Of Lamps	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Existing					Proposed					Implementation						
					Hours Per Week	Percent Of Kw On-Peak	Demand Kw	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost	Maintenance Cost	Labor Cost	Bag Cost	Total Cost	Energy Savings \$
Ck. Depot Prop. Div. Office	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F40T12/2EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Main Office South End	14	4	40	4,416	50	95%	4.2	958	\$387.94	\$285.18	\$673.12	4- F40T12/2EW Energy Saving Lamps	156	3.6	815	\$572.15	\$384	\$240	\$0	\$624	\$100.97
Contracting Office Area	24	4	40	2,576	50	95%	2.4	559	\$226.30	\$166.36	\$392.65	4- F40T12/2EW Energy Saving Lamps	156	2.1	475	\$333.76	\$224	\$140	\$0	\$364	\$58.90
Contracting Office Conf. Room	6	3	40	828	35	75%	0.6	126	\$57.43	\$37.43	\$94.86	3- F40T12/2EW Energy Saving Lamps	117	0.5	107	\$80.63	\$72	\$45	\$0	\$117	\$14.23
Office (left of Acquisition Chief)	1	4	40	184	50	95%	0.2	40	\$16.16	\$11.90	\$28.07	4- F40T12/2EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.23
Building 44																					
Cable & Harness	3	3	40	414	90	95%	0.4	162	\$54.57	\$48.12	\$84.49	3- F40T12/2EW Energy Saving Lamps	117	0.3	137	\$71.82	\$56	\$23	\$0	\$59	\$12.67
Unpacking	4	3	40	552	90	95%	0.5	216	\$48.49	\$35.65	\$84.14	3- F40T12/2EW Energy Saving Lamps	117	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$16.90
Pile Area	5	3	40	690	90	95%	0.7	270	\$60.62	\$80.21	\$140.82	3- F40T12/2EW Energy Saving Lamps	117	0.6	229	\$119.70	\$60	\$38	\$0	\$98	\$21.12
Cable Test Station	3	3	40	414	90	95%	0.4	162	\$54.57	\$48.12	\$84.49	3- F40T12/2EW Energy Saving Lamps	117	0.3	137	\$71.82	\$56	\$23	\$0	\$59	\$12.67
Work Station	5	3	40	690	90	95%	0.7	270	\$60.62	\$80.21	\$140.82	3- F40T12/2EW Energy Saving Lamps	117	0.6	229	\$119.70	\$60	\$38	\$0	\$98	\$21.12
Cable Termination Area	6	2	40	552	90	95%	0.5	216	\$48.49	\$35.65	\$84.14	3- F40T12/2EW Energy Saving Lamps	117	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$16.90
Cable Termination Area	3	2	40	92	90	95%	0.1	36	\$8.08	\$10.69	\$18.78	2- F40T12/2EW Energy Saving Lamps	78	0.1	31	\$19.96	\$8	\$5	\$0	\$13	\$2.82
Assembly Area Desk Lighting	1	2	40	276	90	95%	0.3	108	\$24.25	\$32.68	\$56.33	2- F40T12/2EW Energy Saving Lamps	78	0.2	92	\$47.88	\$24	\$15	\$0	\$39	\$8.45
Assembly Area	21	3	40	2,898	90	95%	2.8	1132	\$254.58	\$336.87	\$591.46	3- F40T12/2EW Energy Saving Lamps	117	2.3	962	\$502.14	\$252	\$156	\$0	\$408	\$88.72
Break Room	3	3	40	414	90	95%	0.4	162	\$54.57	\$48.12	\$84.49	3- F40T12/2EW Energy Saving Lamps	117	0.3	137	\$71.82	\$56	\$23	\$0	\$59	\$12.67
Break Room	3	3	40	414	90	95%	0.3	108	\$24.25	\$32.68	\$56.33	2- F40T12/2EW Energy Saving Lamps	78	0.2	92	\$47.88	\$24	\$15	\$0	\$39	\$8.45
Office (Day)	4	3	40	552	90	95%	0.5	216	\$48.49	\$35.65	\$84.14	3- F40T12/2EW Energy Saving Lamps	117	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$16.90
Office	2	4	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	4- F40T12/2EW Energy Saving Lamps	156	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27
Building 423																					
Counseling	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Counseling Managers Office	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	4- F40T12/2EW Energy Saving Lamps	78	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Corridor to Managers Office	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Copy Room	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Main Entrance Corridor	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Counselors Office	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Counselors Office	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Conference Room (Day)	8	2	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	2- F40T12/2EW Energy Saving Lamps	78	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Building 401																					
Administration	1																				
Main Entrance Lobby	8	4	40	1,472	50	95%	1.4	319	\$129.31	\$95.06	\$224.37	4- F40T12/2EW Energy Saving Lamps	156	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$33.66
Lab #4 (Entrance Lobby)	1	4	40	552	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	4- F40T12/2EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Supply Section	10	4	40	1,840	50	95%	1.7	399	\$161.64	\$118.83	\$280.47	4- F40T12/2EW Energy Saving Lamps	156	1.5	339	\$238.40	\$160	\$100	\$0	\$260	\$42.07
Corridor around Lab #4	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	3- F40T12/2EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
TDME Office Area	25	4	40	4,600	50	95%	4.4	998	\$404.10	\$297.06	\$701.17	4- F40T12/2EW Energy Saving Lamps	156	3.7	848	\$595.99	\$400	\$250	\$0	\$650	\$105.18
ACTL Office	5	4	40	920	50	95%	0.9	200	\$80.82	\$59.41	\$140.23	4- F40T12/2EW Energy Saving Lamps	156	0.7	170	\$119.20	\$80	\$50	\$0	\$130	\$21.04
Women's Room	1	4	40	184	30	50%	0.1	24	\$8.51	\$7.13	\$15.64	4- F40T12/2EW Energy Saving Lamps	156	0.1	20	\$13.20	\$16	\$10	\$0	\$26	\$2.35
Executive Secretary	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4- F40T12/2EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Computer Room	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Mouse Room	1	4	40	184	30	50%	0.1	24	\$8.51	\$7.13	\$15.64	4- F40T12/2EW Energy Saving Lamps	156	0.1	20	\$13.20	\$16	\$10	\$0	\$26	\$2.35
TDME Chief Office	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	4- F40T12/2EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
TDME Chief Lab Calibration	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	4- F40T12/2EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Conference Room 1 & 2	6	4	40	1,104	35	75%	0.8	168	\$76.57	\$49.91	\$126.47	4- F40T12/2EW Energy Saving Lamps	156	0.7	143	\$107.50	\$96	\$60	\$0	\$156	\$18.97
Building 418																					
Repair Shop																					
Shipping Area	3	2	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	2- F40T12/2EW Energy Saving Lamps	78	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Building 441																					
Warehouse																					
Outside Office	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Warehouse Parts Bay	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
TOTALS	1772			19018			174.3	61002	\$16,000	\$18,000	\$34,000			148.1	\$1852	\$29,000	\$17,000	\$10,000	\$0	\$27,000	\$5,000

G:\PROJECTS\4130\01\SS\ECO\ECO-7C.WK4

22 May/95

ECO-7D
Buildings 500 - 581
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Existing										Proposed				Implementation							
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Luminaire	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$
Building 500																					
First Floor																					
Office	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3-F40T12/EW Energy Saving Lamps	117	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$3.16
Laboratory Room #33	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4-F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Dispensary Corridor	14	2	40	1288	90	95%	1.2	503.1	\$113.15	\$149.72	\$262.87	2-F40T12/EW Energy Saving Lamps	78	1.0	428	\$223.44	\$112	\$70	\$0	\$182	\$30.43
Restroom	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2-F40T12/EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17
Room #47 (Office)	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4-F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Pharmacy	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4-F40T12/EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Room #31 Open Office Area	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	4-F40T12/EW Energy Saving Lamps	156	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24
Treatment Room #2 Room #45	2	4	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	4-F40T12/EW Energy Saving Lamps	156	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.77
Treatment Room #1 Room #46	2	4	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	4-F40T12/EW Energy Saving Lamps	156	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.77
Physical Therapy Room #34	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3-F40T12/EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Command Wing Entrance	2	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2-F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Waiting Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3-F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Waiting Room Restroom	1	3	40	138	30	50%	0.1	18.0	\$6.38	\$5.35	\$11.73	3-F40T12/EW Energy Saving Lamps	117	0.1	15	\$9.97	\$12	\$8	\$0	\$20	\$1.76
Occupational Health Room #38	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4-F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Emergency Rm. Entrance Lobby	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2-F40T12/EW Energy Saving Lamps	78	0.1	57	\$23.84	\$8	\$5	\$0	\$13	\$1.17
Conference Room (Room #41)	5	4	40	920	35	75%	0.7	139.7	\$63.81	\$41.59	\$105.39	4-F40T12/EW Energy Saving Lamps	156	0.6	119	\$89.59	\$60	\$50	\$0	\$130	\$15.81
Restroom	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2-F40T12/EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17
Emergency Treatment Rm. #40	6	4	40	1104	90	95%	1.0	431.2	\$96.98	\$71.30	\$225.32	4-F40T12/EW Energy Saving Lamps	156	0.9	367	\$191.52	\$96	\$60	\$0	\$156	\$33.80
Occupational Health Room #39	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4-F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Office Room #42	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4-F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Occupational Health Room #37	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4-F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3-F40T12/EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Occupational Health Rm. #43C	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2-F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Occupational Health Rm. #43B	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2-F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Occupational Health Rm. #43A	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2-F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Occupational Health Room #43	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2-F40T12/EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Break Room (Room #36)	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4-F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Diagnostic Waiting Room	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3-F40T12/EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Room #26 (Office)	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3-F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Copy Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3-F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Admin. Pgm. Coordinators Ofc.	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4-F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
P. Growing Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3-F40T12/EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Corridor	8	2	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	2-F40T12/EW Energy Saving Lamps	78	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Meat Room	2	3	40	276	30	50%	0.1	35.9	\$12.76	\$10.69	\$23.46	3-F40T12/EW Energy Saving Lamps	117	0.1	31	\$19.94	\$24	\$15	\$0	\$39	\$3.52
Ladies Room	2	3	40	276	30	50%	0.1	35.9	\$12.76	\$10.69	\$23.46	3-F40T12/EW Energy Saving Lamps	117	0.1	31	\$19.94	\$24	\$15	\$0	\$39	\$3.52
Protocol Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3-F40T12/EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Copy Room	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	2-F40T12/EW Energy Saving Lamps	78	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Public Affairs Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4-F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Entrance to Rear Office	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3-F40T12/EW Energy Saving Lamps	117	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$3.16
Depot Sergeant Major's Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4-F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Commander's Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4-F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Commander's Secretary	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4-F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Depot Commander	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4-F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
G. Patterson Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4-F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Rear Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3-F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Legal Office 15 Reception	6	3	40	828	50	95%	0.8	179.7	\$74.74	\$53.47	\$126.21	3-F40T12/EW Energy Saving Lamps	117	0.7	153	\$107.28	\$72	\$45	\$0	\$117	\$18.93
Computer Corridor	10	3	40	1380	50	95%	1.3	299.5	\$121.23	\$89.12	\$210.35	3-F40T12/EW Energy Saving Lamps	117	1.1	255	\$178.80	\$120	\$75	\$0	\$195	\$31.55
Computer Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3-F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Front Office 15A	1	3	40	138	30	50%	0.1	18.0	\$6.38	\$5.35	\$11.73	3-F40T12/EW Energy Saving Lamps	117	0.1	15	\$9.97	\$12	\$8	\$0	\$20	\$1.76
Women's Room	4	3	40	552	90	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3-F40T12/EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Police Sign in Room	3	3	40	414	168	95%	0.4	301.9	\$36.37	\$89.83	\$126.20	3-F40T12/EW Energy Saving Lamps	117	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$12.62
Police Room	3	3	40	414	168	95%	0.4	301.9	\$36.37	\$89.83	\$126.20	3-F40T12/EW Energy Saving Lamps	117	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$12.62
Mens Room	1	3	40	138	30	50%	0.1	18.0	\$6.38	\$5.35	\$11.73	3-F40T12/EW Energy Saving Lamps	117	0.1	15	\$9.97	\$12	\$8	\$0	\$20	\$1.76
Office #17	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3-F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15			

ECO-7D
Buildings 500 - 581
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lum.	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost (\$/Kwh)	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost (\$)	Mat. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings
Computer Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$56.09	\$28.04	4- F40T12/25W Energy Saving Lamp	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Employee Relations Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$56.09	\$28.04	4- F40T12/25W Energy Saving Lamp	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Auditorium	27	2	40	2160	35	75%	1.9	377.3	\$172.28	\$112.29	\$284.57	2- F40T12/25W Energy Saving Lamp	78	1.6	321	\$241.88	\$216	\$135	\$0	\$351	\$12.68
Center Bldg. Open Office Area	26	4	40	4160	35	95%	4.5	1038.1	\$420.77	\$308.95	\$729.21	4- F40T12/25W Energy Saving Lamp	156	3.9	882	\$619.83	\$416	\$260	\$0	\$676	\$109.38
Conference Room (Locked)	2	3	40	276	35	75%	0.2	41.9	\$19.14	\$12.48	\$31.62	3- F40T12/25W Energy Saving Lamp	117	0.2	36	\$26.88	\$24	\$15	\$0	\$39	\$4.74
Room #7 (Office)	4	4	40	736	50	95%	0.7	139.7	\$64.66	\$47.53	\$112.19	4- F40T12/25W Energy Saving Lamp	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Basement Level																					
Starwell #2 Police Area	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2- F40T12/25W Energy Saving Lamp	78	0.1	57	\$23.84	\$8	\$5	\$0	\$13	\$4.21
Starwell #3 Legal Office	2	4	40	368	168	95%	0.3	268.3	\$32.33	\$56.09	\$28.04	4- F40T12/25W Energy Saving Lamp	156	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83
Room #16 (Rear Office)	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3- F40T12/25W Energy Saving Lamp	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Starwell #1 Dispensary Side	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2- F40T12/25W Energy Saving Lamp	78	0.1	57	\$23.84	\$8	\$5	\$0	\$13	\$4.21
Room #16 (File Down Lighting)	6	1	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	1- F40T12/25W Energy Saving Lamp	39	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Open Office Area Room #16	32	3	40	4416	50	95%	4.2	958.3	\$387.94	\$285.18	\$673.12	3- F40T12/25W Energy Saving Lamp	117	3.6	815	\$572.15	\$384	\$240	\$0	\$624	\$100.07
Starwell #2 Police Area	2	2	40	184	168	95%	0.2	134.2	\$16.16	\$18.88	\$28.05	2- F40T12/25W Energy Saving Lamp	78	0.1	114	\$47.68	\$16	\$10	\$0	\$26	\$8.41
Room #14-15 (Office)	10	4	40	1840	50	95%	1.7	399.3	\$161.64	\$118.83	\$280.47	4- F40T12/25W Energy Saving Lamp	156	1.5	339	\$238.40	\$160	\$100	\$0	\$260	\$42.07
Room #13 (Coff. Room)	4	4	40	736	50	95%	0.7	139.7	\$64.66	\$47.53	\$112.19	4- F40T12/25W Energy Saving Lamp	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Room #3A (Internal Review)	6	3	40	828	35	75%	0.6	125.8	\$57.43	\$47.53	\$94.86	3- F40T12/25W Energy Saving Lamp	117	0.6	107	\$80.63	\$72	\$45	\$0	\$117	\$14.23
Corridor	10	3	40	1380	50	95%	1.3	299.5	\$121.23	\$89.12	\$210.35	3- F40T12/25W Energy Saving Lamp	117	1.1	255	\$178.80	\$120	\$75	\$0	\$195	\$31.55
Room #2 (Office)	5	3	40	690	50	95%	0.7	149.7	\$60.62	\$44.56	\$105.18	3- F40T12/25W Energy Saving Lamp	117	0.6	127	\$89.40	\$60	\$38	\$0	\$98	\$15.78
Room #4 (Office)	6	3	40	828	50	95%	0.8	179.7	\$72.74	\$53.47	\$126.21	3- F40T12/25W Energy Saving Lamp	117	0.7	153	\$107.28	\$72	\$45	\$0	\$117	\$18.93
Room #5 (Office)	12	3	40	1656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	3- F40T12/25W Energy Saving Lamp	117	1.3	305	\$214.56	\$144	\$90	\$0	\$234	\$37.86
Room #7 (Conference Room)	2	3	40	276	35	75%	0.2	41.9	\$19.14	\$12.48	\$31.62	3- F40T12/25W Energy Saving Lamp	117	0.2	36	\$26.88	\$24	\$15	\$0	\$39	\$4.74
Room #3 (Open Work Space)	12	3	40	1656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	3- F40T12/25W Energy Saving Lamp	117	1.3	305	\$214.56	\$144	\$90	\$0	\$234	\$37.86
Room #12	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	1- F40T12/25W Energy Saving Lamp	39	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
DICA Office Coordinator	5	3	40	690	50	95%	0.7	149.7	\$60.62	\$44.56	\$105.18	3- F40T12/25W Energy Saving Lamp	117	0.6	127	\$89.40	\$60	\$38	\$0	\$98	\$15.78
Room #11 (Open Office Area)	10	3	40	1380	50	95%	1.3	299.5	\$121.23	\$89.12	\$210.35	3- F40T12/25W Energy Saving Lamp	117	1.1	255	\$178.80	\$120	\$75	\$0	\$195	\$31.55
Room #11A (Files)	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3- F40T12/25W Energy Saving Lamp	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Entrance/Vending Area	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/25W Energy Saving Lamp	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Building \$21																					
Basement Floor																					
Open Area	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$56.09	\$28.04	4- F40T12/25W Energy Saving Lamp	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Open Area	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	2- F40T12/25W Energy Saving Lamp	78	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Weight Room	4	4	40	736	50	95%	0.7	139.7	\$64.66	\$47.53	\$112.19	4- F40T12/25W Energy Saving Lamp	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Pool Table Room	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	4- F40T12/25W Energy Saving Lamp	156	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24
Stairs to First Floor	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F40T12/25W Energy Saving Lamp	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
First Floor																					
Smokers Lounge	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F40T12/25W Energy Saving Lamp	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Ladies Room	1	3	40	138	30	50%	0.1	18.0	\$6.38	\$5.35	\$11.73	3- F40T12/25W Energy Saving Lamp	117	0.1	15	\$9.97	\$12	\$8	\$0	\$20	\$1.76
Kitchen Area	2	4	40	368	30	50%	0.2	47.9	\$17.01	\$14.36	\$31.27	4- F40T12/25W Energy Saving Lamp	156	0.2	41	\$26.58	\$32	\$20	\$0	\$52	\$4.69
Corridor	5	2	40	460	50	95%	0.4	99.8	\$40.41	\$29.71	\$70.12	2- F40T12/25W Energy Saving Lamp	78	0.4	85	\$59.60	\$40	\$25	\$0	\$65	\$10.52
Dining Area	4	4	40	736	30	50%	0.4	93.8	\$34.03	\$28.52	\$62.55	4- F40T12/25W Energy Saving Lamp	156	0.3	81	\$53.17	\$64	\$40	\$0	\$104	\$9.38
Stairs to Second Floor	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12/25W Energy Saving Lamp	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
Stairs to Second Floor	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12/25W Energy Saving Lamp	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
General Office Area	18	2	40	1656	90	95%	1.6	646.8	\$145.48	\$192.50	\$337.97	2- F40T12/25W Energy Saving Lamp	78	1.3	550	\$387.28	\$144	\$90	\$0	\$234	\$50.70
Radio Equipment Room	2	4	40	368	168	95%	0.3	268.3	\$32.33	\$56.09	\$28.04	4- F40T12/25W Energy Saving Lamp	156	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83
Union Office	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F40T12/25W Energy Saving Lamp	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Copier/Fax Machine Room	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12/25W Energy Saving Lamp	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Chief Office	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$56.09	\$28.04	4- F40T12/25W Energy Saving Lamp	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Research Area/Library	2	3	40	276	90	95%	0.3	107.8	\$24.25	\$22.08	\$56.33	3- F40T12/25W Energy Saving Lamp	78	0.2	92	\$47.68	\$24	\$15	\$0	\$39	\$6.31
Plans Review Conference Room	6	2	40	552	35	75%	0.4	83.8	\$38.28	\$24.95	\$63.24	2- F40T12/25W Energy Saving Lamp	78	0.4	71	\$55.75	\$48	\$30	\$0	\$78	\$9.49
Watch Room	2	4	40	368	168	95%	0.3	268.3	\$32.33	\$56.09	\$28.04	4- F40T12/25W Energy Saving Lamp	156	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83
Main Room	1	3	40	138	30	50%	0.1	18.0	\$6.38	\$5.35	\$11.73	3- F40T12/25W Energy Saving Lamp	117	0.1	15	\$9.97	\$12	\$8	\$0	\$20	\$1.76
Assistance Chief Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$56.09	\$28.04	4- F40T12/25W Energy Saving Lamp	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Second Floor																					
Comidor	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F40T12/25W Energy Saving Lamp	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21

ECO-7D
Buildings 500 - 581
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Existing										Proposed										Implementation									
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Misc. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$								
Building 522																													
First Floor																													
Office of the Chief of Staff	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F40T12/2EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83								
Office of the Chief of Staff Recp.	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F40T12/2EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62								
Rear Office #2 (not occupied)	3	4	40	552	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41								
Secretary's Ofc. to the General	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	4- F40T12/2EW Energy Saving Lamps	156	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24								
Main Entrance	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F40T12/2EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21								
Rear Office #2 (not occupied)	2	4	40	368	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F40T12/2EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21								
Rear Office #1 (not occupied)	2	4	40	368	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F40T12/2EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21								
Lobby	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F40T12/2EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83								
Reception Area	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21								
Left Reception Area	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21								
Commanding General Conf. Rm.	9	4	40	1656	35	75%	1.2	251.5	\$114.85	\$74.86	\$189.71	4- F40T12/2EW Energy Saving Lamps	156	0.3	68	\$47.68	\$68	\$30	\$0	\$52	\$8.41								
Commanding Generals Office	4	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F40T12/2EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62								
Secretary's Ofc. to the General	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41								
Second Floor																													
Inspector Gen. Admin. Office	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	2- F40T12/2EW Energy Saving Lamps	78	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31								
Copy Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41								
Inspector General Office	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2- F40T12/2EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41								
Inspector General Reception	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12/2EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21								
Protocol Office	5	2	40	460	50	95%	0.4	99.8	\$40.41	\$29.71	\$70.12	2- F40T12/2EW Energy Saving Lamps	78	0.4	85	\$59.60	\$40	\$25	\$0	\$65	\$10.52								
Liaison Office	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	4- F40T12/2EW Energy Saving Lamps	156	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24								
Protocol Office	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F40T12/2EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21								
Conference Room	10	4	40	1840	35	75%	1.4	279.5	\$127.61	\$83.18	\$210.79	4- F40T12/2EW Energy Saving Lamps	156	1.2	238	\$179.17	\$160	\$100	\$0	\$260	\$31.62								
Corridor	8	2	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	2- F40T12/2EW Energy Saving Lamps	78	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83								
Building 523																													
Administration																													
Cornelius Office	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2- F40T12/2EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41								
Grayson Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F40T12/2EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83								
Helbert Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F40T12/2EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83								
Descom Office A	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31								
Hawser Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31								
Baran Office	6	3	40	828	50	95%	0.8	179.7	\$72.74	\$53.47	\$126.21	3- F40T12/2EW Energy Saving Lamps	117	0.7	155	\$107.28	\$72	\$45	\$0	\$117	\$18.93								
Garhart Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31								
Creamer Office	6	2	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	2- F40T12/2EW Energy Saving Lamps	78	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62								
Sheffield Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41								
Conference Room B	2	4	40	368	35	75%	0.3	55.9	\$25.52	\$16.64	\$42.16	4- F40T12/2EW Energy Saving Lamps	156	0.2	48	\$35.83	\$32	\$20	\$0	\$52	\$8.41								
Myers Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3- F40T12/2EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62								
Horn Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3- F40T12/2EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62								
Descom Office B	6	2	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	2- F40T12/2EW Energy Saving Lamps	78	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62								
Conference Room A	8	3	40	1104	35	75%	0.8	167.7	\$76.57	\$58.91	\$126.47	3- F40T12/2EW Energy Saving Lamps	117	0.7	143	\$107.50	\$96	\$60	\$0	\$156	\$25.24								
Kiehn	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3- F40T12/2EW Energy Saving Lamps	117	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$3.16								
Library	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2- F40T12/2EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41								
Descom Office C	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	2- F40T12/2EW Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41								
Corridor	11	2	40	1012	50	95%	1.0	219.6	\$88.90	\$65.35	\$154.26	2- F40T12/2EW Energy Saving Lamps	78	0.8	187	\$131.12	\$88	\$55	\$0	\$143	\$23.14								
Building 524																													
Conference Center																													
Entrance Lobby	7	2	40	644	50	95%	0.6	139.7	\$56.57	\$41.59	\$98.16	2- F40T12/2EW Energy Saving Lamps	78	0.5	119	\$83.44	\$56	\$35	\$0	\$91	\$14.72								
Mens Restroom	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2- F40T12/2EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17								
Womens Restroom	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2- F40T12/2EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17								

ECO-7D
Buildings 500 - 581
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room	NO. Of Luminaires	Existing										Proposed										Implementation					Energy Savings \$
		Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mnt. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$							
Building 529																											
First Floor																											
Gold Shop Lunch Room	6	2	40	552	60	95%	0.5	143.7	\$48.49	\$42.78	\$91.27	2- F40T12/EW Energy Saving Lamps	78	0.4	122	\$77.58	\$48	\$30	\$0	\$78	\$13.69						
Golf Equipment Shop Office	1	4	40	184	60	95%	0.2	47.9	\$16.16	\$14.26	\$30.42	4- F40T12/EW Energy Saving Lamps	156	0.1	41	\$25.86	\$16	\$10	\$0	\$26	\$4.56						
Golf Equipment Shop	9	2	40	828	60	95%	0.8	215.6	\$72.74	\$64.17	\$136.90	2- F40T12/EW Energy Saving Lamps	78	0.7	183	\$116.37	\$72	\$45	\$0	\$117	\$20.54						
Golf Equipment Shop Office	1	2	40	92	60	95%	0.1	24.0	\$8.08	\$7.13	\$15.21	2- F40T12/EW Energy Saving Lamps	78	0.1	20	\$12.93	\$8	\$5	\$0	\$13	\$2.28						
Golf Equip. Shop Entrance Lobby	2	2	40	184	60	95%	0.2	47.9	\$16.16	\$14.26	\$30.42	2- F40T12/EW Energy Saving Lamps	78	0.1	41	\$25.86	\$16	\$10	\$0	\$26	\$4.56						
Mens Room	2	2	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	\$15.64	2- F40T12/EW Energy Saving Lamps	78	0.1	20	\$13.29	\$16	\$10	\$0	\$26	\$2.35						
Bar Table Area	19	4	40	3496	60	95%	3.3	910.4	\$270.92	\$70.92	\$578.04	3- F40T12/EW Energy Saving Lamps	156	2.8	774	\$491.33	\$304	\$190	\$0	\$494	\$86.71						
Kitchen Dish Room	6	3	40	828	60	95%	0.8	215.6	\$72.74	\$64.17	\$136.90	3- F40T12/EW Energy Saving Lamps	117	0.7	183	\$116.37	\$72	\$45	\$0	\$117	\$20.54						
Restroom Lobby	2	4	40	184	60	95%	0.2	47.9	\$16.16	\$14.26	\$30.42	2- F40T12/EW Energy Saving Lamps	78	0.1	41	\$25.86	\$16	\$10	\$0	\$26	\$4.56						
Bar Counter	2	4	40	368	60	95%	0.3	95.8	\$32.33	\$28.52	\$60.85	4- F40T12/EW Energy Saving Lamps	156	0.3	81	\$51.72	\$32	\$20	\$0	\$52	\$9.13						
Food Counter	4	4	40	736	60	95%	0.7	191.7	\$64.66	\$57.04	\$121.69	4- F40T12/EW Energy Saving Lamps	156	0.6	163	\$103.41	\$64	\$40	\$0	\$104	\$18.25						
Mens Room	1	2	40	92	60	95%	0.1	24.0	\$8.08	\$7.13	\$15.21	2- F40T12/EW Energy Saving Lamps	78	0.1	20	\$12.93	\$8	\$5	\$0	\$13	\$2.28						
Dumb Waiter Room	1	4	40	184	60	95%	0.2	47.9	\$16.16	\$14.26	\$30.42	4- F40T12/EW Energy Saving Lamps	156	0.1	41	\$25.86	\$16	\$10	\$0	\$26	\$4.56						
Women's Room	1	2	40	92	60	95%	0.1	24.0	\$8.08	\$7.13	\$15.21	2- F40T12/EW Energy Saving Lamps	78	0.1	20	\$12.93	\$8	\$5	\$0	\$13	\$2.28						
Women's Room	2	2	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	\$15.64	2- F40T12/EW Energy Saving Lamps	78	0.1	20	\$13.29	\$16	\$10	\$0	\$26	\$2.35						
Second Floor																											
Corridor to Mens Room	1	2	40	92	60	95%	0.1	24.0	\$8.08	\$7.13	\$15.21	2- F40T12/EW Energy Saving Lamps	78	0.1	20	\$12.93	\$8	\$5	\$0	\$13	\$2.28						
Mens Room	2	4	40	368	60	95%	0.3	95.8	\$32.33	\$28.52	\$60.85	4- F40T12/EW Energy Saving Lamps	156	0.3	81	\$51.72	\$32	\$20	\$0	\$52	\$9.13						
Food Prep Room	5	4	40	920	60	95%	0.9	239.6	\$80.82	\$71.30	\$152.12	4- F40T12/EW Energy Saving Lamps	156	0.7	204	\$129.30	\$80	\$50	\$0	\$130	\$22.82						
Women's Restroom	4	2	40	368	60	95%	0.3	95.8	\$32.33	\$28.52	\$60.85	2- F40T12/EW Energy Saving Lamps	78	0.3	81	\$51.72	\$32	\$20	\$0	\$52	\$9.13						
Second Floor Entrance Lobby	2	4	40	368	60	95%	0.3	95.8	\$32.33	\$28.52	\$60.85	4- F40T12/EW Energy Saving Lamps	156	0.3	81	\$51.72	\$32	\$20	\$0	\$52	\$9.13						
Dining Room	14	4	40	2576	60	95%	2.4	670.8	\$226.30	\$199.63	\$425.92	4- F40T12/EW Energy Saving Lamps	156	2.1	570	\$362.04	\$224	\$140	\$0	\$364	\$63.89						
Handicap Restroom	1	4	40	184	60	95%	0.2	47.9	\$16.16	\$14.26	\$30.42	4- F40T12/EW Energy Saving Lamps	156	0.1	41	\$25.86	\$16	\$10	\$0	\$26	\$4.56						
Building 530																											
Cable TV for Housing																											
Open Office Area	16	2	40	1472	50	95%	1.4	319.4	\$129.31	\$95.06	\$224.37	2- F40T12/EW Energy Saving Lamps	78	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$33.66						
Building 536																											
Bath House																											
Mens Locker Area	7	2	40	644	168	95%	0.6	469.6	\$56.57	\$130.74	\$196.31	2- F40T12/EW Energy Saving Lamps	78	0.5	399	\$166.87	\$56	\$35	\$0	\$91	\$29.45						
Mens Shower Area	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$28.52	\$60.85	2- F40T12/EW Energy Saving Lamps	78	0.3	278	\$95.35	\$32	\$20	\$0	\$52	\$16.83						
Women's Locker Area	3	2	40	276	168	95%	0.3	201.2	\$24.25	\$20.89	\$41.13	2- F40T12/EW Energy Saving Lamps	78	0.2	171	\$71.51	\$24	\$15	\$0	\$39	\$12.62						
Women's Shower Area	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$28.52	\$60.85	2- F40T12/EW Energy Saving Lamps	78	0.3	278	\$95.35	\$32	\$20	\$0	\$52	\$16.83						
Women's Pool Shower Area	2	2	40	184	168	95%	0.2	134.2	\$16.16	\$19.93	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.1	114	\$47.68	\$16	\$10	\$0	\$26	\$8.41						
Mens Pool Shower Area Locked	2	2	40	184	168	95%	0.2	134.2	\$16.16	\$19.93	\$56.09	2- F40T12/EW Energy Saving Lamps	78	0.1	114	\$47.68	\$16	\$10	\$0	\$26	\$8.41						
Building 581																											
First Floor																											
SIDS Office	8	4	40	1472	50	95%	1.4	319.4	\$129.31	\$95.06	\$224.37	4- F40T12/EW Energy Saving Lamps	156	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$33.66						
Mens Room	2	4	40	368	30	50%	0.2	47.9	\$17.01	\$14.26	\$31.27	2- F40T12/EW Energy Saving Lamps	156	0.2	41	\$26.58	\$32	\$20	\$0	\$52	\$4.69						
Copy Room	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10						
Copy Room	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$24.05	4- F40T12/EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21						
LEAD Valve Engine Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41						
Breakroom	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41						
Mens Room Sink Lighting	1	1	40	46	30	50%	0.0	6.0	\$2.13	\$1.78	\$3.91	1- F40T12/EW Energy Saving Lamp	39	0.0	5	\$3.32	\$4	\$3	\$0	\$7	\$0.59						
Dir. Resource Mgrs. Office	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$81.30	\$168.28	4- F40T12/EW Energy Saving Lamps	156	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24						
Dir. Resource Mgrs. Recp. Area	5	4	40	920	50	95%	0.9	199.6	\$80.82	\$69.41	\$140.23	4- F40T12/EW Energy Saving Lamps	156	0.7	170	\$119.20	\$80	\$50	\$0	\$130	\$21.04						
Women's Room	2	4	40	368	30	50%	0.2	47.9	\$17.01	\$14.26	\$31.27	4- F40T12/EW Energy Saving Lamps	156	0.2	41	\$26.58	\$32	\$20	\$0	\$52	\$4.69						
Conference Room	6	4	40	1104	35	75%	0.8	167.7	\$76.57	\$49.91	\$126.47	4- F40T12/EW Energy Saving Lamps	156	0.7	143	\$97.50	\$96	\$60	\$0	\$156	\$18.97						
Corridor	5	2	40	460	50	95%	0.4	99.8	\$40.41	\$29.71	\$70.12	2- F40T12/EW Energy Saving Lamps	78	0.4	85	\$59.60	\$40	\$25	\$0	\$65	\$10.52						
LEAD Valve Engine Area	8	4	40	1472	50	95%	1.4	319.4	\$129.31	\$95.06	\$224.37	4- F40T12/EW Energy Saving Lamps	156	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$33.66						
Open Office Area	16	4	40	2944		95%	2.8	638.8	\$258.63	\$190.12	\$448.75	4- F40T12/EW Energy Saving Lamps	156	2.4	543	\$381.43	\$256	\$160	\$0	\$416	\$67.31						

ECO-7D
Buildings 500 - 581
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Existing										Proposed			Implementation								
Room	NO Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$	Energy Savings \$
Second Floor																					
Room #15 Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$24.95	\$112.19	4- F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Room #17 Conference Room	3	4	40	552	35	75%	0.4	83.8	\$38.28	\$24.95	\$63.24	4- F40T12/EW Energy Saving Lamps	156	0.4	71	\$53.75	\$48	\$30	\$0	\$78	\$9.49
Room #20A	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Room #20	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F40T12/EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Room #14 Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	4- F40T12/EW Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41
Room #19 Smoke Room	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F40T12/EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Room #8 & #10	5	4	40	920	50	95%	0.9	199.6	\$80.82	\$59.41	\$140.23	4- F40T12/EW Energy Saving Lamps	156	0.7	170	\$119.20	\$80	\$50	\$0	\$130	\$21.04
Room #14A Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F40T12/EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Room #11 Office	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F40T12/EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Room #12 Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F40T12/EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Room #1 Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F40T12/EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$10	\$0	\$26	\$4.21
Room #9 Office	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F40T12/EW Energy Saving Lamps	156	0.1	36	\$23.84	\$16	\$0	\$0	\$104	\$16.83
Room #5 & #7 Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Room #3 Office	3	4	40	552	35	75%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F40T12/EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Room #4 Conference Room	3	4	40	552	35	75%	0.4	83.8	\$38.28	\$24.95	\$63.24	4- F40T12/EW Energy Saving Lamps	156	0.4	71	\$53.75	\$48	\$30	\$0	\$78	\$9.49
Room #1 Conference Area	2	4	40	368	35	75%	0.3	55.3	\$25.52	\$16.64	\$42.16	4- F40T12/EW Energy Saving Lamps	156	0.2	48	\$35.83	\$32	\$20	\$0	\$52	\$6.32
Corridor	11	4	40	2024	50	95%	1.9	499.2	\$177.81	\$130.71	\$308.51	4- F40T12/EW Energy Saving Lamps	156	1.6	373	\$262.24	\$176	\$110	\$0	\$286	\$46.28
TOTAL S	894			128800			117.7	30327	\$11,000	\$9,000	\$20,000			100.0	25778	\$17,000	\$11,000	\$7,000	\$0	\$18,000	\$3,000
CAPROJECT784130.01SSSECOE.CO.7.D.WK.4																					
22-May-95																					

GA\PROJECTS\4300\ISS\ECOECO-7D\WK4

22 May 95

ECO-7E
Buildings 616 - 5426
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Existing				Proposed				Implementation								
					Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw/Hr Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/Hr Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$
Building 616																					
Police Building																					
Police Conference Room	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$79.85	\$112.18	2- F40T12/EW Energy Saving Lamps	78	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83
Police Conference Room	4	4	40	736	168	95%	0.7	536.6	\$64.66	\$159.70	\$224.36	4- F40T12/EW Energy Saving Lamps	156	0.6	456	\$190.70	\$64	\$40	\$0	\$104	\$33.65
Building 618																					
First Floor																					
Hole Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Corridor	8	2	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	2- F40T12/EW Energy Saving Lamps	78	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Room #11 Office	3	40	414	50	95%	0.4	89.8	36.74	\$36.74	\$63.11	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47
Copy Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Coffee Mess	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Handicap Restroom	1	3	40	138	30	50%	0.1	18.0	\$6.38	\$5.35	\$11.73	3- F40T12/EW Energy Saving Lamps	117	0.1	15	\$9.97	\$12	\$8	\$0	\$20	\$1.76
Mens Room	2	3	40	276	30	50%	0.1	35.9	\$12.76	\$10.69	\$23.46	3- F40T12/EW Energy Saving Lamps	117	0.1	31	\$19.94	\$24	\$15	\$0	\$39	\$3.52
Room #7	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Marine Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Keefe Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Walter Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Hunting & Fishing Office	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3- F40T12/EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47
Second Floor																					
Warlock Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Corridor	8	2	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	2- F40T12/EW Energy Saving Lamps	78	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Stairwell to Second Floor	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3- F40T12/EW Energy Saving Lamps	117	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$1.66
Copier Office	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Younge Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Locust Office	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21
Quinn Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Haz Waste Conference Room	5	3	40	690	35	75%	0.5	104.8	\$47.85	\$31.19	\$79.05	3- F40T12/EW Energy Saving Lamps	117	0.4	89	\$67.19	\$24	\$15	\$0	\$39	\$6.31
Greening Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Williams Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Eggen Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Conference Room	3	3	40	414	35	75%	0.3	62.9	\$28.71	\$18.72	\$47.43	3- F40T12/EW Energy Saving Lamps	117	0.3	55	\$40.31	\$36	\$23	\$0	\$59	\$9.47
Women's Room	2	3	40	276	30	50%	0.1	35.9	\$12.76	\$10.69	\$23.46	3- F40T12/EW Energy Saving Lamps	117	0.1	31	\$19.94	\$24	\$15	\$0	\$39	\$3.52
Building 619																					
Dining Area																					
Women's Room	2	3	40	276	30	50%	0.1	35.9	\$12.76	\$10.69	\$23.46	3- F40T12/EW Energy Saving Lamps	117	0.1	31	\$19.94	\$24	\$15	\$0	\$39	\$3.52
Entrance Lobby	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
Staff Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Women's Room Sink	1	1	40	46	30	50%	0.0	6.0	\$2.13	\$1.78	\$3.91	1- F40T12/EW Energy Saving Lamp	39	0.0	5	\$3.32	\$4	\$3	\$0	\$7	\$0.59
Mens Room Sink	1	1	40	46	30	50%	0.0	6.0	\$2.13	\$1.78	\$3.91	1- F40T12/EW Energy Saving Lamp	39	0.0	5	\$3.32	\$4	\$3	\$0	\$7	\$0.59
Rear Dining Area	4	4	40	736	30	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83
Mens Room	2	3	40	276	30	50%	0.1	35.9	\$12.76	\$10.69	\$23.46	3- F40T12/EW Energy Saving Lamps	117	0.1	31	\$19.94	\$24	\$15	\$0	\$39	\$3.52
Open Dining Area	27	3	40	3726	50	95%	3.5	808.5	\$377.32	\$240.62	\$567.95	3- F40T12/EW Energy Saving Lamps	117	3.0	687	\$482.75	\$324	\$203	\$0	\$527	\$85.19
Serving Area	7	2	40	644	50	95%	0.6	139.7	\$56.37	\$41.59	\$98.16	2- F40T12/EW Energy Saving Lamps	78	0.5	119	\$83.44	\$56	\$35	\$0	\$91	\$14.72
Rear Dining Area	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3- F40T12/EW Energy Saving Lamps	117	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$1.66
Building 628																					
First Floor																					
Information Security	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Badge Photo Room	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	3- F40T12/EW Energy Saving Lamps	117	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62
Badge Photo Room File	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10
Conference Room A	3	3	40	414	35	75%	0.3	62.9	\$28.71	\$18.72	\$47.43	3- F40T12/EW Energy Saving Lamps	117	0.3	55	\$40.31	\$36	\$23	\$0	\$59	\$9.47
First Floor Corridor	5	3	40	690	50	95%	0.7	149.7	\$60.62	\$44.56	\$105.18	3- F40T12/EW Energy Saving Lamps	117	0.6	127	\$89.40	\$60	\$38	\$0	\$98	\$15.78
Women's Restroom & Shower	3	3	40	414	30	50%	0.2	53.9	\$19.14	\$16.04	\$35.18	3- F40T12/EW Energy Saving Lamps	117	0.2	46	\$29.91	\$36	\$23	\$0	\$59	\$5.28
Handicap Restroom	1	3	40	138	30	50%	0.1	18.0	\$6.38	\$5.35	\$11.73	3- F40T12/EW Energy Saving Lamps	117	0.1	15	\$9.97	\$12	\$8	\$0	\$20	\$1.76
Copier Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Smoking Room	1	1	40	46	50	95%	0.0	10.0	\$4.04	\$2.97	\$7.01	1- F40T12/EW Energy Saving Lamp	39	0.0	8	\$3.96	\$4	\$3	\$0	\$7	\$0.59
Automation Security Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Police Officers Room #3 Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Room #1 Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31
Physical Security	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3- F40T12/EW Energy Saving Lamps	117	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$1.66

ECO-7E
Buildings 616 - 5426
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Existing													Proposed					Implementation				
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$	
Second Floor																						
Stairway to Second Floor	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12/2EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10	
Corridor	5	3	40	690	50	95%	0.7	149.7	\$60.62	\$41.56	\$105.18	3- F40T12/2EW Energy Saving Lamps	117	0.6	127	\$89.40	\$60	\$38	\$0	\$98	\$15.78	
Investigation Office Room #19	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31	
Investigation Office Room #18	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3- F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47	
Interview Room #17	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31	
Secretary & Plans Div. Office	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3- F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47	
Chief Secretary & Plans Div. Ofc.	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3- F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47	
Mens Room & Shower	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3- F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47	
Mens Room & Shower	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	3- F40T12/2EW Energy Saving Lamps	117	0.3	76	\$53.64	\$36	\$23	\$0	\$59	\$9.47	
Director - PM Office Room #11	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/2EW Energy Saving Lamps	117	0.2	46	\$29.91	\$24	\$15	\$0	\$39	\$6.31	
Directorate Secretary Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/2EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31	
Building 637																						
Chapel																						
Chapel Lighting	40	1	40	1840	40	75%	1.4	319.4	\$127.61	\$95.06	\$222.67	1- F40T12/2EW Energy Saving Lamp	39	1.2	272	\$189.27	\$160	\$100	\$0	\$260	\$33.40	
Corridor Behind Ailer	2	2	40	184	40	75%	0.1	31.9	\$12.76	\$9.51	\$22.27	2- F40T12/2EW Energy Saving Lamps	78	0.1	27	\$18.93	\$16	\$10	\$0	\$26	\$3.34	
Building 639																						
Physical Fitness Center																						
Rear Entrance Lobby	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2- F40T12/2EW Energy Saving Lamps	78	0.1	57	\$23.84	\$8	\$5	\$0	\$13	\$4.21	
Weight Room Restroom	2	2	40	184	101	95%	0.2	80.7	\$16.16	\$24.00	\$40.17	2- F40T12/2EW Energy Saving Lamps	78	0.1	69	\$34.14	\$16	\$10	\$0	\$26	\$6.03	
Wright Room	14	3	40	1932	168	95%	1.8	1408.7	\$169.72	\$419.22	\$588.94	3- F40T12/2EW Energy Saving Lamps	117	1.6	1,197	\$500.60	\$168	\$105	\$0	\$273	\$88.34	
Gym Entrance	2	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2- F40T12/2EW Energy Saving Lamps	78	0.1	57	\$23.84	\$8	\$5	\$0	\$13	\$4.21	
Womens Rear Locker Room	1	2	40	184	168	95%	0.2	134.2	\$16.16	\$39.93	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.1	114	\$47.68	\$16	\$10	\$0	\$26	\$8.41	
Corridor to Sauna	3	2	40	276	168	95%	0.3	201.2	\$24.25	\$59.80	\$84.13	2- F40T12/2EW Energy Saving Lamps	78	0.2	171	\$71.51	\$24	\$15	\$0	\$39	\$12.62	
Corridor to Womens Locker Rm.	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2- F40T12/2EW Energy Saving Lamps	78	0.1	57	\$23.84	\$8	\$5	\$0	\$13	\$4.21	
Womens Shower Room	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$79.85	\$112.18	2- F40T12/2EW Energy Saving Lamps	78	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83	
Corridor to Mens Locker Room	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2- F40T12/2EW Energy Saving Lamps	78	0.1	57	\$23.84	\$8	\$5	\$0	\$13	\$4.21	
Gym Office	2	2	40	368	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	2- F40T12/2EW Energy Saving Lamps	78	0.1	57	\$23.84	\$8	\$5	\$0	\$13	\$4.21	
Corridor to Restroom	2	2	40	184	168	95%	0.2	134.2	\$16.16	\$39.93	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83	
Mens Locker Room	4	4	40	736	168	95%	0.7	536.6	\$64.66	\$159.70	\$224.36	4- F40T12/2EW Energy Saving Lamps	156	0.6	456	\$190.70	\$64	\$40	\$0	\$104	\$33.65	
Womens Locker Room	4	4	40	736	168	95%	0.7	536.6	\$64.66	\$159.70	\$224.36	4- F40T12/2EW Energy Saving Lamps	156	0.6	456	\$190.70	\$64	\$40	\$0	\$104	\$33.65	
Mens Shower Room	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$79.85	\$112.18	2- F40T12/2EW Energy Saving Lamps	78	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83	
Mens Shower Room	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$79.85	\$112.18	2- F40T12/2EW Energy Saving Lamps	78	0.3	228	\$95.35	\$32	\$20	\$0	\$52	\$16.83	
Mens Rear Locker Room	1	4	40	184	168	95%	0.2	134.2	\$16.16	\$39.93	\$56.09	4- F40T12/2EW Energy Saving Lamps	156	0.1	114	\$47.68	\$16	\$10	\$0	\$26	\$8.41	
Gym Entrance	1	1	40	46	168	95%	0.0	33.5	\$4.04	\$9.98	\$14.02	1- F40T12/2EW Energy Saving Lamp	39	0.0	29	\$11.92	\$4	\$3	\$0	\$7	\$2.10	
Building 640																						
Camper Check-In																						
Main Entrance Area	2	4	40	368	20	50%	0.2	31.9	\$17.01	\$9.51	\$26.52	4- F40T12/2EW Energy Saving Lamps	156	0.2	27	\$22.54	\$32	\$20	\$0	\$52	\$3.98	
Office #1	1	4	40	184	20	50%	0.1	16.0	\$8.51	\$4.75	\$13.26	4- F40T12/2EW Energy Saving Lamps	156	0.1	14	\$11.27	\$16	\$10	\$0	\$26	\$1.99	
Office #2	1	4	40	184	20	50%	0.1	16.0	\$8.51	\$4.75	\$13.26	4- F40T12/2EW Energy Saving Lamps	156	0.1	14	\$11.27	\$16	\$10	\$0	\$26	\$1.99	
Mens Room	2	4	40	368	20	50%	0.2	31.9	\$17.01	\$9.51	\$26.52	4- F40T12/2EW Energy Saving Lamps	156	0.2	27	\$22.54	\$32	\$20	\$0	\$52	\$3.98	
Womens Room	2	4	40	368	20	50%	0.2	31.9	\$17.01	\$9.51	\$26.52	4- F40T12/2EW Energy Saving Lamps	156	0.2	27	\$22.54	\$32	\$20	\$0	\$52	\$3.98	
Laundry Room	1	4	40	184	20	50%	0.1	16.0	\$8.51	\$4.75	\$13.26	4- F40T12/2EW Energy Saving Lamps	156	0.1	14	\$11.27	\$16	\$10	\$0	\$26	\$1.99	
Building 645																						
Day Care																						
Entrance Lobby	1	2	40	92	90	95%	0.1	35.9	\$8.08	\$10.69	\$18.78	2- F40T12/2EW Energy Saving Lamps	78	0.1	31	\$15.96	\$8	\$5	\$0	\$13	\$2.82	
Changing Area	2	2	40	184	54	95%	0.2	43.1	\$16.16	\$12.83	\$29.00	2- F40T12/2EW Energy Saving Lamps	78	0.1	37	\$24.65	\$16	\$10	\$0	\$26	\$4.35	
Bathroom #3	1	2	40	92	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	2- F40T12/2EW Energy Saving Lamps	78	0.1	18	\$12.32	\$8	\$5	\$0	\$13	\$2.17	
Baby Area	4	2	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	2- F40T12/2EW Energy Saving Lamps	78	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27	
Bathroom #2	1	2	40	92	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	2- F40T12/2EW Energy Saving Lamps	78	0.1	18	\$12.32	\$8	\$5	\$0	\$13	\$2.17	
Kitchen Area	1	2	40	92	90	95%	0.1	35.9	\$8.08	\$10.69	\$18.78	2- F40T12/2EW Energy Saving Lamps	78	0.1	31	\$15.96	\$8	\$5	\$0	\$13	\$2.82	
Play Area	1	2	40	92	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	2- F40T12/2EW Energy Saving Lamps	78	0.1	18	\$12.32	\$8	\$5	\$0	\$13	\$2.17	
Bathroom #1	16	2	40	1472	90	95%	1.4	575.0	\$129.31	\$171.11	\$500.42	2- F40T12/2EW Energy Saving Lamps	78	1.2	489	\$255.36	\$128	\$80	\$0	\$208	\$45.06	
Staff Office	3	2	40	276	90	95%	0.3	107.8	\$24.25	\$32.08	\$56.33	2- F40T12/2EW Energy Saving Lamps	78	0.2	92	\$47.88	\$24	\$15	\$0	\$39	\$8.45	

ECO-7E
Buildings 616 - 5426
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Existing				Proposed				Implementation								
				Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost (\$)	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost (\$)	Mat. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings \$
Building 646																				
Entrance Area	2	3	40	276	126	95%	150.9	\$24.25	\$44.92	\$69.16	3-F40T12/EW Energy Saving Lamps	117	0.2	128	\$38.79	\$24	\$15	\$0	\$39	\$10.37
Lounge Area	5	3	40	690	126	95%	377.3	\$60.62	\$112.29	\$172.91	3-F40T12/EW Energy Saving Lamps	117	0.6	321	\$146.97	\$60	\$38	\$0	\$98	\$25.94
Girls Room	2	2	40	184	76	95%	60.7	\$16.16	\$18.06	\$34.23	2-F40T12/EW Energy Saving Lamps	78	0.1	52	\$29.09	\$16	\$10	\$0	\$26	\$5.13
Boys Room	2	2	40	184	76	95%	60.7	\$16.16	\$18.06	\$34.23	2-F40T12/EW Energy Saving Lamps	78	0.1	52	\$29.09	\$16	\$10	\$0	\$26	\$5.13
Staff Office	2	3	40	276	126	95%	150.9	\$24.25	\$44.92	\$69.16	3-F40T12/EW Energy Saving Lamps	117	0.2	128	\$38.79	\$24	\$15	\$0	\$39	\$10.37
Corridor to Play Room	1	2	40	92	126	95%	50.3	\$8.08	\$14.97	\$23.05	2-F40T12/EW Energy Saving Lamps	78	0.1	43	\$19.60	\$8	\$5	\$0	\$13	\$3.46
Play Room	2	3	40	276	126	95%	150.9	\$24.25	\$44.92	\$69.16	3-F40T12/EW Energy Saving Lamps	117	0.2	128	\$38.79	\$24	\$15	\$0	\$39	\$10.37
Open Area	20	2	40	1840	126	95%	1006.2	\$161.64	\$299.44	\$461.08	2-F40T12/EW Energy Saving Lamps	78	1.5	855	\$391.92	\$160	\$100	\$0	\$260	\$69.16
Kitchen	1	3	40	138	126	95%	75.3	\$12.12	\$22.46	\$34.58	3-F40T12/EW Energy Saving Lamps	117	0.1	64	\$29.39	\$12	\$8	\$0	\$20	\$5.19
Kitchen	2	2	40	184	126	95%	100.6	\$16.16	\$29.94	\$46.11	2-F40T12/EW Energy Saving Lamps	78	0.1	86	\$39.19	\$16	\$10	\$0	\$26	\$6.92
Building 663																				
Administration & Trades																				
Heating & Plumbing Shop Area	19	4	40	3496	90	95%	1365.5	\$307.12	\$406.38	\$713.50	4-F40T12/EW Energy Saving Lamps	156	2.8	1161	\$606.48	\$304	\$190	\$0	\$494	\$107.03
Main Entrance Lobby	4	4	40	736	90	95%	287.5	\$64.66	\$85.55	\$150.21	4-F40T12/EW Energy Saving Lamps	156	0.6	244	\$127.68	\$64	\$40	\$0	\$104	\$22.53
Lunch Area	8	4	40	1472	90	95%	575.0	\$129.31	\$171.11	\$300.42	4-F40T12/EW Energy Saving Lamps	156	1.2	489	\$255.36	\$128	\$80	\$0	\$208	\$45.06
Production Division Office #3	4	2	40	368	90	95%	143.7	\$32.33	\$42.78	\$75.11	2-F40T12/EW Energy Saving Lamps	78	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27
Production Division Office #2	2	2	40	184	90	95%	71.9	\$16.16	\$21.39	\$37.55	2-F40T12/EW Energy Saving Lamps	78	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63
Production Division Office Front Rm.	6	4	40	1104	90	95%	431.2	\$96.98	\$128.33	\$225.32	4-F40T12/EW Energy Saving Lamps	156	0.9	367	\$191.52	\$96	\$60	\$0	\$156	\$33.60
Production Division Office Back Rm.	2	4	40	368	90	95%	143.7	\$32.33	\$42.78	\$75.11	2-F40T12/EW Energy Saving Lamps	156	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27
Production Division Office #1	1	2	40	92	90	95%	35.9	\$8.08	\$10.69	\$18.78	2-F40T12/EW Energy Saving Lamps	78	0.1	31	\$15.96	\$8	\$5	\$0	\$13	\$2.82
Building & Structural Office	4	2	40	368	90	95%	143.7	\$32.33	\$42.78	\$75.11	2-F40T12/EW Energy Saving Lamps	78	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27
Lunch Room	4	3	40	552	90	95%	215.6	\$48.40	\$64.17	\$112.66	3-F40T12/EW Energy Saving Lamps	117	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$16.90
Computer Supply Room	4	3	40	552	90	95%	215.6	\$48.40	\$64.17	\$112.66	3-F40T12/EW Energy Saving Lamps	117	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$16.90
Capitler Shop Area	28	3	40	3684	90	95%	1509.3	\$339.45	\$449.16	\$788.61	3-F40T12/EW Energy Saving Lamps	117	3.1	1283	\$670.32	\$336	\$210	\$0	\$546	\$118.29
S. C. Office	3	4	40	414	90	95%	161.7	\$36.37	\$48.12	\$84.49	3-F40T12/EW Energy Saving Lamps	117	0.3	137	\$71.82	\$36	\$23	\$0	\$59	\$12.67
Dispatch Office	2	4	40	368	90	95%	143.7	\$32.33	\$42.78	\$75.11	2-F40T12/EW Energy Saving Lamps	156	0.6	244	\$127.68	\$64	\$40	\$0	\$104	\$22.53
Dispatch Office	2	4	40	368	90	95%	143.7	\$32.33	\$42.78	\$75.11	2-F40T12/EW Energy Saving Lamps	156	0.6	244	\$127.68	\$64	\$40	\$0	\$104	\$22.53
Dispatch Office	1	3	40	138	90	95%	53.9	\$12.12	\$16.04	\$28.16	3-F40T12/EW Energy Saving Lamps	117	0.1	46	\$23.94	\$12	\$8	\$0	\$20	\$4.22
Computer Room	4	3	40	552	90	95%	215.6	\$48.40	\$64.17	\$112.66	3-F40T12/EW Energy Saving Lamps	117	0.4	183	\$95.76	\$48	\$30	\$0	\$78	\$16.90
Welding Shop Area	8	3	40	1416	90	95%	575.0	\$129.31	\$171.11	\$300.42	4-F40T12/EW Energy Saving Lamps	117	3.3	1375	\$718.20	\$360	\$225	\$0	\$585	\$126.74
Production Division Office #1	2	4	40	368	90	95%	143.7	\$32.33	\$42.78	\$75.11	2-F40T12/EW Energy Saving Lamps	156	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27
Operations & Maint. Conf. Room	2	3	40	276	63	95%	75.3	\$24.25	\$22.46	\$34.58	3-F40T12/EW Energy Saving Lamps	117	0.2	64	\$39.70	\$24	\$15	\$0	\$39	\$7.01
Work Planning & Control Office	12	4	40	2208	90	95%	862.4	\$193.97	\$256.66	\$500.63	4-F40T12/EW Energy Saving Lamps	156	1.8	733	\$383.04	\$192	\$120	\$0	\$312	\$67.59
Business Management Office	3	3	40	414	90	95%	161.7	\$36.37	\$48.12	\$84.49	3-F40T12/EW Energy Saving Lamps	117	0.3	137	\$71.82	\$36	\$23	\$0	\$59	\$12.67
Copy Room	1	4	40	184	54	95%	43.1	\$16.16	\$12.83	\$29.00	4-F40T12/EW Energy Saving Lamps	156	0.1	37	\$24.65	\$16	\$10	\$0	\$26	\$4.35
Computer Room	1	2	40	92	90	95%	35.9	\$8.08	\$10.69	\$18.78	2-F40T12/EW Energy Saving Lamps	78	0.1	31	\$15.96	\$8	\$5	\$0	\$13	\$2.82
Women's Room	2	3	40	276	54	95%	64.7	\$24.25	\$19.25	\$43.50	3-F40T12/EW Energy Saving Lamps	117	0.2	55	\$26.97	\$24	\$15	\$0	\$39	\$6.52
Meat Room	2	3	40	276	54	95%	64.7	\$24.25	\$19.25	\$43.50	3-F40T12/EW Energy Saving Lamps	117	0.2	55	\$26.97	\$24	\$15	\$0	\$39	\$6.52
Conference Room	7	3	40	966	63	95%	264.1	\$84.86	\$78.60	\$163.46	3-F40T12/EW Energy Saving Lamps	117	0.8	225	\$118.95	\$84	\$53	\$0	\$137	\$24.52
Corridor to Drawing Files Area	2	3	40	276	90	95%	107.8	\$24.25	\$32.08	\$56.33	3-F40T12/EW Energy Saving Lamps	117	0.2	92	\$47.88	\$24	\$15	\$0	\$39	\$8.45
Director of Public Works	1	4	40	184	90	95%	71.9	\$16.16	\$21.39	\$37.55	4-F40T12/EW Energy Saving Lamps	156	0.1	61	\$31.92	\$16	\$10	\$0	\$26	\$5.63
Director of Public Works	3	2	40	276	90	95%	107.8	\$24.25	\$32.08	\$56.33	2-F40T12/EW Energy Saving Lamps	78	0.2	92	\$47.88	\$24	\$15	\$0	\$39	\$8.45
Office	1	3	40	414	90	95%	161.7	\$36.37	\$48.12	\$84.49	3-F40T12/EW Energy Saving Lamps	117	0.3	137	\$71.82	\$36	\$23	\$0	\$59	\$12.67
Office	2	3	40	276	90	95%	107.8	\$24.25	\$32.08	\$56.33	3-F40T12/EW Energy Saving Lamps	117	0.2	92	\$47.88	\$24	\$15	\$0	\$39	\$8.45
Print Room	1	4	40	184	54	95%	43.1	\$16.16	\$12.83	\$29.00	4-F40T12/EW Energy Saving Lamps	156	0.1	37	\$24.65	\$16	\$10	\$0	\$26	\$4.35
Drawing Files Area	8	4	40	1472	54	95%	345.0	\$129.31	\$102.87	\$231.98	4-F40T12/EW Energy Saving Lamps	156	1.2	293	\$197.18	\$128	\$80	\$0	\$208	\$44.30
Open Office Area	47	3	40	6886	90	95%	2533.4	\$569.78	\$753.95	\$1194.3	3-F40T12/EW Energy Saving Lamps	117	5.2	2153	\$1125.17	\$564	\$353	\$0	\$917	\$198.56
Corridor to Snack Bar	1	75	40	2700	90	95%	101.1	\$22.73	\$30.08	\$52.81	1-F60T12/EW Energy Saving Lamps	69	0.2	81	\$42.25	\$25	\$8	\$0	\$33	\$10.56
Operations & Maint. Room	12	4	40	2208	90	95%	862.4	\$193.97	\$256.66	\$500.63	4-F40T12/EW Energy Saving Lamps	156	1.8	733	\$383.04	\$192	\$120	\$0	\$312	\$67.59
Electrical Supply	2	3	40	276	90	95%	107.8	\$24.25	\$32.08	\$56.33	3-F40T12/EW Energy Saving Lamps	117	0.2	92	\$47.88	\$24	\$15	\$0	\$39	\$8.45
Electrical Supply	4	2	40	368	90	95%	143.7	\$32.33	\$42.78	\$75.11	2-F40T12/EW Energy Saving Lamps	78	0.3	122	\$63.84	\$32	\$20	\$0	\$52	\$11.27
Corridor to Snack Bar	1	2	40	92	90	95%	35.9	\$8.08	\$10.69	\$18.78	2-F40T12/EW Energy Saving Lamps	78	0.1	31	\$15.96	\$8	\$5	\$0	\$13	\$2.82
Receiving - Supply Area	14	2	40	628	90	95%	503.1	\$113.15	\$149.72	\$262.87	2-F40T12/EW Energy Saving Lamps	78	1.0	428	\$223.44	\$112	\$70	\$0	\$182	\$39.43
Drafting Office Area	34	4	40	2256	90	95%	2433.6	\$549.38	\$727.21	\$1177.4	4-F40T12/EW Energy Saving Lamps	156	5.1	2077	\$1085.77	\$544	\$340	\$0	\$884	\$193.52
Engineering Office Area	8	4	40	1472	90	95%	575.0	\$129.31	\$171.11	\$300.42	4-F40T12/EW Energy Saving Lamps	156	1.2	489	\$255.36	\$128	\$80	\$0	\$208	\$45.06
Restroom	1	2	40	92	54	95%	21.6	\$8.08	\$6.42	\$14.50	2-F40T12/EW Energy Saving Lamps	78	0.1	18	\$12.32	\$8	\$5	\$0	\$13	\$2.17

ECO-7E
Buildings 616 - 5426
Letterkenny Army Depot
Fluorescent Lamp Retrofit

Room		NO. Of Luminaires		Lamps Per Luminaire		Watts Per Lamp		Existing					Proposed					Implementation				
								Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$
Building 664																						
First Floor																						
Entrance Lobby	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10	
Locker/Shower Room	5	2	40	460	30	50%	0.2	59.9	\$21.27	\$17.82	\$39.09	2- F40T12/EW Energy Saving Lamps	78	0.2	51	\$33.23	\$40	\$25	\$0	\$65	\$5.86	
Corridor to Restroom	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83	
Locker Room	2	3	40	276	30	50%	0.1	35.9	\$12.76	\$10.60	\$252.42	3- F40T12/EW Energy Saving Lamps	117	0.1	31	\$19.94	\$24	\$15	\$0	\$39	\$3.52	
Open Office Area	9	4	40	1656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	4- F40T12/EW Energy Saving Lamps	156	1.3	305	\$214.56	\$144	\$90	\$0	\$234	\$37.86	
Empty Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83	
Issue Center Office	9	4	40	1656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	4- F40T12/EW Energy Saving Lamps	156	1.3	305	\$214.56	\$144	\$90	\$0	\$234	\$37.86	
Second Floor																						
Library Check Out	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21	
Chaplain's Office	1	3	40	138	50	95%	0.1	29.9	\$8.91	\$21.04	\$31.16	3- F40T12/EW Energy Saving Lamps	117	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$3.16	
Reading Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31	
Children's Room	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	3- F40T12/EW Energy Saving Lamps	117	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$3.16	
Library Stocks	36	2	40	3312	50	95%	3.1	718.7	\$290.95	\$213.89	\$504.84	2- F40T12/EW Energy Saving Lamps	78	2.7	611	\$429.11	\$288	\$180	\$0	\$468	\$75.73	
Reading Room	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21	
Administrative Office	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21	
Library	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10	
Class Room	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10	
Sunday School Room	5	2	40	460	30	95%	0.4	99.8	\$40.41	\$29.71	\$70.12	2- F40T12/EW Energy Saving Lamps	78	0.4	85	\$59.60	\$40	\$25	\$0	\$65	\$10.52	
Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	3- F40T12/EW Energy Saving Lamps	117	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31	
Building 2260																						
Administration																						
Ladies Room	2	4	40	368	30	50%	0.2	47.9	\$17.01	\$14.26	\$31.27	4- F40T12/EW Energy Saving Lamps	156	0.2	41	\$26.98	\$32	\$20	\$0	\$52	\$4.69	
Mens Room	1	4	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	\$15.64	4- F40T12/EW Energy Saving Lamps	156	0.1	20	\$13.29	\$16	\$10	\$0	\$26	\$2.35	
Mens Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2- F40T12/EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17	
Handicap Restroom	1	4	40	184	30	50%	0.1	24.0	\$8.51	\$7.13	\$15.64	4- F40T12/EW Energy Saving Lamps	156	0.1	20	\$13.29	\$16	\$10	\$0	\$26	\$2.35	
Distri. Branch Chief Reception	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	4- F40T12/EW Energy Saving Lamps	156	0.9	204	\$143.04	\$96	\$60	\$0	\$256	\$25.24	
Open Office Area	52	4	40	9568	50	95%	9.1	2076.3	\$840.53	\$617.89	\$1,458.4	4- F40T12/EW Energy Saving Lamps	156	7.7	1765	\$1,239.66	\$832	\$520	\$0	\$1,352	\$218.76	
Property Disposal Office	8	4	40	1472	50	95%	1.4	319.4	\$129.31	\$95.06	\$224.37	4- F40T12/EW Energy Saving Lamps	156	1.2	272	\$190.72	\$128	\$80	\$0	\$208	\$33.66	
Distri. Branch Chief Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	4- F40T12/EW Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83	
Exit Lobby	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	4- F40T12/EW Energy Saving Lamps	156	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21	
Building 2329																						
Pestle																						
Pesticide Sink Area	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	2- F40T12/EW Energy Saving Lamps	78	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31	
Restroom	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2- F40T12/EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17	
Staff Office	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	2- F40T12/EW Energy Saving Lamps	78	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31	
Corridor	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	2- F40T12/EW Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21	
Building 2755																						
Warehouse																						
Lab Room	5	3	40	690	50	95%	0.7	149.7	\$60.62	\$44.56	\$105.18	3- F40T12/EW Energy Saving Lamps	117	0.6	127	\$89.40	\$60	\$38	\$0	\$98	\$15.78	
Corridor to Rest Room	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	2- F40T12/EW Energy Saving Lamps	78	0.2	51	\$35.76	\$24	\$15	\$0	\$39	\$6.31	
Main Corridor	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	2- F40T12/EW Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10	
File Room	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	4- F40T12/EW Energy Saving Lamps	156	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62	
Mens Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/EW Energy Saving Lamps	39	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17	
Open Office Area	12	4	40	2208	50	95%	2.1	479.1	\$193.97	\$142.99	\$336.56	4- F40T12/EW Energy Saving Lamps	156	1.8	407	\$286.08	\$192	\$120	\$0	\$312	\$50.48	
Mens Room Shower	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2- F40T12/EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17	
Women's Room	1	1	40	46	30	50%	0.0	6.0	\$2.13	\$1.78	\$3.91	1- F40T12/EW Energy Saving Lamps	39	0.0	5	\$3.32	\$4	\$3	\$0	\$7	\$0.59	
Breakroom	6	2	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	2- F40T12/EW Energy Saving Lamps	78	0.4	102	\$71.52	\$48	\$30	\$0	\$78	\$12.62	
Mens Room Mirror	1	1	40	46	30	50%	0.0	6.0	\$2.13	\$1.78	\$3.91	1- F40T12/EW Energy Saving Lamps	39	0.0	5	\$3.32	\$4	\$3	\$0	\$7	\$0.59	
Women's Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	2- F40T12/EW Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17	

ECO-7E
Buildings 616 - 5426
Letterkenny Army Depot
Fluorescent Lamp Retrofit

		Existing										Proposed										Implementation				
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost	Mat. Cost	Labor Cost	Eng Cost	Total Cost	Energy Savings					
Building 3311																										
Administration	18	4	40	3312	50	95%	3.1	718.7	290.95	213.89	\$504.84	1- F40T12/2W Energy Saving Lamps	156	2.7	611	\$429.11	\$288	\$180	\$0	\$668	\$75.73					
Surveillance Office #1	1	3	40	138	50	95%	0.1	29.9	12.12	\$8.91	\$21.04	1- F40T12/2W Energy Saving Lamps	117	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$3.16					
Smoke Room	2	1	40	92	50	95%	0.1	20.0	\$8.68	\$5.94	\$14.02	1- F40T12/2W Energy Saving Lamps	39	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10					
Vending Area	1	2	40	92	50	95%	0.1	20.0	\$8.68	\$5.94	\$14.02	1- F40T12/2W Energy Saving Lamps	78	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10					
Surveillance Office #2	1	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	1- F40T12/2W Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83					
Entrance Lobby	1	1	40	46	50	95%	0.0	10.0	\$4.04	\$2.97	\$7.01	1- F40T12/2W Energy Saving Lamps	99	0.0	8	\$5.96	\$4	\$0	\$0	\$7	\$1.05					
Office #9	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	1- F40T12/2W Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21					
Office #14	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Office #15	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Office #13	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Entrance #13 & #14	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	1- F40T12/2W Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21					
Office #10	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	1- F40T12/2W Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21					
Office #12	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	1- F40T12/2W Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21					
Office #11	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	1- F40T12/2W Energy Saving Lamps	78	0.1	34	\$23.84	\$16	\$10	\$0	\$26	\$4.21					
Vending Area	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	1- F40T12/2W Energy Saving Lamps	156	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24					
Office #8	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Office #9	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Office #4	12	4	40	2208	50	95%	2.1	479.1	\$193.97	\$142.59	\$336.56	1- F40T12/2W Energy Saving Lamps	156	1.8	407	\$286.08	\$192	\$120	\$0	\$312	\$50.48					
Director's Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	1- F40T12/2W Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83					
Director's Surveillance Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Office #1	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	1- F40T12/2W Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83					
Conference Room	8	4	40	1472	35	75%	1.1	223.6	\$102.09	\$66.54	\$168.63	1- F40T12/2W Energy Saving Lamps	156	0.9	190	\$143.34	\$128	\$80	\$0	\$208	\$25.29					
Office #2	6	4	40	1472	35	75%	1.1	223.6	\$102.09	\$66.54	\$168.63	1- F40T12/2W Energy Saving Lamps	156	0.9	190	\$143.34	\$128	\$80	\$0	\$208	\$25.29					
Open Office Area	30	4	40	5520	50	95%	5.2	1197.8	\$484.92	\$356.48	\$841.40	1- F40T12/2W Energy Saving Lamps	156	4.5	1,018	\$715.19	\$480	\$300	\$0	\$780	\$126.21					
Office #3	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	1- F40T12/2W Energy Saving Lamps	156	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24					
Exit Corridor	2	1	40	92	50	95%	0.1	20.0	\$8.68	\$5.94	\$14.02	1- F40T12/2W Energy Saving Lamps	39	0.1	17	\$11.92	\$8	\$5	\$0	\$13	\$2.10					
Office #5	12	4	40	2208	50	95%	2.1	479.1	\$193.97	\$142.59	\$336.56	1- F40T12/2W Energy Saving Lamps	156	1.8	407	\$286.08	\$192	\$120	\$0	\$312	\$50.48					
Insurance Corridor	8	1	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Copy and Mail Room	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	1- F40T12/2W Energy Saving Lamps	156	0.6	136	\$95.36	\$64	\$40	\$0	\$104	\$16.83					
Women's Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/2W Energy Saving Lamps	39	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Women's Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/2W Energy Saving Lamps	39	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Men's Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/2W Energy Saving Lamps	39	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Men's Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/2W Energy Saving Lamps	39	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Office #6	9	4	40	1656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	1- F40T12/2W Energy Saving Lamps	156	1.3	305	\$214.56	\$144	\$90	\$0	\$234	\$37.86					
Office #7	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Building 3315																										
Warehouse	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Managers Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Office Area	12	2	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	1- F40T12/2W Energy Saving Lamps	78	0.9	204	\$143.04	\$96	\$60	\$0	\$156	\$25.24					
Break Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Women's Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/2W Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Women's Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/2W Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Men's Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/2W Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Men's Room	2	1	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/2W Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Office #6	9	4	40	1656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	1- F40T12/2W Energy Saving Lamps	156	1.3	305	\$214.56	\$144	\$90	\$0	\$234	\$37.86					
Office #7	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Building 3321																										
Hunter Check-In	3	1	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	1- F40T12/2W Energy Saving Lamps	39	0.1	25	\$17.88	\$12	\$8	\$0	\$20	\$3.16					
Meeting Room	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	78	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Meeting Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Meeting Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Locker Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	1- F40T12/2W Energy Saving Lamps	156	0.3	68	\$47.68	\$32	\$20	\$0	\$52	\$8.41					
Building 5426																										
Warehouse	7	4	40	1288	50	95%	1.2	279.5	\$113.15	\$83.18	\$106.33	1- F40T12/2W Energy Saving Lamps	156	1.0	238	\$166.88	\$112	\$70	\$0	\$182	\$29.45					
Office	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/2W Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Men's Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/2W Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
Women's Room	1	2	40	92	30	50%	0.0	12.0	\$4.25	\$3.56	\$7.82	1- F40T12/2W Energy Saving Lamps	78	0.0	10	\$6.65	\$8	\$5	\$0	\$13	\$1.17					
TOTALS																										
APROJECTS413601USSECONC07EWEK4		1104		151099			139.5	44856	\$13,000	\$13,000	\$26,000			118.5	3811	\$22,000	\$13,000	\$8,000	\$0	\$21,000	\$4,000					
22 May 95																										

GA PROJECT 75413601SSSECO/TEWK4

ECO-8

Efficient Fluorescent Fixture Replacement

Existing.

Seventy buildings at the Letterkenny Army Depot contain approximately 6,660 fluorescent luminaires of various types. The total watts for the existing luminaires is 942,563 watts. The luminaires operate between 50 and 168 hours per week and contribute approximately 95% of their connected load to the demand. The annual electric demand, usage, and cost for these fixtures are as follows:

$$\text{Electric Demand} = 10,744 \text{ kW/yr } (895.3 \text{ kW/mo} \times 12 \text{ mo/yr})$$

$$\text{Electric Usage} = 3,411,696 \text{ kWh/yr } (284,308 \text{ kWh/mo} \times 12 \text{ mo/yr})$$

$$\begin{aligned} \text{Electric Cost} &= \$169,000 (10,744 \text{ kW/yr} \times \$7.706/\text{kW}) + (3,411,696 \text{ kWh/yr} \times \$0.0248/\text{kWh}) = \\ & \$167,403, \text{ use } \$169,000 \end{aligned}$$

Proposed.

Remove the luminaires and install new luminaires with T-8 lamps and electronic ballast. Reference the attached data tables for ECO-8. The annual electric demand, usage, and cost of the proposed ECO is noted below:

$$\text{Electric Demand} = 6,676 \text{ kW/yr } (556.3 \text{ kW/mo} \times 12 \text{ mo/yr})$$

$$\text{Electric Usage} = 2,114,736 \text{ kWh/yr } (176,228 \text{ kWh/mo} \times 12 \text{ mo/yr})$$

$$\begin{aligned} \text{Electric Cost} &= \$104,000 (6,676 \text{ kW/yr} \times \$7.706/\text{kW}) + (2,114,736 \text{ kWh/yr} \times \$0.0248/\text{kWh}) = \\ & \$103,891, \text{ use } \$104,000 \end{aligned}$$

Implementation Cost. The expected construction cost for implementing the project is expected to be \$879,000. The breakdown is noted below and shown on the attached ECO data sheet.

Material	\$414,000
Labor	\$371,000
Engineering	<u>\$ 94,000</u>
Total	\$879,000

Energy Savings. The annual electric demand, usage, and cost saved is noted below:

Electric Demand	=	4,068 kW/yr (10,744 - 6,676)
Electric Usage	=	1,296,960 kWh/yr (3,411,696 - 2,114,736)
Energy Cost	=	\$63,000/yr (\$169,000 - \$104,000) (use \$63,000 due to rounding)
Annual Energy Savings	=	4,426 mmBtu/yr
Energy Usage	=	4,426 mmBtu/yr (1,296,960 kWh/yr x 3,413 Btu/kWh) ÷ 1,000,000 Btu/mmBtu

Maintenance Savings. The T-8 lamps have the same rated average life as the existing T-12 lamps, 20,000 hours; therefore, there is no annual recurring maintenance savings. The installation of new luminaires will reduce the existing required lamp and ballast changes, since all new lamps and ballast are being installed.

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations, construction supervision, and annual recurring maintenance costs in addition to construction cost and engineering services. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 14.6 years with a savings to investment ratio of 1.21.

This ECO will maintain existing light levels while using less energy.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO8

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO8

ANALYSIS DATE: 04-19-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	785000.	
B. SIOH	\$	43175.	
C. DESIGN COST	\$	94000.	
D. TOTAL COST (1A+1B+1C)	\$	922175.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$	922175.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	4426.	\$ 32177.	18.17	\$ 584656.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 31000.	17.22	\$ 533820.
N. TOTAL		4426.	\$ 63177.		\$ 1118476.

3. NON ENERGY SAVINGS(+) / COST(-)

A. ANNUAL RECURRING (+/-)		\$	0.
(1) DISCOUNT FACTOR (TABLE A)	17.22		
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$	0.

B. NON RECURRING SAVINGS(+) / COSTS(-)

ITEM	SAVINGS(+) COST(-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS(+)/ COST(-) (4)
d. TOTAL	\$ 0.			0.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ 0.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 63177.

5. SIMPLE PAYBACK PERIOD (1G/4) 14.60 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 1118476.

7. SAVINGS TO INVESTMENT RATIO (SIR) = (6 / 1G) = 1.21
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 3.90 %

**Summary ECO8A - ECO8E
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement**

Room	NO. Of Luminaires	Existing										Proposed				Implementation						Energy Savings \$																			
		Lamps Per Luminaire	Watts Per Luminaire	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Bag Cost \$	Total Cost \$																					
ECO-8A Summary	3374			461392			438.3	138096	\$41,000	\$41,000	\$82,000			276.0	86426	\$51,000	\$209,000	\$193,000	\$48,000	\$451,000	\$30,000																				
ECO-8B Summary	521			73071			69.4	20734	\$6,000	\$6,000	\$13,000			40.8	11968	\$7,000	\$31,000	\$27,000	\$7,000	\$65,000	\$5,000																				
ECO-8C Summary	1073			165278			156.9	57100	\$15,000	\$17,000	\$32,000																														
ECO-8D Summary	757			109940			104.4	27528	\$10,000	\$8,000	\$18,000						\$20,000	\$58,000	\$15,000	\$143,000	\$12,000																				
ECO-8E Summary	935			132883			126.2	40850	\$12,000	\$12,000	\$24,000						\$11,000	\$43,000	\$10,800	\$100,000	\$6,700																				
														77.6	25224	\$15,000	\$57,000	\$50,000	\$13,000	\$120,000	\$9,000																				
TOTALS	6660			942563			895.3	284308	\$84,000	\$84,000	\$169,000						\$104,000	\$414,000	\$371,000	\$84,000	\$879,000	\$63,000																			
CAPROJECTSH13001NSSECOECO_AWK4																																									22-Mar-95

G:\PROJECTS\41300\ISSUE\ECO 8A.WK4

23 May 95

ECO-8A
Buildings 1 - 10
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Existing										Proposed										Implementation				
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand On Peak	Usage Kwh Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$			
Building 1																								
Office Area																								
Office	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86			
Chief Engineering Support Office	3	3	40	414	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24			
Engineering Work Area	113	3	40	15594	50	95%	14.8	388.9	\$1,007.91	\$736.96	\$1,744.87	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	9.4	2,158	\$1,515.74	\$6,950	\$6,498	\$1,614	\$15,061	\$861.22			
DPME Section Office	8	4	40	1472	50	95%	1.4	319.4	\$1,007.91	\$736.96	\$1,744.87	Recessed 2x4, 3L, T8 Fluorescent Ballast	112	0.9	194	\$1,365.58	\$5,512	\$4,600	\$1,177	\$1,089	\$37.80			
Production Engineering Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$553	\$30.49			
Chief Production Eng. Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24			
Conference Room Corridor	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 3L, T8 Fluorescent Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95			
DPME File Room	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Industrial 4', 2L, T8 Fluorescent Ballast	112	0.1	24	\$17.07	\$55	\$46	\$12	\$113	\$10.97			
DPME Work Area	18	4	40	2484	50	95%	2.4	330.0	\$218.22	\$160.41	\$378.63	Recessed 2x4, 3L, T8 Fluorescent Ballast	112	1.5	344	\$241.45	\$1,107	\$1,035	\$257	\$2,399	\$137.18			
DPME Copy Room	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.03	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.1	19	\$13.41	\$62	\$58	\$14	\$133	\$7.62			
Chief Requisition Office	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86			
Logistics Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24			
Production Planning Conf. Rm.	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 3L, T8 Fluorescent Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95			
Chief Production Office	5	4	40	920	50	95%	0.9	199.6	\$80.82	\$59.41	\$140.23	Recessed 2x4, 3L, T8 Fluorescent Ballast	112	0.5	122	\$85.36	\$320	\$288	\$73	\$681	\$21.87			
Chief Maintenance Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24			
Manager Analysis Office	10	1	40	460	50	95%	0.4	99.8	\$40.41	\$29.71	\$70.12	Surface wraparound, 1L, T8 Fluorescent Ballast	31	0.3	67	\$47.25	\$506	\$328	\$100	\$934	\$27.86			
Deputy Director Maint. Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24			
Director Maintenance Office	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86			
Corridor A	16	1	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Surface wraparound, 1L, T8 Fluorescent Ballast	31	0.5	108	\$75.60	\$810	\$524	\$160	\$1,494	\$36.58			
Corridor A Entrance Lobby	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	Industrial 4', 2L, T8 Fluorescent Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88			
Chrome Plate Area (CP)	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L, T8 Fluorescent Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76			
CP Office	2	4	40	1472	50	95%	1.4	319	\$1,007.91	\$736.96	\$1,744.87	Pendant 1x4, 4L, T8 Fluorescent Ballast	112	1.4	194	\$1,365.58	\$5,512	\$4,600	\$1,177	\$1,089	\$37.80			
Editors Office	13	4	40	2,392	50	95%	2.3	519	\$2,101.13	\$1,544.7	\$3,646.81	Pendant 1x4, 4L, T8 Fluorescent Ballast	112	1.9	316	\$2,211.93	\$9,100	\$7,480	\$1,990	\$1,857	\$142.67			
IBM Support Office	6	4	40	1,104	50	95%	1.0	240	\$66.66	\$47.53	\$112.19	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	0.6	146	\$102.43	\$384	\$345	\$87	\$816	\$65.85			
Record Managers Office	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	0.4	97	\$86.29	\$256	\$230	\$58	\$544	\$43.90			
Cable Area	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	0.3	73	\$51.22	\$192	\$173	\$44	\$409	\$32.92			
Receiving Bay	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	Industrial 4', 2L, T8 Fluorescent Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88			
Corridor to Rooms #2-6	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Industrial 4', 2L, T8 Fluorescent Ballast	60	0.2	52	\$36.58	\$180	\$184	\$44	\$408	\$19.51			
CP Shop Area B	2	75	40	4,830	50	95%	4.6	1,048	\$2,424.31	\$1,711.92	\$3,136.23	Industrial 8', 2L, T8 Fluorescent Ballast	104	2.8	632	\$4,437.87	\$17,870	\$14,820	\$3,920	\$2,920.36	\$1,075.31			
CP Shop Area A	63	2	75	10,868	50	95%	10.3	2,358	\$9,541.69	\$7,018.81	\$15,560.51	Industrial 8', 2L, T8 Fluorescent Ballast	104	6.2	1,422	\$9,981.71	\$40,950	\$37,890	\$8,060	\$6,820	\$1,075.31			
CP Shop Area A	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	Industrial 4', 2L, T8 Fluorescent Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88			
CP Shop Area B	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	Industrial 4', 2L, T8 Fluorescent Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88			
CP Text Lobby	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Industrial 4', 2L, T8 Fluorescent Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88			
Corridor to Cule	6	4	20	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x2, 4L, T8 Fluorescent Ballast	65	0.4	85	\$59.45	\$408	\$276	\$82	\$766	\$24.69			
Building 2																								
Administration																								
South Entrance #2 Open Office	12	3	40	1,656	50	95%	1.6	359	\$1,455.48	\$1,069.94	\$2,524.42	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	1.0	229	\$1,600.96	\$738	\$690	\$171	\$1,599	\$91.46			
G. Kirk Office	8	4	40	1,472	50	95%	1.4	319	\$1,007.91	\$736.96	\$1,744.87	Pendant 1x4, 4L, T8 Fluorescent Ballast	112	0.9	194	\$1,365.58	\$5,560	\$4,600	\$1,171	\$1,599	\$87.80			
Movement Branch Mgrs. Office	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	0.4	97	\$86.29	\$256	\$230	\$58	\$544	\$43.90			
Industrial Hygiene	36	4	40	6,624	50	95%	6.3	1,437	\$591.91	\$427.77	\$1,019.68	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	3.8	875	\$6,145.59	\$2,304	\$2,070	\$525	\$4,899	\$395.09			
South Entrance #2 Office	10	3	40	1,380	50	95%	1.3	299	\$1,211.23	\$891.12	\$2,103.35	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.8	191	\$1,341.14	\$615	\$575	\$143	\$1,331	\$76.21			
Entrance Lobby South East	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24			
Director/Commander Reception	9	4	40	1,656	50	95%	1.6	359	\$1,455.48	\$1,069.94	\$2,524.42	Pendant 1x4, 2L, T8 Fluorescent Ballast	60	0.1	13	\$9.15	\$60	\$58	\$14	\$132	\$4.88			
South Entrance Lobby #1	5	3	40	690	50	95%	0.7	153	\$60.62	\$44.56	\$105.18	Pendant 1x4, 4L, T8 Fluorescent Ballast	112	1.0	219	\$1,535.65	\$630	\$518	\$138	\$1,286	\$98.77			
South East Open Office Area	18	4	40	3,312	50	95%	3.1	719	\$2,990.95	\$2,138.89	\$5,048.84	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.4	95	\$67.07	\$308	\$288	\$71	\$666	\$38.11			
Middle Office	8	4	40	1,472	50	95%	1.4	319	\$1,007.91	\$736.96	\$1,744.87	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	1.9	437	\$3,072.29	\$1,152	\$1,035	\$262	\$2,449	\$197.55			
Open Office Area	4	40	18,032	50	95%	17.1	3,913	\$1,584.08	\$1,164.49	\$2,748.57	Pendant 1x4, 4L, T8 Fluorescent Ballast	112	0.9	194	\$1,365.58	\$5,560	\$4,600	\$1,172	\$1,442	\$87.80				
Commanders Office	98	4	40	18,032	50	95%	17.1	3,913	\$1,584.08	\$1,164.49	\$2,748.57	Pendant 1x4, 4L, T8 Fluorescent Ballast	112	10.4	2,382	\$1,673.05	\$6,860	\$5,635	\$1,499	\$1,994	\$107.53			
Directors Office	6	4	40	1,472	50	95%	1.4	319	\$1,007.91	\$736.96	\$1,744.87	Pendant 1x4, 4L, T8 Fluorescent Ballast	112	0.9	194	\$1,365.58	\$5,560	\$4,600	\$1,172	\$1,442	\$87.80			
Entrance Lobby South West	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	Pendant 1x4, 4L, T8 Fluorescent Ballast	112	0.6	146	\$102.43	\$420	\$345	\$92	\$857	\$65.85			
Building 3																								
Computer Area																								
Library	25	3	40	3,450	126	95%	3.3	1,887	\$3,030.08	\$2,161.45	\$6,191.53	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	2.1	1,203	\$551.29	\$1,538	\$1,438	\$357	\$3,332	\$131.23			
Computer Office 132	4	3	40	552	126	95%	0.5	302	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	192	\$88.21	\$246	\$230	\$57	\$553	\$50.12			
Vault	8	4	40	1,472	50	95%	1.4	319	\$1,007.91	\$736.96	\$1,744.87	Pendant 1x4, 4L, T8 Fluorescent Ballast	112	0.9	194	\$1,365.58	\$5,560	\$4,600	\$1,172	\$1,442	\$87.80			
Raised Floor Computer Rm. #8	4	40	1,104	126	95%	1.0	604	\$66.66	\$47.53	\$123.19	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	0.6	367	\$168.40	\$584	\$545	\$87	\$816	\$118.25				
Raised Floor Computer Center	34	4	40	6,256	126	95%	5.9	3,421	\$1,018.09	\$1,563.07	\$3,581.16	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	3.6	2,082	\$954.24	\$2,176	\$1,955	\$496	\$4,677				

ECO-8A
Buildings 1 - 10
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Room	NO Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Existing				Proposed										Implementation				Energy Savings \$
				Hours Per Week	Percent On Kw	Demand Kw	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost (\$)	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost (\$)	Mac Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$			
Raised Floor Computer Rm. #3	65	4	40	11,960	126	95%	6540	\$1,050.07	\$1,946.37	\$2,997.03	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	6.9	3,981	\$1,231.28	\$4,160	\$3,738	\$948	\$8,846	\$1,172.75		
Raised Floor Computer Rm. #6	76	4	40	13,984	126	95%	7647	\$1,228.47	\$2,275.73	\$3,504.22	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	8.1	4,655	\$1,521.00	\$4,864	\$4,370	\$1,108	\$10,342	\$1,371.22		
Raised Floor Comp. Ctr. Office	9	4	40	1,656	126	95%	906	\$149.48	\$269.50	\$414.97	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	1.0	551	\$181.25	\$576	\$518	\$131	\$1,225	\$162.38		
Raised Floor Computer Rm. #5	64	4	40	11,776	126	95%	6440	\$1,034.50	\$1,916.42	\$2,950.02	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	6.8	3,920	\$1,296.21	\$4,096	\$3,680	\$923	\$8,709	\$1,154.71		
Raised Floor Computer Rm. #7	55	4	40	10,120	126	95%	5534	\$889.03	\$1,646.92	\$2,555.95	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	5.9	3,369	\$1,143.62	\$3,520	\$3,106	\$802	\$7,428	\$992.33		
Raised Floor Computer Rm. #6A	6	4	40	1,104	126	95%	604	\$96.98	\$179.66	\$276.05	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	0.6	367	\$126.40	\$384	\$345	\$87	\$816	\$108.25		
Computer Office 132A	24	4	40	4,416	126	95%	2415	\$387.94	\$718.66	\$1,106.60	Recessed 2x4, 4L, T8 Fluorescent Ballast	112	2.6	1,470	\$673.58	\$1,536	\$1,380	\$350	\$3,266	\$433.02		
South East Area																						
Office 1-K	6	3	40	828	50	95%	180	\$72.74	\$53.47	\$126.21	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.5	115	\$80.48	\$369	\$345	\$86	\$800	\$45.73		
Office 6-F	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Office 6-J	3	3	40	414	50	95%	90	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86		
Open Office Area 7-G	39	3	40	5,382	50	95%	1168	\$472.80	\$347.57	\$820.37	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	3.3	745	\$252.13	\$2,399	\$2,243	\$557	\$5,198	\$297.23		
Room #120 1-H	2	2	40	184	50	95%	40	\$16.16	\$11.88	\$28.05	Recessed 2x4, 3L, T8 Fluorescent Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76		
Office 5-F	4	3	40	552	50	95%	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49		
Automation Open Area 10-H	25	3	40	3,450	50	95%	749	\$933.08	\$222.80	\$525.88	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	2.1	477	\$335.34	\$1,538	\$1,438	\$357	\$3,332	\$190.53		
Office 7-F	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Office 2-I	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
DMC Office 8-J	3	3	40	414	50	95%	90	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86		
Room #130 10-J	24	3	40	3,312	50	95%	719	\$290.95	\$213.89	\$504.84	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	2.0	458	\$321.93	\$1,476	\$1,380	\$343	\$3,109	\$182.91		
Open Office Area 13-G	3	3	40	414	50	95%	90	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86		
Office 1-G	1	3	40	138	50	95%	30	\$12.12	\$8.91	\$21.04	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.1	19	\$13.41	\$62	\$58	\$14	\$133	\$7.62		
DMC Open Area 4-F	70	3	40	9,660	50	95%	2096	\$948.63	\$633.84	\$1,472.45	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	5.9	1,377	\$948.95	\$4,305	\$4,025	\$1,000	\$9,330	\$533.50		
Office 1-J	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Office 2-K	6	3	40	828	50	95%	180	\$72.74	\$53.47	\$126.21	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.5	115	\$80.48	\$369	\$345	\$86	\$800	\$45.73		
Office 3-K	7	3	40	966	50	95%	210	\$84.86	\$62.38	\$147.25	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.5	115	\$80.48	\$369	\$345	\$86	\$800	\$45.73		
Office 4-K	12	4	40	2,208	50	95%	479	\$193.97	\$142.59	\$336.56	Pendant 1x4, 4L, T8 Fluorescent Ballast	88	0.6	134	\$93.90	\$431	\$403	\$100	\$933	\$53.35		
Snack Bar 9-K	4	2	40	368	50	95%	80	\$32.33	\$23.77	\$56.09	Industrial 4', 2L, T8 Fluorescent Ballast	112	1.3	292	\$204.86	\$840	\$690	\$184	\$1,714	\$131.70		
Snack Bar 10-K	6	3	40	828	50	95%	180	\$72.74	\$53.47	\$126.21	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.5	115	\$80.48	\$369	\$345	\$86	\$800	\$45.73		
Room #8 12-J	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Industrial 4', 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Stairwell Lobby 11-K	14	2	40	1,288	50	95%	279	\$113.15	\$83.18	\$196.33	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.8	182	\$128.04	\$805	\$805	\$193	\$1,803	\$68.29		
Open Office 14-K	24	3	40	3,312	50	95%	719	\$290.95	\$213.89	\$504.84	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	2.0	458	\$321.93	\$1,476	\$1,380	\$343	\$3,199	\$182.91		
Corridor 14-L	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Office 1-F	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
South West Area																						
Room #109 6-A	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Office 5-A	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Room #111 6-A	3	3	40	414	50	95%	90	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86		
Room #105 8-A	4	3	40	552	50	95%	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49		
Room #107 7-A	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Office Rear 4-B	4	3	40	552	50	95%	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49		
Corridor 5-10-B	10	2	40	920	50	95%	200	\$80.82	\$59.41	\$140.23	Recessed 2x4, 3L, T8 Fluorescent Ballast	60	0.6	130	\$91.46	\$575	\$575	\$138	\$1,288	\$48.78		
Office 5-B	4	3	40	552	50	95%	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49		
Office Front 4-B	3	3	40	414	50	95%	90	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49		
Office A 2-D	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Corridor 4-1-C	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Office B 2-D	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Office 2-C	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Room #117 Front 2-B	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Office 4-B	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Office Rear 2-B	3	3	40	414	50	95%	90	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86		
Room #117 Rear 2-B	2	3	40	276	50	95%	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24		
Office Front 3-B	3	3	40	414	50	95%	90	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86		
Office 2-E	1	3	40	138	50	95%	30	\$12.12	\$8.91	\$21.04	Recessed 2x4, 3L, T8 Fluorescent Ballast	88	0.1	19	\$13.41	\$62	\$58	\$14	\$133	\$7.62		

ECO-8A
Buildings 1 - 10
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Existing										Proposed										Implementation									
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Off Kw On Peak	Demand On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost	Mt. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings								
North West Area																													
Office 19 E	5	3	40	690	50	95%	0.7	150	\$60.62	\$44.56	\$105.18	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.4	95	\$67.07	\$308	\$288	\$71	\$666	\$38.11								
Office 26 E	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, 18" Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90								
Office 26 D	6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Recessed 2x4, 4L, 18" Fluorescent Ballast	112	0.6	146	\$102.43	\$384	\$246	\$38	\$816	\$65.85								
Office 26 C	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$220	\$57	\$553	\$30.49								
Office 26 B	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, 18" Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90								
Office 24 A	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, 18" Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90								
Office 21 A	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86								
Lobby 25 A	7	4	40	1,288	50	95%	1.2	279	\$113.15	\$83.18	\$196.33	Recessed 2x4, 4L, 18" Fluorescent Ballast	112	0.7	170	\$119.50	\$448	\$403	\$102	\$953	\$76.82								
Office 19 A	7	3	40	966	50	95%	0.9	210	\$84.86	\$62.38	\$147.25	Recessed 2x4, 4L, 18" Fluorescent Ballast	88	0.6	134	\$93.90	\$431	\$403	\$100	\$933	\$53.35								
Office 23 A	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$553	\$30.49								
Office 21 D	6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Recessed 2x4, 4L, 18" Fluorescent Ballast	112	0.6	146	\$102.43	\$384	\$246	\$38	\$816	\$65.85								
Open Office Area 25-19-A	111	3	40	15,318	50	95%	14.6	3324	\$1,345.66	\$989.22	\$2,334.89	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	9.3	2,120	\$1,488.91	\$6,827	\$6,383	\$1,585	\$14,794	\$845.97								
North East Area																													
Office 21-G	6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Recessed 2x4, 4L, 18" Fluorescent Ballast	112	0.6	146	\$102.43	\$384	\$246	\$38	\$816	\$65.85								
Office 16-K	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$553	\$30.49								
Office A 21-F	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 4L, 18" Fluorescent Ballast	112	0.3	73	\$51.22	\$192	\$173	\$44	\$409	\$32.92								
Office B 21-F	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 4L, 18" Fluorescent Ballast	112	0.3	73	\$51.22	\$192	\$173	\$44	\$409	\$32.92								
Office 21-H	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 26-H	8	3	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.7	153	\$107.31	\$492	\$460	\$114	\$1,066	\$60.97								
Office 22-H	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 26-J	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-J	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-K	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-L	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-M	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-N	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-O	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-P	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-Q	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-R	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-S	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-T	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-U	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-V	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-W	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-X	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-Y	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 22-Z	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office 23-J	12	3	40	1,656	50	95%	1.6	359	\$145.48	\$106.94	\$252.42	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	1.6	359	\$106.94	\$507.98	\$475.30	\$110	\$1,030	\$39.02								
Office 16 J	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.3	73	\$51.22	\$192	\$173	\$44	\$409	\$32.92								
Office 17 J	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.3	73	\$51.22	\$192	\$173	\$44	\$409	\$32.92								
Office 21 J	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$553	\$30.49								
Office 17-K	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.5	115	\$80.48	\$369	\$345	\$86	\$800	\$45.73								
Office A 22-J	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
Office B 22-J	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$553	\$30.49								
Office Office Area 26-18-K	40	3	40	5,520	50	95%	5.2	1198	\$484.92	\$356.48	\$841.40	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	3.3	764	\$536.55	\$2,460	\$2,300	\$571	\$5,331	\$304.86								
Open Office Area 25-J	14	3	40	1,932	50	95%	1.8	419	\$169.72	\$124.77	\$294.49	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	1.2	267	\$187.79	\$861	\$805	\$200	\$1,866	\$106.70								
Open Office Area 25-F	57	3	40	7,866	50	95%	7.5	1707	\$691.02	\$507.98	\$1,199.00	Recessed 2x4, 3L, 18" Fluorescent Ballast	88	4.8	1,088	\$764.58	\$3,506	\$3,278	\$814	\$7,597	\$454.42								
Building 4																													
Warehouse	8	2	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 2L, 18" Fluorescent Ballast	60	0.5	104	\$73.17	\$460	\$460	\$110	\$1,030	\$39.02								
Warehouse Packaging Office																													
Building 5																													
Administration																													
Book Office	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 4L, 18" Fluorescent Ballast	112	0.3	73	\$51.22	\$192	\$173	\$44	\$409	\$32.92								
Open Office Area	126	2	40	11,592	50	95%	11.0	2515	\$1,018.34	\$748.60	\$1,766.94	Recessed 2x4, 2L, 18" Fluorescent Ballast	60	7.2	1,641	\$1,152.35	\$7,245	\$7,245	\$1,739	\$16,229	\$614.59								
West Entrance Lobby	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L, 18" Fluorescent Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76								
Product Receipt Office	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Recessed 2x4, 2L, 18" Fluorescent Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95								
Snider Office	9	4	40	1,656	50	95%	1.6																						

ECO-8A
Buildings 1 - 10
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Room		Existing										Proposed				Implementation					Energy Savings	
		NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$		
Building 10																						
Computer Area																						
Computer Room	146	3	40	20,148	126	95%	19.1	11018	\$1,729.97	\$3,278.88	\$5,048.85	Pendant 1x4, 3L-18 Fluorescent Ballast	88	12.2	7,026	\$3,219.55	\$9,490	\$8,395	\$2,146	\$20,031	\$1,829.29	
Tape Library	8	4	40	1,472	84	95%	1.4	537	\$159.70	\$289.01	\$159.70	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.9	327	\$175.92	\$512	\$460	\$117	\$1,089	\$113.09	
Classified Tape Library	8	2	40	736	84	95%	0.7	268	\$64.66	\$79.85	\$144.51	Surface 1x4, 2L-18 Fluorescent Ballast	60	0.5	175	\$94.24	\$338	\$300	\$101	\$939	\$103.26	
Page Printing Room	22	3	40	3,036	126	95%	2.9	1660	\$666.71	\$458.05	\$760.79	Pendant 1x4, 3L-18 Fluorescent Ballast	88	1.8	1,059	\$485.14	\$1,430	\$1,265	\$323	\$3,018	\$275.65	
South East Area																						
Office 9-A	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.3	78	\$54.87	\$345	\$345	\$83	\$773	\$29.27	
Open Office Area 9-14 E	188	2	40	17,296	50	95%	16.4	3753	\$1,519.43	\$1,116.96	\$2,636.39	Pendant 1x4, 2L-18 Fluorescent Ballast	60	10.7	2,448	\$1,719.38	\$11,280	\$10,810	\$2,651	\$24,741	\$917.00	
Office 9-B	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$38	\$544	\$43.90		
Office 10-B	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76		
Office 11-B	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.2	52	\$36.58	\$230	\$230	\$55	\$515	\$19.51	
Office A 9-A	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.3	78	\$54.87	\$345	\$345	\$83	\$773	\$29.27	
Office 14-A	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.2	52	\$36.58	\$230	\$230	\$55	\$515	\$19.51	
Office B 10-A	3	2	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.2	39	\$27.44	\$173	\$173	\$41	\$386	\$14.63	
Office A 10-A	8	2	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.5	104	\$73.17	\$460	\$460	\$110	\$1,030	\$39.02	
Office 11-A	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.2	52	\$36.58	\$230	\$230	\$55	\$515	\$19.51	
Entrance Lobby	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76	
South West Area																						
Open Office Area 9-16 J	214	2	40	19,688	50	95%	18.7	4272	\$1,729.56	\$1,271.44	\$3,000.99	Pendant 1x4, 2L-18 Fluorescent Ballast	60	12.2	2,786	\$1,957.17	\$12,840	\$12,305	\$3,017	\$28,162	\$1,043.82	
Office 9-K	3	2	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.2	39	\$27.44	\$173	\$173	\$41	\$386	\$14.63	
Office 9-K	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	Recessed 2x4, 3L-18 Fluorescent Ballast	88	0.1	19	\$13.41	\$62	\$58	\$14	\$133	\$7.62	
Office 10-K	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.2	52	\$36.58	\$230	\$230	\$55	\$515	\$19.51	
Office 11-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90	
Office 12-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90	
Office 13-K	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Pendant 1x4, 2L-18 Fluorescent Ballast	60	0.3	78	\$54.87	\$345	\$345	\$85	\$790	\$29.27	
North East Area																						
Open Office Area 2-8 E	247	2	40	22,724	50	95%	21.6	4931	\$1,996.27	\$1,467.50	\$3,463.76	Pendant 1x4, 2L-18 Fluorescent Ballast	60	14.1	3,216	\$2,258.98	\$14,820	\$14,203	\$3,483	\$32,506	\$1,204.79	
Office 1-E	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95	
Office 1-E	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-18 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49	
Office 1-D	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-18 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49	
Office 1-C	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-18 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49	
Smokers Room 6-A	16	2	40	1,472	50	95%	1.4	519	\$129.31	\$159.70	\$224.37	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.9	208	\$146.33	\$920	\$920	\$221	\$2,061	\$78.04	
Computer Room 1-A	20	2	40	1,840	50	95%	1.7	999	\$161.64	\$118.83	\$280.47	Recessed 2x4, 2L-18 Fluorescent Ballast	60	1.1	260	\$182.91	\$1,150	\$1,150	\$276	\$2,576	\$97.55	
Male 5-B	8	3	40	1,040	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Pendant 1x4, 3L-18 Fluorescent Ballast	88	0.7	153	\$102.31	\$320	\$320	\$118	\$1,098	\$60.97	
Vending Area 5-B	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Pendant 1x4, 3L-18 Fluorescent Ballast	60	0.2	52	\$36.58	\$240	\$230	\$56	\$526	\$19.51	
Office 8-A	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.3	78	\$54.87	\$345	\$345	\$83	\$773	\$29.27	
North West Area																						
Office 5-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90	
Office 8-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90	
Office 7-K	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-18 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49	
Office 1-B K	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-18 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49	
Office A 6-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90	
Office 3-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90	
Office 4-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90	
Office 1-G	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-18 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49	
Office 2-K	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	Recessed 2x4, 3L-18 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49	
Office 1-H	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-18 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49	
Office 1-F	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-18 Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49	
TOTALS																						
														276.0	86426	\$51,000	\$209,000	\$193,000	\$48,000	\$451,000	\$30,000	
C:\PROJECTS\TSM\B\JUNSS\CONCO_8A.WK4																						
														22-May-95								

ECO-8B
Buildings 14 - 57
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Existing										Proposed										Implementation				
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost	Mtl. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings \$			
Building 14																								
First Floor																								
Receiving Room	15	3	40	2070	50	95%	2.0	449.2	\$181.85	\$133.68	\$315.53	Industrial 4', 3L-T8 Elec Ballast	88	1.3	286	\$201.20	\$750	\$690	\$173	\$1,613	\$114.32			
Sand Blast Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Industrial 4', 3L-T8 Elec Ballast	88	0.2	38	\$26.83	\$100	\$92	\$23	\$215	\$15.24			
Machine Shop Breakroom	7	4	40	1288	50	95%	1.2	279.5	\$113.15	\$83.18	\$196.33	Pendant 1x4, 4L-T8 Elec Ballast	112	0.7	170	\$119.50	\$490	\$403	\$107	\$1,000	\$76.82			
Machine Shop Office	3	2	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Industrial 4', 2L-T8 Elec Ballast	60	0.2	39	\$27.44	\$135	\$138	\$33	\$306	\$14.63			
Quality Control/Shop Area	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Pendant 1x4, 4L-T8 Elec Ballast	112	0.4	97	\$68.29	\$280	\$230	\$61	\$571	\$43.90			
Quality Control/Shop Area	6	3	40	828	50	95%	0.8	179.7	\$72.74	\$53.47	\$126.21	Industrial 4', 3L-T8 Elec Ballast	88	0.5	115	\$80.48	\$300	\$276	\$69	\$645	\$45.73			
Optical Shop	14	4	40	2576	50	95%	2.4	559.0	\$226.30	\$166.36	\$392.65	Industrial 4', 4L-T8 Elec Ballast	112	1.5	340	\$239.01	\$770	\$644	\$170	\$1,584	\$153.65			
Building 19																								
Warehouse																								
Exterior Office	5	2	40	460	50	95%	0.4	99.8	\$40.41	\$29.71	\$70.12	Surface wraparound, 1L-T8 Elec Ballast	31	0.1	34	\$23.63	\$253	\$164	\$50	\$467	\$46.49			
Warehouse North West Area	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	Industrial 4', 3L-T8 Elec Ballast	88	0.1	19	\$13.41	\$50	\$46	\$12	\$108	\$7.62			
Warehouse Work Area	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Pendant 1x4, 4L-T8 Elec Ballast	112	0.1	24	\$17.07	\$70	\$58	\$15	\$143	\$10.97			
Building TS20-1																								
Warehouse																								
Office	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L-T8 Elec Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95			
Building 31																								
Warehouse																								
Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Industrial 4', 3L-T8 Elec Ballast	88	0.2	38	\$26.83	\$100	\$92	\$23	\$215	\$15.24			
Receiving Area	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	Industrial 4', 2L-T8 Elec Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88			
Building 32																								
Warehouse																								
Receiving Area	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Industrial 4', 3L-T8 Elec Ballast	88	0.3	57	\$40.24	\$150	\$138	\$35	\$323	\$22.86			
Office	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Industrial 4', 2L-T8 Elec Ballast	60	0.1	26	\$18.29	\$90	\$92	\$22	\$204	\$9.76			
Building 33N																								
Warehouse																								
Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Pendant 1x4, 3L-T8 Elec Ballast	88	0.3	57	\$40.24	\$195	\$173	\$44	\$412	\$22.86			
Receiving Area	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Industrial 4', 2L-T8 Elec Ballast	60	0.1	26	\$18.29	\$90	\$92	\$22	\$204	\$9.76			
Fenced Area in Warehouse	2	2	75	345	50	95%	0.3	75	\$30.31	\$22.28	\$52.59	Industrial 8', 2L-T8 Elec Ballast	104	0.2	45	\$31.70	\$130	\$120	\$30	\$280	\$20.88			
Fenced Area in Warehouse	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Surface, 1x4, 2L-T8 Elec Ballast	60											
Building 34																								
Warehouse																								
Warehouse	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	Industrial 4', 3L-T8 Elec Ballast	88	0.1	19	\$13.41	\$50	\$46	\$12	\$108	\$7.62			
Warehouse Elec. Dist. Equip.	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Industrial 4', 2L-T8 Elec Ballast	60	0.1	26	\$18.29	\$90	\$92	\$22	\$204	\$9.76			
Office South	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Industrial 4', 3L-T8 Elec Ballast	88	0.2	38	\$26.83	\$100	\$92	\$23	\$215	\$15.24			
Building 37																								
Modular																								
Modular Office-Powertrain #1	3	4	40	552	90	95%	0.5	216	\$88.49	\$64.17	\$112.66	Pendant 1x4, 4L-T8 Elec Ballast	112	0.3	131	\$68.57	\$210	\$173	\$46	\$429	\$44.08			
Modular Office-Powertrain #2	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	Pendant 1x4, 4L-T8 Elec Ballast	112	0.4	175	\$91.43	\$280	\$220	\$61	\$571	\$38.78			
Modular Office-Powertrain #3	3	4	40	552	90	95%	0.5	216	\$88.49	\$64.17	\$112.66	Pendant 1x4, 4L-T8 Elec Ballast	112	0.3	131	\$68.57	\$210	\$173	\$46	\$429	\$44.08			
Motor Room Office	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	Pendant 1x4, 4L-T8 Elec Ballast	112	0.4	175	\$91.43	\$280	\$230	\$61	\$571	\$38.78			
Motor Room Test Area	2	4	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	Pendant 1x4, 4L-T8 Elec Ballast	112	0.2	87	\$45.72	\$140	\$115	\$31	\$286	\$29.39			
Motor Room Box Office	3	4	40	552	90	95%	0.5	216	\$88.49	\$64.17	\$112.66	Recessed 2x4, 4L-T8 Elec Ballast	112	0.3	131	\$68.57	\$192	\$173	\$44	\$409	\$44.08			
Building 37 Office	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	Recessed 2x4, 4L-T8 Elec Ballast	112	0.4	175	\$91.43	\$256	\$173	\$44	\$409	\$44.08			
Building Supply 47	2	4	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	Recessed 2x4, 4L-T8 Elec Ballast	112	0.2	87	\$45.72	\$128	\$115	\$29	\$272	\$21.95			
Breakroom	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	Recessed 2x4, 4L-T8 Elec Ballast	112	0.4	175	\$91.43	\$256	\$230	\$61	\$571	\$38.78			
Disassembly Office	5	2	40	460	90	95%	0.4	180	\$40.41	\$53.47	\$126.21	Recessed 2x4, 4L-T8 Elec Ballast	60	0.3	117	\$61.23	\$288	\$288	\$69	\$644	\$32.65			
Transmission Office	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	Recessed 2x4, 4L-T8 Elec Ballast	112	0.4	175	\$91.43	\$256	\$230	\$61	\$571	\$38.78			
Building 41																								
Warehouse																								
Receiving Office	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	Industrial 4', 2L-T8 Elec Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88			
Office	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Industrial 4', 2L-T8 Elec Ballast	60	0.1	26	\$18.29	\$90	\$92	\$22	\$204	\$9.76			

ECO-8B
Buildings 14 - 57
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Existing										Proposed					Implementation						
Room	NO Of Luminaires	Large Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$	Energy Savings \$
Building 42S																					
Warehouse																					
Office	9	4	40	1,656	50	95%	1.6	359	\$145.48	\$106.94	\$252.42	Recessed 2x4, 4L-18 Fluorescent Ballast	112	1.0	219	\$153.65	\$576	\$518	\$131	\$1,225	\$98.77
Break Room	6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Pendant 1x4, 4L-18 Fluorescent Ballast	112	0.6	146	\$102.43	\$420	\$345	\$92	\$857	\$65.85
Building 43																					
Warehouse																					
Office - 1 x 4 window differ	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-18 Fluorescent Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95
Lockers	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Industrial 4', 3L-18 Fluorescent Ballast	88	0.3	57	\$40.24	\$150	\$138	\$35	\$323	\$22.86
Building 44																					
Warehouse																					
Office Area	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Industrial 4', 3L-18 Fluorescent Ballast	88	0.3	76	\$53.65	\$200	\$184	\$46	\$430	\$30.49
Building 47																					
Warehouse																					
Office - South	4	3	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	Industrial 4', 3L-18 Fluorescent Ballast	88	0.3	137	\$71.84	\$200	\$184	\$46	\$430	\$40.82
Receiving South	2	3	40	276	90	95%	0.3	108	\$24.25	\$32.08	\$56.33	Industrial 4', 3L-18 Fluorescent Ballast	88	0.2	69	\$35.92	\$100	\$92	\$23	\$215	\$20.41
Office - North	4	2	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	Industrial 4', 2L-18 Fluorescent Ballast	60	0.2	94	\$48.98	\$180	\$184	\$44	\$408	\$26.12
Filing Area - North	24	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	Surface 1x4, 2L-18 Fluorescent Ballast	60	0.2	94	\$48.98	\$269	\$150	\$50	\$469	\$101.23
Filing Area - North	24	1	40	1,104	90	95%	1.0	431	\$96.98	\$128.33	\$225.32	Industrial 4', 1L-18 Fluorescent Ballast	31	0.7	291	\$151.84	\$960	\$1,104	\$248	\$2,312	\$73.47
Building 51																					
Warehouse																					
Self Service Parts Room	14	2	40	1,288	50	95%	1.2	279	\$113.15	\$83.18	\$196.33	Pendant 1x4, 2L-18 Fluorescent Ballast	60	0.8	182	\$128.04	\$840	\$805	\$197	\$1,842	\$68.29
Self Service Shelf Area	69	2	40	6,348	50	95%	6.0	1,378	\$57.66	\$409.95	\$676.61	Pendant 1x4, 2L-18 Fluorescent Ballast	60	3.9	898	\$631.05	\$4,140	\$3,968	\$973	\$9,081	\$336.56
Self Service Shelf Area	12	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Industrial 4', 2L-18 Fluorescent Ballast	60	0.7	156	\$109.75	\$340	\$352	\$131	\$1,223	\$58.53
Entrance Lobby	1	4	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.1	24	\$17.07	\$64	\$58	\$15	\$137	\$10.97
Self Service Rear Corridor	10	3	40	1,380	50	95%	1.3	299	\$121.23	\$89.12	\$210.35	Industrial 4', 3L-18 Fluorescent Ballast	88	0.8	191	\$134.14	\$500	\$460	\$115	\$1,075	\$76.21
Self Service Entrance Lobby	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	Recessed 2x4, 2L-18 Fluorescent Ballast	60	0.1	13	\$9.15	\$38	\$38	\$14	\$129	\$4.88
Self Service Rear Office	24	4	40	4,416	50	95%	4.2	958	\$87.94	\$285.18	\$673.12	Pendant 1x4, 4L-18 Fluorescent Ballast	112	2.6	583	\$409.73	\$1,680	\$1,380	\$367	\$3,427	\$263.39
Self Service Office	15	2	40	1,380	50	95%	1.3	299	\$121.23	\$89.12	\$210.35	Pendant 1x4, 2L-18 Fluorescent Ballast	60	0.9	195	\$137.18	\$900	\$863	\$212	\$1,975	\$73.17
Warehouse Radio Active Room	6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Pendant 1x4, 4L-18 Fluorescent Ballast	112	0.6	146	\$102.43	\$420	\$345	\$92	\$857	\$65.85
Warehouse Break Room	9	4	40	1,656	50	95%	1.6	359	\$145.48	\$106.94	\$252.42	Pendant 1x4, 4L-18 Fluorescent Ballast	112	1.0	219	\$153.65	\$500	\$518	\$138	\$1,286	\$98.77
Warehouse Proc. Workstation	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	Industrial 4', 3L-18 Fluorescent Ballast	88	0.1	19	\$13.41	\$50	\$46	\$12	\$108	\$7.62
Warehouse Work Room	21	4	40	3,864	50	95%	3.7	838	\$339.45	\$249.53	\$588.98	Pendant 1x4, 4L-18 Fluorescent Ballast	112	2.2	510	\$338.51	\$1,470	\$1,208	\$321	\$2,999	\$220.47
Warehouse Mil. Work Station	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-18 Fluorescent Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95
Warehouse Milvan Office	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 4L-18 Fluorescent Ballast	60	0.3	78	\$54.87	\$345	\$345	\$83	\$773	\$29.27
Main Office	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Fluorescent Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90
Building 52																					
Warehouse																					
Warehouse Receiving	1	2	40	92	50	95%	0.1	20	\$8.08	\$5.94	\$14.02	Industrial 4', 2L-18 Fluorescent Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88
Warehouse Office	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-18 Fluorescent Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95
Building 53																					
Warehouse																					
Warehouse Receiving South	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Industrial 4', 3L-18 Fluorescent Ballast	88	0.3	76	\$53.65	\$200	\$184	\$46	\$430	\$30.49
Warehouse Receiving North	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Pendant 1x4, 4L-18 Fluorescent Ballast	112	0.4	97	\$68.29	\$280	\$230	\$61	\$571	\$43.90
Warehouse Battery Area	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	Industrial 4', 3L-18 Fluorescent Ballast	88	0.1	19	\$13.41	\$50	\$46	\$12	\$108	\$7.62
Warehouse Office (2 lamps only)	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Pendant 1x4, 2L-18 Fluorescent Ballast	60	0.1	26	\$18.29	\$120	\$115	\$28	\$263	\$9.76
Building 54																					
Warehouse																					
Warehouse Office	4	2	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Industrial 4', 2L-18 Fluorescent Ballast	60	0.2	52	\$36.58	\$180	\$184	\$44	\$408	\$19.51
Warehouse Parts Area	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Surface wraparound, 1L-18 Fluorescent Ballast	31	0.2	40	\$28.35	\$304	\$197	\$60	\$560	\$55.79
Building 55																					
Warehouse																					
Warehouse Battery Area	1	4	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Pendant 1x4, 4L-18 Fluorescent Ballast	112	0.1	24	\$17.07	\$70	\$58	\$15	\$143	\$10.97

ECO-8B
Buildings 14 - 57
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Existing										Proposed				Implementation							
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost (\$/kwh)	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$
Warehouse	23	4	40	4,232	90	95%	4.0	1653	\$371.77	\$491.94	\$863.71	Recessed 2x4, 4L-T8 Fluor Ballast	112	2.4	1,006	\$525.74	\$1,472	\$1,323	\$335	\$3,130	\$337.97
Office Area/Parts Area	5	3	40	920	90	95%	0.9	359	\$80.82	\$106.94	\$187.76	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.5	219	\$114.29	\$550	\$288	\$77	\$715	\$73.47
Tool Parts Room (Locked)	11	3	40	1,318	90	95%	1.4	593	\$133.55	\$176.46	\$309.81	Industrial 4', 3L-T8 Fluor Ballast	88	0.9	378	\$197.56	\$550	\$506	\$127	\$1,183	\$112.25
Bulk Warehouse Office #1	12	4	40	2,208	90	95%	2.1	862	\$193.97	\$256.66	\$450.63	Surface 1x4, 2L-T8 Fluor Ballast	60	0.7	281	\$146.95	\$807	\$450	\$151	\$1,408	\$303.69
Fire Equipment Cage Area	4	2	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	Surface 1x4, 2L-T8 Fluor Ballast	60	0.2	94	\$48.98	\$269	\$150	\$50	\$469	\$26.12
Ladies Room	3	2	40	276	54	95%	0.3	65	\$24.25	\$19.25	\$43.50	Industrial 4', 2L-T8 Fluor Ballast	60	0.2	42	\$28.37	\$135	\$138	\$33	\$306	\$15.13
Bulk Warehouse Office #2	9	4	40	1,656	90	95%	1.6	647	\$145.48	\$192.50	\$337.97	Surface 1x4, 2L-T8 Fluor Ballast	60	0.5	211	\$110.21	\$605	\$338	\$113	\$1,056	\$277.77
Breakroom	6	4	40	1,104	90	95%	1.0	431	\$96.98	\$128.33	\$225.32	Surface 1x4, 2L-T8 Fluor Ballast	60	0.3	141	\$73.47	\$404	\$225	\$75	\$704	\$151.84
Ladies Room	1	4	40	184	54	95%	0.2	43	\$16.16	\$12.83	\$20.00	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.1	26	\$17.65	\$70	\$58	\$15	\$143	\$11.35
Equipment Operations Unit	15	4	40	2,760	90	95%	2.6	1078	\$242.46	\$320.83	\$563.29	Pendant 1x4, 4L-T8 Fluor Ballast	112	1.6	656	\$342.87	\$1,050	\$863	\$290	\$2,143	\$220.42
Driver Exam Corridor	6	4	40	1,104	90	95%	1.0	431	\$96.98	\$128.33	\$225.32	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.6	262	\$137.15	\$384	\$345	\$87	\$816	\$88.17
Locker Room	4	2	40	368	54	95%	0.3	86	\$23.33	\$25.67	\$57.99	Industrial 4', 2L-T8 Fluor Ballast	60	0.2	56	\$37.82	\$180	\$184	\$44	\$408	\$20.17
Office (Locked)	2	2	40	184	90	95%	0.2	72	\$16.16	\$12.39	\$37.55	Recessed 2x4, 2L-T8 Fluor Ballast	60	0.1	47	\$24.49	\$115	\$115	\$28	\$258	\$13.06
Robertson Office	3	4	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.3	131	\$68.57	\$192	\$173	\$44	\$409	\$44.08
Office	2	2	40	184	90	95%	0.2	72	\$16.16	\$12.39	\$37.55	Recessed 2x4, 2L-T8 Fluor Ballast	60	0.1	47	\$24.49	\$115	\$115	\$28	\$258	\$13.06
Office (Locked)	1	4	40	184	90	95%	0.2	72	\$16.16	\$12.39	\$37.55	Recessed 2x4, 4L-T8 Fluor Ballast	60	0.1	44	\$22.86	\$64	\$58	\$15	\$137	\$14.69
Corridor Behind Office Area	1	4	40	184	90	95%	0.2	72	\$16.16	\$12.39	\$37.55	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.1	44	\$22.86	\$64	\$58	\$15	\$137	\$14.69
Office Area	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.4	175	\$91.43	\$256	\$240	\$58	\$544	\$58.78
Office Area	3	4	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.3	131	\$68.57	\$210	\$173	\$46	\$429	\$44.08
TOTALS	321			73071			69.4	20734	\$6,000	\$6,000	\$13,000			40.8	11968	\$7,000	\$31,000	\$27,000	\$7,000	\$65,000	\$5,000
G:\PROJECT\TSH13601\SS\ECOE\CO. 80.WK4																					23-May-99

G:\PROJECTS\1360155\ECO8B.WK4

22 May 99

ECO-8C
Buildings 102-441
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Existing										Proposed				Implementation							
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$
Building 102																					
Lab	4	2	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Recessed 2x4, 2L-T8 Fluor Ballast	60	0.2	94	\$48.98	\$230	\$230	\$55	\$515	\$26.12
Front Lab Workstation	2	2	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	Recessed 2x4, 2L-T8 Fluor Ballast	60	0.1	47	\$24.49	\$115	\$115	\$28	\$258	\$13.06
Entrance to Office	18	2	40	1656	90	95%	1.6	646.8	\$145.18	\$192.50	\$337.68	Recessed 2x4, 2L-T8 Fluor Ballast	60	1.0	422	\$220.42	\$1,035	\$1,035	\$248	\$2,318	\$117.26
Main Lab Area	1	2	40	92	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	Recessed 2x4, 2L-T8 Fluor Ballast	60	0.1	14	\$9.46	\$58	\$58	\$14	\$129	\$5.04
Bathroom																					
Building 199																					
Warehouse	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.6	146	\$102.43	\$420	\$345	\$92	\$857	\$65.85
Work Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Surface 1x4, 2L-T8 Fluor Ballast	60	0.1	13	\$9.15	\$67	\$38	\$13	\$118	\$4.86
Office																					
Building 200																					
Lab	11	4	40	2024	50	95%	1.9	439.2	\$177.81	\$130.71	\$308.51	Pendant 1x4, 4L-T8 Fluor Ballast	112	1.2	267	\$187.79	\$770	\$633	\$168	\$1,571	\$120.72
Lab Area																					
Building 211																					
Administration																					
Kitchen	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Surface 1x4, 2L-T8 Fluor Ballast	60	0.1	13	\$9.15	\$67	\$38	\$13	\$118	\$4.88
Main Office Area	5	4	40	920	50	95%	0.9	199.6	\$80.82	\$59.41	\$140.23	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.5	122	\$85.36	\$320	\$288	\$73	\$681	\$34.87
Managers Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90
Building 247																					
Warehouse	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.4	97	\$68.29	\$280	\$230	\$61	\$571	\$43.90
Receiving Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Surface 1x4, 2L-T8 Fluor Ballast	60	0.1	13	\$9.15	\$67	\$38	\$13	\$118	\$4.88
Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 3L-T8 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$56.09
Rear Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 3L-T8 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$56.09
Corridor to Office	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L-T8 Fluor Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$15.24
Kitchen	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.1	24	\$17.07	\$64	\$58	\$15	\$137	\$9.76
Receiving Area	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	Industrial 4' 3L-T8 Fluor Ballast	88	0.1	19	\$13.41	\$50	\$46	\$12	\$108	\$7.62
Copy Room	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Industrial 4' 2L-T8 Fluor Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88
Receiving Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Surface 1x4, 2L-T8 Fluor Ballast	60	0.1	13	\$9.15	\$67	\$38	\$13	\$118	\$4.88
Receiving Area	6	1	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.6	146	\$102.43	\$420	\$345	\$92	\$857	\$60.36
Receiving Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Industrial 4' 2L-T8 Fluor Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88
Building 320																					
Maintenance	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Industrial 4' 2L-T8 Fluor Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88
Main Area Machine Shop	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.3	73	\$51.22	\$192	\$173	\$44	\$409	\$32.92
Maintenance Area Office	11	1	40	506	168	95%	0.5	368.9	\$44.45	\$109.79	\$154.25	Surface wraparound, 1L-T8 Fluor Ballast	31	0.3	249	\$103.95	\$557	\$360	\$110	\$1,027	\$50.30
Mens Locker Room	3	2	40	276	168	95%	0.3	201.2	\$24.25	\$59.89	\$84.13	Surface 1x4, 2L-T8 Fluor Ballast	60	0.2	131	\$54.87	\$202	\$113	\$38	\$352	\$29.26
Toilet Area	47	2	40	4324	168	95%	4.1	3152.7	\$379.86	\$938.25	\$1,318.10	Recessed 2x4, 2L-T8 Fluor Ballast	60	2.7	2,056	\$859.63	\$2,703	\$2,703	\$649	\$6,054	\$438.47
Main Office Area																					
Building 349																					
Boiler Plant	9	2	40	828	168	95%	0.8	603.7	\$72.74	\$179.66	\$252.40	Pendant 1x4, 2L-T8 Fluor Ballast	60	0.5	394	\$164.61	\$540	\$518	\$127	\$1,185	\$87.79
Entrance Cage Area	2	2	40	184	168	95%	0.2	134.2	\$16.16	\$9.93	\$22.09	Recessed 2x4, 2L-T8 Fluor Ballast	60	0.1	87	\$36.58	\$115	\$115	\$28	\$258	\$19.51
Control Room	2	2	40	184	168	95%	0.2	134.2	\$16.16	\$9.93	\$22.09	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.1	817	\$341.41	\$700	\$575	\$153	\$1,428	\$219.48
Boiler Room Ground Level	10	4	40	1840	168	95%	1.7	1341.6	\$161.64	\$399.25	\$560.90	Pendant 1x4, 4L-T8 Fluor Ballast	112	1.1	817	\$341.41	\$700	\$575	\$153	\$1,428	\$15.24
Boiler Room Ground Level	1	3	40	138	168	95%	0.1	100.6	\$12.12	\$29.94	\$42.07	Industrial 4' 3L-T8 Fluor Ballast	88	0.1	64	\$26.83	\$50	\$46	\$12	\$108	\$15.24
Breakroom	4	4	40	736	84	95%	0.7	268.3	\$64.66	\$79.85	\$144.51	Industrial 4' 2L-T8 Fluor Ballast	112	0.4	163	\$87.96	\$280	\$230	\$61	\$571	\$56.55
Boiler Room Ground Level	4	1	40	184	168	95%	0.2	134.2	\$16.16	\$9.93	\$22.09	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.4	327	\$136.57	\$280	\$230	\$61	\$571	\$80.48
Building 350																					
Office #1	5	4	40	920	54	95%	0.9	215.6	\$80.82	\$64.17	\$144.99	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.5	131	\$88.25	\$320	\$288	\$73	\$681	\$56.73
Mens Room	12	4	40	2208	63	95%	2.1	603.7	\$193.97	\$179.66	\$373.63	Recessed 2x4, 4L-T8 Fluor Ballast	112	1.3	367	\$227.43	\$768	\$690	\$175	\$1,633	\$146.20
Conference Room	5	4	40	920	54	95%	0.9	215.6	\$80.82	\$64.17	\$144.99	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.5	131	\$88.25	\$320	\$288	\$73	\$681	\$56.73
Women's Room	3	4	40	552	90	95%	0.5	215.6	\$80.82	\$64.17	\$144.99	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.3	131	\$88.25	\$320	\$288	\$73	\$681	\$44.08
Corridor to Shop	4	4	40	736	90	95%	0.7	267.5	\$64.66	\$85.55	\$150.21	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.4	175	\$91.43	\$256	\$230	\$58	\$544	\$58.78
Managers Office	4	4	40	736	90	95%	0.7	267.5	\$64.66	\$85.55	\$150.21	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.4	175	\$91.43	\$256	\$230	\$58	\$544	\$58.78
Copy Room	2	4	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.2	87	\$45.72	\$128	\$115	\$29	\$272	\$29.39
Reception	11	4	40	2024	90	95%	1.9	790.6	\$177.81	\$235.27	\$413.08	Recessed 2x4, 4L-T8 Fluor Ballast	112	1.2	481	\$251.44	\$704	\$633	\$160	\$1,497	\$161.64

ECO-8C
Buildings 102-441
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Room	NO. Of Luminaires	Existing					Proposed					Implementation									
		Hours Per Week	Total Watts	Lamps Per Luminare	Watts Per Lamp	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Hr Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Hr Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$
Office #2																					
Reception Area	8		1472	4	40	95%	1.4	575.0	\$129.31	\$171.11	\$300.42	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.9	350	\$182.87	\$512	\$460	\$117	\$1,080	\$117.56
Managers Office	1		40	4	40	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.1	44	\$22.86	\$64	\$58	\$15	\$137	\$14.69
Office #3																					
Work Area	6		1104	4	40	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.6	262	\$137.15	\$384	\$345	\$87	\$816	\$88.17
Separate Office Area	4		736	4	40	95%	0.7	287.5	\$64.66	\$85.55	\$150.21	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.4	175	\$91.43	\$280	\$250	\$61	\$571	\$58.78
ASRS plus Office Area Corridor	3		40	4	40	95%	0.5	215.6	\$48.49	\$64.17	\$112.66	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.3	131	\$68.57	\$173	\$149	\$46	\$429	\$44.08
ASRS plus Office Computer Rm.	8		1472	4	40	95%	1.4	575.0	\$129.31	\$171.11	\$300.42	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.9	350	\$182.87	\$512	\$460	\$117	\$1,080	\$117.56
Office #4																					
Office Area	5		460	2	40	95%	0.4	179.7	\$40.41	\$53.47	\$93.88	Industrial 4', 2L-T8 Fluor Ballast	50	0.3	117	\$61.23	\$225	\$230	\$55	\$510	\$32.65
Library Conference Room	2		276	3	40	95%	0.3	75.5	\$24.25	\$22.46	\$46.70	Industrial 4', 3L-T8 Fluor Ballast	88	0.2	48	\$29.78	\$100	\$92	\$23	\$215	\$16.92
Quality Control Room	6		828	3	40	95%	0.8	323.4	\$72.74	\$96.25	\$168.99	Pendant 1x4, 3L-T8 Fluor Ballast	88	0.5	206	\$107.76	\$390	\$345	\$88	\$823	\$61.23
Annex Office Area #6																					
Stairway to Shop	2		184	2	40	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	Surface 1x4, 2L-T8 Fluor Ballast	60	0.1	47	\$24.49	\$135	\$75	\$25	\$235	\$13.06
Annex Office Corridor	7		644	2	40	95%	0.6	251.5	\$66.57	\$74.86	\$131.43	Surface 1x4, 2L-T8 Fluor Ballast	60	0.4	164	\$82.49	\$471	\$263	\$88	\$821	\$45.72
Stairway to Shop	2		184	2	40	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	Surface 1x4, 2L-T8 Fluor Ballast	60	0.1	47	\$24.49	\$135	\$75	\$25	\$235	\$13.06
Meeting Room	19		1748	63	95%	1.7	477.9	\$153.56	\$142.23	\$295.79	\$259.79	Surface 1x4, 2L-T8 Fluor Ballast	60	1.1	312	\$192.91	\$1,278	\$713	\$239	\$2,229	\$102.88
Planning Production Fabrication	12		1104	40	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	\$225.32	Surface 1x4, 2L-T8 Fluor Ballast	60	0.7	281	\$146.95	\$807	\$450	\$151	\$1,408	\$78.37
Trades Branch Conference Rm.	12		1104	40	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	\$225.32	Surface 1x4, 2L-T8 Fluor Ballast	60	0.7	281	\$146.95	\$807	\$450	\$151	\$1,408	\$78.37
Mens Room	6		552	3	40	95%	0.5	129.4	\$48.49	\$64.17	\$112.66	Surface 1x4, 2L-T8 Fluor Ballast	60	0.3	84	\$56.73	\$404	\$225	\$75	\$704	\$50.26
Ladies Room	3		276	2	40	95%	0.3	64.7	\$24.25	\$19.25	\$33.50	Surface 1x4, 2L-T8 Fluor Ballast	60	0.2	42	\$28.37	\$202	\$113	\$38	\$352	\$15.13
Unders Office Room #2	12		1104	40	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	\$225.32	Surface 1x4, 2L-T8 Fluor Ballast	60	0.7	281	\$146.95	\$807	\$450	\$151	\$1,408	\$78.37
Unders Office Room #1	12		1104	40	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	\$225.32	Surface 1x4, 2L-T8 Fluor Ballast	60	0.7	281	\$146.95	\$807	\$450	\$151	\$1,408	\$78.37
Stairway to Shop	2		184	2	40	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	Surface 1x4, 2L-T8 Fluor Ballast	60	0.1	47	\$24.49	\$135	\$75	\$25	\$235	\$13.06
Building 370																					
Equipment Repair																					
Mens Room	3		552	4	40	95%	0.5	129.4	\$48.49	\$64.17	\$112.66	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.3	79	\$29.05	\$210	\$173	\$46	\$429	\$34.04
Shop Area Task Lighting	4		368	2	40	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Industrial 4', 2L-T8 Fluor Ballast	60	0.2	94	\$48.98	\$180	\$184	\$44	\$408	\$26.12
Shop Area	318		58512	90	95%	55.6	2085.8	\$5,140.19	\$6,801.58	\$11,942	\$11,942	Pendant 1x4, 4L-T8 Fluor Ballast	112	33.8	13,912	\$7,268.90	\$22,260	\$18,285	\$4,665	\$45,410	\$1,072.87
Shop Area Office	5		40	4	40	95%	0.9	359.4	\$80.82	\$106.94	\$187.76	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.5	219	\$114.29	\$350	\$288	\$77	\$715	\$73.47
Test Room/Workstation	2		368	2	40	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.2	87	\$45.72	\$140	\$115	\$31	\$286	\$29.39
Test Room	4		736	4	40	95%	0.7	287.5	\$64.66	\$85.55	\$150.21	Pendant 1x4, 4L-T8 Fluor Ballast	112	0.4	175	\$91.43	\$280	\$230	\$61	\$571	\$58.78
Shop Area Task Lighting	2		184	2	40	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	Surface 1x4, 2L-T8 Fluor Ballast	60	0.1	47	\$24.49	\$135	\$75	\$25	\$235	\$13.06
Building 412																					
Training & Conf. Center																					
Computer Training Area	11		2024	4	40	95%	1.9	439.2	\$177.81	\$130.71	\$308.51	Recessed 2x4, 4L-T8 Fluor Ballast	112	1.2	267	\$187.79	\$704	\$633	\$160	\$1,497	\$120.72
Administration Area	11		2024	4	40	95%	1.9	439.2	\$177.81	\$130.71	\$308.51	Recessed 2x4, 4L-T8 Fluor Ballast	112	1.2	267	\$187.79	\$704	\$633	\$160	\$1,497	\$120.72
Building 416																					
Administration																					
Managers Office	2		368	4	40	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L-T8 Fluor Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Main Office Area	30		5520	4	40	95%	5.2	1197.8	\$484.92	\$356.48	\$841.40	Recessed 2x4, 4L-T8 Fluor Ballast	112	3.2	729	\$512.16	\$1,920	\$1,725	\$437	\$4,082	\$329.24
Building 417																					
Personnel Barracks																					
Corridor	9		828	168	95%	0.8	603.7	\$72.74	\$79.66	\$292.40	\$292.40	Recessed 2x4, 2L-T8 Fluor Ballast	60	0.5	944	\$164.61	\$518	\$518	\$124	\$1,159	\$87.79
Mens Room/Shower	4		368	168	95%	0.3	268.3	\$32.33	\$39.85	\$112.18	\$112.18	Surface 1x4, 2L-T8 Fluor Ballast	60	0.2	175	\$73.16	\$269	\$150	\$50	\$469	\$39.02
Womens Room	4		368	168	95%	0.3	268.3	\$32.33	\$39.85	\$112.18	\$112.18	Surface 1x4, 2L-T8 Fluor Ballast	60	0.2	175	\$73.16	\$269	\$150	\$50	\$469	\$39.02
Building 418																					
Personnel Barracks																					
Corridor	9		828	168	95%	0.8	603.7	\$72.74	\$79.66	\$292.40	\$292.40	Recessed 2x4, 2L-T8 Fluor Ballast	60	0.5	944	\$164.61	\$518	\$518	\$124	\$1,159	\$87.79
Mens Room/Shower	4		368	168	95%	0.3	268.3	\$32.33	\$39.85	\$112.18	\$112.18	Surface 1x4, 2L-T8 Fluor Ballast	60	0.2	175	\$73.16	\$269	\$150	\$50	\$469	\$39.02
Womens Room	4		368	168	95%	0.3	268.3	\$32.33	\$39.85	\$112.18	\$112.18	Surface 1x4, 2L-T8 Fluor Ballast	60	0.2	175	\$73.16	\$269	\$150	\$50	\$469	\$39.02

ECO-8C
Buildings 102-441
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Room	NO. OF Luminaires	Existing					Proposed					Implementation									
		Lamps Per Lumen	Watts Per Lumen	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Lumen	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Labor Coat \$	Bag Coat \$	Total Cost \$	Energy Savings \$	
Building G21																					
Administration	28	4	40	4512	50	95%	4.9	1118.0	\$452.59	\$332.71	\$785.31	Recessed 2x4, 4L-18 Effic Ballast	112	3.0	681	\$478.01	\$1,792	\$1,610	\$408	\$3,810	\$307.29
Main Office Area North End	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L-18 Effic Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76
Support Division Chief Office	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 4L-18 Effic Ballast	112	0.1	26	\$17.07	\$64	\$58	\$15	\$137	\$10.97
Managers Office	3	4	40	552	50	95%	0.2	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 4L-18 Effic Ballast	112	0.3	73	\$51.22	\$192	\$173	\$44	\$409	\$32.92
File/Copy Room on Files	4	1	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Surface wraparound, 1L-18 Effic Ballast	31	0.1	27	\$18.90	\$202	\$131	\$44	\$373	\$9.15
Main Entrance Lobby	3	4	40	552	50	95%	0.3	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 4L-18 Effic Ballast	112	0.3	73	\$51.22	\$192	\$173	\$44	\$409	\$32.92
Acquisition Chief	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Surface wraparound, 1L-18 Effic Ballast	31	0.1	27	\$18.90	\$202	\$131	\$44	\$373	\$9.15
Cont. Office Patch, Office Area	26	4	40	4784	50	95%	4.5	1038.1	\$402.77	\$308.95	\$779.21	Recessed 2x4, 4L-18 Effic Ballast	112	2.8	692	\$443.87	\$1,664	\$1,495	\$379	\$3,538	\$285.34
Impress Office	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 4L-18 Effic Ballast	112	0.1	24	\$17.07	\$64	\$58	\$15	\$137	\$10.97
Receptionist	2	4	40	368	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 4L-18 Effic Ballast	112	0.2	38	\$26.83	\$123	\$115	\$29	\$272	\$21.95
Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 4L-18 Effic Ballast	112	0.5	122	\$45.36	\$204	\$190	\$57	\$353	\$263.32
Bid Room #2	3	3	40	368	50	95%	0.3	89.8	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L-18 Effic Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$333	\$30.49
Office	2	4	40	368	50	95%	0.3	89.8	\$36.37	\$26.74	\$63.11	Recessed 2x4, 4L-18 Effic Ballast	112	0.3	76	\$53.65	\$246	\$230	\$57	\$333	\$30.49
Support Division Chief Office	5	4	40	920	50	95%	0.9	200	\$80.82	\$59.41	\$140.23	Recessed 2x4, 4L-18 Effic Ballast	112	0.5	122	\$45.36	\$204	\$190	\$57	\$353	\$263.32
Property Accountability Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Effic Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$272	\$21.95
Vending Area	2	4	40	368	50	95%	0.3	89.8	\$36.37	\$26.74	\$63.11	Recessed 2x4, 4L-18 Effic Ballast	112	0.3	76	\$53.65	\$246	\$230	\$57	\$333	\$30.49
Equipment Mgt. Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Effic Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$272	\$21.95
Main Exit Lobby	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 4L-18 Effic Ballast	112	0.1	24	\$17.07	\$64	\$58	\$15	\$137	\$10.97
Managers Office	6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Recessed 2x4, 4L-18 Effic Ballast	112	0.6	146	\$102.43	\$384	\$345	\$87	\$816	\$65.85
C.K. Depot Prop. Div. Reception	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-18 Effic Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$333	\$30.49
C.K. Depot Prop. Div. Office	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-18 Effic Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$333	\$30.49
Main Office South End	24	4	40	4,416	50	95%	4.2	958	\$387.94	\$295.18	\$673.12	Recessed 2x4, 4L-18 Effic Ballast	112	2.6	583	\$409.73	\$1,536	\$1,380	\$350	\$3,266	\$263.32
Contracting Office Area	14	4	40	2,576	50	95%	2.4	559	\$226.30	\$166.36	\$392.65	Recessed 2x4, 4L-18 Effic Ballast	112	1.5	340	\$239.01	\$896	\$805	\$204	\$1,905	\$153.65
Office (left of Acquisition Chief)	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 4L-18 Effic Ballast	112	0.1	24	\$17.07	\$64	\$58	\$15	\$137	\$10.97
Building G24																					
Cable & Harness																					
Unpopulated	4	3	40	552	90	95%	0.5	216	\$84.49	\$64.17	\$112.66	Pendant 1x4, 3L-18 Effic Ballast	88	0.3	137	\$71.84	\$260	\$230	\$59	\$549	\$40.82
File Area	5	3	40	690	90	95%	0.7	270	\$60.62	\$80.21	\$140.82	Recessed 2x4, 3L-18 Effic Ballast	88	0.4	172	\$89.80	\$308	\$288	\$71	\$666	\$51.02
Cable Test Station	3	3	40	414	90	95%	0.4	162	\$36.37	\$48.12	\$84.49	Recessed 2x4, 3L-18 Effic Ballast	88	0.3	103	\$53.88	\$185	\$173	\$43	\$400	\$30.61
Work Station	5	3	40	690	90	95%	0.7	270	\$60.62	\$80.21	\$140.82	Recessed 2x4, 3L-18 Effic Ballast	88	0.4	172	\$89.80	\$308	\$288	\$71	\$666	\$51.02
Cable Termination Area	6	2	40	552	90	95%	0.5	216	\$84.49	\$64.17	\$112.66	Recessed 2x4, 2L-18 Effic Ballast	60	0.1	141	\$73.47	\$345	\$345	\$83	\$773	\$39.19
Cable Termination Area	1	2	40	92	90	95%	0.1	36	\$8.08	\$10.69	\$18.78	Industrial 4, 2L-18 Effic Ballast	60	0.1	23	\$12.25	\$45	\$46	\$11	\$102	\$6.53
Assembly Area Desk Lighting	2	4	40	368	90	95%	0.3	108	\$24.25	\$32.08	\$56.33	Surface 1x4, 2L-18 Effic Ballast	60	0.2	70	\$36.74	\$202	\$113	\$38	\$352	\$19.59
Assembly Area	21	3	40	2,898	90	95%	2.8	1132	\$254.58	\$336.87	\$991.46	Recessed 2x4, 3L-18 Effic Ballast	88	1.8	722	\$377.16	\$1,292	\$1,208	\$300	\$2,799	\$214.30
Break Room	3	3	40	414	90	95%	0.4	162	\$36.37	\$48.12	\$84.49	Recessed 2x4, 3L-18 Effic Ballast	88	0.3	103	\$53.88	\$185	\$173	\$43	\$400	\$30.61
Office (Day)	4	3	40	552	90	95%	0.5	216	\$84.49	\$64.17	\$112.66	Recessed 2x4, 2L-18 Effic Ballast	60	0.2	70	\$36.74	\$202	\$113	\$38	\$352	\$19.59
Office	2	4	40	368	90	95%	0.3	108	\$24.25	\$32.08	\$56.33	Recessed 2x4, 3L-18 Effic Ballast	88	0.3	137	\$71.84	\$246	\$230	\$57	\$533	\$40.82
Building G28																					
Counseling																					
Counseling Manager Office	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-18 Effic Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95
Corridor to Managers Office	6	2	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Surface wraparound, 1L-18 Effic Ballast	31	0.2	40	\$28.35	\$304	\$288	\$60	\$560	\$55.79
Copy Room	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Surface wraparound, 1L-18 Effic Ballast	31	0.1	13	\$9.45	\$101	\$66	\$20	\$187	\$18.60
Main Entrance Corridor	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Surface wraparound, 1L-18 Effic Ballast	31	0.1	13	\$9.45	\$101	\$66	\$20	\$187	\$18.60
Counselors Office	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Surface wraparound, 1L-18 Effic Ballast	31	0.1	13	\$9.45	\$101	\$66	\$20	\$187	\$18.60
Counselors Office	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Surface wraparound, 1L-18 Effic Ballast	31	0.1	13	\$9.45	\$101	\$66	\$20	\$187	\$18.60
Conference Room (Day)	8	2	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Surface wraparound, 1L-18 Effic Ballast	31	0.2	54	\$37.80	\$405	\$262	\$80	\$747	\$74.38
Building G31																					
Administration																					
Main Entrance Lobby	8	4	40	1,472	50	95%	1.4	319	\$129.31	\$95.06	\$224.37	Pendant 1x4, 4L-18 Effic Ballast	112	0.9	194	\$136.58	\$560	\$460	\$122	\$1,142	\$87.80
Lab #4 (Entrance Lobby)	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 4L-18 Effic Ballast	112	0.1	24	\$17.07	\$64	\$58	\$15	\$137	\$10.97
Supply Section	10	4	40	1,840	50	95%	1.7	399	\$161.64	\$118.83	\$280.47	Pendant 1x4, 4L-18 Effic Ballast	112	1.1	243	\$170.72	\$700	\$575	\$153	\$1,428	\$109.75
Corridor around Lab #4	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Industrial 4, 3L-18 Effic Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$333	\$30.49
TDME Office Area	25	4	40	4,600	50	95%	4.4	998	\$404.10	\$297.06	\$701.17	Pendant 1x4, 4L-18 Effic Ballast	112	2.7	608	\$426.80	\$1,750	\$1,438	\$383	\$3,571	\$274.37
ACL Office	5	4	40	920	50	95%	0.9	200	\$80.82	\$59.41	\$140.23	Recessed 2x4, 4L-18 Effic Ballast	112	0.5	122	\$45.36	\$204	\$190	\$57	\$353	\$263.32
Women's Room	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Pendant 1x4, 4L-18 Effic Ballast	112	0.1	15	\$9.52	\$70	\$58	\$15	\$143	\$6.12
Executive Secretary	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Pendant 1x4, 4L-18 Effic Ballast	112	0.4	97	\$68.29	\$280	\$230	\$61	\$571	\$43.90
Computer Room	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L-18 Effic Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95
TDME Chief Office	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Pendant 1x4, 4L-18 Effic Ballast	112	0.4	97	\$68.29	\$280	\$230	\$61	\$571	\$43.90
TDME Chief Lab Calibration	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Pendant 1x4, 4L-18 Effic Ballast	112	0.3	73	\$51.22	\$210	\$173	\$46	\$429	\$32.92

ECO-8C
Buildings 102-441
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Room	NO. Of Luminaires	Existing										Proposed										Implementation					Energy Savings \$
		Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaires Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$							
Building 418																											
Repair Shop	3	2	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Surface 1x4, 2L-78 Ectec Ballast	60	0.2	39	\$27.44	\$202	\$113	\$38	\$352	\$14.63						
Building 441																											
Warehouse																											
Outside Office	2	2	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Recessed 2x4 2L-78 Ectec Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76						
Warehouse Parts Bay	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-78 Ectec Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95						
TOTALS	1073			165278			156.9	57100	\$15,000	\$17,000	\$32,000			96.8	35551	\$20,000	\$70,000	\$58,000	\$15,000	\$143,000	\$12,000						
G:\PROJECTS\418\418\SS\COECO 8C.WK4																											
22-Mar-95																											

CA PROJECTS4130.01SSSECOECO 8C.WK4

22 May 98

ECO-8D
Buildings 500 - 581
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Room	NO. Of Luminaires	Existing					Proposed					Implementation									
		Lamps Per Luminaires	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost	Material Cost	Labor Cost	Eng Cost	Total Cost	Energy Savings
Building 500																					
First Floor																					
Office	1	3	40	138	50	95%	0.1	29.9	112.12	\$8.91	\$21.04	Recessed 2x4, 3L, T8 Flu Ballast	88	0.1	19	\$13.41	\$62	\$58	\$14	\$133	\$7.62
Laboratory Room #33	4	4	40	736	50	95%	0.7	150.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, T8 Flu Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90
Dispensary Corridor	14	4	40	1288	50	95%	1.2	503.1	\$115.15	\$149.72	\$262.87	Recessed 2x4, 2L, T8 Flu Ballast	60	0.8	328	\$171.44	\$805	\$805	\$193	\$1,803	\$91.43
Room #47 (Office)	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Pharmacy	1	4	40	184	50	95%	0.3	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	24	\$17.07	\$64	\$58	\$15	\$137	\$10.97
Room #51 Open Office Area	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	Recessed 2x4, 4L, T8 Flu Ballast	112	0.6	146	\$102.43	\$384	\$345	\$87	\$816	\$65.85
Treatment Room #2 Room #45	2	4	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	87	\$45.72	\$128	\$115	\$29	\$272	\$29.39
Treatment Room #1 Room #46	2	4	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	87	\$45.72	\$128	\$115	\$29	\$272	\$29.39
Physical Therapy Room #34	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Flu Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.48
Command Wing Entrance	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L, T8 Flu Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76
Waiting Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Flu Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$272	\$15.24
Occupational Health Room #38	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Emergency Rm Entrance Lobby	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	Recessed 2x4, 2L, T8 Flu Ballast	60	0.1	44	\$18.29	\$58	\$58	\$14	\$129	\$9.75
Emergency Treatment Rm #40	6	4	40	1104	90	95%	1.0	431.2	\$96.98	\$71.30	\$168.28	Recessed 2x4, 4L, T8 Flu Ballast	112	0.6	146	\$102.43	\$384	\$345	\$87	\$816	\$65.85
Occupational Health Room #39	4	4	40	736	50	95%	0.7	150.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, T8 Flu Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90
Office Room #42	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Occupational Health Room #37	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Flu Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.48
Occupational Health Rm #43C	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L, T8 Flu Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76
Occupational Health Rm #43B	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L, T8 Flu Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76
Occupational Health Rm #43A	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L, T8 Flu Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76
Occupational Health Room #43	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Break Room (Room #36)	4	4	40	736	50	95%	0.7	150.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, T8 Flu Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90
Dispensary Waiting Room	4	3	40	552	90	95%	0.5	215.6	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Flu Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.48
Room #26 (Office)	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Flu Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.48
Copy Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Flu Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$272	\$15.24
Admin. Prgm. Coordinators Ofc.	4	4	40	736	50	95%	0.7	150.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, T8 Flu Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90
P. Greeting Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Flu Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.48
Protocol Office	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Copy Room	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Public Affairs Office	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L, T8 Flu Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76
Entrance to Rear Office	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Depot Sergeant Majors Office	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	Recessed 2x4, 4L, T8 Flu Ballast	112	0.1	19	\$13.41	\$62	\$58	\$14	\$133	\$7.62
Commander's Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Commander's Secretary	4	4	40	736	50	95%	0.7	150.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, T8 Flu Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90
Depot Commander	4	4	40	736	50	95%	0.7	150.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, T8 Flu Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90
Depot Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Legal Office 15 Reception	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L, T8 Flu Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76
Legal Office 15A	6	3	40	828	50	95%	0.8	179.7	\$72.74	\$53.47	\$126.21	Recessed 2x4, 3L, T8 Flu Ballast	88	0.5	115	\$80.48	\$369	\$345	\$86	\$800	\$45.73
Computer Room	10	3	40	1380	50	95%	1.3	299.5	\$121.23	\$99.12	\$210.35	Recessed 2x4, 3L, T8 Flu Ballast	88	0.5	191	\$134.14	\$615	\$575	\$143	\$1,333	\$76.21
Front Office 15A	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Flu Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$272	\$15.24
Police Sign in Room	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Flu Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.48
Police Room	3	3	40	414	108	95%	0.4	301.9	\$36.37	\$89.83	\$126.20	Recessed 2x4, 3L, T8 Flu Ballast	88	0.3	137	\$71.84	\$246	\$230	\$57	\$533	\$30.48
Police #17	3	3	40	414	108	95%	0.4	301.9	\$36.37	\$89.83	\$126.20	Recessed 2x4, 3L, T8 Flu Ballast	88	0.3	137	\$71.84	\$246	\$230	\$57	\$533	\$30.48
Room #25 (Office)	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Flu Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$272	\$15.24
Rear Office 15B	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Flu Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.48
Employment Info. Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Flu Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$272	\$15.24
Second Floor																					
Room #3 (Office)	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L, T8 Flu Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$272	\$15.24
Office #10	4	4	40	736	50	95%	0.7	150.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, T8 Flu Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90
Computer Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Employee Relations Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L, T8 Flu Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95
Center Bldg. Open Office Area	26	4	40	4784	50	95%	4.5	1038.1	\$420.71	\$308.95	\$729.21	Recessed 2x4, 4L, T8 Flu Ballast	112	2.8	632	\$443.87	\$1,664	\$1,495	\$379	\$3,558	\$285.34
Room #7 (Office)	4	4	40	736	50	95%	0.7	150.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L, T8 Flu Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90
Basement Level																					
Starwell #2 Police Area	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	Surface 1x4, 2L, T8 Flu Ballast	60	0.1	44	\$18.29	\$67	\$38	\$13	\$118	\$9.75
Starwell #3 Legal Office	2	4	40	368	168	95%	0.3	268.3	\$32.33	\$79.85	\$112.18	Recessed 2x4, 3L, T8 Flu Ballast	112	0.2	163	\$68.28	\$246	\$230	\$57	\$533	\$30.49
Room #16 (Rear Office)	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L, T8 Flu Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49
Starwell #1 Dispensary Side	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	Surface 1x4, 2L, T8 Flu Ballast	60	0.1	44	\$18.29	\$67	\$38	\$13	\$118	\$9.75
Open Office Area Room #16	32	3	40	4416																	

ECO-8D
Buildings 500 - 581
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Existing										Proposed										Implementation									
Room	No. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw/yr	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/yr	Annual Cost	Mat. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings								
Building 524	Descom Office A	2	3	40	276	50	95%	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-T8, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
	Hoover Office	2	3	40	276	50	95%	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-T8, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
	Barney Office	2	3	40	276	50	95%	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-T8, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
	Garhart Office	2	3	40	276	50	95%	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-T8, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
	Creamer Office	2	3	40	276	50	95%	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-T8, 18" Fluorescent Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24								
	Sheffield Office	2	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.3	78	\$54.87	\$128	\$115	\$29	\$272	\$21.95							
	Myers Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L-T8, 18" Fluorescent Ballast	112	0.2	40	\$36.58	\$230	\$57	\$533	\$30.49								
	Horn Office	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-T8, 18" Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49							
	Descom Office B	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-T8, 18" Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49							
	Kitchen	6	2	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-T8, 18" Fluorescent Ballast	88	0.3	76	\$53.65	\$246	\$230	\$57	\$533	\$30.49							
Building 529	Descom Office C	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 3L-T8, 18" Fluorescent Ballast	60	0.2	52	\$36.58	\$230	\$30	\$55	\$515	\$19.51							
	Library	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	88	0.1	19	\$13.41	\$62	\$58	\$14	\$133	\$7.62							
	Descom Office C	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.2	52	\$36.58	\$230	\$30	\$55	\$515	\$19.51							
	Corridor	11	2	40	1012	50	95%	1.0	219.6	\$88.90	\$65.35	\$154.26	Industrial 4', 2L-T8, 18" Fluorescent Ballast	60	0.6	143	\$100.60	\$495	\$506	\$120	\$1,121	\$53.65							
	Conference Center																												
	Entrance Lobby	7	2	40	644	50	95%	0.6	139.7	\$56.57	\$41.59	\$98.16	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.4	91	\$64.02	\$403	\$403	\$97	\$902	\$34.14							
	Building 530	First Floor																											
		Golf Shop Lunch Room	6	2	40	552	60	95%	0.5	143.7	\$48.49	\$42.78	\$91.27	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.3	94	\$59.52	\$345	\$345	\$83	\$773	\$31.75						
		Golf Equipment Shop Office	1	4	40	184	60	95%	0.2	47.9	\$16.16	\$14.26	\$30.42	Recessed 2x4, 4L-T8, 18" Fluorescent Ballast	112	0.1	29	\$18.52	\$64	\$58	\$15	\$137	\$19.90						
		Golf Equipment Shop	9	2	40	828	60	95%	0.8	215.6	\$72.74	\$64.17	\$136.90	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.5	141	\$89.29	\$318	\$318	\$124	\$1,159	\$47.62						
Golf Equipment Shop Office		1	2	40	92	60	95%	0.1	24.0	\$8.08	\$7.13	\$15.21	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.1	16	\$9.92	\$58	\$58	\$14	\$129	\$5.29							
Golf Equip. Shop Entrance Lobby		2	2	40	184	60	95%	0.2	47.9	\$16.16	\$14.26	\$30.42	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.1	31	\$19.84	\$115	\$115	\$28	\$258	\$10.58							
Bar Table Area		19	4	40	3496	60	95%	3.3	910.4	\$307.12	\$270.92	\$78.04	Recessed 2x4, 4L-T8, 18" Fluorescent Ballast	112	2.0	554	\$351.85	\$1,216	\$1,093	\$277	\$2,586	\$226.19							
Kitchen Dish Room		6	3	40	828	60	95%	0.8	215.6	\$72.74	\$64.17	\$136.90	Recessed 2x4, 3L-T8, 18" Fluorescent Ballast	88	0.5	137	\$87.30	\$369	\$345	\$86	\$800	\$49.60							
Restroom Lobby		2	2	40	184	60	95%	0.2	47.9	\$16.16	\$14.26	\$30.42	Surface 1x4, 2L-T8, 18" Fluorescent Ballast	60	0.1	31	\$19.84	\$115	\$75	\$25	\$235	\$10.58							
Bar Counter		2	4	40	368	60	95%	0.3	93.8	\$32.33	\$28.52	\$60.85	Recessed 2x4, 4L-T8, 18" Fluorescent Ballast	112	0.2	58	\$74.07	\$128	\$115	\$29	\$272	\$23.81							
Building 536	Food Counter	4	4	40	736	60	95%	0.7	191.7	\$64.66	\$57.04	\$121.69	Recessed 2x4, 4L-T8, 18" Fluorescent Ballast	112	0.4	117	\$74.07	\$256	\$230	\$58	\$544	\$47.62							
	Mens Room	1	2	40	92	60	95%	0.1	24.0	\$8.08	\$7.13	\$15.21	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.1	16	\$9.92	\$58	\$58	\$14	\$129	\$5.29							
	Dumb Waiter Room	1	4	40	184	60	95%	0.2	47.9	\$16.16	\$14.26	\$30.42	Recessed 2x4, 4L-T8, 18" Fluorescent Ballast	112	0.1	29	\$18.52	\$64	\$58	\$15	\$137	\$19.90							
	Womens Room	1	2	40	92	60	95%	0.1	24.0	\$8.08	\$7.13	\$15.21	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.1	16	\$9.92	\$58	\$58	\$14	\$129	\$5.29							
	Second Floor																												
	Corridor to Mens Room	1	2	40	92	60	95%	0.1	24.0	\$8.08	\$7.13	\$15.21	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.1	16	\$9.92	\$58	\$58	\$14	\$129	\$5.29							
	Mens Room	2	4	40	368	60	95%	0.3	93.8	\$32.33	\$28.52	\$60.85	Recessed 2x4, 4L-T8, 18" Fluorescent Ballast	112	0.2	58	\$74.07	\$128	\$115	\$29	\$272	\$23.81							
	Food Prep Room	5	4	40	920	60	95%	0.9	239.6	\$80.82	\$71.30	\$152.12	Recessed 2x4, 4L-T8, 18" Fluorescent Ballast	112	0.5	146	\$92.59	\$320	\$288	\$73	\$681	\$59.52							
	Womens Restroom	4	2	40	368	60	95%	0.3	93.8	\$32.33	\$28.52	\$60.85	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.2	62	\$37.04	\$230	\$230	\$55	\$515	\$21.16							
	Second Floor Entrance Lobby	2	4	40	368	60	95%	0.3	93.8	\$32.33	\$28.52	\$60.85	Recessed 2x4, 4L-T8, 18" Fluorescent Ballast	112	0.2	58	\$74.07	\$128	\$115	\$29	\$272	\$23.81							
Building 536	Dining Room	14	4	40	2576	60	95%	2.4	670.8	\$226.30	\$199.63	\$425.92	Recessed 2x4, 4L-T8, 18" Fluorescent Ballast	112	1.5	408	\$259.26	\$896	\$805	\$204	\$1,905	\$166.67							
	Handicap Restroom	1	4	40	184	60	95%	0.2	47.9	\$16.16	\$14.26	\$30.42	Recessed 2x4, 4L-T8, 18" Fluorescent Ballast	112	0.1	29	\$18.52	\$64	\$58	\$15	\$137	\$19.90							
	Building 530																												
	Cable TV for Housing																												
	Open Office Area	16	2	40	1472	50	95%	1.4	319.4	\$129.31	\$95.06	\$224.37	Industrial 4', 2L-T8, 18" Fluorescent Ballast	60	0.9	208	\$146.33	\$720	\$736	\$175	\$1,631	\$78.04							
	Bath House																												
	Mens Locker Area	7	2	40	644	168	95%	0.6	469.6	\$56.57	\$39.74	\$196.31	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.4	306	\$128.03	\$403	\$403	\$97	\$902	\$34.14							
	Mens Shower Area	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$20.85	\$112.18	Surface 1x4, 2L-T8, 18" Fluorescent Ballast	60	0.2	175	\$73.16	\$269	\$150	\$50	\$469	\$39.02							
	Womens Locker Area	3	2	40	276	168	95%	0.3	201.2	\$24.25	\$15.89	\$84.13	Recessed 2x4, 2L-T8, 18" Fluorescent Ballast	60	0.2	131	\$54.87	\$173	\$173	\$41	\$386	\$29.26							
	Womens Shower Area	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$20.85	\$112.18	Surface 1x4, 2L-T8, 18" Fluorescent Ballast	60	0.2	175	\$73.16	\$269	\$150	\$50	\$469	\$39.02							
Womens Pool Shower Area	2	4	40	184	168	95%	0.2	134.2	\$16.16	\$10.93	\$56.09	Surface wraparound, 1L-T8, 18" Fluorescent Ballast	31	0.1	45	\$18.90	\$101	\$66	\$20	\$187	\$37.19								
Mens Pool Shower Area Locked	2	2	40	184	168	95%	0.2	134.2	\$16.16	\$10.93	\$56.09	Surface wraparound, 1L-T8, 18" Fluorescent Ballast	31	0.1	45	\$18.90	\$101	\$66	\$20	\$187	\$37.19								

ECO-8D
Buildings 500 - 581
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Room		Existing										Proposed										Implementation					Energy Savings \$
		NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$						
Building 561																											
First Floor																											
	SIDS Office	8	4	40	1472	50	95%	1.4	319.4	\$129.31	\$95.06	\$224.37	Recessed 2x4, 4L-18 Elce Ballast	112	0.9	194	\$136.58	\$512	\$460	\$117	\$1,089	\$87.80					
	Copy Room	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Pendant 1x4, 2L-18 Elce Ballast	60	0.1	13	\$9.15	\$60	\$58	\$14	\$132	\$4.88					
	Copy Room	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Pendant 1x4, 4L-18 Elce Ballast	112	0.1	24	\$17.07	\$70	\$58	\$15	\$143	\$10.97					
	LEAD Valve Engin. Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-18 Elce Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95					
	Breakroom	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-18 Elce Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95					
	Dir. Resource Mgrs. Office	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	Pendant 1x4, 4L-18 Elce Ballast	112	0.6	146	\$102.43	\$420	\$345	\$92	\$857	\$65.85					
	Dir. Resource Mgrs. Resp. Area	5	2	40	400	50	95%	0.4	99.8	\$80.82	\$59.41	\$140.23	Pendant 1x4, 4L-18 Elce Ballast	112	0.5	122	\$85.36	\$350	\$288	\$77	\$715	\$54.87					
	Corridor	5	2	40	460	50	95%	0.4	99.8	\$40.41	\$29.71	\$70.12	Pendant 1x4, 2L-18 Elce Ballast	60	0.3	65	\$45.73	\$300	\$288	\$71	\$659	\$24.39					
	LEAD Valve Engin. Area	8	4	40	1472	50	95%	1.4	319.4	\$129.31	\$95.06	\$224.37	Pendant 1x4, 4L-18 Elce Ballast	112	0.9	194	\$136.58	\$560	\$460	\$122	\$1,142	\$87.80					
	Open Office Area	16	4	40	2944	50	95%	2.8	638.8	\$238.63	\$190.12	\$448.75	Pendant 1x4, 4L-18 Elce Ballast	112	1.7	389	\$273.15	\$1,120	\$920	\$245	\$2,285	\$175.60					
Second Floor																											
	Room #15 Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Pendant 1x4, 4L-18 Elce Ballast	112	0.4	97	\$68.29	\$280	\$230	\$61	\$571	\$43.90					
	Room #20A	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-18 Elce Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95					
	Room #20	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Pendant 1x4, 4L-18 Elce Ballast	112	0.3	73	\$51.22	\$210	\$173	\$46	\$429	\$32.92					
	Room #14 Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-18 Elce Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95					
	Room #19 Smoke Room	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Pendant 1x4, 4L-18 Elce Ballast	112	0.3	73	\$51.22	\$210	\$173	\$46	\$429	\$32.92					
	Room #8 & #10	5	4	40	920	50	95%	0.9	199.6	\$80.82	\$59.41	\$140.23	Pendant 1x4, 4L-18 Elce Ballast	112	0.5	122	\$85.36	\$350	\$288	\$77	\$715	\$54.87					
	Room #14A Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Pendant 1x4, 4L-18 Elce Ballast	112	0.3	73	\$51.22	\$210	\$173	\$46	\$429	\$32.92					
	Room #11 Office	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Pendant 1x4, 4L-18 Elce Ballast	112	0.1	24	\$17.07	\$70	\$58	\$15	\$143	\$10.97					
	Room #12 Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Pendant 1x4, 4L-18 Elce Ballast	112	0.3	73	\$51.22	\$210	\$173	\$46	\$429	\$32.92					
	Room #1 Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Pendant 1x4, 4L-18 Elce Ballast	112	0.3	73	\$51.22	\$210	\$173	\$46	\$429	\$32.92					
	Room #9 Office	1	4	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Pendant 1x4, 4L-18 Elce Ballast	112	0.1	24	\$17.07	\$70	\$58	\$15	\$143	\$10.97					
	Room #5 & #7 Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Pendant 1x4, 4L-18 Elce Ballast	112	0.4	97	\$68.29	\$280	\$230	\$61	\$571	\$43.90					
	Room #3 Office	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Pendant 1x4, 4L-18 Elce Ballast	112	0.3	73	\$51.22	\$210	\$173	\$46	\$429	\$32.92					
	Corridor	11	4	40	2024	50	95%	1.9	439.2	\$177.81	\$130.71	\$308.51	Pendant 1x4, 4L-18 Elce Ballast	112	1.2	267	\$187.79	\$770	\$633	\$168	\$1,571	\$120.72					
TOTALS		757			109940			104.4	27528	\$10,000	\$8,000	\$18,000			65.0	17119	\$11,000	\$47,000	\$43,000	\$10,800	\$100,000	\$6,700					
CAPROJECTS41310VSSNECECOO_8D.WK4																											

G:\PROJECTS\41301\SS\ECO-8D.WK4

ECO-8E
Buildings 616 - 5426
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Room	NO. Of Luminaires	Existing										Proposed										Implementation				
		Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$						
Building 616																										
Police Building																										
Police Conference Room	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$79.85	\$112.18	Industrial 4', 2L-18 Fluor Ballast	60	0.2	175	\$73.16	\$180	\$184	\$44	\$408	\$39.02					
Police Conference Room	4	4	40	736	168	95%	0.7	536.6	\$64.66	\$159.70	\$224.36	Pendant 1x4, 4L-18 Fluor Ballast	112	0.4	327	\$136.57	\$280	\$220	\$61	\$571	\$87.79					
Building 618																										
First Floor																										
Police Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Corridor	8	2	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 2L-18 Fluor Ballast	60	0.5	104	\$73.17	\$460	\$460	\$110	\$1,030	\$39.02					
Room #11 Office	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L-18 Fluor Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86					
Copy Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Coffee Mess	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Room #7	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Meeting Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Kitchen Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Water Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Hunting & Fishing Office	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L-18 Fluor Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86					
Second Floor																										
Wannock Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Corridor	8	2	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 2L-18 Fluor Ballast	60	0.5	104	\$73.17	\$460	\$460	\$110	\$1,030	\$39.02					
Stairwell to Second Floor	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	Recessed 2x4, 3L-18 Fluor Ballast	60	0.1	19	\$13.41	\$62	\$58	\$14	\$133	\$7.62					
Casinet	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L-18 Fluor Ballast	88	0.1	26	\$18.29	\$115	\$115	\$29	\$267	\$9.76					
Yeager Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Yeager Office	2	3	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 3L-18 Fluor Ballast	60	0.1	26	\$18.29	\$115	\$115	\$29	\$267	\$9.76					
Quinn Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Guesting Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Williams Office	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L-18 Fluor Ballast	60	0.1	26	\$18.29	\$115	\$115	\$29	\$267	\$9.76					
Expain Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Building 619																										
Dining Area																										
Dining Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Recessed 2x4, 3L-18 Fluor Ballast	60	0.1	13	\$9.15	\$58	\$58	\$14	\$129	\$4.88					
Staff Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Rear Dining Area	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Fluor Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90					
Open Dining Area	27	3	40	3726	50	95%	3.5	808.5	\$377.32	\$240.62	\$567.95	Recessed 2x4, 3L-18 Fluor Ballast	88	2.3	516	\$462.17	\$1,661	\$1,553	\$386	\$3,599	\$205.78					
Serving Area	7	2	40	644	50	95%	0.6	139.7	\$56.57	\$41.59	\$98.16	Recessed 2x4, 2L-18 Fluor Ballast	60	0.4	91	\$64.02	\$403	\$403	\$97	\$902	\$34.13					
Rear Dining Area	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	Recessed 2x4, 3L-18 Fluor Ballast	60	0.1	19	\$13.41	\$62	\$58	\$14	\$133	\$7.62					
Building 628																										
First Floor																										
Information Security	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Badge Photo Room	4	3	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 3L-18 Fluor Ballast	88	0.3	76	\$53.65	\$246	\$220	\$57	\$333	\$30.49					
First Floor Corridor	5	3	40	690	50	95%	0.7	149.7	\$60.62	\$44.56	\$105.18	Recessed 2x4, 3L-18 Fluor Ballast	88	0.4	95	\$67.07	\$308	\$288	\$71	\$666	\$38.11					
Copy Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Smoking Room	1	1	40	46	50	95%	0.0	10.0	\$4.04	\$2.97	\$7.01	Industrial 4', 1L-18 Fluor Ballast	31	0.0	7	\$4.73	\$40	\$46	\$10	\$96	\$2.29					
Automation Security Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Police Officers Room #3 Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Room #1 Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Physical Security	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	Recessed 2x4, 3L-18 Fluor Ballast	60	0.1	19	\$13.41	\$62	\$58	\$14	\$133	\$7.62					
Second Floor																										
Stairway to Second Floor	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Recessed 2x4, 2L-18 Fluor Ballast	60	0.1	13	\$9.15	\$58	\$58	\$14	\$129	\$4.88					
Corridor	5	3	40	690	50	95%	0.7	149.7	\$60.62	\$44.56	\$105.18	Recessed 2x4, 3L-18 Fluor Ballast	88	0.4	95	\$67.07	\$308	\$288	\$71	\$666	\$38.11					
Investigation Office Room #19	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Investigation Office Room #18	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L-18 Fluor Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86					
Interview Room #17	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Secretary & Plans Div. Office	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L-18 Fluor Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86					
Chief Secretary & Plans Div. Ofc.	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	Recessed 2x4, 3L-18 Fluor Ballast	88	0.3	57	\$40.24	\$185	\$173	\$43	\$400	\$22.86					
Director - PM Office Room #11	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					
Directorate Secretary Office	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 3L-18 Fluor Ballast	88	0.2	38	\$26.83	\$123	\$115	\$29	\$267	\$15.24					

ECO-8E
Buildings 616 - 5426
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Existing										Proposed										Implementation									
Room	NO. Of Luminaires	Lamps Per Luminaire	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$									
Building 639																													
Physical Fitness Center																													
Rear Entrance Lobby	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	Surface 1x4, 2L-18 Elc Ballast	60	0.1	44	\$18.20	\$67	\$38	\$13	\$118	\$9.75								
Weight Room Restroom	2	2	40	184	101	95%	0.2	80.7	\$16.16	\$24.00	\$40.17	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	53	\$26.20	\$115	\$115	\$28	\$258	\$13.97								
Weight Room	14	3	40	1932	168	95%	1.8	1408.7	\$169.72	\$419.22	\$588.94	Industrial 4', 3L-18 Elc Ballast	88	1.2	898	\$375.56	\$700	\$644	\$161	\$1,505	\$213.38								
Gym Entrance	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	Industrial 4', 2L-18 Elc Ballast	60	0.1	44	\$18.20	\$67	\$46	\$11	\$102	\$9.75								
Women's Rest Locker Room	3	2	40	184	168	95%	0.2	134.2	\$16.16	\$39.93	\$56.09	Recessed 2x4, 2L-18 Elc Ballast	112	0.2	82	\$34.40	\$64	\$58	\$15	\$137	\$21.95								
Corridor to Sauna	3	2	40	276	168	95%	0.3	201.2	\$24.25	\$59.89	\$84.13	Recessed 2x4, 2L-18 Elc Ballast	60	0.2	131	\$54.87	\$173	\$173	\$41	\$386	\$29.26								
Corridor to Women's Locker Rm.	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	44	\$18.20	\$67	\$58	\$14	\$129	\$9.75								
Women's Shower Room	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$79.85	\$112.18	Surface 1x4, 2L-18 Elc Ballast	60	0.2	175	\$73.16	\$269	\$150	\$50	\$469	\$39.02								
Corridor to Mens Locker Room	1	2	40	92	168	95%	0.1	67.1	\$8.08	\$19.96	\$28.04	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	44	\$18.20	\$67	\$58	\$14	\$129	\$9.75								
Gym Office	2	4	40	368	168	95%	0.3	268.3	\$32.33	\$79.85	\$112.18	Pendant 1x4, 4L-18 Elc Ballast	112	0.2	163	\$68.28	\$140	\$115	\$31	\$286	\$43.90								
Corridor to Restroom	2	2	40	184	168	95%	0.2	134.2	\$16.16	\$39.93	\$56.09	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	44	\$18.20	\$67	\$58	\$14	\$129	\$9.75								
Mens Locker Room	4	4	40	736	168	95%	0.7	536.6	\$64.66	\$159.70	\$224.36	Recessed 2x4, 4L-18 Elc Ballast	112	0.4	377	\$136.57	\$256	\$230	\$58	\$544	\$87.79								
Women's Locker Room	4	4	40	736	168	95%	0.7	536.6	\$64.66	\$159.70	\$224.36	Recessed 2x4, 4L-18 Elc Ballast	112	0.4	377	\$136.57	\$256	\$230	\$58	\$544	\$87.79								
Mens Shower Room	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$79.85	\$112.18	Surface 1x4, 2L-18 Elc Ballast	60	0.2	175	\$73.16	\$269	\$150	\$50	\$469	\$39.02								
Mens Rest Locker Room	4	2	40	368	168	95%	0.3	268.3	\$32.33	\$79.85	\$112.18	Surface 1x4, 2L-18 Elc Ballast	60	0.2	175	\$73.16	\$269	\$150	\$50	\$469	\$39.02								
Gym Entrance	1	1	40	184	168	95%	0.2	134.2	\$16.16	\$39.93	\$56.09	Recessed 2x4, 4L-18 Elc Ballast	112	0.1	82	\$34.40	\$64	\$58	\$15	\$137	\$21.95								
				46	168	95%	0.0	33.5	\$4.04	\$9.98	\$14.02	Surface wraparound, 1L-18 Elc Ballast	31	0.0	23	\$9.45	\$51	\$33	\$10	\$93	\$4.57								
Building 645																													
Day Care																													
Entrance Lobby	1	2	40	92	90	95%	0.1	35.9	\$8.08	\$10.69	\$18.78	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	23	\$12.25	\$58	\$58	\$14	\$129	\$6.53								
Changing Area	2	2	40	184	54	95%	0.2	43.1	\$16.16	\$12.83	\$29.00	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	28	\$18.91	\$115	\$115	\$28	\$258	\$10.09								
Bathroom #3	1	2	40	92	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	14	\$9.46	\$58	\$58	\$14	\$129	\$5.04								
Baby Area	4	2	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Recessed 2x4, 2L-18 Elc Ballast	60	0.2	94	\$48.98	\$230	\$230	\$55	\$515	\$26.12								
Bathroom #2	1	2	40	92	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	14	\$9.46	\$58	\$58	\$14	\$129	\$5.04								
Kitchen Area	1	2	40	92	90	95%	0.1	35.9	\$8.08	\$10.69	\$18.78	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	23	\$12.25	\$58	\$58	\$14	\$129	\$6.53								
Bathroom #1	1	2	40	92	54	95%	0.1	21.6	\$8.08	\$6.42	\$14.50	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	14	\$9.46	\$58	\$58	\$14	\$129	\$5.04								
Play Area	16	2	40	1472	90	95%	1.4	575.0	\$129.31	\$171.11	\$300.42	Recessed 2x4, 2L-18 Elc Ballast	60	0.9	375	\$195.93	\$920	\$920	\$221	\$2,061	\$104.49								
Staff Office	3	2	40	276	90	95%	0.3	107.8	\$24.25	\$32.08	\$56.33	Recessed 2x4, 2L-18 Elc Ballast	60	0.2	70	\$36.74	\$173	\$173	\$41	\$386	\$19.59								
Building 646																													
Youth Center																													
Entrance Area	2	3	40	276	126	95%	0.3	150.9	\$24.25	\$44.92	\$69.16	Recessed 2x4, 3L-18 Elc Ballast	88	0.2	96	\$44.10	\$123	\$115	\$29	\$267	\$25.06								
Lounge Area	5	3	40	690	126	95%	0.7	377.3	\$60.62	\$112.29	\$172.91	Recessed 2x4, 3L-18 Elc Ballast	88	0.4	241	\$110.26	\$308	\$288	\$71	\$666	\$62.65								
Girls Room	2	2	40	184	76	95%	0.2	60.7	\$16.16	\$18.06	\$34.23	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	40	\$22.32	\$115	\$115	\$28	\$258	\$11.90								
Boys Room	2	2	40	184	76	95%	0.2	60.7	\$16.16	\$18.06	\$34.23	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	40	\$22.32	\$115	\$115	\$28	\$258	\$11.90								
Staff Office	2	3	40	276	126	95%	0.3	150.9	\$24.25	\$44.92	\$69.16	Recessed 2x4, 3L-18 Elc Ballast	88	0.2	96	\$44.10	\$123	\$115	\$29	\$267	\$25.06								
Corridor to Play Room	1	2	40	92	126	95%	0.1	50.3	\$8.08	\$14.97	\$23.05	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	33	\$15.04	\$58	\$58	\$14	\$129	\$6.02								
Play Room	2	3	40	276	126	95%	0.3	150.9	\$24.25	\$44.92	\$69.16	Recessed 2x4, 3L-18 Elc Ballast	88	0.2	96	\$44.10	\$123	\$115	\$29	\$267	\$25.06								
Open Area	20	2	40	1840	126	95%	1.7	1006.2	\$161.64	\$299.44	\$461.08	Recessed 2x4, 2L-18 Elc Ballast	60	1.1	656	\$300.71	\$1,150	\$1,150	\$276	\$2,576	\$160.38								
Kitchen	1	3	40	138	126	95%	0.1	75.5	\$12.12	\$22.46	\$34.58	Recessed 2x4, 3L-18 Elc Ballast	88	0.1	48	\$22.05	\$62	\$58	\$14	\$133	\$12.53								
Kitchen	2	2	40	184	126	95%	0.2	100.6	\$16.16	\$29.94	\$46.11	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	66	\$30.07	\$115	\$115	\$28	\$258	\$16.04								
Building 663																													
Administration & Trades																													
Heating & Plumbing Shop Area	19	4	40	3496	90	95%	3.3	1365.5	\$347.12	\$606.38	\$713.50	Pendant 1x4, 4L-18 Elc Ballast	112	2.0	831	\$434.31	\$1,330	\$1,093	\$291	\$2,714	\$279.20								
Main Entrance Lobby	4	4	40	736	90	95%	0.7	287.5	\$44.66	\$85.55	\$150.21	Recessed 2x4, 2L-18 Elc Ballast	112	0.4	175	\$91.43	\$256	\$230	\$58	\$544	\$58.78								
Lunch Area	8	4	40	1472	90	95%	1.4	575.0	\$129.31	\$171.11	\$300.42	Recessed 2x4, 4L-18 Elc Ballast	112	0.9	350	\$182.87	\$512	\$460	\$117	\$1,089	\$117.56								
Production Division Office #3	4	2	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Recessed 2x4, 4L-18 Elc Ballast	60	0.2	94	\$48.98	\$230	\$230	\$55	\$515	\$26.12								
Production Division Office #2	2	2	40	184	90	95%	0.2	71.9	\$16.16	\$21.39	\$37.55	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	47	\$24.49	\$115	\$115	\$28	\$258	\$13.06								
Heating Branch Office Front Rm	6	4	40	1104	90	95%	1.0	431.2	\$96.98	\$128.33	\$225.32	Recessed 2x4, 2L-18 Elc Ballast	112	0.6	262	\$137.15	\$384	\$345	\$87	\$816	\$88.17								
Heating Branch Office Back Rm	2	4	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Recessed 2x4, 4L-18 Elc Ballast	112	0.2	87	\$45.72	\$258	\$115	\$29	\$272	\$29.39								
Production Division Office #1	1	2	40	92	90	95%	0.1	35.9	\$8.08	\$10.69	\$18.78	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	23	\$12.25	\$58	\$58	\$14	\$129	\$6.53								
Building & Structural Office	4	2	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Recessed 2x4, 2L-18 Elc Ballast	112	0.2	94	\$48.98	\$230	\$230	\$55	\$515	\$26.12								
S. C. Office	3	3	40	414	90	95%	0.4	161.7	\$36.37	\$48.12	\$84.49	Pendant 1x4, 3L-18 Elc Ballast	88	0.2	93	\$33.88	\$230	\$170	\$44	\$412	\$30.61								
Dispatch Office	2	4	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Recessed 2x4, 4L-18 Elc Ballast	112	0.2	87	\$45.72	\$259	\$230	\$55	\$515	\$26.12								
Heating Supply Cage	1	3	40	736	90	95%	0.7	287.5	\$44.66	\$85.55	\$150.21	Industrial 4', 3L-18 Elc Ballast	112	0.2	87	\$45.72	\$259	\$184	\$48	\$452	\$58.78								
Dispatch Corridor	4	4	40	1472	90	95%	1.4	575.0	\$129.31	\$171.11	\$300.42	Industrial 4', 3L-18 Elc Ballast	88	0.3	347	\$171.84	\$246	\$230	\$57	\$533	\$10.20								
Computer Room	1	3	40	552	90	95%	0.5	215.6	\$48.49	\$64.17	\$112.66	Recessed 2x4, 3L-18 Elc Ballast	88	0.1	34	\$91.96	\$50	\$46	\$12	\$108	\$40.82								
Welding Shop Area	30	3	40	4140	90	95%	3.9	1617.1	\$563.69	\$481.24	\$844.94	Industrial 4', 3L-18 Elc Ballast	88	2.5	1,031	\$538.80	\$1,500	\$1,360	\$346	\$3,226	\$306.14								
Production Division Office #1	2	4	40	368	90	95%	0.3	143.7	\$32.33	\$42.78	\$75.11	Recessed 2x4, 4L-18 Elc Ballast	112	0.2	87	\$45.72	\$259	\$115	\$29	\$272	\$29.39								
Operations & Maint. Conf. Room	2	3	40	276	63	95%	0.3	75.5	\$24.25	\$22.46	\$34.58	Recessed 2x4, 4L-18 Elc Ballast	88	0.2	48	\$29.78	\$128	\$115	\$29	\$267	\$16.02								
Work Planning & Control Office	12	4	40	2708	90	95%	2.1	802.4	\$193.97	\$256.66	\$450.63	Recessed 2x4, 4L-18 Elc Ballast	112	1.3	525	\$274.30	\$768	\$690	\$175	\$1,633	\$176.33								

ECO-8E
Buildings 616 - 5426
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

Existing												Proposed					Implementation				
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost	Mat. Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$	Energy Savings \$
Building 664																					
Copy Room	1	4	40	160	54	95%	0.2	43.1	\$16.16	\$12.83	\$29.00	Surface 1x4, 2L-18 Elc Ballast	60	0.1	14	\$9.46	\$67	\$38	\$13	\$118	\$19.54
Computer Room	1	2	40	80	92	90	0.5%	35.9	\$8.08	\$10.69	\$18.78	Industrial 4', 2L-18 Elc Ballast	60	0.1	23	\$27.25	\$45	\$46	\$11	\$102	\$6.53
Women's Room	2	3	40	276	54	95%	0.3	64.7	\$24.25	\$19.25	\$43.50	Recessed 2x4, 3L-18 Elc Ballast	88	0.2	41	\$12.74	\$123	\$115	\$29	\$267	\$15.76
Men's Room	2	3	40	276	54	95%	0.3	64.7	\$24.25	\$19.25	\$43.50	Recessed 2x4, 3L-18 Elc Ballast	88	0.2	41	\$27.74	\$123	\$115	\$29	\$267	\$15.76
Conference Room	7	3	40	966	63	95%	0.9	264.1	\$84.86	\$78.60	\$163.46	Recessed 2x4, 3L-18 Elc Ballast	88	0.6	168	\$104.24	\$431	\$403	\$200	\$933	\$59.23
Corridor to Drawing Files Area	2	3	40	276	90	95%	0.3	107.8	\$24.25	\$22.08	\$56.33	Recessed 2x4, 3L-18 Elc Ballast	88	0.2	69	\$35.92	\$123	\$115	\$29	\$267	\$20.41
Director of Public Works	1	4	40	160	184	90	0.5%	71.9	\$16.16	\$21.30	\$37.55	Recessed 2x4, 4L-18 Elc Ballast	112	0.2	44	\$22.86	\$64	\$38	\$15	\$137	\$14.69
Director of Public Works	3	2	40	276	90	95%	0.3	107.8	\$24.25	\$22.08	\$56.33	Recessed 2x4, 4L-18 Elc Ballast	60	0.2	70	\$36.74	\$173	\$173	\$41	\$386	\$19.59
Office	2	3	40	276	90	95%	0.3	107.8	\$24.25	\$22.08	\$56.33	Recessed 2x4, 3L-18 Elc Ballast	88	0.3	103	\$35.88	\$185	\$173	\$43	\$500	\$30.61
Office	1	4	40	160	184	54	0.5%	43.1	\$16.16	\$12.83	\$29.00	Surface 1x4, 2L-18 Elc Ballast	88	0.2	69	\$35.92	\$123	\$115	\$29	\$267	\$20.41
Print Room	8	4	40	1472	54	95%	1.4	345.0	\$129.31	\$102.67	\$231.98	Pendant 1x4, 4L-18 Elc Ballast	112	0.9	210	\$141.20	\$560	\$460	\$122	\$1142	\$90.77
Drawing Files Area	47	3	40	6846	90	95%	6.2	2533.4	\$569.78	\$753.95	\$1324.81	Recessed 2x4, 3L-18 Elc Ballast	88	3.9	1616	\$844.12	\$2891	\$2703	\$671	\$6264	\$479.61
Open Office Area	3	1	75	225	75	90	0.5%	101.1	\$22.73	\$30.08	\$52.81	Strip, 1L-18, Elc Ballast	31	0.1	36	\$18.98	\$75	\$86	\$19	\$180	\$33.83
Corridor to Snack Bar	12	4	40	2208	90	95%	2.1	862.4	\$193.97	\$256.66	\$450.63	Recessed 2x4, 4L-18 Elc Ballast	112	1.3	525	\$274.30	\$768	\$690	\$175	\$1633	\$176.33
Operative & Maint. Room	7	1	75	607.5	90	95%	0.6	235.8	\$53.04	\$70.18	\$123.22	Strip, 1L-18, Elc Ballast	31	0.2	85	\$44.29	\$175	\$200	\$45	\$420	\$78.93
Electrical Supply	2	3	40	276	90	95%	0.3	107.8	\$24.25	\$22.08	\$56.33	Industrial 4', 3L-18 Elc Ballast	88	0.2	94	\$35.92	\$100	\$92	\$23	\$215	\$20.41
Electrical Supply	4	2	40	368	90	95%	0.3	143.7	\$32.53	\$42.78	\$75.11	Recessed 2x4, 2L-18 Elc Ballast	60	0.2	94	\$48.98	\$200	\$230	\$55	\$515	\$26.12
Office	1	2	40	80	92	90	0.5%	35.9	\$8.08	\$10.69	\$18.78	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	23	\$12.25	\$38	\$38	\$14	\$129	\$6.53
Corridor to Snack Bar	14	2	40	1288	90	95%	1.2	503.1	\$133.15	\$149.72	\$262.87	Industrial 4', 2L-18 Elc Ballast	60	0.8	328	\$171.44	\$630	\$644	\$153	\$1427	\$91.43
Receiving - Supply Area	34	4	40	6256	90	95%	5.9	2443.6	\$549.58	\$777.21	\$1277.77	Pendant 1x4, 4L-18 Elc Ballast	112	3.6	1487	\$777.18	\$2380	\$1955	\$520	\$4855	\$499.61
Drafting Office Area	8	4	40	1472	90	95%	1.4	575.0	\$129.31	\$171.11	\$300.42	Recessed 2x4, 4L-18 Elc Ballast	112	0.9	350	\$182.87	\$512	\$460	\$117	\$1089	\$117.56
Engineering Office Area	1	2	40	80	92	54	0.5%	21.6	\$8.08	\$6.42	\$14.50	Industrial 4', 2L-18 Elc Ballast	60	0.1	14	\$9.46	\$45	\$46	\$11	\$102	\$5.04
Building 664																					
First Floor																					
Entrance Lobby	1	2	40	80	92	50	0.5%	20.0	\$8.08	\$5.94	\$14.02	Industrial 4', 2L-18 Elc Ballast	60	0.1	13	\$9.15	\$45	\$46	\$11	\$102	\$4.88
Corridor to Restroom	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Pendant 1x4, 4L-18 Elc Ballast	112	0.4	97	\$68.29	\$280	\$230	\$61	\$571	\$43.90
Open Office Area	9	4	40	1656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	Recessed 2x4, 4L-18 Elc Ballast	112	1.0	219	\$153.65	\$576	\$518	\$131	\$1225	\$98.77
Empty Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Elc Ballast	112	0.4	97	\$68.29	\$256	\$230	\$58	\$544	\$43.90
Issue Center Office	9	4	40	1656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	Recessed 2x4, 4L-18 Elc Ballast	112	1.0	219	\$153.65	\$576	\$518	\$131	\$1225	\$98.77
Second Floor																					
Library Check Out	2	2	40	160	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Surface 1x4, 2L-18 Elc Ballast	60	0.1	26	\$18.29	\$135	\$75	\$25	\$235	\$9.76
Chaplain's Office	1	3	40	120	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	Surface 1x4, 2L-18 Elc Ballast	60	0.1	13	\$9.15	\$67	\$38	\$13	\$118	\$11.89
Reading Room	2	3	40	276	50	95%	0.3	59.9	\$24.25	\$17.82	\$42.07	Surface 1x4, 2L-18 Elc Ballast	60	0.1	26	\$18.29	\$135	\$75	\$25	\$235	\$9.76
Children's Room	1	3	40	120	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	Surface 1x4, 2L-18 Elc Ballast	60	0.1	13	\$9.15	\$67	\$38	\$13	\$118	\$11.89
Library Stacks	36	2	40	3312	50	95%	3.1	718.7	\$290.95	\$213.89	\$504.84	Industrial 4', 2L-18 Elc Ballast	60	2.1	469	\$329.24	\$1620	\$1656	\$393	\$3660	\$175.60
Reading Room	2	2	40	160	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 1x4, 2L-18 Elc Ballast	60	0.1	26	\$18.29	\$110	\$88	\$24	\$222	\$9.76
Administrative Office	2	2	40	160	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Recessed 1x4, 2L-18 Elc Ballast	60	0.1	26	\$18.29	\$110	\$88	\$24	\$222	\$9.76
Library	1	2	40	80	92	50	0.5%	20.0	\$8.08	\$5.94	\$14.02	Recessed 1x4, 2L-18 Elc Ballast	60	0.1	13	\$9.15	\$55	\$44	\$12	\$111	\$4.88
Class Room	1	2	40	80	92	50	0.5%	20.0	\$8.08	\$5.94	\$14.02	Recessed 1x4, 2L-18 Elc Ballast	60	0.1	13	\$9.15	\$55	\$44	\$12	\$111	\$4.88
Sunday School Room	5	2	40	460	50	95%	0.4	99.8	\$40.41	\$29.71	\$70.12	Recessed 1x4, 2L-18 Elc Ballast	60	0.3	65	\$45.73	\$275	\$220	\$59	\$554	\$24.39
Office	2	3	40	276	50	95%	0.3	39.9	\$24.25	\$17.82	\$42.07	Surface 1x4, 2L-18 Elc Ballast	60	0.1	26	\$18.29	\$135	\$75	\$25	\$235	\$9.76
Building 2260																					
Administration																					
Distri. Branch Chief Reception	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	Recessed 2x4, 4L-18 Elc Ballast	112	0.6	146	\$102.43	\$384	\$345	\$87	\$816	\$65.85
Open Office Area	52	4	40	9568	50	95%	9.1	2076.3	\$840.53	\$617.89	\$1458.43	Recessed 2x4, 4L-18 Elc Ballast	112	5.5	1264	\$887.74	\$3328	\$2990	\$738	\$7076	\$570.69
Property Disposal Officer	8	4	40	1472	50	95%	1.4	319.4	\$129.31	\$95.06	\$224.37	Recessed 2x4, 4L-18 Elc Ballast	112	0.9	194	\$136.58	\$512	\$460	\$117	\$1089	\$87.80
Distri. Branch Chief Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Recessed 2x4, 4L-18 Elc Ballast	112	0.4	97	\$68.29	\$256	\$220	\$58	\$544	\$43.90
Exit Lobby	1	4	40	160	184	50	0.5%	43.1	\$16.16	\$11.88	\$28.05	Recessed 2x4, 4L-18 Elc Ballast	112	0.1	24	\$17.07	\$64	\$38	\$15	\$137	\$10.97
Building 2219																					
Pestleide																					
Pestleide Sink Area	3	2	40	276	50	95%	0.3	39.9	\$24.25	\$17.82	\$42.07	Surface 1x4, 2L-18 Elc Ballast	60	0.2	39	\$27.44	\$202	\$113	\$38	\$352	\$14.63
Staff Office	3	2	40	276	50	95%	0.3	39.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 2L-18 Elc Ballast	60	0.2	39	\$27.44	\$173	\$173	\$41	\$386	\$14.63
Corridor	2	2	40	160	184	50	0.5%	43.1	\$16.16	\$11.88	\$28.05	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	26	\$18.29	\$115	\$115	\$28	\$258	\$9.76
Building 2755																					
Warehouse																					
Corridor to Rest Room	3	2	40	276	50	95%	0.3	39.9	\$24.25	\$17.82	\$42.07	Recessed 2x4, 2L-18 Elc Ballast	60	0.2	39	\$27.44	\$173	\$173	\$41	\$386	\$14.63
Main Corridor	1	2	40	80	92	50	0.5%	20.0	\$8.08	\$5.94	\$14.02	Recessed 2x4, 2L-18 Elc Ballast	60	0.1	13	\$9.15	\$58	\$58	\$14	\$129	\$4.88
File Room	3	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Recessed 2x4, 4L-18 Elc Ballast	112	0.3	73	\$51.22	\$192	\$173	\$44	\$409	\$32.92
Open Office Area	12	4	40	2208	49	95%	2.1	479.1	\$193.97	\$136.56	\$336.56	Recessed 2x4, 4L-18 Elc Ballast	112	1.3	292	\$204.86	\$768	\$690	\$175	\$1633	\$131.70
Breakroom	6	2	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Industrial 4', 2L-18 Elc Ballast	60	0.3	78	\$54.87	\$270	\$276	\$66	\$612	\$29.27

ECO-8E
Buildings 616 - 5426
Letterkenny Army Depot
Efficient Fluorescent Fixture Replacement

		Existing										Proposed										Implementation									
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Max. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$										
Building 3321																															
Administration																															
Surveillance Office #1	18	4	40	3312	50	95%	3.1	718.7	\$290.95	\$213.89	\$504.84	Pendant 1x4, 4L-78 Elce Ballast	112	1.9	437	\$307.29	\$1,260	\$1,035	\$275	\$2,570	\$197.55										
Smoke Room	1	3	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	Industrial 4', 3L-78 Elce Ballast	88	0.1	19	\$13.41	\$50	\$46	\$12	\$108	\$7.62										
Smoke Room	2	1	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Surface wraparound 1L-78 Elce Ballast	31	0.1	13	\$9.45	\$101	\$66	\$20	\$187	\$4.57										
Vending Area	1	2	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Pendant 1x4, 2L-78 Elce Ballast	60	0.1	13	\$9.15	\$60	\$38	\$14	\$132	\$4.88										
Surveillance Office #2	4	4	40	736	50	95%	0.7	150.7	\$64.66	\$47.53	\$112.19	Pendant 1x4, 4L-78 Elce Ballast	112	0.4	97	\$68.29	\$280	\$230	\$61	\$771	\$43.90										
Entrance Lobby	1	1	40	46	50	95%	0.0	10.0	\$4.04	\$2.97	\$7.01	Surface wraparound, 1L-78 Elce Ballast	31	0.0	7	\$4.73	\$51	\$33	\$10	\$93	\$2.29										
Office #9	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Surface wraparound, 1L-78 Elce Ballast	31	0.1	13	\$9.45	\$101	\$66	\$20	\$187	\$18.60										
Office #15	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Surface wraparound, 1L-78 Elce Ballast	31	0.1	27	\$18.90	\$202	\$131	\$40	\$373	\$37.19										
Office #13	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Surface wraparound, 1L-78 Elce Ballast	31	0.1	27	\$18.90	\$202	\$131	\$40	\$373	\$37.19										
Entrance #13 & #14	2	2	40	368	50	95%	0.2	39.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L-78 Elce Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$18.60										
Office #10	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Surface wraparound, 1L-78 Elce Ballast	31	0.1	13	\$9.45	\$101	\$66	\$20	\$272	\$18.60										
Office #12	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Surface wraparound, 1L-78 Elce Ballast	31	0.1	13	\$9.45	\$101	\$66	\$20	\$272	\$18.60										
Office #11	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Surface wraparound, 1L-78 Elce Ballast	31	0.1	26	\$18.29	\$90	\$92	\$22	\$204	\$8.76										
Vending Area	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	Surface wraparound, 1L-78 Elce Ballast	60	0.1	13	\$9.45	\$101	\$66	\$20	\$187	\$18.60										
Office #8	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-78 Elce Ballast	112	0.2	146	\$102.43	\$420	\$345	\$92	\$857	\$65.85										
Office #9	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Pendant 1x4, 2L-78 Elce Ballast	112	0.6	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95										
Office #4	12	4	40	2208	50	95%	2.1	479.1	\$193.97	\$142.59	\$336.56	Pendant 1x4, 2L-78 Elce Ballast	60	0.2	52	\$36.58	\$240	\$230	\$56	\$526	\$19.51										
Director Surveillance Office	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Pendant 1x4, 4L-78 Elce Ballast	112	1.3	292	\$204.86	\$840	\$690	\$184	\$1,714	\$131.70										
Office #1	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Surface 1x4, 2L-78 Elce Ballast	112	0.4	97	\$68.29	\$280	\$230	\$61	\$571	\$43.90										
Office #2	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Surface 1x4, 2L-78 Elce Ballast	60	0.1	26	\$18.29	\$135	\$75	\$25	\$235	\$37.80										
Office #3	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	Pendant 1x4, 4L-78 Elce Ballast	112	0.6	146	\$102.43	\$420	\$345	\$92	\$857	\$43.90										
Open Office Area	30	4	40	5520	50	95%	5.2	1197.8	\$484.92	\$356.48	\$841.40	Pendant 1x4, 4L-78 Elce Ballast	112	3.2	729	\$512.16	\$2,100	\$1,725	\$459	\$4,284	\$329.24										
Office #5	6	4	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	Pendant 1x4, 4L-78 Elce Ballast	112	0.6	146	\$102.43	\$420	\$345	\$92	\$857	\$65.85										
Exit Corridor	2	1	40	92	50	95%	0.1	20.0	\$8.08	\$5.94	\$14.02	Surface wraparound, 1L-78 Elce Ballast	31	0.1	13	\$9.45	\$101	\$66	\$20	\$187	\$4.57										
Office #5	12	4	40	2208	50	95%	2.1	479.1	\$193.97	\$142.59	\$336.56	Surface wraparound, 1L-78 Elce Ballast	112	1.3	292	\$204.86	\$840	\$690	\$184	\$1,714	\$131.70										
Insurance Corridor	8	1	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Surface wraparound, 1L-78 Elce Ballast	31	0.2	54	\$37.80	\$405	\$262	\$80	\$747	\$18.29										
Copy and Mail Room	4	4	40	736	50	95%	0.7	159.7	\$64.66	\$47.53	\$112.19	Pendant 1x4, 4L-78 Elce Ballast	112	0.4	97	\$68.29	\$280	\$230	\$61	\$571	\$43.90										
Office #6	9	4	40	1656	50	95%	1.6	359.4	\$145.48	\$106.94	\$252.42	Pendant 1x4, 4L-78 Elce Ballast	112	1.0	219	\$153.65	\$630	\$518	\$138	\$1,286	\$98.77										
Office #7	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-78 Elce Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95										
Building 3315																															
Warehouse																															
Managers Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L-78 Elce Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95										
Office Area	12	2	40	1104	50	95%	1.0	239.6	\$96.98	\$71.30	\$168.28	Pendant 1x4, 2L-78 Elce Ballast	60	0.7	156	\$109.75	\$720	\$690	\$169	\$1,579	\$58.53										
Break Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Recessed 2x4, 4L-78 Elce Ballast	112	0.2	49	\$34.14	\$128	\$115	\$29	\$272	\$21.95										
Key Area	10	2	40	920	50	95%	0.9	199.6	\$80.82	\$59.41	\$140.23	Surface wraparound, 1L-78 Elce Ballast	31	0.3	67	\$47.25	\$506	\$328	\$100	\$931	\$92.98										
Key Area	2	2	40	184	50	95%	0.2	39.9	\$16.16	\$11.88	\$28.05	Pendant 1x4, 2L-78 Elce Ballast	60	0.1	26	\$18.29	\$120	\$115	\$28	\$263	\$9.76										
Building 3321																															
Hunter Check-In																															
Meeting Room	3	1	40	138	50	95%	0.1	29.9	\$12.12	\$8.91	\$21.04	Surface wraparound, 1L-78 Elce Ballast	31	0.1	20	\$14.18	\$152	\$98	\$30	\$280	\$6.86										
Meeting Room	4	2	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Industrial 4', 2L-78 Elce Ballast	60	0.2	52	\$36.58	\$180	\$184	\$44	\$408	\$19.51										
Meeting Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Pendant 1x4, 2L-78 Elce Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95										
Locker Room	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-78 Elce Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95										
Office	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Pendant 1x4, 4L-78 Elce Ballast	112	0.2	49	\$34.14	\$140	\$115	\$31	\$286	\$21.95										
Building 5026																															
Warehouse																															
Office	7	4	40	1288	50	95%	1.2	279.5	\$113.15	\$83.18	\$196.33	Recessed 2x4, 4L-78 Elce Ballast	112	0.7	170	\$119.50	\$448	\$403	\$102	\$953	\$76.82										
TOTALS																															
C:\PROJECTS\130\JMS\SEC\OBCO_8E\W4		915		13283			126.2	40850	\$12,000	\$12,000	\$24,000			77.6	25224	\$15,000	\$57,000	\$50,000	\$13,000	\$120,000	\$9,000										

G:\PROJECTS\1430\101SS\ECO8E\WK4

22 May 98

ECO-9 Fluorescent Reflectors

Existing.

Thirty of the buildings at the Letterkenny Army Depot contain approximately 1,342 fluorescent luminaires that contain three and four lamps. The luminaires generally are located in office and administration areas. These luminaires provide illumination levels of 40 foot candles or greater for three lamp luminaires and 50 foot candles or greater for four lamp luminaires. Typically, the office areas contained desk lamps which were energized as well as the room lights.

In accordance with DOE/EE-0008, Advance Lighting Guidelines: 1993 and the Illuminating Engineering Society, the target maintained light levels for the selected areas is 20 - 50 foot candles. The attached data table for ECO-9 lists the areas which Entech has determined to fall into these categories.

Electric Demand = 2,518 kW/yr (209.8 kW/mo x 12 mo/yr)

Electric Usage = 911,556 kWh/yr (75,963 kWh/mo x 12 mo/yr)

Electric Cost = \$42,000 (2,518 kW/yr x \$7.706/kW) + (911,556 kWh/yr x \$.0248/kWh) = \$42,010, use \$42,000

Proposed.

The three lamp luminaires will have 1 lamp and 1 ballast removed while the four lamp luminaires will have 2 lamps and 1 ballast removed. All luminaires will receive new high reflectivity specular aluminum reflector. In accordance with DOE/EE-0008, delamping a four lamp F40T12 with magnetic ballast to two lamps and adding a reflector will result in a 41% reduction in the light output of the luminaire. Assuming the reduction to be linear, delamping a three lamp

F40T12 with magnetic ballast to two lamps and adding a reflector will result in a 21 % reduction in the luminaire light output. Entech expects the resulting illumination levels to be 30 foot candles or more based on the criteria used to select the areas for reflectors.

Electric Demand = 1,408 kW/yr (117.3 kW/mo x 12 mo/yr)

Electric Usage = 493,428 kWh/yr (41,119 kW/mo x 12 mo/yr)

Electric Cost = \$23,000 (1,408 kW/yr x \$7.706/kW) + (493,428 kWh/yr x \$.0248/kWh) = \$23,087, use \$23,000

Implementation Cost. The expected construction cost for implementing the project is expected to be \$180,000. The breakdown is noted below and shown on the attached ECO data table.

Material	\$107,000
Labor	\$ 54,000
Engineering	<u>\$ 19,000</u>

Total \$180,000

Energy Savings. The annual electric demand, usage, and cost savings is noted below:

Electric Demand = 1,110 kW/yr (2,518 - 1,408)

Electric Usage = 418,128 kWh/yr (911,556 - 493,428)

Energy Cost = \$19,000/yr (\$42,000 - \$23,000)

Annual Energy Savings = 1,427 mmBtu/yr

Energy Usage = $1,427 \text{ mmBtu/yr} (418,128 \text{ kWh/yr} \times 3,413 \text{ Btu/kWh}) \div 1,000,000 \text{ Btu/mmBtu}$

Maintenance Savings.

By delamping and adding reflectors, a maintenance savings will result because there will be approximately 271 less lamps and 671 less ballast to replace. The annual maintenance savings is noted below:

Data

Fluorescent Lamp Life	=	20,000 hours
Ballast Life	=	100,000 hours
Operation Period Per Year	=	3,224 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes
Fluorescent Lamp Cost	=	\$4 each
Ballast Cost	=	\$20 each
Total Quantity Lamps Removed	=	271
Total Quantity Ballast Removed	=	671

Calculation

Maintenance (Fluorescent Lamp) = $\$1.72 (20 \times 1/3 + 4) \times 3,224/20,000$

Maintenance (Ballast) = $\$.86 (20 \times 1/3 + 20) \times 3,224/100,000$

Annual Recurring Maintenance Savings = $\$1,000 (1.72 \times 271) + (.86 \times 671) = \$1,043$, use \$1,000

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations, construction supervision, and annual recurring maintenance costs in addition to construction cost and engineering services. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 9.45 years with a savings to investment ratio of 1.87.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO9

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO9

ANALYSIS DATE: 04-19-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	161000.	
B. SIOH	\$	8855.	
C. DESIGN COST	\$	19000.	
D. TOTAL COST (1A+1B+1C)	\$	188855.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$	188855.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	1427.	\$ 10374.	18.17	\$ 188501.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 8600.	17.22	\$ 148092.
N. TOTAL		1427.	\$ 18974.		\$ 336593.

3. NON ENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)		\$ 1000.
(1) DISCOUNT FACTOR (TABLE A)	17.22	
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$ 17220.

B. NON RECURRING SAVINGS (+) / COSTS (-)

ITEM	SAVINGS (+) COST (-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS (+) / COST (-) (4)
d. TOTAL	\$ 0.			0.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS (+) / COST (-) (3A2+3Bd4) \$ 17220.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 19974.

5. SIMPLE PAYBACK PERIOD (1G/4) 9.45 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 353813.

7. SAVINGS TO INVESTMENT RATIO (SIR) = (6 / 1G) = 1.87
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 5.72 %

**ECO-9
Letterkenny Army Depot
Fluorescent Reflectors**

Existing										Proposed					Implementation						
Room	NO Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost (\$)	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost (\$)	Mat. Cost (\$)	Labor Cost (\$)	Eng. Cost (\$)	Total Cost (\$)	Energy Savings (\$)
Building 1																					
Office Area	3	3	40	414	50	95%	0.4	89.8	\$36.37	\$26.74	\$63.11	Remove 1L-F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04
Engineering Work Area	113	3	40	15594	50	95%	14.8	3383.9	\$1369.91	\$1007.05	\$2376.96	Remove 1L-F40T12, add Reflector	92	9.9	2,256	\$1,584.61	\$9,040	\$4,520	\$1,677	\$15,187	\$792.32
Production Engineering Office	76	4	40	552	50	95%	0.5	119.8	\$48.49	\$35.65	\$84.14	Remove 1L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.05
Conference Room Corridor	2	4	40	368	50	95%	0.3	79.9	\$32.33	\$23.77	\$56.09	Remove 2L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05
DPME Work Area	18	3	40	2484	50	95%	2.4	539.0	\$218.22	\$160.41	\$378.63	Remove 1L-F40T12, add Reflector	92	1.6	359	\$252.42	\$1,440	\$720	\$259	\$2,419	\$126.21
Building 2																					
Administration	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.09
Movement Branch Mgrs. Office																					
Building 3																					
Computer Area	34	4	40	6,256	126	95%	5.9	3421	\$545.58	\$1,018.09	\$1,563.67	Remove 2L-F40T12, add Reflector	92	3.0	1,711	\$783.84	\$2,720	\$1,360	\$490	\$4,570	\$779.84
Raised Floor Computer Rm. #1	54	4	40	9,936	126	95%	9.4	5433	\$872.86	\$1,616.98	\$2,489.84	Remove 2L-F40T12, add Reflector	92	4.7	2,717	\$1,244.92	\$4,320	\$2,160	\$778	\$7,258	\$1,244.92
Raised Floor Computer Rm. #2	76	4	40	13,984	126	95%	13.3	7647	\$1,228.47	\$2,275.75	\$3,504.22	Remove 2L-F40T12, add Reflector	92	6.6	3,824	\$1,752.11	\$6,080	\$3,040	\$1,094	\$10,214	\$1,752.11
Raised Floor Computer Rm. #3	65	4	40	11,960	126	95%	11.4	6540	\$1,050.67	\$1,946.37	\$2,997.03	Remove 2L-F40T12, add Reflector	92	5.7	3,270	\$1,498.52	\$5,200	\$2,600	\$936	\$8,736	\$1,498.52
Raised Floor Computer Rm. #6	76	4	40	13,984	126	95%	13.3	7647	\$1,228.47	\$2,275.75	\$3,504.22	Remove 2L-F40T12, add Reflector	92	6.6	3,824	\$1,752.11	\$6,080	\$3,040	\$1,094	\$10,214	\$1,752.11
Raised Floor Comp. Ctr. Office	9	4	40	1,656	126	95%	1.6	906	\$145.48	\$69.50	\$141.97	Remove 2L-F40T12, add Reflector	92	0.8	453	\$207.49	\$720	\$360	\$130	\$1,210	\$207.49
Raised Floor Computer Rm. #5	64	4	40	11,776	126	95%	11.2	6440	\$1,034.50	\$1,916.42	\$2,950.92	Remove 2L-F40T12, add Reflector	92	5.6	3,220	\$1,475.46	\$5,120	\$2,560	\$922	\$8,602	\$1,475.46
South East Area																					
Office 1-K	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	Remove 1L-F40T12, add Reflector	92	0.5	120	\$84.14	\$480	\$240	\$86	\$806	\$42.07
Open Office Area 7-G	39	3	40	5,382	50	95%	5.1	1168	\$472.80	\$347.57	\$820.37	Remove 1L-F40T12, add Reflector	92	3.4	779	\$536.91	\$3,120	\$1,560	\$562	\$5,242	\$73.46
Office 2-J	5	3	40	690	50	95%	0.7	150	\$60.62	\$44.56	\$105.18	Remove 1L-F40T12, add Reflector	92	0.4	100	\$70.12	\$400	\$200	\$72	\$672	\$35.06
South West Area																					
Room #105 8-A	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 1L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.05
Office 2-C	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02
Office 4-B	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02
Office Rear 3-B	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L-F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04
Office Front 3-B	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L-F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04
North West Area																					
Office 19-E	5	3	40	690	50	95%	0.7	150	\$60.62	\$44.56	\$105.18	Remove 1L-F40T12, add Reflector	92	0.4	100	\$70.12	\$400	\$200	\$72	\$672	\$35.06
Office 26-B	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.09
Office 26-A	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.09
Office 24-A	3	4	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L-F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04
Office 25-A	7	4	40	1,288	50	95%	1.2	279	\$113.15	\$83.18	\$196.33	Remove 2L-F40T12, add Reflector	92	0.6	140	\$98.16	\$560	\$280	\$101	\$911	\$98.16
Office 22-A	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 1L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.05
North East Area																					
Office 21-G	6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Remove 2L-F40T12, add Reflector	92	0.5	120	\$84.14	\$480	\$240	\$86	\$806	\$84.14
Office 16-K	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 1L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.05
Office 26-J	8	3	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Remove 2L-F40T12, add Reflector	92	0.7	160	\$112.19	\$640	\$320	\$115	\$1,075	\$56.09
Office 16-J	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02
Office 17-J	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L-F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04
Office 17-K	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	Remove 1L-F40T12, add Reflector	92	0.5	120	\$84.14	\$480	\$240	\$86	\$806	\$42.07
Open Office Area 26-18-K	40	3	40	5,520	50	95%	5.2	1198	\$484.92	\$356.48	\$841.40	Remove 1L-F40T12, add Reflector	92	3.5	799	\$560.93	\$3,200	\$1,600	\$576	\$5,376	\$280.47
Building 5																					
Administration	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05
Product Receipt Office	9	4	40	1,656	50	95%	1.6	359	\$145.48	\$106.94	\$252.42	Remove 2L-F40T12, add Reflector	92	0.8	180	\$126.21	\$720	\$360	\$130	\$1,210	\$126.21
Snider Office																					
Building 6																					
Administration	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L-F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04
Tucker Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L-F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04
Safety Division Office																					
Building 10																					
North East Area																					
Office 1-E	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 1L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.05
Office 1-D	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 1L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.05
North West Area																					
Office 8-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.09
Office 3-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.09
Office 4-K	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.09
Office 2-K	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	Remove 1L-F40T12, add Reflector	92	0.3	120	\$84.14	\$480	\$240	\$86	\$806	\$42.07

**ECO-9
Letterkenny Army Depot
Fluorescent Reflectors**

Existing										Proposed				Implementation							
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw/Hr Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw/Hr Per Month	Annual Cost	Mat. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings
Office 1-H	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 1L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.05
Building 37																					
Modular																					
Motor Room Box Office	3	4	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	Remove 2L-F40T12, add Reflector	92	0.3	108	\$56.33	\$240	\$120	\$43	\$403	\$56.33
Building 37 Office	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	Remove 2L-F40T12, add Reflector	92	0.3	144	\$75.11	\$320	\$160	\$58	\$538	\$75.11
Building Supply 47	2	4	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	Remove 2L-F40T12, add Reflector	92	0.2	72	\$37.55	\$160	\$80	\$29	\$269	\$37.55
Breakroom	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	Remove 2L-F40T12, add Reflector	92	0.3	144	\$75.11	\$320	\$160	\$58	\$538	\$75.11
Transmission Office	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	Remove 2L-F40T12, add Reflector	92	0.3	144	\$75.11	\$320	\$160	\$58	\$538	\$75.11
Building 57S																					
Warehouse																					
Robertson Office	3	4	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	Remove 2L-F40T12, add Reflector	92	0.3	108	\$56.33	\$240	\$120	\$43	\$403	\$56.33
Building 247																					
Warehouse																					
Rear Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02
Kitchen	1	4	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Remove 2L-F40T12, add Reflector	92	0.1	20	\$14.02	\$80	\$40	\$14	\$134	\$14.02
Building 350																					
Office #1																					
Conference Room	12	4	40	2,208	63	95%	2.1	604	\$193.97	\$179.66	\$373.63	Remove 2L-F40T12, add Reflector	92	1.0	302	\$186.82	\$960	\$480	\$173	\$1,613	\$186.82
Managers Office	4	4	40	736	90	95%	0.7	287	\$64.66	\$85.55	\$150.21	Remove 2L-F40T12, add Reflector	92	0.3	144	\$75.11	\$320	\$160	\$58	\$538	\$75.11
Copy Room	2	4	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	Remove 2L-F40T12, add Reflector	92	0.2	72	\$37.55	\$160	\$80	\$29	\$269	\$37.55
Reception Office #2	11	4	40	2,024	90	95%	1.9	791	\$177.81	\$235.27	\$413.08	Remove 2L-F40T12, add Reflector	92	1.0	395	\$206.54	\$880	\$440	\$158	\$1,478	\$206.54
Reception Area	8	4	40	1,472	90	95%	1.4	575	\$129.31	\$171.11	\$300.42	Remove 2L-F40T12, add Reflector	92	0.7	287	\$150.21	\$640	\$320	\$115	\$1,075	\$150.21
Managers Office	1	4	40	184	90	95%	0.2	72	\$16.16	\$11.39	\$28.05	Remove 2L-F40T12, add Reflector	92	0.1	36	\$18.78	\$80	\$40	\$14	\$134	\$18.78
Office #3																					
ASRS plus Office Computer Rm.	8	4	40	1,472	90	95%	1.4	575	\$129.31	\$171.11	\$300.42	Remove 2L-F40T12, add Reflector	92	0.7	287	\$150.21	\$640	\$320	\$115	\$1,075	\$150.21
Building 416																					
Administration																					
Managers Office	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05
Main Office Area	30	4	40	5,520	50	95%	5.2	1198	\$484.92	\$356.48	\$841.40	Remove 2L-F40T12, add Reflector	92	2.6	599	\$420.70	\$2,400	\$1,200	\$432	\$4,032	\$420.70
Building 421																					
Administration																					
Receptionist	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02
Bid Room #2	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L-F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$42.07
Office	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05
Property Accountability Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02
Equipment Mgt. Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02
Ck. Depot Prop. Div. Office	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 1L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.05
Building 424																					
Cable & Harness																					
File Area	5	3	40	600	90	95%	0.7	270	\$60.62	\$80.21	\$140.82	Remove 1L-F40T12, add Reflector	92	0.4	180	\$93.88	\$400	\$200	\$72	\$672	\$46.94
Work Station	5	3	40	600	90	95%	0.7	270	\$60.62	\$80.21	\$140.82	Remove 1L-F40T12, add Reflector	92	0.4	180	\$93.88	\$400	\$200	\$72	\$672	\$46.94
Assembly Area	21	3	40	2,898	90	95%	2.8	1132	\$254.58	\$336.87	\$591.46	Remove 1L-F40T12, add Reflector	92	1.8	755	\$394.30	\$1,680	\$840	\$302	\$2,822	\$197.15
Office	2	4	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	Remove 2L-F40T12, add Reflector	92	0.2	72	\$37.55	\$160	\$80	\$29	\$269	\$37.55
Building 431																					
Administration																					
ACI Office	5	4	40	920	50	95%	0.9	200	\$80.82	\$59.41	\$140.23	Remove 2L-F40T12, add Reflector	92	0.4	100	\$70.12	\$400	\$200	\$72	\$672	\$70.12

**ECO-9
Letterkenny Army Depot
Fluorescent Reflectors**

Existing										Proposed										Implementation									
NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$									
Building 500																													
First Floor																													
4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
1	4	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Remove 2L F40T12, add Reflector	92	0.1	20	\$14.02	\$80	\$40	\$14	\$134	\$14.02									
6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Remove 2L F40T12, add Reflector	92	0.5	120	\$84.14	\$480	\$240	\$86	\$806	\$84.14									
2	4	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	Remove 2L F40T12, add Reflector	92	0.2	72	\$37.55	\$160	\$80	\$29	\$269	\$37.55									
4	3	40	368	90	95%	0.3	144	\$32.33	\$42.78	\$75.11	Remove 2L F40T12, add Reflector	92	0.2	72	\$37.55	\$160	\$80	\$29	\$269	\$37.55									
6	4	40	1,104	90	95%	1.0	431	\$96.98	\$128.32	\$225.32	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05									
2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05									
4	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
1	4	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Remove 2L F40T12, add Reflector	92	0.1	20	\$14.02	\$80	\$40	\$14	\$134	\$14.02									
4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05									
4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05									
6	3	40	828	50	95%	0.8	180	\$72.14	\$53.47	\$126.21	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05									
3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	\$84.14	Remove 1L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
4	3	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	Remove 1L F40T12, add Reflector	92	0.3	144	\$75.11	\$320	\$160	\$58	\$538	\$56.09									
2	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 1L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
4	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05									
4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 1L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
Second Floor																													
4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05									
4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
Building 521																													
First Floor																													
2	4	40	368	168	95%	0.3	268	\$32.33	\$79.85	\$112.18	Remove 2L F40T12, add Reflector	92	0.2	134	\$56.09	\$160	\$80	\$29	\$269	\$56.09									
1	4	40	184	50	95%	0.2	40	\$16.16	\$11.88	\$28.05	Remove 2L F40T12, add Reflector	92	0.1	20	\$14.02	\$80	\$40	\$14	\$134	\$14.02									
2	3	40	276	90	95%	0.3	108	\$24.25	\$32.08	\$56.33	Remove 2L F40T12, add Reflector	92	0.2	72	\$37.55	\$160	\$80	\$29	\$269	\$37.55									
2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05									
Building 522																													
First Floor																													
4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Remove 2L F40T12, add Reflector	92	0.5	120	\$84.14	\$480	\$240	\$86	\$806	\$84.14									
4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05									
4	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09									
2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05									

ECO-9
Letterkenny Army Depot
Fluorescent Reflectors

Room	NO Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	Proposed					Implementation				Energy Savings \$	
												New Luminaire Description	Watts Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$		
Building 523																						
Administration	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09	
Grayson Office	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09	
Hesbet Office	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09	
Descom Office A	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Hoover Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Barnes Office	6	3	40	828	50	95%	0.8	180	\$72.74	\$53.47	\$126.21	Remove 1L F40T12, add Reflector	92	0.5	120	\$84.14	\$480	\$240	\$86	\$806	\$42.07	
Gerhart Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Sheffield Office	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Kitchen	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	Remove 1L F40T12, add Reflector	92	0.1	20	\$14.02	\$80	\$40	\$14	\$134	\$7.01	
Building 519																						
First Floor																						
Kitchen Dish Room	6	3	40	828	60	95%	0.8	216	\$72.74	\$64.17	\$136.90	Remove 1L F40T12, add Reflector	92	0.5	144	\$91.27	\$480	\$240	\$86	\$806	\$45.03	
Food Prep Room	5	4	40	920	60	95%	0.9	240	\$80.82	\$71.30	\$152.12	Remove 2L F40T12, add Reflector	92	0.4	120	\$76.06	\$400	\$200	\$72	\$672	\$76.06	
Dining Room	14	4	40	2,576	60	95%	2.4	671	\$226.30	\$199.63	\$425.92	Remove 2L F40T12, add Reflector	92	1.2	335	\$212.96	\$1,120	\$560	\$202	\$1,882	\$212.96	
Building 581																						
First Floor																						
SIDS Office	8	4	40	1,472	50	95%	1.4	319	\$129.31	\$95.06	\$224.37	Remove 2L F40T12, add Reflector	92	0.7	160	\$112.19	\$640	\$320	\$115	\$1,075	\$112.19	
Building 618																						
First Floor																						
Hoke Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Room #11 Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04	
Coppy Room	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Coffee Mess	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Merritt Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Keefe Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Walker Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Hunting & Fishing Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04	
Building 619																						
First Floor																						
Wannock Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Yeager Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Quinn Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Geiseking Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Epstein Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Building 628																						
First Floor																						
Information Security	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Bridge Photo Room	4	3	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 1L F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$28.05	
Coppy Room	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Automation Security Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Police Officers Room #3 Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Room #1 Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Physical Security	1	3	40	138	50	95%	0.1	30	\$12.12	\$8.91	\$21.04	Remove 1L F40T12, add Reflector	92	0.1	20	\$14.02	\$80	\$40	\$14	\$134	\$7.01	
Building 646																						
Second Floor																						
Investigation Office Room #19	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Investigation Office Room #18	2	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04	
Interview Room #17	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Secretary & Plans Div. Office	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04	
Chief Secretary & Plans Div. Ofc.	3	3	40	414	50	95%	0.4	90	\$36.37	\$26.74	\$63.11	Remove 1L F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$21.04	
Directorate Secretary Office	2	3	40	276	50	95%	0.3	60	\$24.25	\$17.82	\$42.07	Remove 1L F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$14.02	
Building 646																						
Youth Center																						
Entrance Area	2	3	40	276	126	95%	0.3	151	\$24.25	\$44.92	\$69.16	Remove 1L F40T12, add Reflector	92	0.2	101	\$46.11	\$160	\$80	\$29	\$269	\$23.05	
Lounge Area	5	3	40	690	126	95%	0.7	377	\$60.62	\$112.29	\$172.91	Remove 1L F40T12, add Reflector	92	0.4	252	\$115.27	\$400	\$200	\$72	\$672	\$72.06	
Staff Office	2	3	40	276	126	95%	0.3	151	\$24.25	\$44.92	\$69.16	Remove 1L F40T12, add Reflector	92	0.2	101	\$46.11	\$160	\$80	\$29	\$269	\$23.05	
Play Room	2	3	40	276	126	95%	0.3	151	\$24.25	\$44.92	\$69.16	Remove 1L F40T12, add Reflector	92	0.2	101	\$46.11	\$160	\$80	\$29	\$269	\$23.05	

ECO-9
Letterkenny Army Depot
Fluorescent Reflectors

Room	NO Of Luminaires	Existing						Proposed						Implementation					Energy Savings \$		
		Watts Per Lumire	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kwh Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$		Total Cost \$	
Building 663																					
Administration & Trades	8	4	40	1,472	90	95%	1.4	575	\$129.31	\$171.11	\$300.42	Remove 2L-F40T12, add Reflector	92	0.7	287	\$150.21	\$640	\$320	\$115	\$1,075	\$150.21
Lunch Area	4	3	40	552	90	95%	0.5	216	\$48.49	\$64.17	\$112.66	Remove 1L-F40T12, add Reflector	92	0.3	144	\$75.11	\$320	\$160	\$38	\$538	\$37.35
Computer Room	4	3	40	276	63	95%	0.3	75	\$24.25	\$22.46	\$46.70	Remove 1L-F40T12, add Reflector	92	0.2	50	\$31.14	\$160	\$80	\$29	\$269	\$15.57
Operations & Maint. Conf. Room	12	4	40	2,208	90	95%	2.1	862	\$193.97	\$256.66	\$450.63	Remove 2L-F40T12, add Reflector	92	1.0	431	\$225.32	\$960	\$480	\$173	\$1,613	\$225.32
Work Planning & Control Office	3	3	40	414	90	95%	0.4	162	\$36.37	\$48.12	\$84.49	Remove 1L-F40T12, add Reflector	92	0.3	108	\$56.33	\$240	\$120	\$43	\$403	\$28.16
Business Managers Office	3	3	40	966	63	95%	0.9	264	\$84.86	\$78.60	\$163.46	Remove 1L-F40T12, add Reflector	92	0.6	176	\$108.98	\$560	\$280	\$101	\$941	\$54.49
Conference Room	7	3	40	414	90	95%	0.4	162	\$36.37	\$48.12	\$84.49	Remove 1L-F40T12, add Reflector	92	0.3	108	\$56.33	\$240	\$120	\$43	\$403	\$28.16
Office	2	3	40	276	90	95%	0.3	108	\$24.25	\$32.08	\$56.33	Remove 1L-F40T12, add Reflector	92	0.2	72	\$37.55	\$160	\$80	\$29	\$269	\$18.78
Building 2260																					
Administration	6	4	40	1,104	50	95%	1.0	240	\$96.98	\$71.30	\$168.28	Remove 2L-F40T12, add Reflector	92	0.5	120	\$84.14	\$480	\$240	\$86	\$806	\$84.14
Distri. Branch Chief Reception	52	4	40	9,568	50	95%	9.1	2076	\$840.53	\$617.89	\$1,458.43	Remove 2L-F40T12, add Reflector	92	4.5	1,038	\$729.21	\$4,160	\$2,080	\$749	\$6,989	\$729.21
Open Office Area	8	4	40	1,472	50	95%	1.4	319	\$129.31	\$95.06	\$224.37	Remove 2L-F40T12, add Reflector	92	0.7	160	\$112.19	\$640	\$320	\$115	\$1,075	\$112.19
Property Disposal Office	4	4	40	736	50	95%	0.7	160	\$64.66	\$47.53	\$112.19	Remove 2L-F40T12, add Reflector	92	0.3	80	\$56.09	\$320	\$160	\$58	\$538	\$56.09
Building 2755																					
Warehouse	3	4	40	552	50	95%	0.5	120	\$48.49	\$35.65	\$84.14	Remove 2L-F40T12, add Reflector	92	0.3	60	\$42.07	\$240	\$120	\$43	\$403	\$42.07
File Room																					
Building 3311																					
Administration	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05
Office #13																					
Building 3315																					
Warehouse																					
Managers Office	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05
Break Room	2	4	40	368	50	95%	0.3	80	\$32.33	\$23.77	\$56.09	Remove 2L-F40T12, add Reflector	92	0.2	40	\$28.05	\$160	\$80	\$29	\$269	\$28.05
Building 5426																					
Warehouse																					
Office	7	4	40	1,288	50	95%	1.2	279	\$113.15	\$83.18	\$196.33	Remove 2L-F40T12, add Reflector	92	0.6	140	\$98.16	\$560	\$280	\$101	\$941	\$98.16
TOTALS																					
ANPROJECTS4120.01SSBECODECO DWK4		1342		220892			209.8	73963	\$19,000	\$23,000	\$42,000			117.3	41119	\$23,000	\$107,000	\$54,000	\$19,000	\$180,000	\$19,000

G:\PROJECTS\4130\USSECO\ECO_9.WK4

22 May 95

ECO-10

Industrial Fluorescent to Metal Halide

Existing.

Twelve of the buildings at the Letterkenny Army Depot contain approximately 3,120 fluorescent luminaires. The attached data table for ECO-10 lists the areas which currently utilize these luminaires. The total watts for the existing luminaires is 334,696 watts. The luminaires operate between 50 and 90 hours per week and contribute approximately 95% of their connected load to the demand. The annual electric demand, usage, and cost for these fixtures are as follows:

Electric Demand	=	3,808 kW/yr (317.3 kW/mo x 12 mo/yr)
Electric Usage	=	1,002,924 kWh/yr (83,577 kWh/mo x 12 mo/yr)
Electric Cost	=	\$54,000 (3,808 kW/yr x \$7.706/kW) + (1,002,924 kWh/yr x \$.0248/kWh) = \$54,217, use \$54,000

Proposed.

Replace the current lighting system with metal halide light sources. In all areas, a fewer number of fixtures is required. Reference the attached data table for ECO-10. The annual electric demand, usage and cost of the proposed ECO is noted below:

Electric Demand	=	2,870 kW/yr (239.2 kW/mo x 12 mo/yr)
Electric Usage	=	756,888 kWh/yr (63,074 kWh/mo x 12 mo/yr)
Electric Cost	=	\$41,000 (2,870 kW/yr x \$7.706/kW) + (756,888 kWh/yr x \$.0248/kWh) = \$40,887, use \$41,000

Implementation. The expected construction cost for implementing the project is expected to be \$357,000. The breakdown is noted below and shown on the attached ECO data table.

Material	\$260,000
Labor	\$ 59,000
Engineering	<u>\$ 38,000</u>
Total	\$357,000

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

Electric Demand	=	938 kW/yr (3,808 - 2,870)
Electric Usage	=	246,036 kWh/yr (1,002,924 - 756,888)
Energy Cost	=	\$13,000/yr (\$54,000 - \$41,000)
Annual Energy Savings	=	840 mmBtu/yr
Energy Usage	=	840 mmBtu/yr (246,036 kWh/yr x 3,413 Btu/kWh) ÷ 1,000,000 Btu/mmBtu

Maintenance Savings. By retrofitting the existing fluorescent luminaires with metal Halide luminaires, a maintenance savings will result. The annual maintenance savings is noted below:

Data

Fluorescent Lamp Life	=	20,000 hours
MH Lamp Life (<400W)	=	10,000 hours
MH Lamp Life (>400W)	=	20,000 hours
Operation Period Per Year	=	2,600 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes
Fluorescent Lamp Cost	=	\$4 each

MH Lamp Cost	=	\$55 each (<400)
		\$65 each (>400)
Total Quantity Fluorescent	=	7,276
Total Quantity MH <400W	=	87
Total Quantity MH >400W	=	504

Calculation

Maintenance (Fluorescent)	=	$\$1.39 (20 \times 1/3 + 4) \times 2,600/20,000$
Maintenance (MH <400W)	=	$\$16.03 (20 \times 1/3 + 55) \times 2,600/10,000$
Maintenance (MH >400W)	=	$\$9.31 (20 \times 1/3 + 65) \times 2,600/20,000$
Annual Recurring Maintenance Savings	=	$\$4,000 (1.39 \times 7,276) - (16.03 \times 87) - (9.31 \times 504) = \$4,026, \text{ use } \$4,000$

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. A life cycle cost summary includes energy cost escalations, construction supervision, and annual recurring maintenance costs in addition to construction cost and engineering services. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 21.76 years with a savings to investment ratio of .81.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO10

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO10

ANALYSIS DATE: 04-19-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	319000.	
B. SIOH	\$	17545.	
C. DESIGN COST	\$	38000.	
D. TOTAL COST (1A+1B+1C)	\$	374545.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$	374545.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	840.	\$ 6107.	18.17	\$ 110961.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 7200.	17.22	\$ 123984.
N. TOTAL		840.	\$ 13307.		\$ 234945.

3. NON ENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)	\$	4000.
(1) DISCOUNT FACTOR (TABLE A)	17.22	
(2) DISCOUNTED SAVING/COST (3A X 3A1)	\$	68880.

B. NON RECURRING SAVINGS (+) / COSTS (-)

ITEM	SAVINGS (+) COST (-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS (+) / COST (-) (4)
d. TOTAL	\$	0.		0.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS (+) / COST (-) (3A2+3Bd4) \$ 68880.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 17307.

5. SIMPLE PAYBACK PERIOD (1G/4) 21.64 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 303825.

7. SAVINGS TO INVESTMENT RATIO (SIR) = $(6 / 1G) =$.81
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 2.24 %

ECO10
Letterkenny Army Depot
Industrial Fluorescent to Metal Halide

		Existing										Proposed										Implementation									
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Qty of Luminaires	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$									
Building 1																															
Chrome Plate Area (CP)	178	2	40	16,376	50	95.0%	15.6	3,554	\$1,438.61	\$1,057.55	\$2,496.15	400 Watt MH, High Bay	27	460	11.8	2,695	\$1,893.15	\$12,015	\$2,700	\$1,766	\$16,481	\$603.00									
Paper Storage Area																															
Building 4																															
Warehouse																															
Warehouse Storage	858	2	40	78,936	50	95.0%	75.0	17,129	\$6,934.40	\$5,097.62	\$12,032.03	400 Watt MH, High Bay	127	460	55.5	12,677	\$8,904.82	\$56,515	\$12,000	\$8,306	\$77,521	\$3,127.20									
Warehouse Packaging	820	2	40	75,440	50	95.0%	71.7	16,370	\$6,627.28	\$4,871.85	\$11,499.14	400 Watt MH, High Bay	121	460	52.9	12,078	\$8,484.12	\$53,845	\$12,000	\$7,913	\$73,858	\$3,015.02									
Warehouse Pac Radio Active Room	10	2	40	920	50	95.0%	0.9	200	\$80.82	\$59.41	\$140.23	175 Watt MH, Low Bay	4	201	0.8	174	\$122.55	\$1,600	\$400	\$240	\$2,240	\$17.68									
Building 14																															
Warehouse																															
Tritium Installation Room #2	4	4	40	736	50	95.0%	0.7	160	\$64.66	\$47.53	\$112.19	70 Watt MH, Low Bay	2	80	0.2	35	\$24.39	\$760	\$200	\$115	\$1,075	\$87.80									
Tritium Room	4	3	40	552	50	95.0%	0.5	120	\$48.49	\$35.65	\$84.14	70 Watt MH, Low Bay	2	80	0.2	35	\$24.39	\$760	\$200	\$115	\$1,075	\$87.80									
Tritium Installation Room #1	4	4	40	736	50	95.0%	0.7	160	\$64.66	\$47.53	\$112.19	70 Watt MH, Low Bay	2	80	0.2	35	\$24.39	\$760	\$200	\$115	\$1,075	\$87.80									
Tritium Storage Room	4	4	40	736	50	95.0%	0.7	160	\$64.66	\$47.53	\$112.19	70 Watt MH, Low Bay	2	80	0.2	35	\$24.39	\$760	\$200	\$115	\$1,075	\$87.80									
Tritium Final Area	15	4	40	2,760	50	95.0%	2.6	599	\$242.46	\$178.24	\$420.70	250 Watt MH, Low Bay	8	287	2.2	498	\$349.97	\$3,320	\$800	\$494	\$4,614	\$70.73									
Machine Shop Area	37	3	40	5,106	50	95.0%	4.9	1,108	\$448.55	\$329.74	\$778.30	250 Watt MH, Low Bay	15	287	4.1	934	\$656.20	\$6,225	\$1,500	\$927	\$8,652	\$122.09									
Second Floor																															
Small Parts Work Area	47	3	40	6,486	50	95.0%	6.2	1,407	\$569.78	\$418.86	\$988.65	250 Watt MH, Low Bay	19	287	5.2	1,183	\$831.19	\$7,885	\$1,900	\$1,174	\$10,959	\$157.46									
Building 33N																															
Warehouse																															
Warehouse	77	2	40	7,084	50	95.0%	6.7	1,537	\$622.32	\$457.48	\$1,079.80	400 Watt MH, High Bay	12	460	5.2	1,198	\$841.40	\$5,340	\$1,200	\$785	\$7,325	\$238.40									
Building 34																															
Warehouse Parts Storage Racks	12	2	40	1,104	50	95.0%	1.0	240	\$96.98	\$71.30	\$168.28	175 Watt MH, Low Bay	5	201	1.0	218	\$153.19	\$2,000	\$500	\$300	\$2,800	\$15.09									
Building 42S																															
Warehouse																															
Warehouse South	17	2	40	1,564	50	95.0%	1.5	339	\$137.39	\$101.00	\$238.40	175 Watt MH, High Bay	7	201	1.3	305	\$214.47	\$2,800	\$700	\$420	\$3,920	\$23.95									
Warehouse South	124	4	40	2,2816	50	95.0%	21.7	4,951	\$2,004.35	\$1,473.44	\$3,477.79	400 Watt MH, High Bay	37	460	16.2	3,693	\$2,994.32	\$16,465	\$3,700	\$2,420	\$22,585	\$883.47									
Warehouse South	11	3	40	1,518	50	95.0%	1.4	329	\$133.35	\$98.03	\$231.39	175 Watt MH, High Bay	7	201	1.3	305	\$214.47	\$2,800	\$700	\$420	\$3,920	\$16.92									
Building 43																															
Warehouse																															
Warehouse	258	2	40	2,376	50	95.0%	22.5	5,151	\$2,085.17	\$1,532.85	\$3,618.02	400 Watt MH, High Bay	38	460	16.6	3,793	\$2,664.43	\$16,910	\$3,800	\$2,485	\$23,195	\$953.59									
Building 44																															
Warehouse																															
Receiving Area	9	3	40	1,242	50	95.0%	1.2	270	\$109.11	\$80.21	\$189.32	175 Watt MH, Low Bay	6	201	1.1	262	\$183.83	\$2,400	\$600	\$360	\$3,360	\$5.49									
Building 47																															
Warehouse																															
Warehouse North	20	2	40	1,840	90	95.0%	1.7	719	\$161.64	\$213.89	\$375.53	175 Watt MH, Low Bay	8	201	1.5	628	\$328.18	\$3,200	\$800	\$480	\$4,480	\$47.35									
Building 51																															
Warehouse																															
Warehouse Processing	96	3	40	13,248	50	95.0%	12.6	2,875	\$1,163.82	\$855.55	\$2,019.36	400 Watt MH, High Bay	22	460	9.6	2,196	\$1,542.57	\$9,790	\$2,200	\$1,439	\$13,429	\$476.79									
Warehouse Processing	15	4	40	2,760	50	95.0%	2.6	599	\$242.46	\$178.24	\$420.70	400 Watt MH, High Bay	5	460	2.2	499	\$350.58	\$2,725	\$500	\$327	\$3,052	\$70.12									
Warehouse Milvau Processing	51	3	40	7,038	50	95.0%	6.7	1,527	\$618.28	\$454.51	\$1,072.79	400 Watt MH, High Bay	13	460	5.7	1,298	\$911.52	\$5,785	\$1,300	\$850	\$7,935	\$161.27									
Building 57S																															
Warehouse																															
Warehouse Area	309	3	40	42,642	90	95.0%	40.5	16,656	\$3,746.03	\$4,956.82	\$8,702.85	400 Watt MH, High Bay	69	460	30.2	12,398	\$6,477.85	\$30,705	\$6,900	\$4,513	\$42,118	\$2,225.00									
Building 62A																															
Cable and Harness																															
Upblatory Work Shop	72	3	40	9,936	90	95.0%	9.4	3,881	\$872.86	\$1,154.99	\$2,027.85	400 Watt MH, High Bay	16	460	7.0	2,875	\$1,502.11	\$7,120	\$1,600	\$1,046	\$9,766	\$525.74									
Upblatory Work Shop	32	3	40	4,416	90	95.0%	4.2	1,725	\$387.94	\$513.33	\$901.27	400 Watt MH, High Bay	8	460	3.5	1,437	\$751.05	\$3,560	\$800	\$523	\$4,883	\$150.21									
Rubber Mat Storage Room	12	3	40	1,656	90	95.0%	1.6	647	\$145.48	\$192.50	\$337.97	400 Watt MH, High Bay	3	460	1.3	539	\$281.65	\$1,335	\$300	\$196	\$1,831	\$56.33									
Work Area	12	3	40	1,656	90	95.0%	1.6	647	\$145.48	\$192.50	\$337.97	400 Watt MH, High Bay	3	460	1.3	539	\$281.65	\$1,335	\$300	\$196	\$1,831	\$56.33									
Work Area	12	3	40	1,656	90	95.0%	1.6	647	\$145.48	\$192.50	\$337.97	400 Watt MH, High Bay	3	460	1.3	539	\$281.65	\$1,335	\$300	\$196	\$1,831	\$56.33									
TOTALS	3120			334696			317.3	83577	\$29,000	\$25,000	\$54,000		591		239.2	6074	\$41,000	\$260,000	\$59,000	\$38,000	\$357,000	\$13,000									
G:\PROJECTS\TSM\DATA\SSOURCECO_16.W64																						22-May-95									

G:\PROJECTS\4139\ANSS\COBECO_10.WK4

ECO-11

Industrial Fluorescent to High Pressure Sodium

Existing.

Twelve of the buildings at the Letterkenny Army Depot contain approximately 3,120 fluorescent luminaires. The attached data table for ECO-11 lists the areas which currently utilize these luminaires. The total watts for the existing luminaires is 334,696 watts. The luminaires operate between 50 and 90 hours per week and contribute approximately 95% of their connected load to the demand. The annual energy demand, usage, and cost for these fixtures are as follows:

Electric Demand	=	3,808 kW/yr (317.3 kW/mo x 12 mo/yr)
Electric Usage	=	1,002,924 kWh/yr (83,577 kWh/mo x 12 mo/yr)
Electric Cost	=	\$54,000 (3,808 kW/yr x \$7.706/kW) + (1,002,924 kWh/yr x \$.0248/kWh) = \$54,217, use \$54,000

Proposed.

Replace the current lighting system with high pressure sodium light sources. In all areas, a fewer number of fixtures is required. Reference the attached data table for ECO-11. The annual electric demand, usage, and cost of the proposed ECO is noted below:

Electric Demand	=	2,075 kW/yr (172.9 kW/mo x 12 mo/yr)
Electric Usage	=	547,572 kWh/yr (45,631 kW/mo x 12 mo/yr)
Electric Cost	=	\$30,000 (2,075 kW/yr x \$7.706/kW) + (547,572 kWh/yr x \$.0248/kWh) = \$29,570, use \$30,000

Implementation Costs. The expected construction cost for implementing the project is expected to be \$261,000. The breakdown is noted below and shown on the attached ECO data table.

Material	\$190,000
Labor	\$ 43,000
Engineering	<u>\$ 28,000</u>
Total	\$261,000

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

Electric Demand	=	1,733 kW/yr (3,808 - 2,075)
Electric Usage	=	455,352 kWh/yr (1,002,924 - 547,572)
Energy Cost	=	\$25,000/yr (\$54,000 - \$30,000) = \$24,000, use \$25,000
Annual Energy Savings	=	1,554 mmBtu/yr
Energy Usage	=	1,554 mmBtu/yr (455,352 kWh/yr x 3,413 Btu/kWh) ÷ 1,000,000 Btu/mmBtu

Maintenance Savings. By retrofitting the existing fluorescent luminaires with high-pressure sodium, a maintenance savings will result. The annual maintenance savings is noted below:

Data

Fluorescent Lamp Life	=	20,000 hours
HPS Lamp Life	=	24,000 hours
Operation Period Per Year	=	2,600 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes

Fluorescent Lamp Cost	=	\$4 each
HPS Lamp Cost	=	\$65 each
Total Quantity Fluorescent	=	7,276
Total Quantity HPS	=	434

Calculation

Maintenance (Fluorescent)	=	$\$1.39 (20 \times 1/3 + 4) \times 2,600/20,000$
Maintenance (HPS)	=	$\$7.76 (20 \times 1/3 + 65) \times 2,600/24,000$
Annual Recurring Maintenance Savings	=	$\$6,700 (1.39 \times 7,276) - (\$7.76 \times 434) = \$6,746$, use \$6,700

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations, construction supervision, and annual recurring maintenance costs in addition to construction cost and engineering services. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 8.83 years with a savings to investment ratio of 1.99.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO11

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) LCCID 1.080

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO11

ANALYSIS DATE: 04-19-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	233000.	
B. SIOH	\$	12815.	
C. DESIGN COST	\$	28000.	
D. TOTAL COST (1A+1B+1C)	\$	273815.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$	273815.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU (1)	SAVINGS MBTU/YR (2)	ANNUAL \$ SAVINGS (3)	DISCOUNT FACTOR (4)	DISCOUNTED SAVINGS (5)
A. ELECT	\$ 7.27	1554.	\$ 11298.	18.17	\$ 205277.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 13000.	17.22	\$ 223860.
N. TOTAL		1554.	\$ 24298.		\$ 429137.

3. NON ENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)		\$ 6700.
(1) DISCOUNT FACTOR (TABLE A)	17.22	
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$ 115374.

B. NON RECURRING SAVINGS (+) / COSTS (-)

ITEM	SAVINGS (+) COST (-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS (+) / COST (-) (4)
------	--------------------------------	-----------------	------------------------	---

d. TOTAL	\$ 0.			0.
----------	-------	--	--	----

C. TOTAL NON ENERGY DISCOUNTED SAVINGS (+) / COST (-) (3A2+3Bd4)	\$ 115374.
--	------------

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS \text{ ECONOMIC LIFE}))$	\$ 30998.
--	-----------

5. SIMPLE PAYBACK PERIOD (1G/4)	8.83 YEARS
---------------------------------	------------

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C)	\$ 544511.
--	------------

7. SAVINGS TO INVESTMENT RATIO (SIR) = (6 / 1G) =	1.99
(IF < 1 PROJECT DOES NOT QUALIFY)	

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR):	5.97 %
---	--------

Eco11

TOTALS	
G:PROJECTS4130.01USSECOAECO 11.WK4	

ECO-12 Occupancy Sensors

Existing.

Four of the buildings at the Letterkenny Army Depot were determined to utilize occupancy sensors during the site survey. Since during the walk-through the restroom lights were typically found to be off when not in use, they were not selected. Also, the personal offices were found to be lit only when occupied. The attached data table for ECO-12 lists the areas selected for occupancy sensors. The annual electric demand, usage, and cost for the sensors are as follows:

Electric Demand	=	48 kW/yr (4 kW/mo x 12 mo/yr)
Electric Usage	=	37,032 kWh/yr (3,086 kWh/mo x 12 mo/yr)
Electric Cost	=	\$1,300 (48 kW/yr x \$7.706/kW) + (37,032 kWh/yr x \$.0248/kWh) = \$1,288, use \$1,300

Proposed.

Install ceiling mounted occupant sensors in areas noted on the attached data table for ECO-12. In accordance with DOE/EE-0008 Advanced Lighting Guidelines: 1993, the energy savings potential with occupancy sensors is 30 - 75%. Entech estimates a 45% energy savings could be achieved in these areas. The percent of kW in-peak is expected to remain the same; however, the usage should be reduced by 45%. The annual electric demand, usage, and cost of the proposed ECO is noted below:

Electric Demand	=	48 kW/yr (4 kW/mo x 12 mo/yr)
Electric Usage	=	20,364 kWh/yr (1,697 kWh/mo x 12 mo/yr)

$$\begin{aligned} \text{Electric Cost} &= \$880/\text{yr} (4 \text{ kW}/\text{yr} \times \\ &\quad \$7.706/\text{kW}) + (20,364 \\ &\quad \text{kWh}/\text{yr} \times \$0.0248/\text{kWh}) = \\ &\quad \$875, \text{ use } \$880 \end{aligned}$$

Implementation Cost. The expected construction cost for implementing the project is expected to be \$2,900. The breakdown is noted below and shown on the attached ECO data table.

Material	\$2,100
Labor	\$ 800
Engineering	<u>\$ 0</u>
Total	\$2,900

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

$$\begin{aligned} \text{Electric Demand} &= 0 \text{ kW}/\text{yr} (48 - 48) \\ \text{Electric Usage} &= 16,668 \text{ kWh}/\text{yr} (37,032 - \\ &\quad 20,364) \\ \text{Energy Cost} &= \$410/\text{yr} (\$1,300 - \$880) = \\ &\quad \$420, \text{ use } \$410 \\ \text{Annual Energy Savings} &= 56.9 \text{ mmBtu}/\text{yr} \\ \text{Energy Usage} &= 56.9 \text{ mmBtu}/\text{yr} (16,668 \\ &\quad \text{kWh}/\text{yr} \times 3,413 \text{ Btu}/\text{kWh}) \div \\ &\quad 1,000,000 \text{ Btu}/\text{mmBtu} \end{aligned}$$

Maintenance Savings. By adding occupancy sensors, the existing lamps will be lit less and therefore not be replaced as often. The annual maintenance savings is noted below:

Data

Fluorescent Lamp Life	=	20,000 hours
Operation Period Per Year	=	8,760 hours
Operation Period Per Year w/Sensor	=	4,818 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes
Fluorescent Lamp Cost	=	\$4 each
Total Quantity Lamps	=	92

Calculation

Maintenance (Fluorescent)	=	$\$4.67 (20 \times 1/3 + 4) \times 8,760/20,000$
Maintenance (w/sensor)	=	$\$2.57 (20 \times 1/3 + 4) \times 4,818/20,000$
Annual Recurring Maintenance Savings	=	$\$200 (4.67 - 2.57) \times 92 =$ \$193, use \$200

The estimated life of the sensors by the manufacturers is 10 to 15 years. Assuming 12.5-year life, the sensors will require replacement once during the 25-year life cycle. The cost of replacement is shown below assuming a 4% annual escalation rate:

$$\begin{aligned} \text{One time replace cost} &= 2,900 (1 + .04)^{12.5} = \\ &\$4,730, \text{ use } \$4,700 \end{aligned}$$

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations, construction supervision, and annual recurring maintenance costs in addition to construction cost. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 7.19 years with a savings to investment ratio of 2.45.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO12

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

LCCID 1.080

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO12

ANALYSIS DATE: 03-27-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	2900.	
B. SIOH	\$	160.	
C. DESIGN COST	\$	0.	
D. TOTAL COST (1A+1B+1C)	\$	3060.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$		3060.

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	57.	\$ 414.	18.17	\$ 7516.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 0.	17.22	\$ 0.
N. TOTAL		57.	\$ 414.		\$ 7516.

3. NON ENERGY SAVINGS(+) / COST(-)

A. ANNUAL RECURRING (+/-)		\$	200.
(1) DISCOUNT FACTOR (TABLE A)	17.22		
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$	3444.

B. NON RECURRING SAVINGS(+) / COSTS(-)

ITEM	SAVINGS(+) / COST(-)	YR OC	DISCNT FACTOR	DISCOUNTED SAVINGS(+) / COST(-) (4)
	(1)	(2)	(3)	
1. REPLACEMENT	\$ -4700.	10	.74	-3478.
d. TOTAL	\$ -4700.			-3478.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+) / COST(-) (3A2+3Bd4) \$ -34.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 426.

5. SIMPLE PAYBACK PERIOD (1G/4) 7.19 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 7482.

7. SAVINGS TO INVESTMENT RATIO (SIR) = $(6 / 1G) =$ 2.45
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 6.85 %

ECO-12
Letterkenny Army Depot
Occupancy Sensors

Room	NO. Of Luminaires	Existing						Proposed				Implementation							
		Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$	Energy Savings \$
Building 417																			
Personnel Barracks																			
Mens Room/Shower	4	2	40	368	168	95.0%	0.3	268	332.33	79.85	\$112.18	0.3	148	\$76.25	\$200	\$80	\$0	\$280	\$35.93
Womens Room	4	2	40	368	168	95.0%	0.3	268	332.33	79.85	\$112.18	0.3	148	\$76.25	\$200	\$80	\$0	\$280	\$35.93
Building 418																			
Personnel Barracks																			
Mens Room/Shower	4	2	40	368	168	95.0%	0.3	268	332.33	79.85	\$112.18	0.3	148	\$76.25	\$200	\$80	\$0	\$280	\$35.93
Womens Room	4	2	40	368	168	95.0%	0.3	268	332.33	79.85	\$112.18	0.3	148	\$76.25	\$200	\$80	\$0	\$280	\$35.93
Building 536																			
Bath House																			
Mens Locker Area	7	2	40	644	168	95.0%	0.6	470	556.57	139.74	\$196.31	0.6	258	\$133.43	\$500	\$700	\$0	\$700	\$62.88
Womens Locker Area	3	2	40	276	168	95.0%	0.3	201	24.25	\$59.89	\$84.13	0.3	111	\$57.18	\$200	\$80	\$0	\$280	\$26.95
Building 639																			
Physical Fitness Center																			
Mens Locker Room	4	4	40	736	168	95.0%	0.7	537	564.66	159.70	\$224.36	0.7	295	\$152.49	\$200	\$80	\$0	\$280	\$71.87
Mens Rear Locker Room	1	4	40	184	168	95.0%	0.2	134	16.16	\$39.93	\$56.09	0.2	74	\$38.12	\$100	\$40	\$0	\$140	\$17.97
Womens Rear Locker Room	1	4	40	184	168	95.0%	0.2	134	16.16	\$39.93	\$56.09	0.2	74	\$38.12	\$100	\$40	\$0	\$140	\$17.97
Womens Locker Room	4	4	40	736	168	95.0%	0.7	537	564.66	159.70	\$224.36	0.7	295	\$152.49	\$200	\$80	\$0	\$280	\$71.87
TOTALS		36		4232			4.0	3086	\$370	\$920	\$1,300	4.0	1697	\$880	\$2,100	\$800	\$0	\$2,900	\$410
G:\PROJECTS\130101\SSC\OCCO 12\WK4																			

G:\PROJECTS\4136-01\SS\ECO-12\WK4

22 May '95

ECO-13

Mercury Vapor to Metal Halide

Existing. Ten of the buildings at the Letterkenny Army Depot contain approximately 924 Mercury Vapor luminaires. The luminaires are typically used for illuminating warehouse storage areas. The attached data table for ECO-13 lists the areas which currently utilize these luminaires. The current light levels in most of the areas noted are below the IES recommended levels. The low light levels could be attributed to the mercury vapor lamp lumen output vs. time. The mercury vapor lamps lumen output decreases 50% by the initial output at the average rated life point. The annual electric demand, usage, and cost of these luminaires are as follows:

Electric Demand	=	2,141 kW/yr (178.4 kW/mo x 12 mo/yr)
Electric Usage	=	515,016 kWh/yr (42,918 kWh/mo x 12 mo/yr)
Electric Cost	=	\$29,000 (2,141 kW/yr x \$7.706/kW) + (515,016 kWh/yr x \$.0248/kWh) = \$29,269, use \$29,000

Proposed. Replace the existing high and low bay luminaires with an equal number of metal halide luminaires in the areas noted on the attached data sheet for ECO-13. The new luminaires will increase the existing light levels by 15 - 20%. The average life expectancy of the metal halide lamps are less than that of the mercury vapor; however, the metal halide lamp will produce a more consistent lumen output over the life of the lamp. The annual electric demand, usage, and cost of the proposed ECO is noted below:

Electric Demand	=	1,200 kW/yr (100 kW/mo x 12 mo/yr)
Electric Usage	=	300,000 kWh/yr (25,000 kWh/mo x 12 mo/yr)
Electric Cost	=	\$17,000 (1,200 kW/yr x \$7.706/kW) + (300,000 kWh/yr x \$.0248/kWh) = \$16,687, use \$17,000

Implementation Cost. The expected construction cost for implementing the project is expected to be \$508,000. The breakdown is noted below and shown on the attached ECO data table.

Material	\$361,000
Labor	\$ 92,000
Engineering	<u>\$ 54,000</u>
Total	\$507,000, use \$508,000

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

Electric Demand	=	941 kW/yr (2,141 - 1,200)
Electric Usage	=	215,016 kWh/yr (515,016 - 300,000)
Energy Cost	=	\$12,000/yr (\$29,000 - \$17,000)
Annual Energy Savings	=	733.8 mmBtu/yr
Energy Usage	=	733.8 mmBtu/yr (215,016 kWh/yr x 3,413 Btu/kWh) ÷ 1,000,000 Btu/mmBtu

Maintenance Savings.

By retrofitting the existing mercury vapor luminaires with metal halide luminaires, no maintenance savings is expected because the recommended replacement time of the mercury vapor lamps is the same as the life expectancy of the metal halide lamps.

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations and construction supervision, in addition to construction cost and engineering services. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 42.44 years with a savings to investment ratio of .42.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO13

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO13

ANALYSIS DATE: 04-19-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	453000.		
B. SIOH	\$	24915.		
C. DESIGN COST	\$	54000.		
D. TOTAL COST (1A+1B+1C)	\$	531915.		
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.		
F. PUBLIC UTILITY COMPANY REBATE	\$	0.		
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$		531915.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	734.	\$ 5335.	18.17	\$ 96932.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 7200.	17.22	\$ 123984.
N. TOTAL		734.	\$ 12535.		\$ 220916.

3. NON ENERGY SAVINGS(+) / COST(-)

A. ANNUAL RECURRING (+/-)		\$	0.
(1) DISCOUNT FACTOR (TABLE A)	17.22		
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$	0.

B. NON RECURRING SAVINGS(+) / COSTS(-)

ITEM	SAVINGS(+) COST(-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS(+)/ COST(-) (4)
------	------------------------------	-----------------	------------------------	--

d. TOTAL	\$	0.		0.
----------	----	----	--	----

C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ 0.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 12535.

5. SIMPLE PAYBACK PERIOD (1G/4) 42.44 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 220916.

7. SAVINGS TO INVESTMENT RATIO (SIR)=(6 / 1G)= .42
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): -.46 %

ECO-13
Letterkenny Army Depot
Mercury Vapor to Metal Halide

Existing										Proposed				Implementation							
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$	Energy Savings \$
Building 1S20-1																					
Warehouse																					
Warehouse Receiving	4	1	175	805	50	95%	0.8	175	\$70.72	\$51.99	\$122.70	100 Watt MH, Low Bay	115	0.4	100	\$70.12	\$1,560	\$400	\$235	\$2,195	\$52.59
Warehouse Storage	4	1	175	805	50	95%	0.8	175	\$70.72	\$51.99	\$122.70	100 Watt MH, Low Bay	115	0.4	100	\$70.12	\$1,560	\$400	\$235	\$2,195	\$52.59
Building 31																					
Warehouse																					
Warehouse	152	1	175	30590	50	95%	29.1	6638	\$2,687.28	\$1,975.48	\$4,662.76	100 Watt MH, Low Bay	115	16.6	3,793	\$2,664.43	\$59,280	\$15,200	\$8,938	\$83,418	\$1,998.33
Building 32																					
Warehouse																					
Warehouse	137	1	175	27571	50	95%	26.2	5983	\$2,422.09	\$1,780.53	\$4,202.62	100 Watt MH, Low Bay	115	15.0	3,419	\$2,401.50	\$53,430	\$13,700	\$8,056	\$75,186	\$1,801.12
Warehouse	5	1	175	1006.3	50	95%	1.0	218	\$88.40	\$64.98	\$153.38	100 Watt MH, High Bay	115	0.5	125	\$87.65	\$1,950	\$500	\$294	\$2,744	\$65.73
Building 34																					
Warehouse																					
Warehouse	271	1	175	54539	50	95%	51.8	11835	\$4,791.14	\$3,522.07	\$8,313.21	100 Watt MH, Low Bay	115	29.6	6,763	\$4,750.41	\$105,690	\$27,100	\$15,935	\$148,725	\$3,562.80
Building 41																					
Warehouse																					
Warehouse - Low Bay	165	1	175	33206	50	95%	31.5	7206	\$2,917.12	\$2,144.43	\$5,061.55	100 Watt MH, Low Bay	115	18.0	4,118	\$2,892.31	\$64,350	\$16,500	\$9,702	\$90,552	\$2,169.24
Building 42S																					
Warehouse																					
Warehouse South	15	1	175	3018.8	50	95%	2.9	655	\$265.19	\$194.95	\$460.14	100 Watt MH, High Bay	115	1.6	374	\$262.94	\$5,850	\$1,500	\$882	\$8,232	\$197.20
Building 44																					
Warehouse																					
Warehouse	149	1	175	29986	50	95%	28.5	6507	\$2,634.24	\$1,936.49	\$4,570.73	100 Watt MH, Low Bay	115	16.3	3,718	\$2,611.85	\$58,110	\$14,900	\$8,761	\$81,771	\$1,958.89
Building 47																					
Warehouse																					
Warehouse - North	1	1	175	201.25	90	95%	0.2	79	\$17.68	\$23.39	\$41.07	100 Watt MH, High Bay	115	0.1	45	\$23.47	\$390	\$100	\$59	\$549	\$17.60
Warehouse - North	13	1	175	2616.3	90	95%	2.5	1022	\$229.83	\$304.12	\$533.95	100 Watt MH, Low Bay	115	1.4	384	\$305.12	\$5,070	\$1,300	\$764	\$7,134	\$228.84
Building 320																					
Maintenance																					
Maintenance Area	7	1	400	3220	168	95%	3.1	2348	\$282.87	\$698.70	\$981.57	250 Watt MH, High Bay	288	1.9	1,467	\$613.48	\$3,115	\$700	\$458	\$4,273	\$368.09
Building 24																					
Cable & Harness																					
Carpentry Work Shop	1	1	175	201.25	90	95%	0.2	79	\$17.68	\$23.39	\$41.07	100 Watt MH, Low Bay	115	0.1	45	\$23.47	\$390	\$100	\$59	\$549	\$17.60
TOTALS																					
924				187766			178.4	42918	\$16,000	\$13,000	\$29,000			100.0	25000	\$17,000	\$361,000	\$92,000	\$54,000	\$508,000	\$12,000
G:\PROJECTS\4130.01\SSR\RECOMO 13.WK4																					

G:\PROJECTS\130101\SS\ECO-13.WK4

22 May '95

ECO-14

Mercury Vapor to High Pressure Sodium

Existing.

Ten of the buildings at the Letterkenny Army Depot contain approximately 924 Mercury Vapor luminaires. The luminaires are typically used for illuminating warehouse storage areas. The attached data table for ECO-14 lists the areas which currently utilize these luminaires. The current light levels in most of the areas noted are below the IES recommended levels. The low light levels could be attributed to the mercury vapor lamp lumen output vs. time. The mercury vapor lamps lumen output decreases by 50% of the initial output at the average rated life point. The annual electric demand, usage, and cost of these luminaires are as follows:

Electric Demand	=	2,141 kW/yr (178.4 kW/mo x 12 mo/yr)
Electric Usage	=	515,016 kWh/yr (42,918 kWh/mo x 12 mo/yr)
Electric Cost	=	\$29,000 (2,141 kW/yr x \$7.706/kW) + (515,016 kWh/yr x \$.0248/kWh) = \$29,269, use \$29,000

Proposed.

Replace the existing high and low bay luminaires with an equal number of high pressure sodium luminaires in the areas noted on the attached data sheet for ECO-14. The new luminaires will increase the existing light levels by 30 - 60%. The annual electric demand, usage, and cost of the proposed ECO is noted below:

Electric Demand	=	1,200 kW/yr (100 kW/mo x 12 mo/yr)
Electric Usage	=	300,000 kWh/yr (25,000 kWh/mo x 12 mo/yr)
Electric Cost	=	\$17,000 (1,200 kW/yr x \$7.706/kW) + (300,000 kWh/yr x \$.0248/kWh) = \$16,687, use \$17,000

Implementation Cost. The expected construction cost for implementing the project is expected to be \$518,000. The breakdown is noted below and shown on the attached ECO data table.

Material	\$370,000
Labor	\$ 92,000
Engineering	<u>\$ 55,000</u>
Total	\$517,000, use \$518,000

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

Electric Demand	=	941 kW/yr (2,141 - 1,200)
Electric Usage	=	215,016 kWh/yr (515,016 - 300,000)
Energy Cost	=	\$12,000/yr (29,000 - 17,000)
Annual Energy Savings	=	733.8 mmBtu/yr
Energy Usage	=	733.8 mmBtu/yr (215,016 kWh/yr x 3,413 Btu/kWh) ÷ 1,000,000 Btu/mmBtu

**Maintenance
Savings.**

By retrofitting the existing mercury vapor luminaires with high-pressure sodium luminaires, no maintenance savings is expected because the life of each lamp is 24,000 hours.

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations and construction supervision, costs in addition to construction cost and engineering services. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 42.93 years with a savings to investment ratio of .41.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO14

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO14

ANALYSIS DATE: 04-19-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	462000.	
B. SIOH	\$	25410.	
C. DESIGN COST	\$	55000.	
D. TOTAL COST (1A+1B+1C)	\$	542410.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$	542410.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	734.	\$ 5335.	18.17	\$ 96932.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 7300.	17.22	\$ 125706.
N. TOTAL		734.	\$ 12635.		\$ 222638.

3. NON ENERGY SAVINGS(+) / COST(-)

A. ANNUAL RECURRING (+/-)		\$	0.
(1) DISCOUNT FACTOR (TABLE A)	17.22		
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$	0.

B. NON RECURRING SAVINGS(+) / COSTS(-)

ITEM	SAVINGS(+) COST(-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS(+)/ COST(-) (4)
d. TOTAL	\$ 0.			0.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ 0.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 12635.

5. SIMPLE PAYBACK PERIOD (1G/4) 42.93 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 222638.

7. SAVINGS TO INVESTMENT RATIO (SIR) = $(6 / 1G) = .41$
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): -.51 %

ECO-14
Letterkenny Army Depot
Mercury Vapor to High Pressure Sodium

		Existing										Proposed				Implementation						
		NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$
Building 1S20-1																						
Warehouse	4	1	175	805	50	95%	0.8	175	\$70.72	\$51.99	\$122.70	100 Watt HPS, Low Bay	115	0.4	100	\$70.12	\$1,600	\$400	\$240	\$2,240	\$52.59	
Warehouse Receiving	4	1	175	805	50	95%	0.8	175	\$70.72	\$51.99	\$122.70	100 Watt HPS, Low Bay	115	0.4	100	\$70.12	\$1,600	\$400	\$240	\$2,240	\$52.59	
Warehouse Storage	4	1	175	805	50	95%	0.8	175	\$70.72	\$51.99	\$122.70	100 Watt HPS, Low Bay	115	0.4	100	\$70.12	\$1,600	\$400	\$240	\$2,240	\$52.59	
Building 31																						
Warehouse	152	1	175	30590	50	95%	29.1	6638	\$2,687.28	\$1,975.48	\$4,662.76	100 Watt HPS, Low Bay	115	16.6	3,793	\$2,664.43	\$60,800	\$15,200	\$9,120	\$85,120	\$1,998.33	
Building 32																						
Warehouse	137	1	175	27571	50	95%	26.2	5983	\$2,422.09	\$1,780.53	\$4,202.62	100 Watt HPS, Low Bay	115	15.0	3,419	\$2,401.50	\$54,800	\$13,700	\$8,220	\$76,720	\$1,801.12	
Warehouse	5	1	175	1006.3	50	95%	1.0	218	\$88.40	\$64.98	\$153.38	100 Watt HPS, High Bay	115	0.5	125	\$87.65	\$2,000	\$500	\$300	\$2,800	\$65.73	
Building 34																						
Warehouse	271	1	175	54539	50	95%	51.8	11835	\$4,791.14	\$3,522.07	\$8,313.21	100 Watt HPS, Low Bay	115	29.6	6,763	\$4,750.41	\$108,400	\$27,100	\$16,260	\$151,760	\$3,562.80	
Building 41																						
Warehouse	165	1	175	33206	50	95%	31.5	7206	\$2,917.12	\$2,144.43	\$5,061.55	100 Watt HPS, Low Bay	115	18.0	4,118	\$2,892.31	\$66,000	\$16,500	\$9,900	\$92,400	\$2,169.24	
Building 42S																						
Warehouse	15	1	175	3018.8	50	95%	2.9	655	\$265.19	\$194.95	\$460.14	100 Watt HPS, High Bay	115	1.6	374	\$262.94	\$6,000	\$1,500	\$900	\$8,400	\$197.20	
Building 44																						
Warehouse	149	1	175	29986	50	95%	28.5	6507	\$2,634.24	\$1,936.49	\$4,570.73	100 Watt HPS, Low Bay	115	16.3	3,718	\$2,611.85	\$59,600	\$14,900	\$8,940	\$83,440	\$1,958.89	
Building 47																						
Warehouse	1	1	175	201.25	90	95%	0.2	79	\$17.68	\$23.39	\$41.07	100 Watt HPS, High Bay	115	0.1	45	\$23.47	\$400	\$100	\$60	\$560	\$17.60	
Warehouse - North	13	1	175	2616.3	90	95%	2.5	1022	\$229.83	\$304.12	\$533.95	100 Watt HPS, Low Bay	115	1.4	384	\$305.12	\$5,200	\$1,300	\$780	\$7,280	\$228.84	
Building 320																						
Maintenance	7	1	400	3220	168	95%	3.1	2348	\$282.87	\$698.70	\$981.57	250 Watt HPS, High Bay	288	1.9	1,467	\$613.48	\$3,185	\$700	\$466	\$4,351	\$368.09	
Maintenance Area																						
Building 404																						
Cable & Harness	1	1	175	201.25	90	95%	0.2	79	\$17.68	\$23.39	\$41.07	100 Watt HPS, Low Bay	115	0.1	45	\$23.47	\$400	\$100	\$60	\$560	\$17.60	
Carpentry Work Shop	1	1	175	201.25	90	95%	0.2	79	\$17.68	\$23.39	\$41.07	100 Watt HPS, Low Bay	115	0.1	45	\$23.47	\$400	\$100	\$60	\$560	\$17.60	
TOTALS		924			187766			42918	\$16,000	\$13,000	\$29,000			100.0	25000	\$17,000	\$370,000	\$92,000	\$55,000	\$518,000	\$12,000	
APROJECTS130101SSNECECO_14WK4																					23-May-95	

G:\PROJECTS\1300\UNSUB\COZCO_14WK4

ECO-15

Building Exterior Lighting

Existing. Eleven of the buildings at the Letterkenny Army depot contain 74 building mounted incandescent luminaires. The attached data table for ECO-15 lists the areas which currently utilize these luminaires. The eleven buildings selected were found to have their exterior lights on during the site survey. Since the lights only operate at night, there is no on-peak demand cost. Mostly all the Depot buildings had some building mounted exterior lighting; however, most was found not to be in current use. The annual electric demand, usage, and cost for these luminaires are as follows:

Electric Demand	=	0 kW/yr (0 kW/mo x 12 mo/yr)
Electric Usage	=	43,764 kWh/yr (3,647 kWh/mo x 12 mo/yr)
Electric Cost	=	\$1,100 (0 kW/yr x \$7.706/kW) + (43,764 kWh/yr x \$.0248/kWh) = \$1,085, use \$1,100

Proposed. Remove the existing incandescent luminaires and install high pressure sodium wall pack units with photocell control. Refer to the attached data table for ECO-15. The quantity of wall pack units was determined based on matching the existing lumen output of the existing luminaires along with observations made during the site survey. The annual electric demand, usage, and cost of the proposed ECO is noted below:

Electric Demand	=	0 kW/yr (0 kW/mo x 12 mo/yr)
-----------------	---	------------------------------

Electric Usage = 13,752 kWh/yr (1,146 kW/mo
x 12 mo/yr)

Electric Cost = \$340 (0 kW/yr x \$7.706/kW)
+ (13,752 kWh/yr x
\$.0248/kWh) = \$341, use
\$340

Implementation Cost. The expected construction cost for implementing the project is expected to be \$7,000. The breakdown is noted below and shown on the attached ECO data table.

Material	\$5,000
Labor	\$2,000
Engineering	<u>\$ 0</u>

Total \$7,000

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

Electric Demand = 0 kW/yr

Electric Usage = 30,012 kWh/yr (43,764 -
13,752)

Energy Cost = \$740/yr (\$1,100 - \$340)

Annual Energy Savings = 102.4 mmBtu/yr

Energy Usage = 102.4 mmBtu/yr (30,012
kWh/yr x 3,413 Btu/kWh) ÷
1,000,000 Btu/mmBtu

Maintenance Savings. By retrofitting the existing incandescent exterior lighting with high-pressure sodium wall packs, a maintenance savings will result. The annual maintenance savings is noted below:

Data

Incandescent Lamp Life	=	750 hours
HPS Lamp Life	=	24,000 hours
Operation Period Per Year	=	4,160 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes
Incandescent Lamp Cost	=	\$1 each
HPS Lamp Cost	=	\$55 each
Total Quantity Inc Lamps	=	74
Total Quantity HPS Lamps	=	40

Calculation

$$\begin{array}{lcl} \text{Maintenance} & = & \$42.52 (20 \times 1/3 + 1) \times \\ \text{(Incandescent)} & & (4,160/750) \end{array}$$

$$\begin{array}{lcl} \text{Maintenance} & = & \$10.69 (20 \times 1/3 + 55) \times \\ \text{(HPS)} & & (4,160/24,000) \end{array}$$

$$\begin{array}{lcl} \text{Annual Recurring} & = & \$2,700 (42.52 \times 74) - (10.69 \\ \text{Maintenance Savings} & & \times 40) = \$2,719, \text{ use } \$2,700 \end{array}$$

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations, construction supervision, and annual recurring maintenance costs in addition to construction cost. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 2.14 years with a savings to investment ratio of 8.13.

LIFE CYCLE COST ANALYSIS SUMMARY

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) STUDY: ECO15
 INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 LCCID 1.080
 PROJECT NO. & TITLE: 4130.01 EEAP
 FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO15
 ANALYSIS DATE: 04-19-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	7000.		
B. SIOH	\$	385.		
C. DESIGN COST	\$	0.		
D. TOTAL COST (1A+1B+1C)	\$	7385.		
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.		
F. PUBLIC UTILITY COMPANY REBATE	\$	0.		
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$		7385.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT	\$ 7.27	102.	\$ 744.	18.17	\$ 13527.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 0.	17.22	\$ 0.
N. TOTAL		102.	\$ 744.		\$ 13527.

3. NON ENERGY SAVINGS(+) / COST(-)

A. ANNUAL RECURRING (+/-)		\$ 2700.
(1) DISCOUNT FACTOR (TABLE A)	17.22	
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$ 46494.

B. NON RECURRING SAVINGS(+) / COSTS(-)

ITEM	SAVINGS(+) COST(-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS(+)/ COST(-) (4)
------	------------------------------	-----------------	------------------------	--

d. TOTAL	\$ 0.			0.
----------	-------	--	--	----

C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+)/COST(-) (3A2+3Bd4) \$ 46494.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS \text{ ECONOMIC LIFE}))$ \$ 3444.

5. SIMPLE PAYBACK PERIOD (1G/4) 2.14 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 60021.

7. SAVINGS TO INVESTMENT RATIO (SIR) = $(6 / 1G) =$ 8.13
 (IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): 12.11 %

ECO-15
Letterkenny Army Depot
Building Exterior Lighting

Room	NO. Of Luminaires	Existing										Proposed										Implementation				
		Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng. Cost \$	Total Cost \$	Energy Savings \$					
Building 1																										
Building Mounted Exterior Ligs	8	1	100	800	80	0%	0.0	278																		
Exterior	5	1	100	500	80	0%	0.0	174																		
Exterior	1	1	200	200	80	0%	0.0	69																		
Exterior	2	1	100	200	80	0%	0.0	69																		
Exterior	1	1	100	100	80	0%	0.0	35																		
Total building				1800	80	0%	0.0	625	\$0.00	\$185.99	\$185.99	8 - 70 Watt HPS wall packs to cover Bldg	80.5	0.0	224	\$66.54	\$1,000	\$400	\$0	\$1,400	\$119.45					
Building 3																										
Building Mounted Exterior Ligs	4	1	100	400	80	0%	0.0	139																		
Exterior																										
Building 4																										
Building Mounted Exterior Ligs	5	1	300	1500	80	0%	0.0	521																		
East	2	1	300	600	80	0%	0.0	208																		
South	1	1	300	300	80	0%	0.0	104																		
West	1	1	300	300	80	0%	0.0	104																		
West	1	1	300	300	80	0%	0.0	104																		
North	1	1	300	300	80	0%	0.0	104																		
Total building				3000	80	0%	0.0	1042	\$0.00	\$309.98	\$309.98	10 - 70 Watt HPS wall packs to cover Bldg	80.5	0.0	279	\$83.18	\$1,250	\$500	\$0	\$1,750	\$226.80					
Building 10																										
Building Mounted Exterior Ligs	8	1	75	600	80	0%	0.0	208																		
Exterior	1	1	75	75	80	0%	0.0	26																		
Exterior	1	1	175	175	80	0%	0.0	61																		
Exterior	8	1	75	600	80	0%	0.0	208																		
Total building				1450	80	0%	0.0	503	\$0.00	\$149.82	\$149.82	6 - 70 Watt HPS wall packs to cover Bldg	80.5	0.0	168	\$49.91	\$750	\$300	\$0	\$1,050	\$99.92					
Building 42S																										
Building Mounted Exterior Ligs	1	1	1000	1000	80	0%	0.0	347																		
Main Door Entrance																										
Building 349																										
Building Mounted Exterior Ligs	4	1	150	600	80	0%	0.0	208																		
Exterior	1	1	75	75	80	0%	0.0	26																		
Substation	2	1	300	600	80	0%	0.0	208																		
Total building				1275	80	0%	0.0	443	\$0.00	\$131.74	\$131.74	3 - 100 Watt HPS wall packs to cover Bldg	115	0.0	120	\$35.65	\$375	\$150	\$0	\$525	\$96.09					
Building 412																										
Building Mounted Exterior Ligs	2	1	75	150	80	0%	0.0	52																		
Exterior																										
Building 529																										
Building Mounted Exterior Ligs	2	1	200	400	80	0%	0.0	139																		
Exterior																										
Building 619																										
Building Mounted Exterior Ligs	1	1	67	67	80	0%	0.0	23																		
Exterior	1	1	60	60	80	0%	0.0	13																		
Total building				136	80	0%	0.0	36	\$0.00	\$10.80	\$10.80	1 - 50 Watt HPS wall pack	57.5	0.0	20	\$5.94	\$115	\$50	\$0	\$165	\$4.86					
Building 639																										
Building Mounted Exterior Ligs	3	1	75	225	80	0%	0.0	78																		
Exterior	4	1	75	300	80	0%	0.0	104																		
Total building				525	80	0%	0.0	182	\$0.00	\$54.25	\$54.25	3 - 50 Watt HPS wall pack	57.5	0.0	60	\$17.82	\$345	\$150	\$0	\$495	\$36.42					

ECO-15
Letterkenny Army Depot
Building Exterior Lighting

		Existing										Proposed					Implementation						
Room	NO. Of Luminaires	Lamps Per Luminaire	Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On Peak	Demand Kw On Peak	Usage Kw Per Month	Annual Demand (Kw)	Annual Usage (Kwh)	Annual Cost	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kw)	Proposed Kw Per Month	Annual Cost	Mat. Cost	Labor Cost	Eng. Cost	Total Cost	Energy Savings \$		
Building 645																							
Building Mounted Exterior Ligs	4	1	100	400	80	0%	0.0	139	\$0.00	\$41.33	\$41.33	3 - 50 Watt IIPS wall pack	57.5	0.0	60	\$17.82	\$345	\$150	\$0	\$495	\$23.51		
Exterior																							
TOTALS	74			10536			0.0	3627	\$0	\$1,100	\$1,100			0.0	1146	\$340	\$5,000	\$2,000	\$0	\$7,000	\$740		
AP:PROJECT/SH130.01/ISSUE/CORCO. 15.WK4																							22-MAY-95

G:\PROJECTS\130101SS\ECO-15.WK4

22-May-96

ECO-16

Roadway and Parking Area Lighting

Existing.

Presently there are 130 pole-mounted luminaires throughout the base which utilize mercury vapor lamps to provide area illumination. A wide variety of lamps and luminaires are employed. Typically, Army luminaires #402, #403, #505, and #507 used. These luminaires contain lamps rated from 175 watts through 1,000 watts. During site investigations, it was noted that the luminaires operate approximately 80 hours each week and only at night. Operation of the luminaires is accomplished through the use of photocells. Because the luminaires operate when most of the base is shut down, they do not contribute to billing demand. The annual electric demand, usage, and cost for these luminaires are as follows:

Electric Demand	=	0 kW/yr (0 kW/mo x 12 mo/yr)
Electric Usage	=	175,848 kWh/yr (14,654 kWh/mo x 12 mo/yr)
Electric Cost	=	\$4,400 (0 kW/yr x \$7.706/kW) + (175,848 kWh/yr x \$.0248/kWh) = \$4,361, use \$4,400

Proposed.

Remove and replace all 130 mercury vapor luminaires with high-pressure sodium luminaires of equivalent light output. Table 1, on the following page, shows mean lumen output of comparable lamps. This guideline is used for selecting replacements.

Table 1
Lumen Output Comparison

MV		HPS	
<u>Watts</u>	<u>Lumens</u>	<u>Watts</u>	<u>Lumens</u>
175 w	7,200	100 w	8,550
250 w	12,100	150 w	14,400
400 w	17,500	200 w	19,800
1,000 w	40,000	400 w	45,000

The HPS lamps will provide approximately a 10 to 20 percent increase in general light output. Generally both mercury vapor and high pressure sodium lamps last for more than 24,000 hours of operation. However, mercury vapor lamps tend to loose their potential lumen output more rapidly than high pressure sodium lamps. The new luminaires will match existing physical appearance as well as be controlled by photocells. Current wood and metal poles will not be replaced. Reference the attached data table for ECO-16 for the location of the luminaires. The annual electric demand, usage, and cost of the proposed ECO is noted below:

Electric Demand	=	0 kW/yr (0 kW/mo x 12 mo/yr)
Electric Usage	=	99,600 kWh/yr (8,300 kW/mo x 12 mo/yr)
Electric Cost	=	\$2,500 (0 kW/yr x \$7.706/kW) + (99,600 kWh/yr x \$.0248/kWh) = \$2,470, use \$2,500

Implementation Cost. The expected construction cost for implementing the project is expected to be \$51,000. The breakdown is noted below and shown on the attached ECO data table.

Material	\$38,000
Labor	\$ 7,800
Engineering	<u>\$ 5,500</u>

Total \$51,300, use \$51,000

Energy Savings. The annual electric demand, usage, and cost savings resulting from the implementation of this project is noted below:

Electric Demand	=	0 kW/yr (0 - 0)
Electric Usage	=	76,248 kWh/yr (175,848 - 99,600)
Energy Cost	=	\$1,900/yr (\$4,400 - \$2,500)
Annual Cost Savings	=	260 mmBtu/yr
Energy Usage	=	260 mmBtu/yr (76,248 kWh/yr x 3,413 Btu/kWh) ÷ 1,000,000 Btu/mmBtu

Maintenance Savings.

By replacing the existing mercury vapor luminaires with high pressure sodium lamped luminaires, a maintenance increase will result due to the increased lamp cost for HPS and the fact that the replacement lamps do not last any longer. The annual maintenance savings is noted below.

Data

MV Lamp Life	=	24,000 hours
HPS Lamp Life	=	24,000 hours
Operation Period Per Year	=	4,160 hours
Maintenance Labor Rate	=	\$20/hour
Estimated Replacement Time	=	20 minutes
MV Lamp Cost	=	\$45 each
HPS Lamp Cost	=	\$60 each
Total Quantity	=	130

Calculation

$$\begin{array}{lcl} \text{Maintenance} & = & \$18.86 (20 \times 1/3 + 45) \times \\ \text{(MV Lamp)} & & 8,760/24,000 \end{array}$$

$$\begin{array}{lcl} \text{Maintenance} & = & \$24.33 (20 \times 1/3 + 60) \times \\ \text{(HPS Lamp)} & & 8,760/24,000 \end{array}$$

$$\begin{array}{lcl} \text{Annual Recurring} & = & -\$700 (18.86 - 24.33) \times 130 \\ \text{Maintenance Savings} & = & = -\$711, \text{ use } -\$700 \end{array}$$

Discussion.

A life cycle cost for this ECO was prepared and can be found on the following page. The life cycle cost summary includes energy cost escalations, construction supervision, and annual recurring maintenance costs in addition to construction cost and engineering services. The life cycle was analyzed for a 25-year life resulting in a simple pay back of 45.22 years with a savings to investment ratio of .41.

LIFE CYCLE COST ANALYSIS SUMMARY

STUDY: ECO16

LCCID 1.080

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP)

INSTALLATION & LOCATION: LETTERKENNY ARREGION NOS. 3 CENSUS: 1

PROJECT NO. & TITLE: 4130.01 EEAP

FISCAL YEAR 1995 DISCRETE PORTION NAME: ECO16

ANALYSIS DATE: 04-19-95 ECONOMIC LIFE 25 YEARS PREPARED BY: DJB

1. INVESTMENT

A. CONSTRUCTION COST	\$	45800.	
B. SIOH	\$	2519.	
C. DESIGN COST	\$	5500.	
D. TOTAL COST (1A+1B+1C)	\$	53819.	
E. SALVAGE VALUE OF EXISTING EQUIPMENT	\$	0.	
F. PUBLIC UTILITY COMPANY REBATE	\$	0.	
G. TOTAL INVESTMENT (1D - 1E - 1F)	\$	53819.	

2. ENERGY SAVINGS (+) / COST (-)

DATE OF NISTIR 85-3273-X USED FOR DISCOUNT FACTORS OCT 1993

FUEL	UNIT COST \$/MBTU (1)	SAVINGS MBTU/YR (2)	ANNUAL \$ SAVINGS (3)	DISCOUNT FACTOR (4)	DISCOUNTED SAVINGS (5)
A. ELECT	\$ 7.27	260.	\$ 1890.	18.17	\$ 34345.
B. DIST	\$.00	0.	\$ 0.	20.83	\$ 0.
C. RESID	\$.00	0.	\$ 0.	23.76	\$ 0.
D. NAT G	\$.00	0.	\$ 0.	22.78	\$ 0.
E. COAL	\$.00	0.	\$ 0.	20.78	\$ 0.
F. LPG	\$.00	0.	\$ 0.	18.87	\$ 0.
M. DEMAND SAVINGS			\$ 0.	17.22	\$ 0.
N. TOTAL		260.	\$ 1890.		\$ 34345.

3. NON ENERGY SAVINGS (+) / COST (-)

A. ANNUAL RECURRING (+/-)	\$	-700.
(1) DISCOUNT FACTOR (TABLE A)	17.22	
(2) DISCOUNTED SAVING/COST (3A X 3A1)	\$	-12054.

B. NON RECURRING SAVINGS (+) / COSTS (-)

ITEM	SAVINGS (+) COST (-) (1)	YR OC (2)	DISCNT FACTR (3)	DISCOUNTED SAVINGS (+) / COST (-) (4)
d. TOTAL	\$ 0.			0.

C. TOTAL NON ENERGY DISCOUNTED SAVINGS (+) / COST (-) (3A2+3Bd4) \$ -12054.

4. FIRST YEAR DOLLAR SAVINGS $2N3+3A+(3Bd1/(YRS\ ECONOMIC\ LIFE))$ \$ 1190.

5. SIMPLE PAYBACK PERIOD (1G/4) 45.22 YEARS

6. TOTAL NET DISCOUNTED SAVINGS (2N5+3C) \$ 22291.

7. SAVINGS TO INVESTMENT RATIO (SIR) = $(6 / 1G) =$.41
(IF < 1 PROJECT DOES NOT QUALIFY)

8. ADJUSTED INTERNAL RATE OF RETURN (AIRR): -.47 %

ECO-16
Letterkenny Army Depot
Roadway and Parking Area Lighting

Room	NO. Of Luminaires	Lamps Per Luminaire	Existing				Proposed										Implementation				Energy Savings
			Watts Per Lamp	Total Watts	Hours Per Week	Percent Of Kw On-Peak	Demand Kw On-Peak	Usage Kwh Per Month	Annual Demand (Kwh)	Annual Usage (Kwh)	Annual Cost \$	New Luminaire Description	Watts Per Luminaire	Proposed Demand (Kwh)	Proposed Kwh Per Month	Annual Cost \$	Mat. Cost \$	Labor Cost \$	Eng Cost \$	Total Cost \$	
Road/Parking Area Lighting																					
Texas Avenue	2	1	250	575	80	0%	0.0	200	\$0.00	\$59	\$59	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	120	\$35.65	\$640	\$120	\$91	\$851	\$24
Kansas Avenue	4	1	250	1,150	80	0%	0.0	399	\$0.00	\$119	\$119	150w HPS Floodlight	173	0.0	240	\$71.30	\$880	\$240	\$134	\$1,254	\$48
Arkansas Avenue	1	1	175	201	80	0%	0.0	70	\$0.00	\$21	\$21	100w HPS Roadway Luminaire, wood pole mt.	115	0.0	40	\$11.88	\$300	\$60	\$43	\$403	\$9
Arkansas Avenue	5	1	250	1,438	80	0%	0.0	499	\$0.00	\$149	\$149	150w HPS Floodlight	173	0.0	299	\$89.12	\$1,100	\$300	\$168	\$1,568	\$59
Building #57 South Parking	3	1	250	863	80	0%	0.0	299	\$0.00	\$89	\$89	150w HPS Floodlight	173	0.0	180	\$53.47	\$660	\$180	\$101	\$941	\$36
Oregon Avenue	3	1	250	863	80	0%	0.0	299	\$0.00	\$89	\$89	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	180	\$53.47	\$660	\$180	\$101	\$941	\$36
Washington Avenue	6	1	250	1,725	80	0%	0.0	599	\$0.00	\$178	\$178	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	359	\$106.94	\$1,920	\$360	\$274	\$2,554	\$71
Building #139H	1	1	1000	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #51 South	1	1	1000	1,150	80	0%	0.0	399	\$0.00	\$119	\$119	150w HPS Roadway Luminaire, wood pole mt.	460	0.0	160	\$47.53	\$260	\$60	\$38	\$358	\$71
Overcash Drive	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Floodlight	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Overcash Drive	21	1	250	6,038	80	0%	0.0	2096	\$0.00	\$624	\$624	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	1,258	\$374.30	\$6,720	\$1,260	\$958	\$8,938	\$250
Credit Union	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Floodlight	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #320 South	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Floodlight	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #320 South Deck #2	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Floodlight	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #1399	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, wood pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Colby Avenue	5	1	250	1,438	80	0%	0.0	499	\$0.00	\$149	\$149	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	299	\$89.12	\$1,100	\$300	\$228	\$2,128	\$59
Building #500	1	1	400	460	80	0%	0.0	160	\$0.00	\$48	\$48	200w HPS Floodlight	230	0.0	299	\$89.12	\$1,600	\$300	\$228	\$2,128	\$59
Access Road to Golf Club	2	1	250	575	80	0%	0.0	200	\$0.00	\$59	\$59	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	120	\$35.65	\$640	\$120	\$91	\$851	\$24
Wisconsin Avenue	4	1	250	1,150	80	0%	0.0	399	\$0.00	\$119	\$119	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	240	\$71.30	\$1,280	\$240	\$182	\$1,702	\$48
Building #663 West	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #696	1	1	1000	1,150	80	0%	0.0	399	\$0.00	\$119	\$119	150w HPS Roadway Luminaire, metal pole mt.	460	0.0	160	\$47.53	\$260	\$60	\$38	\$358	\$71
Building #691	1	1	400	460	80	0%	0.0	160	\$0.00	\$48	\$48	200w HPS Floodlight	230	0.0	80	\$23.77	\$240	\$60	\$36	\$336	\$24
Storage Pad Hazardous Material	1	1	1000	1,150	80	0%	0.0	399	\$0.00	\$119	\$119	150w HPS Floodlight	460	0.0	160	\$47.53	\$260	\$60	\$38	\$358	\$71
Building #3 Parking Lot	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
New Jersey Avenue	3	1	250	863	80	0%	0.0	299	\$0.00	\$89	\$89	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	180	\$53.47	\$660	\$180	\$137	\$1,277	\$36
Building #37 Parking Lot	2	1	250	575	80	0%	0.0	200	\$0.00	\$59	\$59	150w HPS Floodlight	173	0.0	120	\$35.65	\$440	\$120	\$67	\$627	\$24
Building #426	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #424	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #433	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Carbaugh Avenue	3	1	250	863	80	0%	0.0	299	\$0.00	\$89	\$89	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	180	\$53.47	\$660	\$180	\$137	\$1,277	\$36
Building #37 Parking Lot	1	1	175	201	80	0%	0.0	70	\$0.00	\$21	\$21	100w HPS Roadway Luminaire, wood pole mt.	115	0.0	40	\$11.88	\$300	\$60	\$43	\$403	\$9
California Avenue	9	1	250	2,588	80	0%	0.0	898	\$0.00	\$267	\$267	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	539	\$160.41	\$2,880	\$540	\$410	\$3,830	\$107
Michigan Avenue	3	1	250	863	80	0%	0.0	299	\$0.00	\$89	\$89	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	180	\$53.47	\$660	\$180	\$137	\$1,277	\$36
Building #663 West	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Floodlight	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #616	2	1	250	575	80	0%	0.0	200	\$0.00	\$59	\$59	150w HPS Roadway Luminaire, wood pole mt.	173	0.0	120	\$35.65	\$640	\$120	\$91	\$851	\$24
Building #619	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #619	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #323H	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #324S	3	1	175	604	80	0%	0.0	210	\$0.00	\$62	\$62	100w HPS Roadway Luminaire, wood pole mt.	115	0.0	120	\$35.65	\$900	\$180	\$130	\$1,210	\$27
Gate #17	1	1	175	201	80	0%	0.0	70	\$0.00	\$21	\$21	100w HPS Roadway Luminaire, wood pole mt.	115	0.0	40	\$11.88	\$300	\$60	\$43	\$403	\$9
Kenny Gardens	3	1	250	863	80	0%	0.0	299	\$0.00	\$89	\$89	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	180	\$53.47	\$660	\$180	\$137	\$1,277	\$36
Pennsylvania Avenue	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #365	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #360	3	1	250	863	80	0%	0.0	299	\$0.00	\$89	\$89	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	180	\$53.47	\$660	\$180	\$137	\$1,277	\$36
Amato Parking Area	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, wood pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
Building #349	3	1	250	863	80	0%	0.0	299	\$0.00	\$89	\$89	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	180	\$53.47	\$660	\$180	\$137	\$1,277	\$36
Building #370	14	1	400	6,440	80	0%	0.0	2236	\$0.00	\$665	\$665	200w HPS Floodlight	230	0.0	1,118	\$332.71	\$3,360	\$840	\$504	\$4,704	\$133
Building #139H	1	1	250	288	80	0%	0.0	100	\$0.00	\$30	\$30	150w HPS Roadway Luminaire, metal pole mt.	173	0.0	60	\$17.82	\$320	\$60	\$46	\$426	\$12
TOTALS	130			42,205		0.0	0.0	146,534	\$0	\$4,400	\$4,400			0.0	8,300	\$2,500	\$38,000	\$7,800	\$5,500	\$51,000	\$1,900

PROJECTS\130101\SS\CODECO_16.WK422-March-95

G:\PROJECTS\130\130\SSCODECO_16.WK1

22-May-95